

Lead in School Drinking Water Report

Meadowdale Elementary School - Corrected



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-09-18

Date(s) analyzed: 2025-09-24

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	409872	Unit A - Main Building	Sink	Workroom	1 of 1	Tap	center	11
2	409530	Unit A - Main Building	Fountain/Tap Combo	A120 Shared Space	1 of 1	Tap	center	6
3	409563	Unit A - Main Building	Fountain/Tap Combo	A200 Shared Space	1 of 1	Tap	center	6
4	409531	Unit A - Main Building	Fountain/Tap Combo	A120 Shared Space	1 of 1	Water Fountain	right	5
5	409548	Unit A - Main Building	Fountain/Tap Combo	A220 Shared Space	1 of 1	Tap	center	5
6	409545	Unit A - Main Building	Fountain/Tap Combo	Library Workroom	1 of 1	Tap	center	4
7	409564	Unit A - Main Building	Fountain/Tap Combo	A200 Shared Space	1 of 1	Water Fountain	right	3
8	409523	Unit A - Main Building	Fountain/Tap Combo	A104	1 of 1	Tap	center	2
9	409536	Unit A - Main Building	Fountain/Tap Combo	A123	1 of 1	Tap	center	2
10	409549	Unit A - Main Building	Fountain/Tap Combo	A220 Shared Space	1 of 1	Water Fountain	right	2

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
11	409877	Unit A - Main Building	Fountain/Tap Combo	A101	1 of 1	Tap	center	2
12	409879	Unit A - Main Building	Fountain/Tap Combo	A102	1 of 1	Tap	center	2
13	409521	Unit A - Main Building	Fountain/Tap Combo	A103	1 of 1	Tap	center	1
14	409532	Unit A - Main Building	Fountain/Tap Combo	A121	1 of 1	Tap	center	1
15	409550	Unit A - Main Building	Fountain/Tap Combo	A221	1 of 1	Tap	center	1
16	409556	Unit A - Main Building	Fountain/Tap Combo	A224	1 of 1	Tap	center	1
17	409573	Unit A - Main Building	Fountain/Tap Combo	A205	1 of 1	Tap	center	1
18	409575	Unit A - Main Building	Fountain/Tap Combo	A206	1 of 1	Tap	center	1
19	409867	Unit A - Main Building	Sink	Kitchen	1 of 1 food prep	Tap	center	1
20	409875	Unit A - Main Building	Fountain/Tap Combo	A100 Shared Space	1 of 1	Tap	center	1
21	409520	Unit A - Main Building	Fountain/Tap Combo	A102	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
22	409522	Unit A - Main Building	Fountain/Tap Combo	A103	1 of 1	Water Fountain	right	<1
23	409524	Unit A - Main Building	Fountain/Tap Combo	A104	1 of 1	Water Fountain	right	<1
24	409525	Unit A - Main Building	Fountain/Tap Combo	A105	1 of 1	Tap	center	<1
25	409526	Unit A - Main Building	Fountain/Tap Combo	A105	1 of 1	Water Fountain	right	<1
26	409527	Unit A - Main Building	Fountain/Tap Combo	A106	1 of 1	Tap	center	<1
27	409528	Unit A - Main Building	Fountain/Tap Combo	A106	1 of 1	Water Fountain	right	<1
28	409529	Unit A - Main Building	Fountain	A120 Vestibule	1 of 1	Water Fountain	center	<1
29	409533	Unit A - Main Building	Fountain/Tap Combo	A121	1 of 1	Water Fountain	right	<1
30	409534	Unit A - Main Building	Fountain/Tap Combo	A122	1 of 1	Tap	center	<1
31	409535	Unit A - Main Building	Fountain/Tap Combo	A122	1 of 1	Water Fountain	right	<1
32	409537	Unit A - Main Building	Fountain/Tap Combo	A123	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
33	409538	Unit A - Main Building	Fountain/Tap Combo	A124	1 of 1	Tap	center	<1
34	409539	Unit A - Main Building	Fountain/Tap Combo	A124	1 of 1	Water Fountain	right	<1
35	409540	Unit A - Main Building	Fountain/Tap Combo	A125	1 of 1	Tap	center	<1
36	409541	Unit A - Main Building	Fountain/Tap Combo	A125	1 of 1	Water Fountain	right	<1
37	409542	Unit A - Main Building	Fountain/Tap Combo	A126	1 of 1	Tap	center	<1
38	409543	Unit A - Main Building	Fountain/Tap Combo	A126	1 of 1	Water Fountain	right	<1
39	409544	Unit A - Main Building	Fountain	Library	1 of 1	Water Fountain	center	<1
40	409546	Unit A - Main Building	Fountain/Tap Combo	Library Workroom	1 of 1	Water Fountain	right	<1
41	409547	Unit A - Main Building	Fountain	A220 Vestibule	1 of 1	Water Fountain	center	<1
42	409551	Unit A - Main Building	Fountain/Tap Combo	A221	1 of 1	Water Fountain	right	<1
43	409552	Unit A - Main Building	Fountain/Tap Combo	A222	1 of 1	Tap	center	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
44	409553	Unit A - Main Building	Fountain/Tap Combo	A222	1 of 1	Water Fountain	right	<1
45	409554	Unit A - Main Building	Fountain/Tap Combo	A223	1 of 1	Tap	center	<1
46	409555	Unit A - Main Building	Fountain/Tap Combo	A223	1 of 1	Water Fountain	right	<1
47	409557	Unit A - Main Building	Fountain/Tap Combo	A224	1 of 1	Water Fountain	right	<1
48	409558	Unit A - Main Building	Fountain/Tap Combo	A225	1 of 1	Tap	center	<1
49	409559	Unit A - Main Building	Fountain/Tap Combo	A225	1 of 1	Water Fountain	right	<1
50	409560	Unit A - Main Building	Fountain/Tap Combo	A226	1 of 1	Tap	center	<1
51	409561	Unit A - Main Building	Fountain/Tap Combo	A226	1 of 1	Water Fountain	right	<1
52	409562	Unit A - Main Building	Fountain	A200 Vestibule	1 of 1	Water Fountain	center	<1
53	409565	Unit A - Main Building	Fountain/Tap Combo	A201	1 of 1	Tap	center	<1
54	409566	Unit A - Main Building	Fountain/Tap Combo	A201	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
55	409567	Unit A - Main Building	Fountain/Tap Combo	A202	1 of 1	Tap	center	<1
56	409568	Unit A - Main Building	Fountain/Tap Combo	A202	1 of 1	Water Fountain	right	<1
57	409569	Unit A - Main Building	Fountain/Tap Combo	A203	1 of 1	Tap	center	<1
58	409570	Unit A - Main Building	Fountain/Tap Combo	A203	1 of 1	Water Fountain	right	<1
59	409571	Unit A - Main Building	Fountain/Tap Combo	A204	1 of 1	Tap	center	<1
60	409572	Unit A - Main Building	Fountain/Tap Combo	A204	1 of 1	Water Fountain	right	<1
61	409574	Unit A - Main Building	Fountain/Tap Combo	A205	1 of 1	Water Fountain	right	<1
62	409576	Unit A - Main Building	Fountain/Tap Combo	A206	1 of 1	Water Fountain	right	<1
63	409868	Unit A - Main Building	Fountain with Bottle Filler	Gym Lobby	1 of 1	Water Fountain	center	<1
64	409869	Unit A - Main Building	Fountain with Bottle Filler	Gym Lobby	1 of 1	Water Bottle Filler	center	<1
65	409870	Unit A - Main Building	Fountain	Across Rm149	1 of 1	Water Fountain	center	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
66	409871	Unit A - Main Building	Sink	Health Room	1 of 1	Tap	center	<1
67	409873	Unit A - Main Building	Sink	Staff Lounge	1 of 1	Tap	center	<1
68	409874	Unit A - Main Building	Fountain	A100 Vestibule	1 of 1	Water Fountain	center	<1
69	409876	Unit A - Main Building	Fountain/Tap Combo	A100 Shared Space	1 of 1	Water Fountain	right	<1
70	409878	Unit A - Main Building	Fountain/Tap Combo	A101	1 of 1	Water Fountain	right	<1