



**VENTURA UNIFIED SCHOOL DISTRICT
BUENA HIGH SCHOOL STADIUM SURFACING**

BID # E15-25 REBID

NOVEMBER 17TH, 2025

ADDENDUM #02

NOTICE TO BIDDERS:

The following revisions and/or clarifications shall be made to the bidding requirements and contract documents. Revise and amend the documents for the above-named project in accordance with this addendum. The bid shall reflect these addendum changes and each bidder shall refer in their bid to this addendum.

All bidding requirements and contract documents shall apply to this addendum as originally indicated in the applicable portions of the contract documents, unless otherwise modified by this addendum.

Contractors shall acknowledge this addendum at the space provided on the Bid Proposal.

REVISIONS, CLARIFICATIONS, & RESPONSES TO PRE-BID RFI'S:

1. See attached Pre-Bid RFI responses #10 and #11

REVISIONS TO THE PLANS: N/A

REVISIONS TO THE SPECIFICATIONS: N/A

END OF ADDENDUM #2

Addendum: 1 page

ENCLOSURES: 2 Pages

Total Number of Pages: 3 Pages

Pre-Bid RFI #10

PRE-BID CLARIFICATION FORM (For Contractor's Use)

PROJECT NAME:	Buena High School Stadium Surfacing - Rebid		
PROJECT NUMBER:	Bid #E15-25 Rebid		
TO:	Steve Key Ryan Hughes Anna Kohr	EMAIL:	skey@lpadesignstudios.com ryan.hughes@venturausd.org akohr@balbourbeattyus.com

DATE:	11-17-25		
FROM:	Ohno Construction Company	EMAIL:	estimating@ohnoconstruction.com
DOCUMENT/DIVISION NUMBER:	Addendum 01	DRAWING NUMBER:	

REQUESTED CLARIFICATION:
Due to the inclusion of additional electrical scope in Addendum 01, we would like to request more time to develop quotes for this scope on behalf of several potential subcontractors. Would the District please consider extending the bid submission date to Nov. 24 or 25? Thank you.
RESPONSE TO CLARIFICATION:
Bid submission date will remain as Friday November 21st at 2PM.

Attach additional numbered sheets as necessary; however, only one (1) request shall be contained on each submitted form.

Pre-Bid RFI #11

PRE-BID CLARIFICATION FORM (For Contractor's Use)

PROJECT NAME:	Buena High School Stadium Surfacing - Rebid		
PROJECT NUMBER:	Bid #E15-25 Rebid		
TO:	Steve Key Ryan Hughes Anna Kohr	EMAIL:	skey@lpadesignstudios.com ryan.hughes@venturausd.org akohr@balbourbeattyus.com

DATE:	11-17-2025		
FROM:	Ohno Construction Company	EMAIL:	estimating@ohnoconstruction.com
DOCUMENT/DIVISION NUMBER:		DRAWING NUMBER:	

REQUESTED CLARIFICATION:
Further to RFI Response #7, we would like to verify if contractor needs to replace the existing concrete curb at track (north side to be affected by new conduit) or will remain existing. Also, please confirm if patching back would be asphalt or concrete.
RESPONSE TO CLARIFICATION:
Existing curb at the track is to remain protected in place. Patch-back is asphalt to match existing. M. Michalek; LPA

Attach additional numbered sheets as necessary; however, only one (1) request shall be contained on each submitted form.