



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

July 22, 2025

John Harding
Lake Creek Learning Center
PO Box 548
Eagle Point, OR 97524
TEL: (541) 830-6378
FAX

RE: LCLC 2043317 Lead Testing-AMENDED

Order No.: 25060665

Dear John Harding:

Neilson Research Corporation received 17 sample(s) on 6/12/2025 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501



Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 25060665
Date: 7/22/2025

CLIENT: Lake Creek Learning Center
Project: LCLC 2043317 Lead Testing-AMENDED

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

The report has been amended to include the accreditation status, which was omitted from the original version due to a clerical error. Neilson Research Corporation is, and has been, accredited by ORELAP for the analysis of lead in drinking water.

Revision v1



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25060665
 Date Reported: 7/22/2025

Lake Creek Learning Center
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 25060665
Received Date: 6/12/2025 12:35:00 PM
Reported Date: 7/22/2025 8:31:17 AM

Sample Information:

Lab ID: 25060665-01 Client Sample ID: 2043317-001CF-25A
 Collection Date: 6/12/2025 8:30:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20433171-001CF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/20/2025	15.0	A	

Lab ID: 25060665-02 Client Sample ID: 2043317-002DW-25A
 Collection Date: 6/12/2025 8:30:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20433172-002DW-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/20/2025	15.0	A	

Lab ID: 25060665-03 Client Sample ID: 2043317-003CF-25A
 Collection Date: 6/12/2025 8:30:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20433173-003CF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/20/2025	15.0	A	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25060665
 Date Reported: 7/22/2025

Lake Creek Learning Center
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 25060665
Received Date: 6/12/2025 12:35:00 PM
Reported Date: 7/22/2025 8:31:17 AM

Sample Information:

Lab ID: 25060665-04 Client Sample ID: 2043317-004DW-25A
 Collection Date: 6/12/2025 8:30:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20433174-004DW-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/20/2025	15.0	A	

Lab ID: 25060665-05 Client Sample ID: 2043317-005DW-25A
 Collection Date: 6/12/2025 8:30:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20433175-005DW-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/20/2025	15.0	A	

Lab ID: 25060665-06 Client Sample ID: 2043317-006CF-25A
 Collection Date: 6/12/2025 8:30:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20433176-006CF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/20/2025	15.0	A	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25060665
 Date Reported: 7/22/2025

Lake Creek Learning Center
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 25060665
Received Date: 6/12/2025 12:35:00 PM
Reported Date: 7/22/2025 8:31:17 AM

Sample Information:

Lab ID: 25060665-07 Client Sample ID: 2043317-007BF-25A
 Collection Date: 6/12/2025 8:30:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20433177-007BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/20/2025	15.0	A	

Lab ID: 25060665-08 Client Sample ID: 2043317-008BF-25A
 Collection Date: 6/12/2025 8:30:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20433178-008BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/20/2025	15.0	A	

Lab ID: 25060665-09 Client Sample ID: 2043317-009BF-25A
 Collection Date: 6/12/2025 8:30:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20433179-009BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/20/2025	15.0	A	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25060665
 Date Reported: 7/22/2025

Lake Creek Learning Center
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 25060665
Received Date: 6/12/2025 12:35:00 PM
Reported Date: 7/22/2025 8:31:17 AM

Sample Information:

Lab ID: 25060665-10 Client Sample ID: 2043317-010BF-25A
 Collection Date: 6/12/2025 8:30:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 204331710-010BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/24/2025	15.0	A	

Lab ID: 25060665-11 Client Sample ID: 2043317-011NS-25A
 Collection Date: 6/12/2025 8:30:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 204331711-011NS-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/24/2025	15.0	A	

Lab ID: 25060665-12 Client Sample ID: 2043317-012WB-25A
 Collection Date: 6/12/2025 8:30:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 204331712-012WB-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/24/2025	15.0	A	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25060665
 Date Reported: 7/22/2025

Lake Creek Learning Center
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 25060665
Received Date: 6/12/2025 12:35:00 PM
Reported Date: 7/22/2025 8:31:17 AM

Sample Information:

Lab ID: 25060665-13 Client Sample ID: 2043317-013KF-25A
 Collection Date: 6/12/2025 8:30:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 204331713-013KF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.638		0.500	ppb	1	6/24/2025	15.0	A	

Lab ID: 25060665-14 Client Sample ID: 2043317-014KF-25A
 Collection Date: 6/12/2025 8:30:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 204331714-014KF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/24/2025	15.0	A	


Lab ID: 25060665-15 Client Sample ID: 2043317-015KF-25A
 Collection Date: 6/12/2025 8:30:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 204331715-015KF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.576		0.500	ppb	1	6/24/2025	15.0	A	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25060665
 Date Reported: 7/22/2025

Lake Creek Learning Center
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 25060665
Received Date: 6/12/2025 12:35:00 PM
Reported Date: 7/22/2025 8:31:17 AM

Sample Information:

Lab ID: 25060665-16 Client Sample ID: 2043317-016BF-25A
 Collection Date: 6/12/2025 8:30:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 204331716-016BF-25A

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/24/2025	15.0	A	

Lab ID: 25060665-17 Client Sample ID: 2043317-017DW-25A
 Collection Date: 6/12/2025 8:30:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 204331717-017DW-25A

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.929		0.500	ppb	1	6/24/2025	15.0	A	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25060665
 22-Jul-25

Client: Lake Creek Learning Center

Project: LCLC 2043317 Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: MB-31810	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/20/2025	RunNo: 60496						
Client ID: PBW	Batch ID: 31810	TestNo: E200.8	E200.8	Analysis Date: 6/20/2025	SeqNo: 992209						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.500

Sample ID: LCS-31810	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/20/2025	RunNo: 60496						
Client ID: LCSW	Batch ID: 31810	TestNo: E200.8	E200.8	Analysis Date: 6/20/2025	SeqNo: 992210						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 103 0.500 100 0 103 85 115

Sample ID: 25060490-01AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/20/2025	RunNo: 60496						
Client ID: BatchQC	Batch ID: 31810	TestNo: E200.8	E200.8	Analysis Date: 6/20/2025	SeqNo: 992212						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 103 0.500 100 4.07 98.5 70 130

Sample ID: 25060490-01AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/20/2025	RunNo: 60496						
Client ID: BatchQC	Batch ID: 31810	TestNo: E200.8	E200.8	Analysis Date: 6/20/2025	SeqNo: 992213						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 104 0.500 100 4.07 99.6 70 130 103 1.06 20

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode DF Dilution Factor E Value above quantitation range
 H Holding times for preparation or analysis exceeded MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit
 RL Reporting Limit

Revision v1



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25060665
 22-Jul-25

Client: Lake Creek Learning Center

Project: LCLC 2043317 Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: MB-31836	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/23/2025	RunNo: 60513						
Client ID: PBW	Batch ID: 31836	TestNo: E200.8	E200.8	Analysis Date: 6/24/2025	SeqNo: 992741						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.500									

Sample ID: LCS-31836	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/23/2025	RunNo: 60513						
Client ID: LCSW	Batch ID: 31836	TestNo: E200.8	E200.8	Analysis Date: 6/24/2025	SeqNo: 992742						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	103	0.500	100	0	103	85	115				

Sample ID: 25060565-46AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/23/2025	RunNo: 60513						
Client ID: BatchQC	Batch ID: 31836	TestNo: E200.8	E200.8	Analysis Date: 6/24/2025	SeqNo: 992744						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	103	0.500	100	2.15	101	70	130				

Sample ID: 25060565-46AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/23/2025	RunNo: 60513						
Client ID: BatchQC	Batch ID: 31836	TestNo: E200.8	E200.8	Analysis Date: 6/24/2025	SeqNo: 992745						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	105	0.500	100	2.15	102	70	130	103	1.50	20	

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode
 H Holding times for preparation or analysis exceeded
 RL Reporting Limit
 DF Dilution Factor
 MI Recovery outside control limits due to Matrix Interference
 E Value above quantitation range
 ND Not Detected at the Reporting Limit

Revision v1



Sample Log-In Check List

Client Name: LakeCreekLearning Work Order Number: 25060665 RcptNo: 1

Logged by:	Danielle Garten	6/12/2025 12:35:00 PM	<i>Danielle Garten</i>
Completed By:	Victoria Schleicher	6/16/2025 1:04:46 PM	<i>V Schleicher</i>
Reviewed By:	Ashley Spiegelberg	6/26/2025 11:32:15 AM	<i>Ashley Spiegelberg</i>

Chain of Custody

1. Is Chain of Custody complete? Yes No Not Present
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes No NA
4. Shipping container/cooler in good condition? Yes No
- Custody seals intact on shipping container/cooler? Yes No Not Present NA
- No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes No NA
6. Were all samples received at a temperature of >0° C to 6.0°C Yes No NA
7. Sample(s) in proper container(s)? Yes No
8. Sufficient sample volume for indicated test(s)? Yes No
9. Are samples (except VOA and ONG) properly preserved? Yes No
10. Was preservative added to bottles? Yes No NA
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes No No VOA Vials
12. Were any sample containers received broken? Yes No
13. Does paperwork match bottle labels? Yes No
- (Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes No
15. Is it clear what analyses were requested? Yes No
16. Were all holding times able to be met? Yes No
- (If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes No NA

Person Notified:	<input type="text"/>	Date:	<input type="text"/>
By Whom:	<input type="text"/>	Via:	<input type="checkbox"/> eMail <input type="checkbox"/> Phone <input type="checkbox"/> Fax <input type="checkbox"/> In Person
Regarding:	<input type="text"/>		
Client Instructions:	<input type="text"/>		

18. Additional remarks:

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company: <u>Lake Creek Learning Center</u>		Project Name: <u>LCLC</u>		Attention: <u>John Harding</u>		<input type="checkbox"/> Standard: 10 Business Days <input type="checkbox"/> Priority: 5 Business Days (List x 1.50) <input type="checkbox"/> Express: 3 Business Days (List x 1.75) <input type="checkbox"/> Rush: 2 Business Days (List x 2.00) <input type="checkbox"/> Rush: 1 Business Day (List x 2.50) <input type="checkbox"/> Rush: Same Day (List x 3.00)	
Address: <u>371 Lake Creek Loop</u> <u>Lake Creek, OR</u>		Project Number: <u>2043317</u>		Company Name: <u>JCSDA</u>		<input type="checkbox"/> Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No	
Email:		Report To:		Address: <u>P.O. Box 548</u> <u>Eagle Point, OR</u>			
Phone: <u>830-6378</u> Fax:		Copy To:		P.O. # <u>97524</u>			
Collected By (Print): <u>Steve Lambert</u>							
Collected By (Sign): <u>[Signature]</u>							
Email Report <input type="checkbox"/> Mail Report <input type="checkbox"/> Fax Report <input type="checkbox"/>							

Section E Sample Information					Analysis Requested										NRC Workorder # (Lab Use Only)		
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers												
<u>2043317-011NS-25A</u>	<u>19568</u>		<u>6-12-25</u>	<u>8:30</u>	<u>1</u>												
<u>-012WB-25A</u>	<u>19572</u>			<u>8:30</u>	<u>1</u>												
<u>-013KF-25A</u>	<u>19576</u>			<u>8:30</u>	<u>1</u>												
<u>-014KF-25A</u>	<u>19556</u>			<u>8:30</u>	<u>1</u>												
<u>-015KF-25A</u>	<u>19573</u>			<u>8:30</u>	<u>1</u>												
<u>-016BF-25A</u>	<u>19567</u>			<u>8:30</u>	<u>1</u>												
<u>-017DW-25A</u>	<u>19575</u>			<u>8:30</u>	<u>1</u>												

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive			
Relinquished By: <u>[Signature]</u>	Print: <u>Steve Lambert</u>	Date: <u>6-12-25</u>	Time: <u>12:35</u>
Received By:			
Relinquished By:			
Received By:			
Relinquished By:			
Received By Laboratory: <u>Danielle Gartin</u>		<u>6/12/25</u>	<u>12:35</u>

Section G Lab Use Only	
Temp: <u>Amb</u> IR Therm ID:	
≤6°C: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Received on Ice: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Number of Bottles Received: <u>17</u>	
pH Checked: <u>-</u>	
COC Seals Intact: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <u>(NA)</u>	
Field Blank Included: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	

Received Via UPS FedEx Other Hand
 Payment: Invoice Cash VISA, M/C Check # _____ Amount _____