



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

July 22, 2025

John Harding
Eagle Point School District #9
PO Box 548
Eagle Point, OR 97524
TEL: (541) 830-1240
FAX (541) 830-6375

RE: CTAK Lead Testing-AMENDED

Order No.: 25060714

Dear John Harding:

Neilson Research Corporation received 8 sample(s) on 6/13/2025 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501



Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 25060714
Date: 7/22/2025

CLIENT: Eagle Point School District #9
Project: CTAK Lead Testing-AMENDED

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

The report has been amended to include the accreditation status, which was omitted from the original version due to a clerical error. Neilson Research Corporation is, and has been, accredited by ORELAP for the analysis of lead in drinking water.

Revision v1



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25060714
 Date Reported: 7/22/2025

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 25060714
Received Date: 6/13/2025 12:50:00 PM
Reported Date: 7/22/2025 9:57:29 AM

Sample Information:

Lab ID: 25060714-01 Client Sample ID: 20456789-001KF-25A
 Collection Date: 6/13/2025 7:50:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20456789-001KF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	65.9	*1	0.500	ppb	1	6/24/2025	15.0	A	

Lab ID: 25060714-02 Client Sample ID: 20456789-002KF-25A
 Collection Date: 6/13/2025 7:50:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20456789-002KF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.03		0.500	ppb	1	6/24/2025	15.0	A	

Lab ID: 25060714-03 Client Sample ID: 20456789-003SF-25A
 Collection Date: 6/13/2025 7:50:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20456789-003SF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	2.86		0.500	ppb	1	6/24/2025	15.0	A	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25060714
 Date Reported: 7/22/2025

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 25060714
Received Date: 6/13/2025 12:50:00 PM
Reported Date: 7/22/2025 9:57:29 AM

Sample Information:

Lab ID: 25060714-04 Client Sample ID: 20456789-004DW-25A
 Collection Date: 6/13/2025 7:50:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20456789-004DW-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.670		0.500	ppb	1	6/25/2025	15.0	A	

Lab ID: 25060714-05 Client Sample ID: 20456789-005DW-25A
 Collection Date: 6/13/2025 7:50:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20456789-005DW-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.647		0.500	ppb	1	6/25/2025	15.0	A	

Lab ID: 25060714-06 Client Sample ID: 20456789-006BF-25A
 Collection Date: 6/13/2025 7:50:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20456789-006BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/25/2025	15.0	A	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25060714
 Date Reported: 7/22/2025

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 25060714
Received Date: 6/13/2025 12:50:00 PM
Reported Date: 7/22/2025 9:57:29 AM

Sample Information:

Lab ID: 25060714-07 Client Sample ID: 20456789-008BF-25A
 Collection Date: 6/13/2025 7:50:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20456789-008BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.17		0.500	ppb	1	6/25/2025	15.0	A

Lab ID: 25060714-08 Client Sample ID: 20456789-007BF-25A
 Collection Date: 6/13/2025 7:50:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20456789-007BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.13		0.500	ppb	1	6/25/2025	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25060714
 22-Jul-25

Client: Eagle Point School District #9
Project: CTAK Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: MB-31837	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/23/2025	RunNo: 60570
Client ID: PBW	Batch ID: 31837	TestNo: E200.8	E200.8	Analysis Date: 6/24/2025	SeqNo: 994030
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.500

Sample ID: MB-31837	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/23/2025	RunNo: 60570
Client ID: PBW	Batch ID: 31837	TestNo: E200.8	E200.8	Analysis Date: 6/24/2025	SeqNo: 994031
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.500

Sample ID: LCS-31837	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/23/2025	RunNo: 60570
Client ID: LCSW	Batch ID: 31837	TestNo: E200.8	E200.8	Analysis Date: 6/24/2025	SeqNo: 994032
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 107 0.500 100 0 107 85 115

Sample ID: 25060713-03AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/23/2025	RunNo: 60570
Client ID: BatchQC	Batch ID: 31837	TestNo: E200.8	E200.8	Analysis Date: 6/24/2025	SeqNo: 994034
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 116 0.500 100 11.6 105 70 130

Qualifiers: * Value exceeds Maximum or Minimum Contaminant Level. C1 Sample container temperature is out of limit as specified at testcode DF Dilution Factor
 H Holding times for preparation or analysis exceeded MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit
 RL Reporting Limit

Revision v1



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25060714
 22-Jul-25

Client: Eagle Point School District #9
Project: CTAK Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: 25060713-03AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/23/2025	RunNo: 60570						
Client ID: BatchQC	Batch ID: 31837	TestNo: E200.8	E200.8	Analysis Date: 6/24/2025	SeqNo: 994035						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	116	0.500	100	11.6	104	70	130	116	0.264	20	

Qualifiers:

* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode	DF Dilution Factor
H Holding times for preparation or analysis exceeded	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
RL Reporting Limit		

Revision v1



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Sample Log-In Check List

Client Name: EAGLEPTSCHOOL

Work Order Number: 25060714

RcptNo: 1

Logged by:	Victoria Schleicher	6/13/2025 12:50:00 PM	<i>V Schleicher</i> <i>am</i> <i>am</i>
Completed By:	Ashley Spiegelberg	6/26/2025 1:52:20 PM	
Reviewed By:	Ashley Spiegelberg	6/26/2025 1:52:24 PM	

Chain of Custody

1. Is Chain of Custody complete? Yes No Not Present
 2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes No NA
 4. Shipping container/cooler in good condition? Yes No
 Custody seals intact on shipping container/cooler? Yes No Not Present NA
 No. Seal Date: Signed By:
 5. Was an attempt made to cool the samples? Yes No NA
 6. Were all samples received at a temperature of >0° C to 6.0°C Yes No NA
 7. Sample(s) in proper container(s)? Yes No
 8. Sufficient sample volume for indicated test(s)? Yes No
 9. Are samples (except VOA and ONG) properly preserved? Yes No
 10. Was preservative added to bottles? Yes No NA
 11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes No No VOA Vials
 12. Were any sample containers received broken? Yes No
 13. Does paperwork match bottle labels? Yes No
 (Note discrepancies on chain of custody)
 14. Are matrices correctly identified on Chain of Custody? Yes No
 15. Is it clear what analyses were requested? Yes No
 16. Were all holding times able to be met? Yes No
 (If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes No NA

Person Notified:	<input type="text"/>	Date:	<input type="text"/>
By Whom:	<input type="text"/>	Via:	<input type="checkbox"/> eMail <input type="checkbox"/> Phone <input type="checkbox"/> Fax <input type="checkbox"/> In Person
Regarding:	<input type="text"/>		
Client Instructions:	<input type="text"/>		

18. Additional remarks:

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
1	21.8	Good				DE

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A
Required Client Information

Company: JCS D9
 Address: P.O. BOX 548
Eagle Point, OR 97524
 Email: _____
 Phone: 830-6378 Fax: _____
 Collected By (Print): Steve Lambert
 Collected By (Sign): [Signature]
 Email Report Mail Report Fax Report

Section B
Required Project Information

Project Name: CTAK
 Project Number: 20456789
 Report To: _____
 Copy To: _____

Section C
Invoice Information

Attention: John Harding
 Company Name: JCS D9
 Address: P.O. Box 548
Eagle Point, OR 97524
 P.O. # _____

Section D
Rush Status (Subject to Scheduling)

Standard: 10 Business Days
 Priority: 5 Business Days (List x 1.50)
 Express: 3 Business Days (List x 1.75)
 Rush: 2 Business Days (List x 2.00)
 Rush: 1 Business Day (List x 2.50)
 Rush: Same Day (List x 3.00)

Authorized Yes No

Section E
Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers												
<u>001KF-25A</u>	<u>19537</u>		<u>6/13/25</u>	<u>7:50</u>	<u>1</u>	<u>✓</u>											
<u>002KF-25A</u>	<u>21169</u>			<u>7:50</u>	<u>1</u>	<u>✓</u>											
<u>003SF-25A</u>	<u>21163</u>			<u>7:50</u>	<u>1</u>	<u>✓</u>											
<u>004DW-25A</u>	<u>19535</u>			<u>7:50</u>	<u>1</u>	<u>✓</u>											
<u>005DW-25A</u>	<u>19536</u>			<u>7:50</u>	<u>1</u>	<u>✓</u>											
<u>006BF-25A</u>	<u>19539</u>			<u>7:50</u>	<u>1</u>	<u>✓</u>											
<u>008BF-25A</u>	<u>19534</u>			<u>7:50</u>	<u>1</u>	<u>✓</u>											
<u>007BF-25A</u>	<u>21164</u>			<u>7:50</u>	<u>1</u>	<u>✓</u>											

Analysis Requested

No. of Containers	lead																
-------------------	------	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--

Section D
NRC Workorder # (Lab Use Only) 25060714

Remarks / Field Data	NRC Sample # (Use Only)	(Lab)
	<u>01</u>	
	<u>02</u>	
	<u>03</u>	
	<u>04</u>	
	<u>05</u>	
	<u>06</u>	
	<u>07</u>	
	<u>08</u>	

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F
Relinquish/Receive

Relinquished By: [Signature] Sign
 Received By: Steve Lambert Print
 Date: 6/13/25 Time: 12:50

Relinquished By: _____
 Received By: _____
 Relinquished By: _____
 Received By: _____
 Relinquished By: _____
 Received By Laboratory: V. Schleicher
Victoria Schleicher Print
 Date: 6/13/25 Time: 12:50 vs 12:54 error

Section G
Lab Use Only

Temp: 21.8 IR Therm ID: T
 ≤6°C: Yes No
 Received on Ice: Yes No
 Number of Bottles Received: 8
 pH Checked: _____
 COC Seals Intact: Yes No NA
 Field Blank Included: Yes No

Received Via UPS FedEx Other Hand

Payment: Invoice Cash VISA, M/C Check # _____ Amount _____

-
- A Total Alkalinity and Bicarbonate Alkalinity results are to a pH endpoint of 4.5. Carbonate Alkalinity result is to a pH endpoint of 8.3.
- A-LL The total low level alkalinity results are to a pH endpoint of 4.3-4.7 pH units per SM 2320 B.
- B Analyte detected in the associated method blank.
- C Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
- C1 Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
- CF Results confirmed by re-analysis.
- CU Cleanup performed as specified by method.
- E Estimated value.
- ER Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
- FC Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
- HP Sample re-analysis performed outside of method specified holding time.
- HR Sample received outside of method specified holding time.
- HS Sample analyzed for volatile organics contained headspace.
- HT At the client's request, the sample was analyzed outside of method specified holding time.
- H Analysis performed outside of method specified holding time.
- J Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
- L Dissolved metals were not filtered within 15 minutes of collection per 40 CFR Part 136.
- MI Surrogate, Duplicate Sample (DUP) or Matrix Spikes recoveries are out of control limits due to matrix interference. Sample results may be biased.
- N See Case Narrative on page 2 of report.
- Q Initial calibration verification (ICV), continuing calibration verification (CCV) or laboratory control sample (LCS), and/or matrix spikes exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
- R Relative percent difference (RPD) is outside of the accepted recovery limits.
- R1 The numerical difference between the parent sample and the duplicate (DUP) is outside of the accepted recovery limits. Greater than 5 degrees for Flashpoint, or greater than 0.1 pH units for pH.
- R3 The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
- R4 The Relative percent difference (RPD) is not within control limits because the concentration of the sample result is too low to represent proper statistical error.
- R5 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30% because the results are too low to represent proper statistical error. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series. The sample results are not affected.
- R6 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30%. This may indicate a possible matrix interference. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series.
- S Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
- S1 Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
- SC Sub-contracted to another laboratory for analysis.
- SP Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
- * Value exceeds Maximum Contaminant Level or is outside the acceptable range.<<>>
- 1 Value exceeds one half of the Maximum Contaminant Level.