



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

June 26, 2025

John Harding
Eagle Point School District #9
PO Box 548
Eagle Point, OR 97524
TEL: (541) 830-1240
FAX (541) 830-6375

RE: Student Services Lead Testing

Order No.: 25060716

Dear John Harding:

Neilson Research Corporation received 11 sample(s) on 6/13/2025 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501



Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 25060716
Date: 6/26/2025

CLIENT: Eagle Point School District #9

Project: Student Services Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25060716
 Date Reported: 6/26/2025

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 25060716
Received Date: 6/13/2025 12:50:00 PM
Reported Date: 6/26/2025 1:58:21 PM

Sample Information:

Lab ID: 25060716-01 Client Sample ID: 20435572-001KF-25A
 Collection Date: 6/13/2025 8:15:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20435572-001KF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/25/2025	15.0	

Lab ID: 25060716-02 Client Sample ID: 20435572-002SF-25A
 Collection Date: 6/13/2025 8:15:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20435572-002SF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/25/2025	15.0	

Lab ID: 25060716-03 Client Sample ID: 20435572-003BF-25A
 Collection Date: 6/13/2025 8:15:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20435572-003BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/25/2025	15.0	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25060716
 Date Reported: 6/26/2025

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 25060716
Received Date: 6/13/2025 12:50:00 PM
Reported Date: 6/26/2025 1:58:21 PM

Sample Information:

Lab ID: 25060716-04 Client Sample ID: 20435572-004BF-25A
 Collection Date: 6/13/2025 8:15:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20435572-004BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/25/2025	15.0	

Lab ID: 25060716-05 Client Sample ID: 20435572-005BF-25A
 Collection Date: 6/13/2025 8:15:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20435572-005BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/25/2025	15.0	

Lab ID: 25060716-06 Client Sample ID: 20435572-006BF-25A
 Collection Date: 6/13/2025 8:15:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20435572-006BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/25/2025	15.0	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25060716
 Date Reported: 6/26/2025

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 25060716
Received Date: 6/13/2025 12:50:00 PM
Reported Date: 6/26/2025 1:58:21 PM

Sample Information:

Lab ID: 25060716-07 Client Sample ID: 20435572-007BF-25A
 Collection Date: 6/13/2025 8:15:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20435572-007BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/25/2025	15.0	

Lab ID: 25060716-08 Client Sample ID: 20435572-008BF-25A
 Collection Date: 6/13/2025 8:15:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20435572-008BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/25/2025	15.0	

Lab ID: 25060716-09 Client Sample ID: 20435572-009DW-25A
 Collection Date: 6/13/2025 8:20:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20435572-009DW-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/25/2025	15.0	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25060716
 Date Reported: 6/26/2025

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 25060716
Received Date: 6/13/2025 12:50:00 PM
Reported Date: 6/26/2025 1:58:21 PM

Sample Information:

Lab ID: 25060716-10 Client Sample ID: 20435572-010DW-25A
 Collection Date: 6/13/2025 8:20:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20435572-010DW-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/23/2025	15.0	

Lab ID: 25060716-11 Client Sample ID: 20435572-011WB-25A
 Collection Date: 6/13/2025 8:15:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20435572-011WB-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/23/2025	15.0	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25060716
 26-Jun-25

Client: Eagle Point School District #9
Project: Student Services Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-31838	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/23/2025	RunNo: 60513
Client ID: PBW	Batch ID: 31838	TestNo: E200.8	E200.8	Analysis Date: 6/23/2025	SeqNo: 992595
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.500

Sample ID: LCS-31838	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/23/2025	RunNo: 60513
Client ID: LCSW	Batch ID: 31838	TestNo: E200.8	E200.8	Analysis Date: 6/23/2025	SeqNo: 992596
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 104 0.500 100 0 104 85 115

Sample ID: 25060716-10AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/23/2025	RunNo: 60513
Client ID: 20435572-010DW-25	Batch ID: 31838	TestNo: E200.8	E200.8	Analysis Date: 6/23/2025	SeqNo: 992598
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 103 0.500 100 0.275 102 70 130

Sample ID: 25060716-10AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/23/2025	RunNo: 60513
Client ID: 20435572-010DW-25	Batch ID: 31838	TestNo: E200.8	E200.8	Analysis Date: 6/23/2025	SeqNo: 992599
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 103 0.500 100 0.275 102 70 130 103 0.115 20

Qualifiers: CI Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceeded
 MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25060716
 26-Jun-25

Client: Eagle Point School District #9
Project: Student Services Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-31837	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/23/2025	RunNo: 60570
Client ID: PBW	Batch ID: 31837	TestNo: E200.8	E200.8	Analysis Date: 6/24/2025	SeqNo: 994030
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.500

Sample ID: MB-31837	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/23/2025	RunNo: 60570
Client ID: PBW	Batch ID: 31837	TestNo: E200.8	E200.8	Analysis Date: 6/24/2025	SeqNo: 994031
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.500

Sample ID: LCS-31837	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/23/2025	RunNo: 60570
Client ID: LCSW	Batch ID: 31837	TestNo: E200.8	E200.8	Analysis Date: 6/24/2025	SeqNo: 994032
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 107 0.500 100 0 107 85 115

Sample ID: 25060713-03AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/23/2025	RunNo: 60570
Client ID: BatchQC	Batch ID: 31837	TestNo: E200.8	E200.8	Analysis Date: 6/24/2025	SeqNo: 994034
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 116 0.500 100 11.6 105 70 130

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceeded
 MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25060716
 26-Jun-25

Client: Eagle Point School District #9
Project: Student Services Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: 25060713-03AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/23/2025	RunNo: 60570						
Client ID: BatchQC	Batch ID: 31837	TestNo: E200.8	E200.8	Analysis Date: 6/24/2025	SeqNo: 994035						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	116	0.500	100	11.6	104	70	130	116	0.264	20	

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceeds
 MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Sample Log-In Check List

Client Name: EAGLEPTSCHOOL

Work Order Number: 25060716

RcptNo: 1

Logged by:	Victoria Schleicher	6/13/2025 12:50:00 PM	<i>V Schleicher</i> <i>am</i> <i>am</i>
Completed By:	Ashley Spiegelberg	6/26/2025 1:57:02 PM	
Reviewed By:	Ashley Spiegelberg	6/26/2025 1:57:06 PM	

Chain of Custody

1. Is Chain of Custody complete? Yes No Not Present
 2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes No NA
 4. Shipping container/cooler in good condition? Yes No
 Custody seals intact on shipping container/cooler? Yes No Not Present NA
 No. Seal Date: Signed By:
 5. Was an attempt made to cool the samples? Yes No NA
 6. Were all samples received at a temperature of >0° C to 6.0°C Yes No NA
 7. Sample(s) in proper container(s)? Yes No
 8. Sufficient sample volume for indicated test(s)? Yes No
 9. Are samples (except VOA and ONG) properly preserved? Yes No
 10. Was preservative added to bottles? Yes No NA
 11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes No No VOA Vials
 12. Were any sample containers received broken? Yes No
 13. Does paperwork match bottle labels? Yes No
 (Note discrepancies on chain of custody)
 14. Are matrices correctly identified on Chain of Custody? Yes No
 15. Is it clear what analyses were requested? Yes No
 16. Were all holding times able to be met? Yes No
 (If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes No NA

Person Notified:	<input type="text"/>	Date:	<input type="text"/>
By Whom:	<input type="text"/>	Via:	<input type="checkbox"/> eMail <input type="checkbox"/> Phone <input type="checkbox"/> Fax <input type="checkbox"/> In Person
Regarding:	<input type="text"/>		
Client Instructions:	<input type="text"/>		

18. Additional remarks:

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
1	21.8	Good				DE

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A

Required Client Information

Company: JCSDA
 Address: P.O. Box 548
Eagle Point, OR 97524
 Email: _____
 Phone: 230-6378 Fax: _____
 Collected By (Print): Steve Lambert
 Collected By (Sign): [Signature]
 Email Report Mail Report Fax Report

Section B

Required Project Information

Project Name: Student Services
 Project Number: 20435572
 Report To: _____
 Copy To: _____

Section C

Invoice Information

Attention: John Harding
 Company Name: JCSDA
 Address: P.O. Box 548
Eagle Point, OR 97524
 P.O. # _____

Section D

Rush Status (Subject to Scheduling)

Standard: 10 Business Days
 Priority: 5 Business Days (List x 1.50)
 Express: 3 Business Days (List x 1.75)
 Rush: 2 Business Days (List x 2.00)
 Rush: 1 Business Day (List x 2.50)
 Rush: Same Day (List x 3.00)

Authorized Yes No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	Remarks / Field Data	NRC Sample # (Lab Use Only)	(Lab Use Only)
<u>20435572-001KF-25A</u>	<u>21156</u>		<u>6/13/25</u>	<u>8:15</u>	<u>1</u>	<u>Lead</u>			
<u>-002SF-25A</u>	<u>21174</u>			<u>8:15</u>	<u>1</u>			<u>01</u>	
<u>-003BF-25A</u>	<u>21176</u>			<u>8:15</u>	<u>1</u>			<u>02</u>	
<u>-004BF-25A</u>	<u>21167</u>			<u>8:15</u>	<u>1</u>			<u>03</u>	
<u>-005BF-25A</u>	<u>21165</u>			<u>8:15</u>	<u>1</u>			<u>04</u>	
<u>-006BF-25A</u>	<u>19549</u>			<u>8:15</u>	<u>1</u>			<u>05</u>	
<u>-007BF-25A</u>	<u>19533</u>			<u>8:15</u>	<u>1</u>			<u>06</u>	
<u>-008BF-25A</u>	<u>19526</u>			<u>8:15</u>	<u>1</u>			<u>07</u>	
<u>-009DW-25A</u>	<u>21150</u>			<u>8:20</u>	<u>1</u>			<u>08</u>	
<u>-010DW-25A</u>	<u>21168</u>			<u>8:20</u>	<u>1</u>			<u>09</u>	
								<u>10</u>	

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquished By: [Signature] Sign: _____
 Received By: Steve Lambert Print: _____ Date: 6/13/25 Time: 12:50
 Relinquished By: _____
 Received By: _____
 Relinquished By: _____
 Received By Laboratory: V. Schlicher Print: Victoria Schlicher Date: 6/13/25 Time: 12:54

Section G

Lab Use Only

Temp: 21.8 IR Therm ID: T
 ≤6°C: Yes No
 Received on Ice: Yes No
 Number of Bottles Received: 11
 pH Checked: _____
 COC Seals Intact: Yes No NA
 Field Blank Included: Yes No

Received Via UPS FedEx Other Hand

Payment: Invoice Cash VISA, M/C Check # _____ Amount _____

