



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

July 01, 2025

John Harding
Eagle Point School District #9
PO Box 548
Eagle Point, OR 97524
TEL: (541) 830-1240
FAX (541) 830-6375

RE: URCEO Lead Testing

Order No.: 25060725

Dear John Harding:

Neilson Research Corporation received 22 sample(s) on 6/13/2025 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501



Original



**NEILSON
RESEARCH
CORPORATION**

*Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com*

Case Narrative

WO#: **25060725**
Date: **7/1/2025**

CLIENT: Eagle Point School District #9

Project: URCEO Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25060725
 Date Reported: 7/1/2025

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 25060725
Received Date: 6/13/2025 12:50:00 PM
Reported Date: 7/1/2025 10:50:21 AM

Sample Information:

Lab ID: 25060725-01 Client Sample ID: 20434378-001BF-25A
 Collection Date: 6/13/2025 6:50:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20434378-001BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/26/2025	15.0	

Lab ID: 25060725-02 Client Sample ID: 20434378-002BF-25A
 Collection Date: 6/13/2025 6:50:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20434378-002BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/26/2025	15.0	

Lab ID: 25060725-03 Client Sample ID: 20434378-003DW-25A
 Collection Date: 6/13/2025 6:55:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20434378-003DW-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.52		0.515	ppb	1	6/26/2025	15.0	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25060725
 Date Reported: 7/1/2025

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 25060725
Received Date: 6/13/2025 12:50:00 PM
Reported Date: 7/1/2025 10:50:21 AM

Sample Information:

Lab ID: 25060725-04 Client Sample ID: 20434378-004DW-25A
 Collection Date: 6/13/2025 6:50:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20434378-004DW-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/26/2025	15.0	

Lab ID: 25060725-05 Client Sample ID: 20434378-005BF-25A
 Collection Date: 6/13/2025 6:40:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20434378-005BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/26/2025	15.0	

Lab ID: 25060725-06 Client Sample ID: 20434378-006BF-25A
 Collection Date: 6/13/2025 6:40:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20434378-006BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/26/2025	15.0	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25060725
 Date Reported: 7/1/2025

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 25060725
Received Date: 6/13/2025 12:50:00 PM
Reported Date: 7/1/2025 10:50:21 AM

Sample Information:

Lab ID: 25060725-07 Client Sample ID: 20434378-007BF-25A
 Collection Date: 6/13/2025 6:35:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20434378-007BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/26/2025	15.0	

Lab ID: 25060725-08 Client Sample ID: 20434378-008KF-25A
 Collection Date: 6/13/2025 6:35:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20434378-008KF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/26/2025	15.0	


Lab ID: 25060725-09 Client Sample ID: 20434378-009SF-25A
 Collection Date: 6/13/2025 6:35:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20434378-009SF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/26/2025	15.0	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25060725
 Date Reported: 7/1/2025

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 25060725
Received Date: 6/13/2025 12:50:00 PM
Reported Date: 7/1/2025 10:50:21 AM

Sample Information:

Lab ID: 25060725-10 Client Sample ID: 20434378-010BF-25A
 Collection Date: 6/13/2025 6:12:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20434378-010BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.04		0.515	ppb	1	6/26/2025	15.0	

Lab ID: 25060725-11 Client Sample ID: 20434378-011BF-25A
 Collection Date: 6/13/2025 6:12:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20434378-011BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.31		0.515	ppb	1	6/26/2025	15.0	

Lab ID: 25060725-12 Client Sample ID: 20434378-012CF-25A
 Collection Date: 6/13/2025 6:30:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20434378-012CF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/26/2025	15.0	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25060725
 Date Reported: 7/1/2025

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 25060725
Received Date: 6/13/2025 12:50:00 PM
Reported Date: 7/1/2025 10:50:21 AM

Sample Information:

Lab ID: 25060725-13 Client Sample ID: 20434378-013DW-25A
 Collection Date: 6/13/2025 6:30:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20434378-013DW-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	4.14		0.515	ppb	1	6/27/2025	15.0		

Lab ID: 25060725-14 Client Sample ID: 20434378-014CF-25A
 Collection Date: 6/13/2025 6:20:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20434378-014CF-25A


Trace Metals by EPA 200.8 ICP-MS								Analyst:	KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.857		0.515	ppb	1	6/27/2025	15.0		

Lab ID: 25060725-15 Client Sample ID: 20434378-015CF-25A
 Collection Date: 6/13/2025 6:20:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20434378-015CF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	2.03		0.515	ppb	1	6/27/2025	15.0		

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25060725
 Date Reported: 7/1/2025

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 25060725
Received Date: 6/13/2025 12:50:00 PM
Reported Date: 7/1/2025 10:50:21 AM

Sample Information:

Lab ID: 25060725-16 Client Sample ID: 20434378-016CF-25A
 Collection Date: 6/13/2025 6:20:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20434378-016CF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.18		0.515	ppb	1	6/27/2025	15.0	

Lab ID: 25060725-17 Client Sample ID: 20434378-017CF-25A
 Collection Date: 6/13/2025 6:20:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20434378-017CF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.60		0.515	ppb	1	6/27/2025	15.0	

Lab ID: 25060725-18 Client Sample ID: 20434378-018CF-25A
 Collection Date: 6/13/2025 6:20:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20434378-018CF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/27/2025	15.0	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25060725
 Date Reported: 7/1/2025

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 25060725
Received Date: 6/13/2025 12:50:00 PM
Reported Date: 7/1/2025 10:50:21 AM

Sample Information:

Lab ID: 25060725-19 Client Sample ID: 20434378-019WB-25A
 Collection Date: 6/13/2025 6:15:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20434378-019WB-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/27/2025	15.0	

Lab ID: 25060725-20 Client Sample ID: 20434378-020CF-25A
 Collection Date: 6/13/2025 6:20:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20434378-020CF-25A


Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.548		0.515	ppb	1	6/27/2025	15.0	

Lab ID: 25060725-21 Client Sample ID: 20434378-021DW-25A
 Collection Date: 6/13/2025 6:20:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20434378-021DW-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.01		0.515	ppb	1	6/27/2025	15.0	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25060725
 Date Reported: 7/1/2025

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 25060725
Received Date: 6/13/2025 12:50:00 PM
Reported Date: 7/1/2025 10:50:21 AM

Sample Information:

Lab ID: 25060725-22 Client Sample ID: 20434378-022OT-25A
 Collection Date: 6/13/2025 6:50:00 AM Collected By: Steve Lambert
 Matrix: Drinking Water Sample Location: 20434378-022OT-25A

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	6/27/2025	15.0		

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25060725
 01-Jul-25

Client: Eagle Point School District #9
Project: URCEO Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-31904	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/26/2025	RunNo: 60639						
Client ID: PBW	Batch ID: 31904	TestNo: E200.8	E200.8	Analysis Date: 6/26/2025	SeqNo: 995467						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.515

Sample ID: LCS-31904	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/26/2025	RunNo: 60639						
Client ID: LCSW	Batch ID: 31904	TestNo: E200.8	E200.8	Analysis Date: 6/26/2025	SeqNo: 995468						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 107 0.520 100 0 107 85 115

Sample ID: 25060725-01AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/26/2025	RunNo: 60639						
Client ID: 20434378-001BF-25A	Batch ID: 31904	TestNo: E200.8	E200.8	Analysis Date: 6/26/2025	SeqNo: 995470						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual


Lead 107 0.520 100 0.143 107 70 130

Sample ID: 25060725-01AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/26/2025	RunNo: 60639						
Client ID: 20434378-001BF-25A	Batch ID: 31904	TestNo: E200.8	E200.8	Analysis Date: 6/26/2025	SeqNo: 995471						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 105 0.520 100 0.143 105 70 130 107 1.36 20

Qualifiers: CI Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceed
 MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25060725
 01-Jul-25

Client: Eagle Point School District #9
Project: URCEO Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-31905	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/26/2025	RunNo: 60707
Client ID: PBW	Batch ID: 31905	TestNo: E200.8	E200.8	Analysis Date: 6/27/2025	SeqNo: 996704
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.515

Sample ID: LCS-31905	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/26/2025	RunNo: 60707
Client ID: LCSW	Batch ID: 31905	TestNo: E200.8	E200.8	Analysis Date: 6/27/2025	SeqNo: 996705
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 109 0.520 100 0 109 85 115

Sample ID: 25060725-21AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/26/2025	RunNo: 60707
Client ID: 20434378-021DW-25	Batch ID: 31905	TestNo: E200.8	E200.8	Analysis Date: 6/27/2025	SeqNo: 996707
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 113 0.520 100 4.01 109 70 130

Sample ID: 25060725-21AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/26/2025	RunNo: 60707
Client ID: 20434378-021DW-25	Batch ID: 31905	TestNo: E200.8	E200.8	Analysis Date: 6/27/2025	SeqNo: 996708
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 112 0.520 100 4.01 108 70 130 113 0.914 20


Qualifiers: CI Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceed
 MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Original

Client Name: EAGLEPTSCHOOL

Work Order Number: 25060725

RcptNo: 1

Logged by:	Victoria Schleicher	6/13/2025 12:50:00 PM	
Completed By:	Ashley Spiegelberg	7/1/2025 10:45:01 AM	
Reviewed By:	Ashley Spiegelberg	7/1/2025 10:45:04 AM	

Chain of Custody

1. Is Chain of Custody complete? Yes No Not Present
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes No NA
4. Shipping container/cooler in good condition? Yes No
Custody seals intact on shipping container/cooler? Yes No Not Present NA
- No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes No NA
6. Were all samples received at a temperature of >0° C to 6.0°C Yes No NA
7. Sample(s) in proper container(s)? Yes No
8. Sufficient sample volume for indicated test(s)? Yes No
9. Are samples (except VOA and ONG) properly preserved? Yes No
10. Was preservative added to bottles? Yes No NA
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes No No VOA Vials
12. Were any sample containers received broken? Yes No
13. Does paperwork match bottle labels? Yes No
(Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes No
15. Is it clear what analyses were requested? Yes No
16. Were all holding times able to be met? Yes No
(If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes No NA

Person Notified:	<input type="text"/>	Date:	<input type="text"/>
By Whom:	<input type="text"/>	Via:	<input type="checkbox"/> eMail <input type="checkbox"/> Phone <input type="checkbox"/> Fax <input type="checkbox"/> In Person
Regarding:	<input type="text"/>		
Client Instructions:	<input type="text"/>		

18. Additional remarks:

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
1	21.8	Good				DE

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A
Required Client Information

Company: JCSD9
 Address: P.O. Box 548
Eagle Point, OR 97524
 Email:
 Phone: 830-6378 Fax:
 Collected By (Print): Steve Lambert
 Collected By (Sign): [Signature]
 Email Report Mail Report Fax Report

Section B
Required Project Information

Project Name: URCEO
 Project Number: 20434378
 Report To:
 Copy To:

Section C
Invoice Information

Attention: John Harding
 Company Name: JCSD9
 Address: P.O. Box 548
Eagle Point, OR 97524
 P.O. #

Section D
Rush Status (Subject to Scheduling)

Standard: 10 Business Days
 Priority: 5 Business Days (List x 1.50)
 Express: 3 Business Days (List x 1.75)
 Rush: 2 Business Days (List x 2.00)
 Rush: 1 Business Day (List x 2.50)
 Rush: Same Day (List x 3.00)

Authorized Yes No

Section E
Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Lead
<u>20434378-001BF-25A</u>	<u>19423</u>		<u>6-13-25</u>	<u>6:50</u>	<u>1</u>	<u>✓</u>
<u>-002BF-25A</u>	<u>21154</u>			<u>6:50</u>	<u>1</u>	<u>✓</u>
<u>-003DW-25A</u>	<u>19542</u>			<u>6:55</u>	<u>1</u>	<u>✓</u>
<u>-004DW-25A</u>	<u>19491</u>			<u>6:50</u>	<u>1</u>	<u>✓</u>
<u>-005BF-25A</u>	<u>19554</u>			<u>6:40</u>	<u>1</u>	<u>✓</u>
<u>-006BF-25A</u>	<u>19531</u>			<u>6:40</u>	<u>1</u>	<u>✓</u>
<u>-007BF-25A</u>	<u>19571</u>			<u>6:35</u>	<u>1</u>	<u>✓</u>
<u>-008KF-25A</u>	<u>19541</u>			<u>6:35</u>	<u>1</u>	<u>✓</u>
<u>-009SF-25A</u>	<u>19578</u>			<u>6:35</u>	<u>1</u>	<u>✓</u>
<u>-010BF-25A</u>	<u>21175</u>			<u>6:42</u>	<u>1</u>	<u>✓</u>

Section D
NRC Workorder # (Lab Use Only) 25060725

Remarks / Field Data	NRC Sample # (Use Only)	(Lab)
	<u>01</u>	
	<u>02</u>	
	<u>03</u>	
	<u>04</u>	
	<u>05</u>	
	<u>06</u>	
	<u>07</u>	
	<u>08</u>	
	<u>09</u>	
	<u>10</u>	

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Sol/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F
Relinquish/Receive

Relinquished By:	Print	Date	Time
<u>[Signature]</u>	<u>Steve Lambert</u>	<u>6/13/25</u>	<u>12:50</u>
Received By:			
Relinquished By:			
Received By:			
Relinquished By:			
Received By Laboratory:	<u>Victoria Schleicher</u>	<u>6/13/25</u>	<u>12:54</u>

Section G
Lab Use Only

Temp: 21.8 IR Therm ID: 1
 s6°C: Yes No
 Received on Ice: Yes No
 Number of Bottles Received: 22
 pH Checked:
 COC Seals Intact: Yes No NA
 Field Blank Included: Yes No

Received Via UPS FedEx Other Hand

Payment: Invoice Cash VISA, M/C Check # _____ Amount _____

