

Lead in School Drinking Water Report

Ellen Ochoa Middle School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-06-10, 2025-06-11

Date(s) analyzed: 2025-08-07, 2025-08-11

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	372176	Main Building	Fountain/Tap Combo	Rm 207	1 of 3	Water Fountain	right	316
2	372113	Main Building	Fountain/Tap Combo	Rm 26	1 of 1	Tap	center	20
3	373034	Main Building	Fountain/Tap Combo	Rm 40	1 of 1	Tap	center	16
4	373036	Main Building	Fountain/Tap Combo	Rm 40	1 of 1	Water Fountain	right	10
5	373052	Main Building	Fountain/Tap Combo	Rm 50	9 of 10	Water Fountain	right	5
6	372170	Main Building	Fountain/Tap Combo	Rm 204	3 of 3	Water Fountain	right	4
7	373004	Main Building	Fountain/Tap Combo	Rm 219	1 of 1	Water Fountain	right	4
8	373054	Main Building	Fountain/Tap Combo	Rm 52	2 of 10	Water Fountain	right	4
9	372102	Main Building	Sink	Kitchen	2 of 7	Sprayer	center	3
10	372115	Main Building	Fountain/Tap Combo	Rm 26	1 of 1	Water Fountain	right	3

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
11	372116	Main Building	Fountain/Tap Combo	Rm 127	1 of 1	Tap	center	2
12	373010	Main Building	Fountain	Outside Tennis Field	1 of 1	Water Fountain	center	2
13	373023	Main Building	Fountain/Tap Combo	Rm 67	1 of 1	Tap	center	2
14	373055	Main Building	Sink	Rm 80	1 of 1	Tap	center	2
15	372100	Main Building	Sink	Kitchen	1 of 7	Sprayer	center	1
16	372104	Main Building	Sink - Multi-Compartment	Kitchen	3 of 7	Tap	center	1
17	372105	Main Building	Sink	Library Office	1 of 1	Tap	center	1
18	373048	Main Building	Fountain/Tap Combo	Rm 43	2 of 10	Water Fountain	right	1
19	372101	Main Building	Fountain/Tap Combo	Rm 92	1 of 1	Tap	center	<1
20	372103	Main Building	Fountain/Tap Combo	Rm 92	1 of 1	Water Fountain	right	<1
21	372106	Main Building	Sink	Kitchen	5 of 7 island	Tap	center	<1
22	372107	Main Building	Fountain/Tap Combo	Rm 8	1 of 1	Tap	center	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
23	372108	Main Building	Pot Filler	Kitchen	6 of 7	Tap	center	<1
24	372109	Main Building	Fountain/Tap Combo	Rm 8	1 of 1	Water Fountain	right	<1
25	372110	Main Building	Fountain - Multi-Level with Bottle Filler	Cafetorium	1 of 1	Water Fountain	left	<1
26	372111	Main Building	Sink	Teacher Lounge	1 of 1	Tap	center	<1
27	372112	Main Building	Fountain - Multi-Level with Bottle Filler	Cafetorium	1 of 1	Water Fountain	right	<1
28	372114	Main Building	Fountain - Multi-Level with Bottle Filler	Cafetorium	1 of 1	Water Bottle Filler	left	<1
29	372117	Main Building	Fountain/Tap Combo	Rm 28	1 of 1	Tap	center	<1
30	372118	Main Building	Fountain/Tap Combo	Rm 127	1 of 1	Water Fountain	right	<1
31	372119	Main Building	Fountain/Tap Combo	Rm 28	1 of 1	Water Fountain	right	<1
32	372120	Main Building	Fountain - Multi-Level with Bottle Filler	Outside Rm 127	1 of 1	Water Fountain	left	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
33	372121	Main Building	Fountain - Multi-Level	Across Rm 28	1 of 1	Water Fountain	left	<1
34	372122	Main Building	Fountain - Multi-Level with Bottle Filler	Outside Rm 127	1 of 1	Water Fountain	right	<1
35	372123	Main Building	Fountain - Multi-Level	Across Rm 28	1 of 1	Water Fountain	right	<1
36	372124	Main Building	Fountain - Multi-Level with Bottle Filler	Outside Rm 127	1 of 1	Water Bottle Filler	left	<1
37	372125	Main Building	Fountain/Tap Combo	Rm 30	1 of 1	Tap	center	<1
38	372126	Main Building	Fountain with Bottle Filler	Auxiliary Gym	1 of 1	Water Fountain	center	<1
39	372127	Main Building	Fountain/Tap Combo	Rm 30	1 of 1	Water Fountain	right	<1
40	372128	Main Building	Fountain with Bottle Filler	Auxiliary Gym	1 of 1	Water Bottle Filler	center	<1
41	372129	Main Building	Fountain/Tap Combo	Rm 31	1 of 1	Tap	center	<1
42	372130	Main Building	Fountain	Boys Locker Rm	1 of 1	Water Fountain	center	<1
43	372131	Main Building	Fountain/Tap Combo	Rm 31	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
44	372132	Main Building	Fountain - Multi-Level with Bottle Filler	Main Gym	1 of 1	Water Fountain	left	<1
45	372133	Main Building	Fountain/Tap Combo	Rm 33	1 of 1	Tap	center	<1
46	372134	Main Building	Fountain - Multi-Level with Bottle Filler	Main Gym	1 of 1	Water Fountain	right	<1
47	372135	Main Building	Fountain/Tap Combo	Rm 33	1 of 1	Water Fountain	right	<1
48	372136	Main Building	Fountain - Multi-Level with Bottle Filler	Main Gym	1 of 1	Water Bottle Filler	right	<1
49	372137	Main Building	Fountain/Tap Combo	Rm 32	1 of 1	Tap	center	<1
50	372138	Main Building	Fountain	Girls Locker Rm	1 of 1	Water Fountain	center	<1
51	372139	Main Building	Fountain/Tap Combo	Rm 32	1 of 1	Water Fountain	right	<1
52	372164	Main Building	Fountain - Multi-Level with Bottle Filler	Hallway Across 204	1 of 1	Water Fountain	left	<1
53	372166	Main Building	Fountain - Multi-Level with Bottle Filler	Hallway Across 204	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
54	372168	Main Building	Fountain - Multi-Level with Bottle Filler	Hallway Across 204	1 of 1	Water Bottle Filler	left	<1
55	372172	Main Building	Fountain/Tap Combo	Rm 206	1 of 1	Tap	center	<1
56	372174	Main Building	Fountain/Tap Combo	Rm 206	1 of 1	Water Fountain	right	<1
57	372178	Main Building	Fountain/Tap Combo	Rm 209	1 of 1	Tap	center	<1
58	372980	Main Building	Fountain/Tap Combo	Rm 209	1 of 1	Water Fountain	right	<1
59	372982	Main Building	Fountain/Tap Combo	Rm 208	3 of 3	Water Fountain	right	<1
60	372984	Main Building	Fountain/Tap Combo	Rm 210	1 of 1	Tap	center	<1
61	372986	Main Building	Fountain/Tap Combo	Rm 210	1 of 1	Water Fountain	right	<1
62	372988	Main Building	Fountain/Tap Combo	Rm 211	1 of 3	Water Fountain	right	<1
63	372990	Main Building	Fountain/Tap Combo	Rm 212	1 of 1	Tap	center	<1
64	372992	Main Building	Fountain/Tap Combo	Rm 212	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
65	372994	Main Building	Fountain/Tap Combo	Rm 213	1 of 1	Tap	center	<1
66	372996	Main Building	Fountain/Tap Combo	Rm 213	1 of 1	Water Fountain	right	<1
67	372998	Main Building	Sink	Rm 214 Staff	1 of 1	Tap	center	<1
68	373000	Main Building	Fountain/Tap Combo	Rm 218	1 of 1	Tap	center	<1
69	373002	Main Building	Fountain/Tap Combo	Rm 218	1 of 1	Water Fountain	right	<1
70	373006	Main Building	Fountain/Tap Combo	Rm 217	1 of 1	Tap	center	<1
71	373008	Main Building	Fountain/Tap Combo	Rm 217	1 of 1	Water Fountain	right	<1
72	373020	Main Building	Fountain/Tap Combo	Rm 34	1 of 1	Tap	center	<1
73	373021	Main Building	Fountain - Multi-Level with Bottle Filler	Fountains Outside 67	1 of 1	Water Bottle Filler	left	<1
74	373022	Main Building	Fountain/Tap Combo	Rm 34	1 of 1	Water Fountain	right	<1
75	373024	Main Building	Fountain/Tap Combo	Rm 35	1 of 1	Tap	center	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
76	373025	Main Building	Fountain/Tap Combo	Rm 67	1 of 1	Water Fountain	right	<1
77	373026	Main Building	Fountain/Tap Combo	Rm 35	1 of 1	Water Fountain	right	<1
78	373027	Main Building	Fountain/Tap Combo	Rm 69	1 of 1	Tap	center	<1
79	373028	Main Building	Fountain/Tap Combo	Rm 36	1 of 1	Tap	center	<1
80	373029	Main Building	Fountain/Tap Combo	Rm 69	1 of 1	Water Fountain	right	<1
81	373030	Main Building	Fountain/Tap Combo	Rm 36	1 of 1	Water Fountain	right	<1
82	373031	Main Building	Fountain/Tap Combo	Rm 70	1 of 1	Tap	center	<1
83	373032	Main Building	Sink	Rm 38	1 of 1	Tap	center	<1
84	373033	Main Building	Fountain/Tap Combo	Rm 70	1 of 1	Water Fountain	right	<1
85	373035	Main Building	Fountain/Tap Combo	Rm 71	1 of 1	Tap	center	<1
86	373037	Main Building	Fountain/Tap Combo	Rm 71	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
87	373038	Main Building	Fountain - Multi-Level	Outside Rm 42	1 of 1	Water Fountain	left	<1
88	373039	Main Building	Fountain/Tap Combo	Rm 72	1 of 1	Tap	center	<1
89	373040	Main Building	Fountain - Multi-Level	Outside Rm 42	1 of 1	Water Fountain	right	<1
90	373041	Main Building	Fountain/Tap Combo	Rm 72	1 of 1	Water Fountain	right	<1
91	373042	Main Building	Sink	Rm 44	1 of 3	Tap	center	<1
92	373043	Main Building	Fountain/Tap Combo	Rm 73	1 of 1	Tap	center	<1
93	373044	Main Building	Sink	Rm 44	2 of 3	Tap	center	<1
94	373045	Main Building	Fountain/Tap Combo	Rm 73	1 of 1	Water Fountain	right	<1
95	373046	Main Building	Sink	Rm 44	3 of 3	Tap	center	<1
96	373047	Main Building	Fountain/Tap Combo	Rm 74	1 of 1	Tap	center	<1
97	373049	Main Building	Fountain/Tap Combo	Rm 74	1 of 1	Water Fountain	right	<1
98	373050	Main Building	Fountain/Tap Combo	Rm 49	9 of 10	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
99	373051	Main Building	Fountain/Tap Combo	Rm 78	1 of 1	Tap	center	<1
100	373053	Main Building	Fountain/Tap Combo	Rm 78	1 of 1	Water Fountain	right	<1
101	373056	Main Building	Fountain - Multi-Level with Bottle Filler	Fountains Outside 67	1 of 1	Water Fountain	left	<1
102	373057	Main Building	Fountain/Tap Combo	Rm 81	1 of 1	Tap	center	<1
103	373058	Main Building	Fountain - Multi-Level with Bottle Filler	Fountains Outside 67	1 of 1	Water Fountain	right	<1
104	373059	Main Building	Fountain/Tap Combo	Rm 81	1 of 1	Water Fountain	right	<1