

Lead in School Drinking Water Report

Pasco Senior High School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-05-07, 2025-05-14

Date(s) analyzed: 2025-05-20, 2025-05-22, 2025-05-28, 2025-06-16

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	373118	Main Building	Sink	256c Kitchen	1 of 3	Tap	center	212
2	373124	Main Building	Sink	256c Kitchen	3 of 3	Tap	center	93
3	373093	Main Building	Sink	Rm 179c	1 of 1	Tap	center	72
4	373094	Main Building	Fountain/Tap Combo	Rm 133	1 of 1	Tap	left	39
5	372048	Main Building	Sink	191 Concessions	1 of 1	Tap	center	27
6	373120	Main Building	Sink - Multi-Compartment	256c Kitchen	2 of 3	Tap	center	26
7	373096	Main Building	Fountain/Tap Combo	Rm 133	1 of 1	Water Fountain	right	19
8	373075	Main Building	Fountain/Tap Combo	Rm 137b	1 of 1	Water Fountain	right	14
9	373122	Main Building	Sink - Multi-Compartment	256c Kitchen	2 of 3	Sprayer	center	12
10	373063	Main Building	Fountain/Tap Combo	Rm 135	1 of 1	Water Fountain	right	9
11	373064	Main Building	Sink	Laundry Rm 199f	1 of 1	Tap	center	8
12	373065	Main Building	Sink	Rm 136a	1 of 2	Tap	center	8

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
13	373073	Main Building	Fountain/Tap Combo	Rm 137b	1 of 1	Tap	left	6
14	373102	Main Building	Sink	223 Art	2 of 2	Tap	center	6
15	372054	Main Building	Fountain	South Hallway	3 of 5	Water Fountain	center	5
16	373080	Main Building	Sink	131c	1 of 1	Tap	center	4
17	373061	Main Building	Fountain/Tap Combo	Rm 135	1 of 1	Tap	left	3
18	373067	Main Building	Fountain	Rm 136a	2 of 2	Water Fountain	center	3
19	372047	Main Building	Sink	Kitchen	2 of 12	Tap	center	2
20	373062	Main Building	Fountain/Tap Combo	Band Room	1 of 1	Tap	center	2
21	373079	Main Building	Sink	Rm 140a Art Room	1 of 4	Tap	center	2
22	373098	Main Building	Fountain	Metal Shop	1 of 1	Water Fountain	center	2
23	372053	Main Building	Sink	Kitchen	4 of 12	Tap	center	1
24	372055	Main Building	Sink	Kitchen	6 of 12	Tap	center	1
25	373081	Main Building	Sink	Rm 140a Art Room	2 of 4	Tap	center	1
26	373106	Main Building	Ice Machine	235	2 of 2 fridge		center	1
27	373164	Main Building	Ice Machine	170 Workroom	2 of 2 fridge		right	1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
28	372019	Main Building	Fountain with Bottle Filler	Outside 273a	1 of 1	Water Bottle Filler	center	<1
29	372020	Main Building	Pot Filler	Kitchen	11 of 12	Sprayer	left	<1
30	372022	Main Building	Pot Filler	Kitchen	12 of 12	Tap	right	<1
31	372024	Main Building	Fountain - Multi-Level with Bottle Filler	Ac-123	1 of 1	Water Fountain	left	<1
32	372026	Main Building	Fountain - Multi-Level with Bottle Filler	Ac-123	1 of 1	Water Fountain	right	<1
33	372028	Main Building	Fountain - Multi-Level with Bottle Filler	Ac-123	1 of 1	Water Bottle Filler	right	<1
34	372030	Main Building	Fountain - Multi-Level with Bottle Filler	Hallway Outside Ac-120	1 of 1	Water Fountain	left	<1
35	372032	Main Building	Fountain - Multi-Level with Bottle Filler	Hallway Outside Ac-120	1 of 1	Water Fountain	right	<1
36	372034	Main Building	Fountain - Multi-Level with Bottle Filler	Hallway Outside Ac-120	1 of 1	Water Bottle Filler	right	<1
37	372036	Main Building	Fountain - Multi-Level	Varsity Boys Locker Room	1 of 1 right	Water Fountain	left	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
					fountain off			
38	372038	Main Building	Fountain - Multi-Level	Boys Varsity 194h	1 of 1	Water Fountain	left	<1
39	372040	Main Building	Fountain - Multi-Level	Boys Varsity 194h	1 of 1	Water Fountain	right	<1
40	372042	Main Building	Ice Machine	Training Rm 194b	1 of 2		center	<1
41	372044	Main Building	Sink - Multi-Compartment	Training Rm 194b	2 of 2	Tap	center	<1
42	372046	Main Building	Sink - Multi-Compartment	192a	1 of 1	Tap	center	<1
43	372049	Main Building	Sink	Kitchen	3 of 12	Tap	center	<1
44	372050	Main Building	Fountain	South Hallway	1 of 5	Water Fountain	center	<1
45	372051	Main Building	Sink	Kitchen	3 of 12	Sprayer	center	<1
46	372052	Main Building	Fountain	South Hallway	2 of 5	Water Fountain	center	<1
47	372056	Main Building	Fountain	South Hallway	4 of 5	Water Fountain	center	<1
48	372057	Main Building	Sink	Kitchen	6 of 12	Sprayer	right	<1
49	372058	Main Building	Fountain	South Hallway	5 of 5	Water Fountain	center	<1
50	372059	Main Building	Pot Filler	Kitchen	11 of 12	Tap	left	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
51	373060	Main Building	Fountain/Tap Combo	Band Room	1 of 1	Water Fountain	left	<1
52	373066	Main Building	Sink - Multi-Compartment	M108 Student Store	1 of 2	Tap	center	<1
53	373068	Main Building	Sink	M108 Student Store	2 of 2	Tap	center	<1
54	373069	Main Building	Fountain with Bottle Filler	Hallway Between 137a And 137b	1 of 1	Water Fountain	right	<1
55	373070	Main Building	Sink	M110	1 of 1	Tap	center	<1
56	373071	Main Building	Fountain with Bottle Filler	Hallway Between 137a And 137b	1 of 1	Water Bottle Filler	center	<1
57	373072	Main Building	Fountain - Multi-Level with Bottle Filler	Student Mall	1 of 1	Water Fountain	left	<1
58	373074	Main Building	Fountain - Multi-Level with Bottle Filler	Student Mall	1 of 1	Water Fountain	right	<1
59	373076	Main Building	Fountain - Multi-Level with Bottle Filler	Student Mall	1 of 1	Water Bottle Filler	left	<1
60	373077	Main Building	Fountain	Wood Shop	2 of 2	Water Fountain	center	<1
61	373078	Main Building	Fountain	Auto Shop	1 of 1	Water Fountain	center	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
62	373082	Main Building	Sink - Multi-Compartment	131b Cooking Lab	1 of 6	Tap	center	<1
63	373083	Main Building	Sink	Rm 140a Art Room	3 of 4	Tap	center	<1
64	373084	Main Building	Sink - Multi-Compartment	131b Cooking Lab	2 of 6	Tap	center	<1
65	373085	Main Building	Sink	Rm 140a Art Room	4 of 4	Tap	center	<1
66	373086	Main Building	Sink - Multi-Compartment	131b Cooking Lab	3 of 6	Tap	center	<1
67	373087	Main Building	Ice Machine	Nurse Room 146	1 of 3		center	<1
68	373088	Main Building	Sink - Multi-Compartment	131b Cooking Lab	4 of 6	Tap	center	<1
69	373089	Main Building	Sink	Nurse Room 146	2 of 3	Tap	center	<1
70	373090	Main Building	Sink - Multi-Compartment	131b Cooking Lab	5 of 6	Tap	center	<1
71	373091	Main Building	Sink	Nurse Room 146	3 of 3	Tap	center	<1
72	373092	Main Building	Sink - Multi-Compartment	131b Cooking Lab	6 of 6	Tap	center	<1
73	373095	Main Building	Fountain - Multi-Level	Outside Ac 207	1 of 1	Water Fountain	left	<1
74	373097	Main Building	Fountain - Multi-Level	Outside Ac 207	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
75	373099	Main Building	Fountain with Bottle Filler	Outside 273a	1 of 1	Water Fountain	right	<1
76	373100	Main Building	Sink	223 Art	1 of 2	Tap	center	<1
77	373104	Main Building	Sink	235	1 of 2	Tap	center	<1
78	373108	Main Building	Fountain with Bottle Filler	Outside 250b	1 of 1	Water Fountain	right	<1
79	373110	Main Building	Fountain with Bottle Filler	Outside 250b	1 of 1	Water Bottle Filler	center	<1
80	373112	Main Building	Fountain	Outside 255	1 of 2	Water Fountain	center	<1
81	373114	Main Building	Fountain with Bottle Filler	Outside 255	2 of 2	Water Fountain	right	<1
82	373116	Main Building	Fountain with Bottle Filler	Outside 255	2 of 2	Water Bottle Filler	center	<1
83	373126	Main Building	Fountain - Multi-Level	Emerson Morgan Field	1 of 1	Water Fountain	left	<1
84	373128	Main Building	Fountain - Multi-Level	Emerson Morgan Field	1 of 1	Water Fountain	right	<1
85	373140	Main Building	Fountain - Multi-Level	Choir 198f	1 of 1	Water Fountain	left	<1
86	373142	Main Building	Fountain - Multi-Level	Choir 198f	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
87	373144	Main Building	Fountain	164k Band Entry	1 of 1	Water Fountain	left	<1
88	373146	Main Building	Fountain	164k Band Entry	1 of 1	Water Fountain	right	<1
89	373148	Main Building	Fountain with Bottle Filler	162a South Hallway	1 of 2	Water Fountain	left	<1
90	373150	Main Building	Fountain with Bottle Filler	162a South Hallway	1 of 2	Water Bottle Filler	left	<1
91	373152	Main Building	Fountain	162a South Hallway	2 of 2	Water Fountain	right	<1
92	373154	Main Building	Fountain with Bottle Filler	155a South Hallway	2 of 2 left fountain off	Water Fountain	right	<1
93	373156	Main Building	Fountain with Bottle Filler	155a South Hallway	2 of 2	Water Bottle Filler	right	<1
94	373158	Main Building	Sink	Main Office Staff Workroom	1 of 1	Tap	center	<1
95	373160	Main Building	Sink	Main Office Staff Workroom	1 of 1	Sprayer	right	<1
96	373162	Main Building	Sink	170 Workroom	1 of 2	Tap	center	<1
97	373166	Main Building	Fountain - Multi-Level with Bottle Filler	173a Main Hallway	1 of 1	Water Fountain	left	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
98	373168	Main Building	Fountain - Multi-Level with Bottle Filler	173a Main Hallway	1 of 1	Water Fountain	right	<1
99	373170	Main Building	Fountain - Multi-Level with Bottle Filler	173a Main Hallway	1 of 1	Water Bottle Filler	right	<1
100	373172	Main Building	Sink	174a	1 of 1	Tap	center	<1
101	373174	Main Building	Sink	176a	1 of 1	Tap	center	<1
102	373176	Main Building	Fountain - Multi-Level	146 E Hallway	1 of 1	Water Fountain	left	<1
103	373178	Main Building	Fountain - Multi-Level	146 E Hallway	1 of 1	Water Fountain	right	<1