



November 20, 2025

Lauren Doherty
Intertek PSI
17 British American Boulevard
Latham, NY 12110

RE: Project: KENSINGTON ELEMENTARY 11/1
Pace Project No.: 70389857

Dear Lauren Doherty:

Enclosed are the analytical results for sample(s) received by the laboratory on November 05, 2025. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in cursive script that reads 'Lori Beyer'.

Lori A. Beyer
lori.beyer@pacelabs.com
516-370-6014
Project Manager

Enclosures

cc: Lauren Doherty, Intertek PSI



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CERTIFICATIONS

Project: KENSINGTON ELEMENTARY 11/1

Pace Project No.: 70389857

Pace Analytical Services, LLC - Melville, NY

575 Broad Hollow Rd, Melville, NY 11747

Connecticut Certification #: PH-0435

Delaware Certification # NY 10478

Maryland Certification #: 208

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

New Jersey Certification #: NY158

New York Certification #: 10478 Primary Accrediting Body

Pennsylvania Certification #: 68-00350

Rhode Island Certification #: LAO00340

Texas Certification #: T104704582

Florida Certification #: E871198

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE SUMMARY

Project: KENSINGTON ELEMENTARY 11/1

Pace Project No.: 70389857

Lab ID	Sample ID	Matrix	Date Collected	Date Received
70389857001	K1-01	Drinking Water	11/01/25 11:34	11/05/25 06:00
70389857002	K1-02	Drinking Water	11/01/25 11:30	11/05/25 06:00
70389857003	K1-03	Drinking Water	11/01/25 11:30	11/05/25 06:00
70389857004	K1-04	Drinking Water	11/01/25 11:30	11/05/25 06:00
70389857005	K1-05	Drinking Water	11/01/25 11:37	11/05/25 06:00
70389857006	K1-08 FTN	Drinking Water	11/01/25 11:44	11/05/25 06:00
70389857007	K1-08 FILL	Drinking Water	11/01/25 11:44	11/05/25 06:00
70389857008	K1-20	Drinking Water	11/01/25 12:07	11/05/25 06:00
70389857009	K1-22	Drinking Water	11/01/25 12:12	11/05/25 06:00
70389857010	K1-24	Drinking Water	11/01/25 12:14	11/05/25 06:00
70389857011	K1-26	Drinking Water	11/01/25 12:16	11/05/25 06:00
70389857012	K1-28	Drinking Water	11/01/25 12:15	11/05/25 06:00
70389857013	K1-32	Drinking Water	11/01/25 12:13	11/05/25 06:00
70389857014	K1-34	Drinking Water	11/01/25 12:10	11/05/25 06:00
70389857015	K1-38	Drinking Water	11/01/25 11:57	11/05/25 06:00
70389857016	K1-40	Drinking Water	11/01/25 11:59	11/05/25 06:00
70389857017	K1-42	Drinking Water	11/01/25 11:58	11/05/25 06:00
70389857018	K1-45	Drinking Water	11/01/25 11:56	11/05/25 06:00
70389857019	K1-46	Drinking Water	11/01/25 11:55	11/05/25 06:00
70389857020	K1-51	Drinking Water	11/01/25 12:01	11/05/25 06:00
70389857021	K1-53	Drinking Water	11/01/25 12:03	11/05/25 06:00
70389857022	K1-54	Drinking Water	11/01/25 11:40	11/05/25 06:00
70389857023	K1-55	Drinking Water	11/01/25 11:40	11/05/25 06:00
70389857024	K1-56	Drinking Water	11/01/25 12:06	11/05/25 06:00
70389857025	K1-14	Drinking Water	11/01/25 11:47	11/05/25 06:00
70389857026	K1-16	Drinking Water	11/01/25 11:49	11/05/25 06:00

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: KENSINGTON ELEMENTARY 11/1

Pace Project No.: 70389857

Lab ID	Sample ID	Method	Analysts	Analytes Reported
70389857001	K1-01	EPA 200.8	JP2	1
70389857002	K1-02	EPA 200.8	JP2	1
70389857003	K1-03	EPA 200.8	JP2	1
70389857004	K1-04	EPA 200.8	JP2	1
70389857005	K1-05	EPA 200.8	JP2	1
70389857006	K1-08 FTN	EPA 200.8	JP2	1
70389857007	K1-08 FILL	EPA 200.8	JP2	1
70389857008	K1-20	EPA 200.8	JP2	1
70389857009	K1-22	EPA 200.8	JP2	1
70389857010	K1-24	EPA 200.8	JP2	1
70389857011	K1-26	EPA 200.8	JP2	1
70389857012	K1-28	EPA 200.8	JP2	1
70389857013	K1-32	EPA 200.8	JP2	1
70389857014	K1-34	EPA 200.8	JP2	1
70389857015	K1-38	EPA 200.8	JP2	1
70389857016	K1-40	EPA 200.8	JP2	1
70389857017	K1-42	EPA 200.8	JP2	1
70389857018	K1-45	EPA 200.8	JP2	1
70389857019	K1-46	EPA 200.8	JP2	1
70389857020	K1-51	EPA 200.8	JP2	1
70389857021	K1-53	EPA 200.8	JP2	1
70389857022	K1-54	EPA 200.8	JP2	1
70389857023	K1-55	EPA 200.8	JP2	1
70389857024	K1-56	EPA 200.8	JP2	1
70389857025	K1-14	EPA 200.8	JP2	1
70389857026	K1-16	EPA 200.8	JP2	1

PACE-MV = Pace Analytical Services - Melville

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KENSINGTON ELEMENTARY 11/1
Pace Project No.: 70389857

Sample: K1-01		Lab ID: 70389857001		Collected: 11/01/25 11:34		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 16:22	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: KENSINGTON ELEMENTARY 11/1
Pace Project No.: 70389857

Sample: K1-02		Lab ID: 70389857002		Collected: 11/01/25 11:30		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 16:24	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: KENSINGTON ELEMENTARY 11/1

Pace Project No.: 70389857

Sample: K1-03		Lab ID: 70389857003		Collected: 11/01/25 11:30		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 16:25	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KENSINGTON ELEMENTARY 11/1
Pace Project No.: 70389857

Sample: K1-04		Lab ID: 70389857004		Collected: 11/01/25 11:30		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 16:27	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: KENSINGTON ELEMENTARY 11/1
Pace Project No.: 70389857

Sample: K1-05		Lab ID: 70389857005		Collected: 11/01/25 11:37		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 16:28	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: KENSINGTON ELEMENTARY 11/1
Pace Project No.: 70389857

Sample: K1-08 FTN		Lab ID: 70389857006		Collected: 11/01/25 11:44		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 16:29	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: KENSINGTON ELEMENTARY 11/1
Pace Project No.: 70389857

Sample: K1-08 FILL		Lab ID: 70389857007		Collected: 11/01/25 11:44		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 16:31	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: KENSINGTON ELEMENTARY 11/1

Pace Project No.: 70389857

Sample: K1-20		Lab ID: 70389857008		Collected: 11/01/25 12:07		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 16:32	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KENSINGTON ELEMENTARY 11/1
Pace Project No.: 70389857

Sample: K1-22		Lab ID: 70389857009		Collected: 11/01/25 12:12		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 16:37	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: KENSINGTON ELEMENTARY 11/1
Pace Project No.: 70389857

Sample: K1-24		Lab ID: 70389857010		Collected: 11/01/25 12:14		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.5	ug/L	1.0	1		11/19/25 16:38	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: KENSINGTON ELEMENTARY 11/1

Pace Project No.: 70389857

Sample: K1-26		Lab ID: 70389857011		Collected: 11/01/25 12:16		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 16:40	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KENSINGTON ELEMENTARY 11/1

Pace Project No.: 70389857

Sample: K1-28		Lab ID: 70389857012		Collected: 11/01/25 12:15		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.4	ug/L	1.0	1		11/19/25 16:44	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KENSINGTON ELEMENTARY 11/1
Pace Project No.: 70389857

Sample: K1-32		Lab ID: 70389857013		Collected: 11/01/25 12:13		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 16:48	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: KENSINGTON ELEMENTARY 11/1

Pace Project No.: 70389857

Sample: K1-34		Lab ID: 70389857014		Collected: 11/01/25 12:10		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 16:56	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KENSINGTON ELEMENTARY 11/1

Pace Project No.: 70389857

Sample: K1-38		Lab ID: 70389857015		Collected: 11/01/25 11:57		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 16:57	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KENSINGTON ELEMENTARY 11/1

Pace Project No.: 70389857

Sample: K1-40		Lab ID: 70389857016		Collected: 11/01/25 11:59		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 16:59	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KENSINGTON ELEMENTARY 11/1

Pace Project No.: 70389857

Sample: K1-42		Lab ID: 70389857017		Collected: 11/01/25 11:58		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 17:00	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KENSINGTON ELEMENTARY 11/1
Pace Project No.: 70389857

Sample: K1-45		Lab ID: 70389857018		Collected: 11/01/25 11:56		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 17:02	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: KENSINGTON ELEMENTARY 11/1
Pace Project No.: 70389857

Sample: K1-46		Lab ID: 70389857019		Collected: 11/01/25 11:55		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 17:03	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: KENSINGTON ELEMENTARY 11/1
Pace Project No.: 70389857

Sample: K1-51		Lab ID: 70389857020		Collected: 11/01/25 12:01		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 17:04	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: KENSINGTON ELEMENTARY 11/1
Pace Project No.: 70389857

Sample: K1-53		Lab ID: 70389857021		Collected: 11/01/25 12:03		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 17:06	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: KENSINGTON ELEMENTARY 11/1

Pace Project No.: 70389857

Sample: K1-54		Lab ID: 70389857022		Collected: 11/01/25 11:40		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 17:07	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KENSINGTON ELEMENTARY 11/1
Pace Project No.: 70389857

Sample: K1-55		Lab ID: 70389857023		Collected: 11/01/25 11:40		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 17:12	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: KENSINGTON ELEMENTARY 11/1
Pace Project No.: 70389857

Sample: K1-56		Lab ID: 70389857024		Collected: 11/01/25 12:06		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 17:13	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: KENSINGTON ELEMENTARY 11/1

Pace Project No.: 70389857

Sample: K1-14		Lab ID: 70389857025		Collected: 11/01/25 11:47		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 17:15	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KENSINGTON ELEMENTARY 11/1
Pace Project No.: 70389857

Sample: K1-16		Lab ID: 70389857026		Collected: 11/01/25 11:49		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 17:16	7439-92-1		

REPORT OF LABORATORY ANALYSIS



QUALITY CONTROL DATA

Project: KENSINGTON ELEMENTARY 11/1

Pace Project No.: 70389857

QC Batch:	429071	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70389857001, 70389857002, 70389857003, 70389857004, 70389857005, 70389857006, 70389857007, 70389857008, 70389857009, 70389857010, 70389857011		

METHOD BLANK:	2292898	Matrix:	Water
Associated Lab Samples:	70389857001, 70389857002, 70389857003, 70389857004, 70389857005, 70389857006, 70389857007, 70389857008, 70389857009, 70389857010, 70389857011		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/19/25 15:53	

LABORATORY CONTROL SAMPLE:	2292899					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.7	99	85-115	

MATRIX SPIKE SAMPLE:		2292902					
		70389851022	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	2.1	50	48.4	93	70-130	

MATRIX SPIKE SAMPLE:		2292904					
		70389851023	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	47.0	92	70-130	

SAMPLE DUPLICATE:	2292901					
Parameter	Units	70389851022 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	2.1	2.0	5	20	

SAMPLE DUPLICATE:	2292903					
Parameter	Units	70389851023 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: KENSINGTON ELEMENTARY 11/1

Pace Project No.: 70389857

QC Batch:	429073	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70389857012, 70389857013, 70389857014, 70389857015, 70389857016, 70389857017, 70389857018, 70389857019, 70389857020, 70389857021, 70389857022, 70389857023, 70389857024, 70389857025, 70389857026		

METHOD BLANK:	2292909	Matrix:	Water
Associated Lab Samples:	70389857012, 70389857013, 70389857014, 70389857015, 70389857016, 70389857017, 70389857018, 70389857019, 70389857020, 70389857021, 70389857022, 70389857023, 70389857024, 70389857025, 70389857026		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/19/25 16:41	

LABORATORY CONTROL SAMPLE:	2292910					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.0	98	85-115	

MATRIX SPIKE SAMPLE:	2292912						
Parameter	Units	70389857012 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.4	50	50.2	97	70-130	

MATRIX SPIKE SAMPLE:	2292914						
Parameter	Units	70389857013 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	46.9	93	70-130	

SAMPLE DUPLICATE: 2292911						
		70389857012	Dup		Max	
Parameter	Units	Result	Result	RPD	RPD	Qualifiers
Lead	ug/L	1.4	1.4	0	20	

SAMPLE DUPLICATE: 2292913						
		70389857013	Dup		Max	
Parameter	Units	Result	Result	RPD	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALIFIERS

Project: KENSINGTON ELEMENTARY 11/1

Pace Project No.: 70389857

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: KENSINGTON ELEMENTARY 11/1

Pace Project No.: 70389857

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70389857001	K1-01	EPA 200.8	429071		
70389857002	K1-02	EPA 200.8	429071		
70389857003	K1-03	EPA 200.8	429071		
70389857004	K1-04	EPA 200.8	429071		
70389857005	K1-05	EPA 200.8	429071		
70389857006	K1-08 FTN	EPA 200.8	429071		
70389857007	K1-08 FILL	EPA 200.8	429071		
70389857008	K1-20	EPA 200.8	429071		
70389857009	K1-22	EPA 200.8	429071		
70389857010	K1-24	EPA 200.8	429071		
70389857011	K1-26	EPA 200.8	429071		
70389857012	K1-28	EPA 200.8	429073		
70389857013	K1-32	EPA 200.8	429073		
70389857014	K1-34	EPA 200.8	429073		
70389857015	K1-38	EPA 200.8	429073		
70389857016	K1-40	EPA 200.8	429073		
70389857017	K1-42	EPA 200.8	429073		
70389857018	K1-45	EPA 200.8	429073		
70389857019	K1-46	EPA 200.8	429073		
70389857020	K1-51	EPA 200.8	429073		
70389857021	K1-53	EPA 200.8	429073		
70389857022	K1-54	EPA 200.8	429073		
70389857023	K1-55	EPA 200.8	429073		
70389857024	K1-56	EPA 200.8	429073		
70389857025	K1-14	EPA 200.8	429073		
70389857026	K1-16	EPA 200.8	429073		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Company Name:	Intertek-PSI
Street Address:	17 British American Blvd, Latham, NY 12210

Contact/Report To: **William Kotas**
 Phone #: **(518) 377-9841**
 E-Mail: **william.kotas@**

Customer Project #: **Glens Falls City School District**

Project Name:

Invoice To: **PSI Latham Accounts Payable**
 Invoice E-Mail: **LathamAR@intertek.com**

Site Collection Info/Facility ID (as applicable):

KENSLINGTON FLEM

Quote #:

COPIES

County / State origin of sample(s):

New York

	[] Level III	[] Level III	[] Level IV
[] EQUIS			
[] Other			

Rush (Pre-approval required):
☐ 2 Day ☐ 3 day ☐ 5 day ☐ Other _____
Date Results _____
Standard 10 business day

DW PWSID # or WW Permit # as applicable: _____

Field Filtered (if applicable): () Yes

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Customer Sample ID	Matrix *	Comp / Grab	Collected (or Composite Start)		Composite End		Res. CL2	Number & Type Containers	
			Date	Time	Date	Time		Plastic	Glass
K1-01	DW	G	11/1/2005	11:34					1
K1-02			↓	11:30					
K1-03				↓					
K1-04				11:37					
K1-05				11:44					
K1-06 F1W				↓					
K1-08 F1L									
K1-20				12:07					
K1-22				12:12					
K1-24			↓	12:14					

Customer	Remarks / Special Conditions / Possible Hazards:
1	
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	
13	
14	
15	
16	
17	
18	
19	
20	
21	
22	
23	
24	
25	
26	
27	
28	
29	
30	
31	
32	
33	
34	
35	
36	
37	
38	
39	
40	
41	
42	
43	
44	
45	
46	
47	
48	
49	
50	
51	
52	
53	
54	
55	
56	
57	
58	
59	
60	
61	
62	
63	
64	
65	
66	
67	
68	
69	
70	
71	
72	
73	
74	
75	
76	
77	
78	
79	
80	
81	
82	
83	
84	
85	
86	
87	
88	
89	
90	
91	
92	
93	
94	
95	
96	
97	
98	
99	
100	

Collected By:

Printed Name: WILLIAM A KOTAS
Signature: [Signature]

C. K. Jha et al.

1001

Relinquished by/Company: (Signature)

Date/Time) 1/30/2020

Prepared by/Company: (Signature)

Date/Time: _____

35

Date/Time:

Additional Instructions from Pace®:

Coolers:

Thermometer ID:

Correction Factor (°C)

Obs. Temp. (°C)

Corrected Temp (°C)

Tracking Number:

Date/Time: 11/1/2024 11:11

Delivered by: f

Date/Time:

1500

Date/Time:

[illegible]

CHAIN-OF-CUSTODY Analytical Request Document
Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

LAB USE ONLY - Attach Workorder/Login Label Here



Scan QR Code for instructions

Company Name: Intertek-PSI	Contact/Report To: William Kotas
Street Address: 17 British American Blvd, Latham, NY 12210	Phone #: (518) 377-9841
	E-Mail: william.kotas@intertek.com
	Cc E-Mail:
Customer Project #:	Invoice To: PSI Latham Accounts Payable
Project Name: Glens Falls City School District	Invoice E-Mail: LathamAR@intertek.com
Site Collection Info/Facility ID (as applicable): KENSINGTON ELEM	Purchase Order # (if applicable):
	Quote #: CR-BOCES
Time Zone Collected: [] AK [] MT [] CT [X] ET	County / State origin of sample(s): New York
Data Deliverables: [] Level II [] Level III [] Level IV [] EQUIS [] Other	Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead in School DW
	Rush (Pre-approval required): [] 2 Day [] 3 day [] 5 day [] Other
	Date Results Requested: Standard 10 business day
	Field Filtered (if applicable): [] Yes [] No
	Analysis:
* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk	

Customer Sample ID	Matrix *	Comp / Grab	Collected		Res. CLZ	Composite End		Number & Type of Containers		200.8 Drinking Water (Pb only)
			Date	Time		Date	Time	Plastic	Glass	
K1-26	DW	G	11/12/25	12:16						X
K1-28				12:15						
K1-32				12:13						
K1-34				12:10						
K1-38				11:57						
K1-40				11:59						
K1-42				11:58						
K1-45				11:56						
K1-46				11:55						
K1-51				12:01						

Customer Remarks / Special Conditions / Possible Hazards:	Collected By: WILLIAM A KOTAS
Lead	Printed Name: William A Kotas
	Signature: <i>[Signature]</i>
Relinquished by/Company: (Signature) <i>[Signature]</i> PSI	Received by/Company: (Signature) <i>[Signature]</i> Jan & Co
Date/Time: 11/14/2025 16:20	Date/Time: 11/14/2025 16:00
Relinquished by/Company: (Signature) <i>[Signature]</i> Jan & Co	Received by/Company: (Signature) <i>[Signature]</i> Jan & Co
Date/Time: 11/14/2025 16:20	Date/Time: 11/14/2025 16:00
Relinquished by/Company: (Signature) <i>[Signature]</i> Jan & Co	Received by/Company: (Signature) <i>[Signature]</i> Jan & Co
Date/Time: 11/14/2025 16:20	Date/Time: 11/14/2025 16:00

Specify Container Size **	** Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) EnCore, (8) TerraCore, (9) Other
Identify Container Preservative Type ***	*** Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other
Analysis Requested	
Proj. Mgr: Lori Beyer	AcctNum / Client ID:
Table #:	Profile / Template: 10367
Prelog / Bottle Ord. ID:	
Lab Use Only	Preservation non-conformance identified for sample
Sample Comment	

# Coolers: 1	Thermometer ID: TH211	Correction Factor (°C): +1	Obs. Temp. (°C): 20.2	Corrected Temp. (°C): 20.3
Tracking Number:				
Date/Time: 11/14/25 16:00				
Delivered by: [] In-Person [] Courier				
[] FedEx [] UPS [] Other				
Page: 2 of 3				

WO#: 70389857

PM: LAB

Due Date: 11/19/25

CLIENT: INTER-LATHAM

Client Name:

Inter-Latham

Project #

Courier: ☐ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☒ Pace ☐ Other

Tracking #:

Custody Seal on Cooler/Box Present: ☐ Yes ☒ No Seals intact: ☐ Yes ☒ No Temperature Blank Present: ☐ Yes ☒ No

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ Ziploc ☐ None ☒ Other Type of Ice: Wet Blue None

Thermometer Used: 1/11 Correction Factor: 1.1 2.3 Samples on ice, cooling process has begun

Cooler Temperature (°C): 20.2 Cooler Temperature Corrected (°C): 2.3 Date/Time 5035A kits placed in freezer

Temp should be above freezing to 5-2°C

USDA Regulated Soil (☒ N/A, water sample)

Did samples originate in a quarantine zone within the United States AL AR CA FL GA ID LA MS NC NM NY OK OR SC TN TX or VA (check map)? ☐ Yes ☒ No

Did samples originate from a foreign source including Hawaii and Puerto Rico? ☐ Yes ☒ No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork.

Date and Initials of person examining contents:

				COMMENTS:
Chain of Custody Present	☒ Yes	☐ No	1	
Chain of Custody Filled Out	☒ Yes	☐ No	2	
Chain of Custody Relinquished	☒ Yes	☐ No	3	
Sampler Name & Signature on COC	☒ Yes	☐ No	4	
Samples Arrived within Hold Time	☒ Yes	☐ No	5	
Short Hold Time Analysis (<72hr)	☒ Yes	☐ No	6	
Rush Turn Around Time Requested	☐ Yes	☒ No	7	
Sufficient Volume (Triple volume provided for MS/MSD)	☒ Yes	☐ No	8	
Correct Containers Used	☒ Yes	☐ No	9	
Pace Containers Used	☒ Yes	☐ No	10	
Containers Intact	☒ Yes	☐ No	11	
Filtered volume received for Dissolved tests	☒ Yes	☐ No	12	Note: if sediment is visible in the dissolved container
Sample Labels match COC	☒ Yes	☐ No	13	
Includes date/time/ID/Analysis Matrix	☒ SL	☐ WT	☐ OIL	☐ OTHER

Date and Initials of person checking preservation:

All containers needing preservation have been	☒ Yes	☐ No	☐ N/A	13	☐ HNO ₃ ☐ H ₂ SO ₄ ☐ NaOH ☐ HCl
pH paper Lot #	<u>231224</u>				Sample #
All containers needing preservation are found to be in compliance with method recommendation?	☒ Yes				
(HNO ₃ , H ₂ SO ₄ , HCl, NaOH > 9 Sulfide)	☒ Yes	☐ No	☐ N/A		
NAOH > 12 Cyanide)					
Exceptions VOA Coliform TOC/DOC Oil and Grease DRO/8015 (water)					
Per Method, VOA pH is checked after analysis					
Samples checked for dechlorination	☐ Yes	☐ No	☐ N/A	14	
KI starch test strips Lot #					
Residual chlorine strips Lot #					Positive for Res Chlorine? Y N
SM 4500 CN samples checked for sulf	☐ Yes	☐ No	☐ N/A	15	Positive for Sulfide? Y N
Lead Acetate Strips Lot #					
Headspace in ALK Bottle (>6mm)	☐ Yes	☐ No	☐ N/A	16	
Headspace in VOA Vials (>6mm)	☐ Yes	☐ No	☐ N/A	17	
Trip Blank Present	☐ Yes	☐ No	☐ N/A		
Trip Blank Custody Seals Present	☐ Yes	☐ No	☐ N/A		

Client Notification/ Resolution:

Field Data Required?

Y / N

Person Contacted:

Date/Time:

Comments/ Resolution:

* PM (Project Manager) review (which includes the SCUR) is documented electronically in LIMS