



November 20, 2025

Lauren Doherty
Intertek PSI
17 British American Boulevard
Latham, NY 12110

RE: Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Dear Lauren Doherty:

Enclosed are the analytical results for sample(s) received by the laboratory on November 05, 2025. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in cursive script that reads 'Lori Beyer'.

Lori A. Beyer
lori.beyer@pacelabs.com
516-370-6014
Project Manager

Enclosures

cc: Lauren Doherty, Intertek PSI



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CERTIFICATIONS

Project: SANFORD ELEMENTARY 11/1

Pace Project No.: 70389846

Pace Analytical Services, LLC - Melville, NY

575 Broad Hollow Rd, Melville, NY 11747

Connecticut Certification #: PH-0435

Delaware Certification # NY 10478

Maryland Certification #: 208

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

New Jersey Certification #: NY158

New York Certification #: 10478 Primary Accrediting Body

Pennsylvania Certification #: 68-00350

Rhode Island Certification #: LAO00340

Texas Certification #: T104704582

Florida Certification #: E871198

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE SUMMARY

Project: SANFORD ELEMENTARY 11/1

Pace Project No.: 70389846

Lab ID	Sample ID	Matrix	Date Collected	Date Received
70389846001	S1-06	Drinking Water	11/01/25 13:41	11/05/25 06:00
70389846002	S1-07 FTN	Drinking Water	11/01/25 13:45	11/05/25 06:00
70389846003	S1-07 FILL	Drinking Water	11/01/25 13:45	11/05/25 06:00
70389846004	S1-10 SINK	Drinking Water	11/01/25 13:53	11/05/25 06:00
70389846005	S1-10 FTN	Drinking Water	11/01/25 13:53	11/05/25 06:00
70389846006	S1-14 SINK	Drinking Water	11/01/25 13:56	11/05/25 06:00
70389846007	S1-14 FTN	Drinking Water	11/01/25 13:56	11/05/25 06:00
70389846008	S1-16	Drinking Water	11/01/25 13:43	11/05/25 06:00
70389846009	S1-17	Drinking Water	11/01/25 13:43	11/05/25 06:00
70389846010	S2-02	Drinking Water	11/01/25 14:29	11/05/25 06:00
70389846011	S2-03	Drinking Water	11/01/25 14:31	11/05/25 06:00
70389846012	S2-04	Drinking Water	11/01/25 14:31	11/05/25 06:00
70389846013	S2-05	Drinking Water	11/01/25 14:26	11/05/25 06:00
70389846014	S2-06	Drinking Water	11/01/25 14:26	11/05/25 06:00
70389846015	S2-08	Drinking Water	11/01/25 14:24	11/05/25 06:00
70389846016	S2-09	Drinking Water	11/01/25 14:22	11/05/25 06:00
70389846017	S2-10	Drinking Water	11/01/25 14:22	11/05/25 06:00
70389846018	S2-11 SINK	Drinking Water	11/01/25 14:19	11/05/25 06:00
70389846019	S2-11 FTN	Drinking Water	11/01/25 14:19	11/05/25 06:00
70389846020	S2-13	Drinking Water	11/01/25 14:48	11/05/25 06:00
70389846021	S2-14	Drinking Water	11/01/25 14:14	11/05/25 06:00
70389846022	S2-18	Drinking Water	11/01/25 14:10	11/05/25 06:00
70389846023	S2-20	Drinking Water	11/01/25 14:21	11/05/25 06:00
70389846024	S2-22	Drinking Water	11/01/25 14:08	11/05/25 06:00
70389846025	S2-24	Drinking Water	11/01/25 14:05	11/05/25 06:00
70389846026	S2-25	Drinking Water	11/01/25 14:05	11/05/25 06:00
70389846027	S3-14	Drinking Water	11/01/25 14:49	11/05/25 06:00
70389846028	S3-15	Drinking Water	11/01/25 14:44	11/05/25 06:00
70389846029	S3-19	Drinking Water	11/01/25 14:40	11/05/25 06:00
70389846030	S3-20	Drinking Water	11/01/25 14:40	11/05/25 06:00
70389846031	S3-23	Drinking Water	11/01/25 14:37	11/05/25 06:00
70389846032	S3-24	Drinking Water	11/01/25 14:32	11/05/25 06:00
70389846033	S3-27	Drinking Water	11/01/25 14:41	11/05/25 06:00
70389846034	S3-28	Drinking Water	11/01/25 14:41	11/05/25 06:00

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: SANFORD ELEMENTARY 11/1

Pace Project No.: 70389846

Lab ID	Sample ID	Method	Analysts	Analytes Reported
70389846001	S1-06	EPA 200.8	JJS	1
70389846002	S1-07 FTN	EPA 200.8	JJS	1
70389846003	S1-07 FILL	EPA 200.8	JJS	1
70389846004	S1-10 SINK	EPA 200.8	JJS	1
70389846005	S1-10 FTN	EPA 200.8	JJS	1
70389846006	S1-14 SINK	EPA 200.8	JJS	1
70389846007	S1-14 FTN	EPA 200.8	JJS	1
70389846008	S1-16	EPA 200.8	JJS	1
70389846009	S1-17	EPA 200.8	JJS	1
70389846010	S2-02	EPA 200.8	JJS	1
70389846011	S2-03	EPA 200.8	JJS	1
70389846012	S2-04	EPA 200.8	JJS	1
70389846013	S2-05	EPA 200.8	JJS	1
70389846014	S2-06	EPA 200.8	JJS	1
70389846015	S2-08	EPA 200.8	JJS	1
70389846016	S2-09	EPA 200.8	JJS	1
70389846017	S2-10	EPA 200.8	JJS	1
70389846018	S2-11 SINK	EPA 200.8	JJS	1
70389846019	S2-11 FTN	EPA 200.8	JJS	1
70389846020	S2-13	EPA 200.8	JJS	1
70389846021	S2-14	EPA 200.8	JJS	1
70389846022	S2-18	EPA 200.8	JJS	1
70389846023	S2-20	EPA 200.8	JJS	1
70389846024	S2-22	EPA 200.8	JJS	1
70389846025	S2-24	EPA 200.8	JJS	1
70389846026	S2-25	EPA 200.8	JJS	1
70389846027	S3-14	EPA 200.8	JJS	1
70389846028	S3-15	EPA 200.8	JJS	1
70389846029	S3-19	EPA 200.8	JJS	1
70389846030	S3-20	EPA 200.8	JJS	1
70389846031	S3-23	EPA 200.8	JJS	1
70389846032	S3-24	EPA 200.8	JJS	1
70389846033	S3-27	EPA 200.8	JJS	1
70389846034	S3-28	EPA 200.8	JJS	1

PACE-MV = Pace Analytical Services - Melville

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S1-06		Lab ID: 70389846001		Collected: 11/01/25 13:41		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 13:05	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S1-07 FTN		Lab ID: 70389846002		Collected: 11/01/25 13:45		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 13:07	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S1-07 FILL		Lab ID: 70389846003		Collected: 11/01/25 13:45		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 13:08	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S1-10 SINK		Lab ID: 70389846004		Collected: 11/01/25 13:53		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.6	ug/L	1.0	1		11/19/25 13:09	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S1-10 FTN		Lab ID: 70389846005		Collected: 11/01/25 13:53		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.4	ug/L	1.0	1		11/19/25 13:10	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S1-14 SINK		Lab ID: 70389846006		Collected: 11/01/25 13:56		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	5.3	ug/L	1.0	1		11/19/25 13:12	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S1-14 FTN		Lab ID: 70389846007		Collected: 11/01/25 13:56		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	28.7	ug/L	1.0	1		11/19/25 13:13	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S1-16		Lab ID: 70389846008		Collected: 11/01/25 13:43		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 13:17	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S1-17		Lab ID: 70389846009		Collected: 11/01/25 13:43		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 13:18	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S2-02		Lab ID: 70389846010		Collected: 11/01/25 14:29		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 13:19	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S2-03		Lab ID: 70389846011		Collected: 11/01/25 14:31		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.5	ug/L	1.0	1		11/19/25 13:21	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S2-04		Lab ID: 70389846012		Collected: 11/01/25 14:31		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 13:22	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S2-05		Lab ID: 70389846013		Collected: 11/01/25 14:26		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.5	ug/L	1.0	1		11/19/25 13:23	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S2-06		Lab ID: 70389846014		Collected: 11/01/25 14:26		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 13:24	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S2-08		Lab ID: 70389846015		Collected: 11/01/25 14:24		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 13:26	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S2-09		Lab ID: 70389846016		Collected: 11/01/25 14:22		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 13:32	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S2-10		Lab ID: 70389846017		Collected: 11/01/25 14:22		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 13:36	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S2-11 SINK		Lab ID: 70389846018		Collected: 11/01/25 14:19		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 13:39	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S2-11 FTN		Lab ID: 70389846019		Collected: 11/01/25 14:19		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.0	ug/L	1.0	1		11/19/25 13:41	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S2-13		Lab ID: 70389846020		Collected: 11/01/25 14:48		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.8	ug/L	1.0	1		11/19/25 13:42	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S2-14		Lab ID: 70389846021		Collected: 11/01/25 14:14		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.5	ug/L	1.0	1		11/19/25 13:43	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S2-18		Lab ID: 70389846022		Collected: 11/01/25 14:10		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 13:47	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S2-20		Lab ID: 70389846023		Collected: 11/01/25 14:21		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.5	ug/L	1.0	1		11/19/25 13:48	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S2-22		Lab ID: 70389846024		Collected: 11/01/25 14:08		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.3	ug/L	1.0	1		11/19/25 13:50	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S2-24		Lab ID: 70389846025		Collected: 11/01/25 14:05		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 13:51	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S2-25		Lab ID: 70389846026		Collected: 11/01/25 14:05		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 13:52	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S3-14		Lab ID: 70389846027		Collected: 11/01/25 14:49		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 13:53	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S3-15		Lab ID: 70389846028		Collected: 11/01/25 14:44		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 13:55	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S3-19		Lab ID: 70389846029		Collected: 11/01/25 14:40		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	8.7	ug/L	1.0	1		11/19/25 13:56	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S3-20		Lab ID: 70389846030		Collected: 11/01/25 14:40		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.1	ug/L	1.0	1		11/19/25 13:57	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S3-23		Lab ID: 70389846031		Collected: 11/01/25 14:37		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	11.2	ug/L	1.0	1		11/19/25 13:58	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S3-24		Lab ID: 70389846032		Collected: 11/01/25 14:32		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.1	ug/L	1.0	1		11/19/25 14:02	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S3-27		Lab ID: 70389846033		Collected: 11/01/25 14:41		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 14:04	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: SANFORD ELEMENTARY 11/1
Pace Project No.: 70389846

Sample: S3-28		Lab ID: 70389846034		Collected: 11/01/25 14:41		Received: 11/05/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/25 14:05	7439-92-1		

REPORT OF LABORATORY ANALYSIS



QUALITY CONTROL DATA

Project: SANFORD ELEMENTARY 11/1

Pace Project No.: 70389846

QC Batch:	429025	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70389846001, 70389846002, 70389846003, 70389846004, 70389846005, 70389846006, 70389846007, 70389846008, 70389846009, 70389846010, 70389846011, 70389846012, 70389846013, 70389846014, 70389846015		

METHOD BLANK:	2292543	Matrix:	Water
Associated Lab Samples:	70389846001, 70389846002, 70389846003, 70389846004, 70389846005, 70389846006, 70389846007, 70389846008, 70389846009, 70389846010, 70389846011, 70389846012, 70389846013, 70389846014, 70389846015		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/19/25 12:49	

LABORATORY CONTROL SAMPLE:	2292544					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	45.6	91	85-115	

MATRIX SPIKE SAMPLE:	2292546						
Parameter	Units	70389510034 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	5.0	50	67.0	124	70-130	

MATRIX SPIKE SAMPLE:	2292548						
Parameter	Units	70389510035 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	48.3	95	70-130	

SAMPLE DUPLICATE: 2292545

Parameter	Units	70389510034 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	5.0	5.1	2	20	

SAMPLE DUPLICATE: 2292547

Parameter	Units	70389510035 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: SANFORD ELEMENTARY 11/1

Pace Project No.: 70389846

QC Batch:	429026	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70389846016, 70389846017, 70389846018, 70389846019, 70389846020, 70389846021, 70389846022, 70389846023, 70389846024, 70389846025, 70389846026, 70389846027, 70389846028, 70389846029, 70389846030, 70389846031, 70389846032, 70389846033, 70389846034		

METHOD BLANK:	2292549	Matrix:	Water
Associated Lab Samples:	70389846016, 70389846017, 70389846018, 70389846019, 70389846020, 70389846021, 70389846022, 70389846023, 70389846024, 70389846025, 70389846026, 70389846027, 70389846028, 70389846029, 70389846030, 70389846031, 70389846032, 70389846033, 70389846034		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/19/25 13:27	

LABORATORY CONTROL SAMPLE:	2292550					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	48.0	96	85-115	

MATRIX SPIKE SAMPLE:		2292552					
		70389846016	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	55.3	110	70-130	

MATRIX SPIKE SAMPLE:		2292554					
		70389846017	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	49.7	99	70-130	

SAMPLE DUPLICATE:	2292551					
Parameter	Units	70389846016 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

SAMPLE DUPLICATE:	2292553					
Parameter	Units	70389846017 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALIFIERS

Project: SANFORD ELEMENTARY 11/1

Pace Project No.: 70389846

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: SANFORD ELEMENTARY 11/1

Pace Project No.: 70389846

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70389846001	S1-06	EPA 200.8	429025		
70389846002	S1-07 FTN	EPA 200.8	429025		
70389846003	S1-07 FILL	EPA 200.8	429025		
70389846004	S1-10 SINK	EPA 200.8	429025		
70389846005	S1-10 FTN	EPA 200.8	429025		
70389846006	S1-14 SINK	EPA 200.8	429025		
70389846007	S1-14 FTN	EPA 200.8	429025		
70389846008	S1-16	EPA 200.8	429025		
70389846009	S1-17	EPA 200.8	429025		
70389846010	S2-02	EPA 200.8	429025		
70389846011	S2-03	EPA 200.8	429025		
70389846012	S2-04	EPA 200.8	429025		
70389846013	S2-05	EPA 200.8	429025		
70389846014	S2-06	EPA 200.8	429025		
70389846015	S2-08	EPA 200.8	429025		
70389846016	S2-09	EPA 200.8	429026		
70389846017	S2-10	EPA 200.8	429026		
70389846018	S2-11 SINK	EPA 200.8	429026		
70389846019	S2-11 FTN	EPA 200.8	429026		
70389846020	S2-13	EPA 200.8	429026		
70389846021	S2-14	EPA 200.8	429026		
70389846022	S2-18	EPA 200.8	429026		
70389846023	S2-20	EPA 200.8	429026		
70389846024	S2-22	EPA 200.8	429026		
70389846025	S2-24	EPA 200.8	429026		
70389846026	S2-25	EPA 200.8	429026		
70389846027	S3-14	EPA 200.8	429026		
70389846028	S3-15	EPA 200.8	429026		
70389846029	S3-19	EPA 200.8	429026		
70389846030	S3-20	EPA 200.8	429026		
70389846031	S3-23	EPA 200.8	429026		
70389846032	S3-24	EPA 200.8	429026		
70389846033	S3-27	EPA 200.8	429026		
70389846034	S3-28	EPA 200.8	429026		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

WO#: 70389846

70389846

Company Name: Intertek-PSI
Street Address: 17 British American Blvd, Latham, NY 12210

Contact/Report To: William Kotas
Phone #: (518) 377-9841
E-Mail: william.kotas@intertek.com
Cc E-Mail:

Customer Project #: Glens Falls City School District

Invoice To: PSI Latham Accounts Payable
Invoice E-Mail: LathamAR@intertek.com

Site Collection Info/Facility ID (as applicable):

Purchase Order # (if applicable):
Quote #:

County / State origin of sample(s): New York

Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead in School DW

Rush (Pre-approval required):
1 2 Day 1 3 day 1 5 day 1 Other

Date Results Requested: Standard 10 business day

Field Filtered (if applicable): 1 Yes 1 No

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (PI), Soil/Solid (SS), Oil (OL), Wipe (WI), Tissue (TI), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Customer Sample ID	Matrix *	Comp / Grab	Collected (or Composite Start) Date	Time	Composite End Date	Time	Res. CL2	Number & Type of Containers Plastic Glass
S1-06	DW	G	11/1/25	13:41				1
S1-07 FTYN				13:45				
S1-07 FTYN				13:53				
S1-10 SINK				13:56				
S1-10 FTYN				13:43				
S1-14 SINK				14:29				
S1-14 FTYN								
S1-16								
S1-17								
S1-02								

Customer Remarks / Special Conditions / Possible Hazards:

Collected By: William A Kotas

Printed Name: Signature: [Signature]

Received by/Company (Signature): [Signature]

Received by/Company (Signature): [Signature]

Received by/Company (Signature): [Signature]

Received by/Company (Signature): [Signature]

Received by/Company (Signature): [Signature]

Received by/Company (Signature): [Signature]

Received by/Company (Signature): [Signature]

Received by/Company (Signature): [Signature]

Received by/Company (Signature): [Signature]

Received by/Company (Signature): [Signature]

Specify Container Size **

Identify Container Preservative Type ***

Analysis Requested

Proj. Mgr. Lori Beyer

AcctNum / Client ID:

Table #:

Profile / Template: 10367

Prelog / Bottle Ord. ID:

Sample Comment

Lab Use Only

Preservation on non-conformance identified for sample:

Additional Instructions from Pace*

Coolers: 1

Thermometer ID: +1

Correction Factor (C): 0.0

Obs. Temp (F): 20.5

Corrected Temp (F): 20.3

Tracking Number: 111-125-100

Date/Time: 11/1/25

Delivered by: [] In Person [] Courier

[] FedEx [] UPS [] Other

Page: 1 of 4

ENV-FRM-CORQ-0019_v01_082123 ©

Pace® Location Requested (City/State):
Pace Analytical Long Island NY
575 Broad Hollow Rd, Melville, NY 11747

CHAIN-OF-CUSTODY Analytical Request Document
Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

LAB USE ONLY - Amix Workorder/Login Label Here



Scan QR Code for instructions

Company Name: Intertek-PSI
Street Address: 17 British American Blvd, Latham, NY 12210

Contact/Report To: William Kotas
Phone #: (518) 377-9841
E-Mail: william.kotas@intertek.com
Cc E-Mail:

Customer Project #:
Project Name: Glens Falls City School District

Invoice To: PSI Latham Accounts Payable
Invoice E-Mail: LathamAR@intertek.com

Site Collection Info/Facility ID (as applicable):

Purchase Order # (if applicable):

Quote #: CR-BOCES

Specify Container Size **

** Container Size: (1) 1L, (2) 500ml, (3) 250ml, (4) 125ml, (5) 100ml, (6) 40ml vial, (7) EnCore, (8) TerraCore, (9) Other
*** Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Time Zone Collected: [] AK [] PT [] MT [] CT [X] ET
Data Deliverables:

Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead in School DW

Rush (Pre-approval required):
Field Filtered (if applicable): [] Yes [] No
Date Results Requested: Standard 10 business day

Lab Use Only
Proj Mgr: Lori Beyer
AcctNum / Client ID:
Table #:
Profile / Template: 10367
Prelog / Bottle Ord. ID:
Sample Comment:
Preservation non-conformance identified for sample:

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WI), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Customer Sample ID	Matrix *	Comp / Grab	Collected (or Composite Start) Date	Time	Composite End Date	Time	Res. CL2	Number & Type of Containers Plastic Glass	200.8 Drinking Water (Pb only)	Analysis Requested	Identify Container Preservative Type ***	Specify Container Size **	Additional Instructions from Pace*
S2-14	DW	G	11/12/25	14:10				1	X				
S2-18				14:10									
S2-20				14:21									
S2-22				14:08									
S2-24				14:05									
S2-25				↓									
S3-14				14:49									
S3-15				14:44									
S3-19				14:40									
S3-20				↓									

Customer Remarks / Special Conditions / Possible Hazards:

Collected By:

Printed Name: WILLIAM A KOTAS

Coolers: 1
Thermometer ID: 174211
Correction Factor (°C): f.1
Q10 Temp (°C): 20.2
Correction Temp (°C): 20.30

Relinquished by/Company (Signature):

Date/Time: 11/14/2025 16:00

Received by/Company (Signature):

Tracking Number: 1114125 1600

Relinquished by/Company (Signature):

Date/Time: 11/11/25 16:20

Received by/Company (Signature):

Delivered by: [] In Person [] Courier

Relinquished by/Company (Signature):

Date/Time: 11/15/25 16:00

Received by/Company (Signature):

Delivered by: [] FedEx [] UPS [] Other

Relinquished by/Company (Signature):

Date/Time:

Received by/Company (Signature):

Page: 3 of 4

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace® Terms and Conditions found at <https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions/>

Date/Time:

Received by/Company (Signature):

ENV-FRM-CORQ-0019_v01_082123 ©

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

LAB USE ONLY - Affix Workorder/Login Label Here



Scan QR Code for instructions

Company Name:	Intertek-PSJ	Contact/Report To:	William Kotas
Street Address:	17 British American Blvd, Latham, NY 12210	Phone #:	(518) 377-9841
		E-Mail:	william.kotas@intertek.com
		Cc E-Mail:	
Customer Project #:		Invoice To:	PSJ Latham Accounts Payable
Project Name:	Glens Falls City School District	Invoice E-Mail:	LathamAR@intertek.com
		Purchase Order # (if applicable):	
Site Collection Info/Facility ID (as applicable):		Quote #:	CR-BOCES

Time Zone Collected: { }	AK	{ }	PT	{ }	MT	{ }	CT	{ }	ET	County / State origin of sample(s):	New York
Data Deliverables:											
{ } Level II	{ }	Level III	{ }	Level IV	Rush (Pre-approval required): { } 12 Day { } 13 day { } 15 day { } Other _____						
{ } EQUIS											
{ } Other _____					Date Results Requested: Standard 10 business day						
DW PWSID # or WW Permit # as applicable: Field Filtered (if applicable): { } Yes { } No Analysis:											

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

[illegible]

DC# Title: ENV-FRM-MELV-0024 v07_SCUR
Effective Date: 4/12/2024

WO#: 70389846

PM: LAB Due Date: 11/19/25
CLIENT: INTER-LATHAM

Client Name: Inter - Latham

Project #

Courier: ☐ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☒ Pace ☐ Other

Tracking #:

Custody Seal on Cooler/Box Present: ☐ Yes ☒ No Seals intact: ☐ Yes ☒ No Temperature Blank Present: ☐ Yes ☒ No

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ Ziploc ☐ None ☐ Other Type of Ice: Wet Blue None

Thermometer Used: Ther Correction Factor: 6.1 Samples on ice, cooling process has begun

Cooler Temperature (°C): 20.2 Cooler Temperature Corrected (°C): 20.3 Date/Time 5035A kits placed in freezer

Temp should be above freezing to 5 °C

USDA Regulated Soil ☒ N/A, water sample)

Did samples originate in a quarantine zone within the United States AL AR CA FL GA ID LA MS NC NM NY OK OR SC TN TX, or
VA (check map)? ☐ Yes ☒ No

Did samples originate from a foreign source including Hawaii and Puerto Rico? ☐ Yes ☒ No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork.

Date and Initials of person examining contents:

				COMMENTS:
Chain of Custody Present	☒ Yes	☐ No	1	
Chain of Custody Filled Out	☒ Yes	☐ No	2	
Chain of Custody Relinquished	☒ Yes	☐ No	3	
Sampler Name & Signature on COC	☒ Yes	☐ No	4	
Samples Arrived within Hold Time	☒ Yes	☐ No	5	
Short Hold Time Analysis (<72hr):	☒ Yes	☐ No	6	
Rush Turn Around Time Requested:	☒ Yes	☐ No	7	
Sufficient Volume (Triple volume provided for MS/MSD)	☒ Yes	☐ No	8	
Correct Containers Used	☒ Yes	☐ No	9	
Pace Containers Used	☒ Yes	☐ No	10	
Containers Intact	☒ Yes	☐ No	11	Note: if sediment is visible in the dissolved container
Filtered volume received for Dissolved tests	☒ Yes	☐ No	12	
Sample Labels match COC	☒ Yes	☐ No		
Includes date/time/ID/Analysis	☒ Matrix	☒ SL	☒ WT	☒ OIL

Date and Initials of person checking preservation:

All containers needing preservation have been	☒ Yes	☐ No	N/A	13	☐ HNO ₃ ☐ H ₂ SO ₄ ☐ NaOH ☐ HCl
pH paper Lot #	291224				Sample #
All containers needing preservation are found to be in compliance with method recommendation?	☒ Yes	☐ No	N/A		
(HNO ₃ H ₂ SO ₄ HCl NaOH > 9 Sulfide	☒ Yes	☐ No	N/A		
NaOH > 12 Cyanide)					
Exceptions VOA Coliform TOC/DOC Oil and Grease DRO/8015 (water)					
Per Method VOA pH is checked after analysis					
Samples checked for dechlorination	☒ Yes	☐ No	N/A	14	
KI starch test strips Lot #					
Residual chlorine strips Lot #					
SM 4500 CN samples checked for sulf	☒ Yes	☐ No	N/A	15	Positive for Res. Chlorine? Y N
Lead Acetate Strips Lot #					
Headspace in ALK Bottle (>6mm)	☒ Yes	☐ No	N/A	16	Positive for Sulfide? Y N
Headspace in VOA Vials (>6mm)	☒ Yes	☐ No	N/A		
Trip Blank Present:	☒ Yes	☐ No	N/A	17	
Trip Blank Custody Seals Present	☒ Yes	☐ No	N/A		

Client Notification/ Resolution:

Person Contacted:

Comments/ Resolution:

Field Data Required? Y / N

Date/Time:

* PM (Project Manager) review (which includes the SCUR) is documented electronically in LIMS