



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

December 08, 2025

John Harding  
Eagle Point School District #9  
PO Box 548  
Eagle Point, OR 97524  
TEL: (541) 830-1240  
FAX (541) 830-6375

RE: 20434021 WMMS Lead Testing

Order No.: 25110893

Dear John Harding:

Neilson Research Corporation received 67 sample(s) on 11/19/2025 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,  
Neilson Research Corporation

Tamra Schmedemann  
Director of Project Management  
245 S Grape St  
Medford, OR 97501



Original



**NEILSON  
RESEARCH  
CORPORATION**

*Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com*

## Case Narrative

WO#: 25110893  
Date: 12/8/2025

---

**CLIENT:** Eagle Point School District #9  
**Project:** 20434021 WMMS Lead Testing

---

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

---

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 25110893  
 Date Reported: 12/8/2025

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 25110893  
**Received Date:** 11/19/2025 9:13:00 AM  
**Reported Date:** 12/8/2025 12:37:16 PM

Sample Information:

**Lab ID:** 25110893-01      Client Sample ID: 20434021-001BF-25A  
 Collection Date: 11/19/2025 6:20:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-001BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-02      Client Sample ID: 20434021-002WB-25A  
 Collection Date: 11/19/2025 6:42:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-002WB-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-03      Client Sample ID: 20434021-003BF-25A  
 Collection Date: 11/19/2025 6:19:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-003BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.60		0.515	ppb	1	12/1/2025	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 25110893  
 Date Reported: 12/8/2025

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 25110893  
**Received Date:** 11/19/2025 9:13:00 AM  
**Reported Date:** 12/8/2025 12:37:16 PM

Sample Information:

**Lab ID:** 25110893-04      Client Sample ID: 20434021-004WB-25A  
 Collection Date: 11/19/2025 6:40:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-004WB-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-05      Client Sample ID: 20434021-005DW-25A  
 Collection Date: 11/19/2025 6:53:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-005DW-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-06      Client Sample ID: 20434021-007DW-25A  
 Collection Date: 11/19/2025 7:21:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-007DW-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	12/1/2025	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 25110893  
 Date Reported: 12/8/2025

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 25110893  
**Received Date:** 11/19/2025 9:13:00 AM  
**Reported Date:** 12/8/2025 12:37:16 PM

Sample Information:

**Lab ID:** 25110893-07      Client Sample ID: 20434021-008DW-25A  
 Collection Date: 11/19/2025 6:40:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-008DW-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-08      Client Sample ID: 20434021-009DW-25A  
 Collection Date: 11/19/2025 6:38:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-009DW-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-09      Client Sample ID: 20434021-010DW-25A  
 Collection Date: 11/19/2025 6:42:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-010DW-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	12/1/2025	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 25110893  
 Date Reported: 12/8/2025

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 25110893  
**Received Date:** 11/19/2025 9:13:00 AM  
**Reported Date:** 12/8/2025 12:37:16 PM

Sample Information:

**Lab ID:** 25110893-10      Client Sample ID: 20434021-011CF-25A  
 Collection Date: 11/19/2025 6:48:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-011CF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	12/1/2025	15.0	A

**Lab ID:** 25110893-11      Client Sample ID: 20434021-012WB-25A  
 Collection Date: 11/19/2025 6:21:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-012WB-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	12/1/2025	15.0	A

**Lab ID:** 25110893-12      Client Sample ID: 20434021-013KF-25A  
 Collection Date: 11/19/2025 6:15:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-013KF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.913		0.515	ppb	1	12/1/2025	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 25110893  
 Date Reported: 12/8/2025

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 25110893  
**Received Date:** 11/19/2025 9:13:00 AM  
**Reported Date:** 12/8/2025 12:37:16 PM

Sample Information:

**Lab ID:** 25110893-13      Client Sample ID: 20434021-014CF-25A  
 Collection Date: 11/19/2025 6:18:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-014CF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.10		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-14      Client Sample ID: 20434021-015BF-25A  
 Collection Date: 11/19/2025 6:22:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-015BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-15      Client Sample ID: 20434021-016BF-25A  
 Collection Date: 11/19/2025 6:22:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-016BF-25A


Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	12/1/2025	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 25110893  
 Date Reported: 12/8/2025

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 25110893  
**Received Date:** 11/19/2025 9:13:00 AM  
**Reported Date:** 12/8/2025 12:37:16 PM

Sample Information:

**Lab ID:** 25110893-16      Client Sample ID: 20434021-017BF-25A  
 Collection Date: 11/19/2025 6:20:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-017BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-17      Client Sample ID: 20434021-018BF-25A  
 Collection Date: 11/19/2025 6:21:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-018BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.757		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-18      Client Sample ID: 20434021-019CF-25A  
 Collection Date: 11/19/2025 6:41:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-019CF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.554		0.515	ppb	1	12/1/2025	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 25110893  
 Date Reported: 12/8/2025

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 25110893  
**Received Date:** 11/19/2025 9:13:00 AM  
**Reported Date:** 12/8/2025 12:37:16 PM

Sample Information:

**Lab ID:** 25110893-19      Client Sample ID: 20434021-020CF-25A  
 Collection Date: 11/19/2025 6:42:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-020CF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.758		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-20      Client Sample ID: 20434021-021CF-25A  
 Collection Date: 11/19/2025 6:40:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-021CF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-21      Client Sample ID: 20434021-022CF-25A  
 Collection Date: 11/19/2025 6:40:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-022CF-25A


Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	12/1/2025	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 25110893  
 Date Reported: 12/8/2025

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 25110893  
**Received Date:** 11/19/2025 9:13:00 AM  
**Reported Date:** 12/8/2025 12:37:16 PM

Sample Information:

**Lab ID:** 25110893-22      Client Sample ID: 20434021-023CF-25A  
 Collection Date: 11/19/2025 6:39:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-023CF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-23      Client Sample ID: 20434021-024KF-25A  
 Collection Date: 11/19/2025 6:33:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-024KF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.17		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-24      Client Sample ID: 20434021-025KF-25A  
 Collection Date: 11/19/2025 6:30:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-025KF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	12/1/2025	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 25110893  
 Date Reported: 12/8/2025

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 25110893  
**Received Date:** 11/19/2025 9:13:00 AM  
**Reported Date:** 12/8/2025 12:37:16 PM

Sample Information:

**Lab ID:** 25110893-25      Client Sample ID: 20434021-026KF-25A  
 Collection Date: 11/19/2025 6:30:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-026KF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.657		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-26      Client Sample ID: 20434021-027KF-25A  
 Collection Date: 11/19/2025 6:31:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-027KF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	4.63		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-27      Client Sample ID: 20434021-028KF-25A  
 Collection Date: 11/19/2025 6:32:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-028KF-25A


Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.658		0.515	ppb	1	12/1/2025	15.0	A	

- |                   |   |   |
|-------------------|---|---|
| <b>QUALIFIERS</b> | * Value exceeds Maximum or Minimum Contaminant Level.         | C1 Sample container temperature is out of limit as specified at testcod |
|                   | DF Dilution Factor  | E Value above quantitation range  |
|                   | H Holding times for preparation or analysis exceeded          | J Analyte detected below quantitation limits                            |
|                   | MI Recovery outside control limits due to Matrix Interference | ND Not Detected at the Reporting Limit                                  |
|                   | R RPD outside accepted recovery limits                        | RL Reporting Limit  |

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 25110893  
 Date Reported: 12/8/2025

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 25110893  
**Received Date:** 11/19/2025 9:13:00 AM  
**Reported Date:** 12/8/2025 12:37:16 PM

Sample Information:

**Lab ID:** 25110893-28      Client Sample ID: 20434021-029BF-25A  
 Collection Date: 11/19/2025 6:37:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-029BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-29      Client Sample ID: 20434021-030BF-25A  
 Collection Date: 11/19/2025 6:23:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-030BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.643		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-30      Client Sample ID: 20434021-031BF-25A  
 Collection Date: 11/19/2025 6:26:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-031BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.607		0.515	ppb	1	12/1/2025	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 25110893  
 Date Reported: 12/8/2025

Eagle Point School District #9  
 PO Box 548  
 Eagle Point , OR 97524

**Lab Order:** 25110893  
**Received Date:** 11/19/2025 9:13:00 AM  
**Reported Date:** 12/8/2025 12:37:16 PM

Sample Information:

**Lab ID:** 25110893-31      Client Sample ID: 20434021-032BF-25A  
 Collection Date: 11/19/2025 6:24:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-032BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CSB	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	40.6	*1	0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-32      Client Sample ID: 20434021-033BF-25A  
 Collection Date: 11/19/2025 6:22:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-033BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CSB	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.68		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-33      Client Sample ID: 20434021-034BF-25A  
 Collection Date: 11/19/2025 6:21:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-034BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CSB	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.36		0.515	ppb	1	12/1/2025	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 25110893  
 Date Reported: 12/8/2025

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 25110893  
**Received Date:** 11/19/2025 9:13:00 AM  
**Reported Date:** 12/8/2025 12:37:16 PM

Sample Information:

**Lab ID:** 25110893-34      Client Sample ID: 20434021-035SF-25A  
 Collection Date: 11/19/2025 6:30:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-035SF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-35      Client Sample ID: 20434021-036NS-25A  
 Collection Date: 11/19/2025 6:33:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-036NS-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-36      Client Sample ID: 20434021-037BF-25A  
 Collection Date: 11/19/2025 6:35:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-037BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.716		0.515	ppb	1	12/1/2025	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 25110893  
 Date Reported: 12/8/2025

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 25110893  
**Received Date:** 11/19/2025 9:13:00 AM  
**Reported Date:** 12/8/2025 12:37:16 PM

Sample Information:

**Lab ID:** 25110893-37      Client Sample ID: 20434021-038BF-25A  
 Collection Date: 11/19/2025 6:39:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-038BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.567		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-38      Client Sample ID: 20434021-039CF-25A  
 Collection Date: 11/19/2025 6:39:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-039CF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-39      Client Sample ID: 20434021-040BF-25A  
 Collection Date: 11/19/2025 6:43:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-040BF-25A


Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.622		0.515	ppb	1	12/1/2025	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 25110893  
 Date Reported: 12/8/2025

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 25110893  
**Received Date:** 11/19/2025 9:13:00 AM  
**Reported Date:** 12/8/2025 12:37:16 PM

Sample Information:

**Lab ID:** 25110893-40      Client Sample ID: 20434021-041BF-25A  
 Collection Date: 11/19/2025 6:45:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-041BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.855		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-41      Client Sample ID: 20434021-042BF-25A  
 Collection Date: 11/19/2025 6:50:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-042BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.693		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-42      Client Sample ID: 20434021-043BF-25A  
 Collection Date: 11/19/2025 6:50:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-043BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.603		0.515	ppb	1	12/1/2025	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 25110893  
 Date Reported: 12/8/2025

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 25110893  
**Received Date:** 11/19/2025 9:13:00 AM  
**Reported Date:** 12/8/2025 12:37:16 PM

Sample Information:

**Lab ID:** 25110893-43      Client Sample ID: 20434021-044BF-25A  
 Collection Date: 11/19/2025 6:50:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-044BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.758		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-44      Client Sample ID: 20434021-045NS-25A  
 Collection Date: 11/19/2025 7:18:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-045NS-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.915		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-45      Client Sample ID: 20434021-0546NS-25A  
 Collection Date: 11/19/2025 7:15:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-046NS-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.03		0.515	ppb	1	12/1/2025	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 25110893  
 Date Reported: 12/8/2025

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 25110893  
**Received Date:** 11/19/2025 9:13:00 AM  
**Reported Date:** 12/8/2025 12:37:16 PM

Sample Information:

**Lab ID:** 25110893-46      Client Sample ID: 20434021-056DW-25A  
 Collection Date: 11/19/2025 7:18:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-056DW-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-47      Client Sample ID: 20434021-057BF-25A  
 Collection Date: 11/19/2025 6:55:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-057BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-48      Client Sample ID: 20434021-047BF-25A  
 Collection Date: 11/19/2025 6:50:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-047BF-25A


Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.857		0.515	ppb	1	12/1/2025	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 25110893  
 Date Reported: 12/8/2025

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 25110893  
**Received Date:** 11/19/2025 9:13:00 AM  
**Reported Date:** 12/8/2025 12:37:16 PM

Sample Information:

**Lab ID:** 25110893-49      Client Sample ID: 20434021-048CF-25A  
 Collection Date: 11/19/2025 6:46:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-048CF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.77		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-50      Client Sample ID: 20434021-049BF-25A  
 Collection Date: 11/19/2025 6:33:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-049BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.699		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-51      Client Sample ID: 20434021-050BF-25A  
 Collection Date: 11/19/2025 6:29:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-050BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.746		0.515	ppb	1	12/1/2025	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 25110893  
 Date Reported: 12/8/2025

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 25110893  
**Received Date:** 11/19/2025 9:13:00 AM  
**Reported Date:** 12/8/2025 12:37:16 PM

Sample Information:

**Lab ID:** 25110893-52      Client Sample ID: 20434021-051BF-25A  
 Collection Date: 11/19/2025 6:30:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-051BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.584		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-53      Client Sample ID: 20434021-052BF-25A  
 Collection Date: 11/19/2025 6:31:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-052BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.829		0.515	ppb	1	12/1/2025	15.0	A	

**Lab ID:** 25110893-54      Client Sample ID: 20434021-053BF-25A  
 Collection Date: 11/19/2025 6:25:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-053BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.750		0.515	ppb	1	12/1/2025	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 25110893  
 Date Reported: 12/8/2025

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 25110893  
**Received Date:** 11/19/2025 9:13:00 AM  
**Reported Date:** 12/8/2025 12:37:16 PM

Sample Information:

**Lab ID:** 25110893-55      Client Sample ID: 20434021-054BF-25A  
 Collection Date: 11/19/2025 6:27:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-054BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.668		0.515	ppb	1	12/2/2025	15.0	A	

**Lab ID:** 25110893-56      Client Sample ID: 20434021-055BF-25A  
 Collection Date: 11/19/2025 6:28:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-055BF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.645		0.515	ppb	1	12/2/2025	15.0	A	

**Lab ID:** 25110893-57      Client Sample ID: 20434021-058CF-25A  
 Collection Date: 11/19/2025 6:37:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-058CF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.546		0.515	ppb	1	12/2/2025	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 25110893  
 Date Reported: 12/8/2025

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 25110893  
**Received Date:** 11/19/2025 9:13:00 AM  
**Reported Date:** 12/8/2025 12:37:16 PM

Sample Information:

**Lab ID:** 25110893-58      Client Sample ID: 20434021-059CF-25A  
 Collection Date: 11/19/2025 6:56:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-059CF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.616		0.515	ppb	1	12/2/2025	15.0	A	

**Lab ID:** 25110893-59      Client Sample ID: 20434021-060CF-25A  
 Collection Date: 11/19/2025 6:55:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-060CF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	4.51		0.515	ppb	1	12/2/2025	15.0	A	

**Lab ID:** 25110893-60      Client Sample ID: 20434021-061CF-25A  
 Collection Date: 11/19/2025 6:54:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-061CF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.521		0.515	ppb	1	12/2/2025	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 25110893  
 Date Reported: 12/8/2025

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 25110893  
**Received Date:** 11/19/2025 9:13:00 AM  
**Reported Date:** 12/8/2025 12:37:16 PM

Sample Information:

**Lab ID:** 25110893-61      Client Sample ID: 20434021-062CF-25A  
 Collection Date: 11/19/2025 6:53:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-062CF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.00		0.515	ppb	1	12/2/2025	15.0	A	

**Lab ID:** 25110893-62      Client Sample ID: 20434021-063CF-25A  
 Collection Date: 11/19/2025 6:52:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-063CF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.01		0.515	ppb	1	12/2/2025	15.0	A	

**Lab ID:** 25110893-63      Client Sample ID: 20434021-064CF-25A  
 Collection Date: 11/19/2025 7:02:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-064CF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.597		0.515	ppb	1	12/2/2025	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 25110893  
 Date Reported: 12/8/2025

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 25110893  
**Received Date:** 11/19/2025 9:13:00 AM  
**Reported Date:** 12/8/2025 12:37:16 PM

Sample Information:

**Lab ID:** 25110893-64      Client Sample ID: 20434021-065CF-25A  
 Collection Date: 11/19/2025 6:52:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-065CF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	12/2/2025	15.0	A	

**Lab ID:** 25110893-65      Client Sample ID: 20434021-066CF-25A  
 Collection Date: 11/19/2025 6:39:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-066CF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	12/2/2025	15.0	A	

**Lab ID:** 25110893-66      Client Sample ID: 20434021-067CF-25A  
 Collection Date: 11/19/2025 6:41:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-067CF-25A

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	12/2/2025	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 25110893  
 Date Reported: 12/8/2025

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 25110893  
**Received Date:** 11/19/2025 9:13:00 AM  
**Reported Date:** 12/8/2025 12:37:16 PM

Sample Information:

**Lab ID:** 25110893-67      Client Sample ID: 20434021-069CF-25A  
 Collection Date: 11/19/2025 7:00:00 AM      Collected By: Steve Lambert  
 Matrix: Drinking Water      Sample Location: 20434021-069CF-25A

Trace Metals by EPA 200.8 ICP-MS						Analyst: CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.80		0.515	ppb	1	12/2/2025	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# QC SUMMARY REPORT

WO#: 25110893  
 08-Dec-25

**Client:** Eagle Point School District #9  
**Project:** 20434021 WMMS Lead Testing

**TestCode:** LEAD\_SCHOOLS

Sample ID: <b>MB-34849</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_SCHO</b>	Units: <b>ppb</b>	Prep Date: <b>12/1/2025</b>	RunNo: <b>65696</b>						
Client ID: <b>PBW</b>	Batch ID: <b>34849</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/1/2025</b>	SeqNo: <b>1072365</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.515

Sample ID: <b>LCS-34849</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_SCHO</b>	Units: <b>ppb</b>	Prep Date: <b>12/1/2025</b>	RunNo: <b>65696</b>						
Client ID: <b>LCSW</b>	Batch ID: <b>34849</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/1/2025</b>	SeqNo: <b>1072366</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 99.7 0.520 100 0 99.7 85 115

Sample ID: <b>25110893-01AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_SCHO</b>	Units: <b>ppb</b>	Prep Date: <b>12/1/2025</b>	RunNo: <b>65696</b>						
Client ID: <b>20434021-001BF-25A</b>	Batch ID: <b>34849</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/1/2025</b>	SeqNo: <b>1072368</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 101 0.520 100 0.383 100 70 130

Sample ID: <b>25110893-01AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_SCHO</b>	Units: <b>ppb</b>	Prep Date: <b>12/1/2025</b>	RunNo: <b>65696</b>						
Client ID: <b>20434021-001BF-25A</b>	Batch ID: <b>34849</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/1/2025</b>	SeqNo: <b>1072369</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 99.1 0.520 100 0.383 98.8 70 130 101 1.56 20

**Qualifiers:** \* Value exceeds Maximum or Minimum Contaminant Level. C1 Sample container temperature is out of limit as specified at testcode DF Dilution Factor  
 H Holding times for preparation or analysis exceeded MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit  
 RL Reporting Limit

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# QC SUMMARY REPORT

WO#: 25110893  
 08-Dec-25

**Client:** Eagle Point School District #9  
**Project:** 20434021 WMMS Lead Testing

**TestCode:** LEAD\_SCHOOLS

Sample ID: <b>MB-34850</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_SCHO</b>	Units: <b>ppb</b>	Prep Date: <b>12/1/2025</b>	RunNo: <b>65696</b>						
Client ID: <b>PBW</b>	Batch ID: <b>34850</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/1/2025</b>	SeqNo: <b>1072393</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.515

Sample ID: <b>LCS-34850</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_SCHO</b>	Units: <b>ppb</b>	Prep Date: <b>12/1/2025</b>	RunNo: <b>65696</b>						
Client ID: <b>LCSW</b>	Batch ID: <b>34850</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/1/2025</b>	SeqNo: <b>1072394</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 102 0.520 100 0 102 85 115

Sample ID: <b>25110893-21AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_SCHO</b>	Units: <b>ppb</b>	Prep Date: <b>12/1/2025</b>	RunNo: <b>65696</b>						
Client ID: <b>20434021-022CF-25A</b>	Batch ID: <b>34850</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/1/2025</b>	SeqNo: <b>1072396</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual


Lead 100 0.520 100 0.272 100 70 130

Sample ID: <b>25110893-21AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_SCHO</b>	Units: <b>ppb</b>	Prep Date: <b>12/1/2025</b>	RunNo: <b>65696</b>						
Client ID: <b>20434021-022CF-25A</b>	Batch ID: <b>34850</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/1/2025</b>	SeqNo: <b>1072397</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 99.2 0.520 100 0.272 98.9 70 130 100 1.09 20

**Qualifiers:** \* Value exceeds Maximum or Minimum Contaminant Level. C1 Sample container temperature is out of limit as specified at testcode DF Dilution Factor  
 H Holding times for preparation or analysis exceeded MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit  
 RL Reporting Limit

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# QC SUMMARY REPORT

WO#: 25110893  
 08-Dec-25

**Client:** Eagle Point School District #9  
**Project:** 20434021 WMMS Lead Testing

**TestCode:** LEAD\_SCHOOLS

Sample ID: <b>MB-34852</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_SCHO</b>	Units: <b>ppb</b>	Prep Date: <b>12/1/2025</b>	RunNo: <b>65696</b>						
Client ID: <b>PBW</b>	Batch ID: <b>34852</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/1/2025</b>	SeqNo: <b>1072424</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.515

Sample ID: <b>LCS-34852</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_SCHO</b>	Units: <b>ppb</b>	Prep Date: <b>12/1/2025</b>	RunNo: <b>65696</b>						
Client ID: <b>LCSW</b>	Batch ID: <b>34852</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/1/2025</b>	SeqNo: <b>1072425</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 104 0.520 100 0 104 85 115

Sample ID: <b>25110893-41AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_SCHO</b>	Units: <b>ppb</b>	Prep Date: <b>12/1/2025</b>	RunNo: <b>65696</b>						
Client ID: <b>20434021-042BF-25A</b>	Batch ID: <b>34852</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/1/2025</b>	SeqNo: <b>1072427</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 102 0.520 100 0.693 101 70 130

Sample ID: <b>25110893-41AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_SCHO</b>	Units: <b>ppb</b>	Prep Date: <b>12/1/2025</b>	RunNo: <b>65696</b>						
Client ID: <b>20434021-042BF-25A</b>	Batch ID: <b>34852</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/1/2025</b>	SeqNo: <b>1072428</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 101 0.520 100 0.693 100 70 130 102 1.05 20

**Qualifiers:** \* Value exceeds Maximum or Minimum Contaminant Level. C1 Sample container temperature is out of limit as specified at testcode DF Dilution Factor  
 H Holding times for preparation or analysis exceeded MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit  
 RL Reporting Limit

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# QC SUMMARY REPORT

WO#: 25110893  
 08-Dec-25

**Client:** Eagle Point School District #9  
**Project:** 20434021 WMMS Lead Testing

**TestCode:** LEAD\_SCHOOLS

Sample ID: <b>MB-34853</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_SCHO</b>	Units: <b>ppb</b>	Prep Date: <b>12/1/2025</b>	RunNo: <b>65696</b>						
Client ID: <b>PBW</b>	Batch ID: <b>34853</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/2/2025</b>	SeqNo: <b>1072452</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.515

Sample ID: <b>LCS-34853</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_SCHO</b>	Units: <b>ppb</b>	Prep Date: <b>12/1/2025</b>	RunNo: <b>65696</b>						
Client ID: <b>LCSW</b>	Batch ID: <b>34853</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/2/2025</b>	SeqNo: <b>1072453</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 101 0.520 100 0 101 85 115

Sample ID: <b>25110893-61AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_SCHO</b>	Units: <b>ppb</b>	Prep Date: <b>12/1/2025</b>	RunNo: <b>65696</b>						
Client ID: <b>20434021-062CF-25A</b>	Batch ID: <b>34853</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/2/2025</b>	SeqNo: <b>1072455</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 99.5 0.520 100 1.00 98.5 70 130

Sample ID: <b>25110893-61AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_SCHO</b>	Units: <b>ppb</b>	Prep Date: <b>12/1/2025</b>	RunNo: <b>65696</b>						
Client ID: <b>20434021-062CF-25A</b>	Batch ID: <b>34853</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/2/2025</b>	SeqNo: <b>1072456</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 100 0.520 100 1.00 99.1 70 130 99.5 0.515 20

**Qualifiers:** \* Value exceeds Maximum or Minimum Contaminant Level. C1 Sample container temperature is out of limit as specified at testcode DF Dilution Factor  
 H Holding times for preparation or analysis exceeded MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit  
 RL Reporting Limit

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Sample Log-In Check List

Client Name: EAGLEPTSCHOOL

Work Order Number: 25110893

RcptNo: 1

Logged by:	Ashley Spiegelberg	11/19/2025 9:13:00 AM	<i>Am</i>
Completed By:	Kyler Woolsey	11/21/2025 11:00:11 AM	<i>Kyler Woolsey</i>
Reviewed By:	Ashley Spiegelberg	12/8/2025 12:21:59 PM	<i>Am</i>

**Chain of Custody**

1. Is Chain of Custody complete? Yes  No  Not Present
2. How was the sample delivered? Client

**Log In**

3. Coolers are present? Yes  No  NA
4. Shipping container/cooler in good condition? Yes  No   
 Custody seals intact on shipping container/cooler? Yes  No  Not Present  NA
- No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes  No  NA
6. Were all samples received at a temperature of >0° C to 6.0°C Yes  No  NA
7. Sample(s) in proper container(s)? Yes  No
8. Sufficient sample volume for indicated test(s)? Yes  No
9. Are samples (except VOA and ONG) properly preserved? Yes  No
10. Was preservative added to bottles? Yes  No  NA
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes  No  No VOA Vials
12. Were any sample containers received broken? Yes  No
13. Does paperwork match bottle labels? Yes  No   
 (Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes  No
15. Is it clear what analyses were requested? Yes  No
16. Were all holding times able to be met? Yes  No   
 (If no, notify customer for authorization.)

**Special Handling (if applicable)**

17. Was client notified of all discrepancies with this order? Yes  No  NA

Person Notified:	<input type="text"/>	Date:	<input type="text"/>
By Whom:	<input type="text"/>	Via:	<input type="checkbox"/> eMail <input type="checkbox"/> Phone <input type="checkbox"/> Fax <input type="checkbox"/> In Person
Regarding:	<input type="text"/>		
Client Instructions:	<input type="text"/>		

18. Additional remarks:

**Cooler Information**

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------

**Chain of Custody Record**

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

**Section A**

**Required Client Information**

Company: JCSD9  
 Address: P.O. BOX 548  
Eagle Point, OR 97524  
 Email: \_\_\_\_\_  
 Phone: 830-6378 Fax: \_\_\_\_\_  
 Collected By (Print): Steve Lambert  
 Collected By (Sign): [Signature]  
 Email Report  Mail Report  Fax Report

**Section B**

**Required Project Information**

Project Name: WMMS  
 Project Number: 20434021  
 Report To: \_\_\_\_\_  
 Copy To: \_\_\_\_\_

**Section C**

**Invoice Information**

Attention: John Harding  
 Company Name: JCSD9  
 Address: P.O. Box 548  
Eagle Point, OR 97524  
 P.O. # \_\_\_\_\_

**Section D**

**Rush Status (Subject to Scheduling)**

Standard: 10 Business Days  
 Priority: 5 Business Days (List x 1.50)  
 Express: 3 Business Days (List x 1.75)  
 Rush: 2 Business Days (List x 2.00)  
 Rush: 1 Business Day (List x 2.50)  
 Rush: Same Day (List x 3.00)

Authorized  Yes  No

**Section E**

**Sample Information**

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	NRC Sample # Use Only	(Lab Use Only)
<u>20434021-001BF-25A</u>			<u>11-19-25</u>	<u>6:20</u>	<u>1</u>	<u>LEAD</u>	<u>25110893</u>	<u>01</u>	
<u>-002WB-25A</u>				<u>6:42</u>	<u>1</u>			<u>02</u>	
<u>-003BF-25A</u>				<u>6:19</u>	<u>1</u>			<u>03</u>	
<u>-004WB-25A</u>				<u>6:40</u>	<u>1</u>			<u>04</u>	
<u>-005DW-25A</u>				<u>6:53</u>	<u>1</u>			<u>05</u>	
<u>-007DW-25A</u>				<u>7:21</u>	<u>1</u>			<u>06</u>	
<u>-008DW-25A</u>				<u>6:40</u>	<u>1</u>			<u>07</u>	
<u>-009DW-25A</u>				<u>6:38</u>	<u>1</u>			<u>08</u>	
<u>-010DW-25A</u>	<u>010DW-25A</u>			<u>6:42</u>	<u>1</u>			<u>09</u>	
<u>-011CF-25A</u>				<u>6:48</u>	<u>1</u>			<u>10</u>	

\*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

**Section F**

**Relinquish/Receive**

Relinquished By:	Print	Date	Time
<u>[Signature]</u>	<u>Steve Lambert</u>	<u>11-19-25</u>	<u>9:13</u>
Received By:			
Relinquished By:			
Received By:			
Relinquished By:			
Received By Laboratory:	<u>Ashley Spegelburg</u>	<u>11/19/25</u>	<u>9:13</u>

\* Client error  
DE 11/19/25

**Section G**

**Lab Use Only**

Temp: AMB IR Therm ID: UA  
 ≤6°C:  Yes  No  
 Received on Ice:  Yes  No  
 Number of Bottles Received: \_\_\_\_\_  
 pH Checked: \_\_\_\_\_  
 COC Seals Intact:  Yes  No  NA  
 Field Blank Included:  Yes  No  
 Received Via  UPS  FedEx  Other  Hand  
 Payment:  Invoice  Cash  VISA, M/C  Check # \_\_\_\_\_ Amount \_\_\_\_\_

**Chain of Custody Record**

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

**Section A**

**Required Client Information**

Company: JCS D9  
 Address: P.O. BOX 548  
Eagle Point, OR 97524  
 Email: \_\_\_\_\_  
 Phone: 830-6378 Fax: \_\_\_\_\_  
 Collected By (Print): Stere Lambert  
 Collected By (Sign): [Signature]  
 Email Report  Mail Report  Fax Report

**Section B**

**Required Project Information**

Project Name: WMMS  
 Project Number: 20434021  
 Report To: \_\_\_\_\_  
 Copy To: \_\_\_\_\_

**Section C**

**Invoice Information**

Attention: John Harding  
 Company Name: JCS D9  
 Address: P.O. Box 548  
Eagle Point, OR 97524  
 P.O. # \_\_\_\_\_

**Section D**

**Rush Status (Subject to Scheduling)**

Standard: 10 Business Days  
 Priority: 5 Business Days (List x 1.50)  
 Express: 3 Business Days (List x 1.75)  
 Rush: 2 Business Days (List x 2.00)  
 Rush: 1 Business Day (List x 2.50)  
 Rush: Same Day (List x 3.00)  
 Authorized  Yes  No

**Section E**

**Sample Information**

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	NRC Sample # (Use Only)	(Lab)
<u>20434021-012WB25A</u>			<u>11-19-25</u>	<u>6:21</u>	<u>1</u>	<u>LEAD</u>	<u>25110893</u>		
<u>-013KF-25A</u>			}	<u>6:15</u>	<u>1</u>			<u>11</u>	
<u>-014CF-25A</u>				<u>6:18</u>	<u>1</u>			<u>12</u>	
<u>-015BF-25A</u>				<u>6:22</u>	<u>1</u>			<u>13</u>	
<u>-016BF-25A</u>				<u>6:22</u>	<u>1</u>			<u>14</u>	
<u>-017BF-25A</u>				<u>6:26</u>	<u>1</u>			<u>15</u>	
<u>-018BF-25A</u>				<u>6:21</u>	<u>1</u>			<u>16</u>	
<u>-019CF-25A</u>				<u>6:41</u>	<u>1</u>			<u>17</u>	
<u>-020CF-25A</u>				<u>6:42</u>	<u>1</u>			<u>18</u>	
<u>-021CF-25A</u>				<u>6:40</u>	<u>1</u>			<u>19</u>	
<u>-022CF-25A</u>								<u>20</u>	

\*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

**Section F**

**Relinquish/Receive**

Relinquished By: <u>[Signature]</u>	Sign	Print	Date	Time
Received By: <u>[Signature]</u>		<u>Stere Lambert</u>	<u>11-19-25</u>	<u>9:13</u>
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory: <u>[Signature]</u>		<u>Ashley Spigelberg</u>	<u>11/19/25</u>	<u>9:13</u>

**Section G**

**Lab Use Only**

Temp: Amb IR Therm ID: NA  
 ≤6°C:  Yes  No  
 Received on Ice:  Yes  No  
 Number of Bottles Received: \_\_\_\_\_  
 pH Checked:   
 COC Seals Intact:  Yes  No  NA  
 Field Blank Included:  Yes  No  
 Received Via  UPS  FedEx  Other  Hand  
 Payment:  Invoice  Cash  VISA, M/C  Check # \_\_\_\_\_ Amount \_\_\_\_\_

**Section A**

**Required Client Information**

Company: JCS D9  
 Address: P.O. BOX 548  
Eagle Point, OR 97524  
 Email: \_\_\_\_\_  
 Phone: 830-6378 Fax: \_\_\_\_\_  
 Collected By (Print): Steve Lambert  
 Collected By (Sign): [Signature]  
 Email Report  Mail Report  Fax Report

**Section B**

**Required Project Information**

Project Name: WMMS  
 Project Number: 20434021  
 Report To: \_\_\_\_\_  
 Copy To: \_\_\_\_\_

**Section C**

**Invoice Information**

Attention: John Harding  
 Company Name: JCS D9  
 Address: P.O. Box 548  
Eagle Point, OR 97524  
 P.O. # \_\_\_\_\_

**Section D**

**Rush Status (Subject to Scheduling)**

Standard: 10 Business Days  
 Priority: 5 Business Days (List x 1.50)  
 Express: 3 Business Days (List x 1.75)  
 Rush: 2 Business Days (List x 2.00)  
 Rush: 1 Business Day (List x 2.50)  
 Rush: Same Day (List x 3.00)  
 Authorized  Yes  No

**Section E**

**Sample Information**

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	Remarks / Field Data	NRC Sample # Use Only	(Lab)
<u>20434021-022CF-25A</u>			<u>11-19-25</u>	<u>6:40</u>	<u>1</u>	<u>LEAD</u>				
<u>-023CF-25A</u>				<u>6:39</u>	<u>1</u>				<u>21</u>	
<u>-024KF-25A</u>				<u>6:33</u>	<u>1</u>				<u>22</u>	
<u>-025KF-25A</u>				<u>6:30</u>	<u>1</u>				<u>23</u>	
<u>-026KF-25A</u>				<u>6:30</u>	<u>1</u>				<u>24</u>	
<u>-027KF-25A</u>				<u>6:31</u>	<u>1</u>				<u>25</u>	
<u>-028KF-25A</u>				<u>6:32</u>	<u>1</u>				<u>26</u>	
<u>-029BF-25A</u>				<u>6:37</u>	<u>1</u>				<u>27</u>	
<u>-030BF-25A</u>				<u>6:23</u>	<u>1</u>				<u>28</u>	
<u>-031BF-25A</u>				<u>6:26</u>	<u>1</u>				<u>29</u>	
									<u>30</u>	

\*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

**Section F**

**Relinquish/Receive**

Relinquished By: <u>[Signature]</u>	Sign	Print	Date	Time
Received By: _____		<u>Steve Lambert</u>	<u>11-19-25</u>	<u>9:13</u>
Relinquished By: _____				
Received By: _____				
Relinquished By: _____				
Received By Laboratory: <u>[Signature]</u>		<u>Ashley Spiegelberg</u>	<u>11/19/25</u>	<u>9:13</u>

**Section G**

**Lab Use Only**

Temp: Amb IR Therm ID: NA  
 ≤6°C:  Yes  No  
 Received on Ice:  Yes  No  
 Number of Bottles Received: \_\_\_\_\_  
 pH Checked: \_\_\_\_\_  
 COC Seals Intact:  Yes  No  NA  
 Field Blank Included:  Yes  No  
 Received Via  UPS  FedEx  Other  Hand  
 Payment:  Invoice  Cash  VISA, M/C  Check # \_\_\_\_\_ Amount \_\_\_\_\_

**Chain of Custody Record**

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

**Section A**

**Required Client Information**

Company: JCS D9  
 Address: P.O. BOX 548  
Eagle Point, OR 97524  
 Email: \_\_\_\_\_  
 Phone: 830-6378 Fax: \_\_\_\_\_  
 Collected By (Print): Steve Lambert  
 Collected By (Sign): [Signature]  
 Email Report  Mail Report  Fax Report

**Section B**

**Required Project Information**

Project Name: WMMMS  
 Project Number: 20434021  
 Report To: \_\_\_\_\_  
 Copy To: \_\_\_\_\_

**Section C**

**Invoice Information**

Attention: John Harding  
 Company Name: JCS D9  
 Address: P.O. Box 548  
Eagle Point, OR 97524  
 P.O. # \_\_\_\_\_

**Section D**

**Rush Status (Subject to Scheduling)**

Standard: 10 Business Days  
 Priority: 5 Business Days (List x 1.50)  
 Express: 3 Business Days (List x 1.75)  
 Rush: 2 Business Days (List x 2.00)  
 Rush: 1 Business Day (List x 2.50)  
 Rush: Same Day (List x 3.00)  
 Authorized  Yes  No

**Section E**

**Sample Information**

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	NRC Sample # (Lab Use Only)	(Lab)
<u>20434021-032BF-25A</u>			<u>11-19-25</u>	<u>6:24</u>	<u>1</u>	<u>LEAD</u>	<u>25110893</u>		
<u>-033BF-25A</u>				<u>6:22</u>	<u>1</u>				
<u>-034BF-25A</u>				<u>6:21</u>	<u>1</u>				
<u>-035BF-25A</u>				<u>6:30</u>	<u>1</u>				
<u>036NS-25A</u>				<u>6:33</u>	<u>1</u>				
<u>-037BF-25A</u>				<u>6:35</u>	<u>1</u>				
<u>-038BF-25A</u>				<u>6:39</u>	<u>1</u>				
<u>-039CF-25A</u>				<u>6:39</u>	<u>1</u>				
<u>-040BF-25A</u>				<u>6:43</u>	<u>1</u>				
<u>-041BF-25A</u>				<u>6:45</u>	<u>1</u>				

\*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

**Section F**

**Relinquish/Receive**

Relinquished By: <u>[Signature]</u>	Sign	Print	Date	Time
Received By:		<u>Steve Lambert</u>	<u>11-19-25</u>	<u>9:13</u>
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:		<u>Ashley Spiegelberg</u>	<u>11/19/25</u>	<u>9:13</u>

**Section G**

**Lab Use Only**

Temp: Amb IR Therm ID: NA  
 ≤6°C:  Yes  No  
 Received on Ice:  Yes  No  
 Number of Bottles Received: \_\_\_\_\_  
 pH Checked: \_\_\_\_\_  
 COC Seals Intact:  Yes  No  NA  
 Field Blank Included:  Yes  No  
 Received Via  UPS  FedEx  Other  Hand  
 Payment:  Invoice  Cash  VISA, M/C  Check # \_\_\_\_\_ Amount \_\_\_\_\_



**Section A  
Required Client Information**

Company: JCSDA  
 Address: P.O. BOX 548  
Eagle Point, OR 97524  
 Email: \_\_\_\_\_  
 Phone: 830-6378 Fax: \_\_\_\_\_  
 Collected By (Print): Steve Lambert  
 Collected By (Sign): [Signature]  
 Email Report  Mail Report  Fax Report

**Section B  
Required Project Information**

Project Name: WMMS  
 Project Number: 20434021  
 Report To: \_\_\_\_\_  
 Copy To: \_\_\_\_\_

**Section C  
Invoice Information**

Attention: John Harding  
 Company Name: JCSDA  
 Address: P.O. Box 548  
Eagle Point, OR 97524  
 P.O. # \_\_\_\_\_

**Section D  
Rush Status (Subject to Scheduling)**

Standard: 10 Business Days  
 Priority: 5 Business Days (List x 1.50)  
 Express: 3 Business Days (List x 1.75)  
 Rush: 2 Business Days (List x 2.00)  
 Rush: 1 Business Day (List x 2.50)  
 Rush: Same Day (List x 3.00)

Authorized  Yes  No

**Section E  
Sample Information**

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	LEAD
<u>20434021-050BF-25A</u>			<u>11.19.25</u>	<u>6:29</u>	<u>1</u>	<u>X</u>
<u>-051BF-25A</u>				<u>6:30</u>	<u>1</u>	<u>X</u>
<u>-052BF-25A</u>				<u>6:31</u>	<u>1</u>	<u>X</u>
<u>-053BF-25A</u>				<u>6:25</u>	<u>1</u>	<u>X</u>
<u>-054BF-25A</u>				<u>6:27</u>	<u>1</u>	<u>X</u>
<u>-055BF-25A</u>				<u>6:28</u>	<u>1</u>	<u>X</u>
<u>-056BF-25A</u>					<u>1</u>	<u>X</u>
<u>-057BF-25A</u>					<u>1</u>	<u>X</u>
<u>-058CF-25A</u>				<u>6:37</u>	<u>1</u>	<u>X</u>
<u>-059CF-25A</u>				<u>6:56</u>	<u>1</u>	<u>X</u>

**Analysis Requested**

| Analysis Requested |
|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|
|                    |                    |                    |                    |                    |                    |                    |                    |                    |                    |

NRC Workorder # 25110893  
 (Lab Use Only) 25110839 error 2 DE  
 Remarks / Field Data \_\_\_\_\_  
 NRC Sample # 11/19/25  
 (Lab Use Only)

51  
52  
53  
54  
55  
56  
57  
58

**Section F  
Relinquish/Receive**

Relinquished By	Print	Date	Time
<u>[Signature]</u>	<u>Steve Lambert</u>	<u>11.19.25</u>	<u>7:13</u>
Received By:			
Relinquished By:			
Received By:			
Relinquished By:			
Received By Laboratory:	<u>Ashley Spiegelberg</u>	<u>11/19/25</u>	<u>9:13</u>

**Section G  
Lab Use Only**

Temp: AWD IR Therm ID: WA  
 ≤6°C:  Yes  No  
 Received on Ice:  Yes  No  
 Number of Bottles Received: \_\_\_\_\_  
 pH Checked: \_\_\_\_\_  
 COC Seals Intact:  Yes  No  NA  
 Field Blank Included:  Yes  No

Received Via  UPS  FedEx  Other  Hand  
 Payment:  Invoice  Cash  VISA, M/C  Check # \_\_\_\_\_ Amount \_\_\_\_\_

**Section A**

**Required Client Information**

Company: JCS D9  
 Address: P.O. BOX 548  
Eagle Point, OR 97524  
 Email: \_\_\_\_\_  
 Phone: 830-6378 Fax: \_\_\_\_\_  
 Collected By (Print): Steve Lambert  
 Collected By (Sign): [Signature]  
 Email Report  Mail Report  Fax Report

**Section B**

**Required Project Information**

Project Name: WMMS  
 Project Number: 20434021  
 Report To: \_\_\_\_\_  
 Copy To: \_\_\_\_\_

**Section C**

**Invoice Information**

Attention: John Harding  
 Company Name: JCS D9  
 Address: P.O. Box 548  
Eagle Point, OR 97524  
 P.O. # \_\_\_\_\_

**Section D**

**Rush Status (Subject to Scheduling)**

Standard: 10 Business Days  
 Priority: 5 Business Days (List x 1.50)  
 Express: 3 Business Days (List x 1.75)  
 Rush: 2 Business Days (List x 2.00)  
 Rush: 1 Business Day (List x 2.50)  
 Rush: Same Day (List x 3.00)  
 Authorized  Yes  No

**Section E**

**Sample Information**

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	Remarks / Field Data	NRC Sample # Use Only	(Lab)
<u>20434021-060CF-25A</u>			<u>11.19.25</u>	<u>6:55</u>	<u>1</u>	<u>LEAD</u>	<u>25110893</u>			
<u>-061CF-25A</u>				<u>6:54</u>	<u>1</u>				<u>59</u>	
<u>-062CF-25A</u>				<u>6:53</u>	<u>1</u>				<u>60</u>	
<u>-063CF-25A</u>				<u>6:52</u>	<u>1</u>				<u>61</u>	
<u>-064CF-25A</u>				<u>7:02</u>	<u>1</u>				<u>62</u>	
<u>-065CF-25A</u>				<u>6:52</u>	<u>1</u>				<u>63</u>	
<u>-066CF-25A</u>				<u>6:39</u>	<u>1</u>				<u>64</u>	
<u>-067CF-25A</u>				<u>6:41</u>	<u>1</u>				<u>65</u>	
<u>-069CF-25A</u>				<u>7:00</u>	<u>1</u>				<u>66</u>	
									<u>67</u>	

\*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

**Section F**

**Relinquish/Receive**

Relinquished By:	Sign	Print	Date	Time
<u>[Signature]</u>	<u>[Signature]</u>	<u>Steve Lambert</u>	<u>11.19.25</u>	<u>9:13</u>
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	<u>[Signature]</u>	<u>Ashley Spigelberg</u>	<u>11/19/25</u>	<u>9:13</u>

**Section G**

**Lab Use Only**

Temp: Amb IR Therm ID: NA  
 ≤6°C:  Yes  No  
 Received on Ice:  Yes  No  
 Number of Bottles Received: \_\_\_\_\_  
 pH Checked:   
 COC Seals Intact:  Yes  No  NA  
 Field Blank Included:  Yes  No  
 Received Via  UPS  FedEx  Other  Hand  
 Payment:  Invoice  Cash  VISA, M/C  Check # \_\_\_\_\_ Amount \_\_\_\_\_

- 
- A Total Alkalinity and Bicarbonate Alkalinity results are to a pH endpoint of 4.5. Carbonate Alkalinity result is to a pH endpoint of 8.3.
- A-LL The total low level alkalinity results are to a pH endpoint of 4.3-4.7 pH units per SM 2320 B.
- B Analyte detected in the associated method blank.
- C Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
- C1 Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
- CF Results confirmed by re-analysis.
- CU Cleanup performed as specified by method.
- E Estimated value.
- ER Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
- FC Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
- HP Sample re-analysis performed outside of method specified holding time.
- HR Sample received outside of method specified holding time.
- HS Sample analyzed for volatile organics contained headspace.
- HT At the client's request, the sample was analyzed outside of method specified holding time.
- H Analysis performed outside of method specified holding time.
- J Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
- L Dissolved metals were not filtered within 15 minutes of collection per 40 CFR Part 136.
- MI Surrogate, Duplicate Sample (DUP) or Matrix Spikes recoveries are out of control limits due to matrix interference. Sample results may be biased.
- N See Case Narrative on page 2 of report.
- Q Initial calibration verification (ICV), continuing calibration verification (CCV) or laboratory control sample (LCS), and/or matrix spikes exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
- R Relative percent difference (RPD) is outside of the accepted recovery limits.
- R1 The numerical difference between the parent sample and the duplicate (DUP) is outside of the accepted recovery limits. Greater than 5 degrees for Flashpoint, or greater than 0.1 pH units for pH.
- R3 The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
- R4 The Relative percent difference (RPD) is not within control limits because the concentration of the sample result is too low to represent proper statistical error.
- R5 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30% because the results are too low to represent proper statistical error. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series. The sample results are not affected.
- R6 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30%. This may indicate a possible matrix interference. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series.
- S Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
- S1 Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
- SC Sub-contracted to another laboratory for analysis.
- SP Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
- \* Value exceeds Maximum Contaminant Level or is outside the acceptable range.<<>>
- 1 Value exceeds one half of the Maximum Contaminant Level.