



October 23, 2025

Service Request No:R2512668

Cory Stamp
Labella Associates, PC
300 State Street, 2nd Floor
Suite 201
Rochester, NY 14614

Laboratory Results for: Monroe 1 BOCES Bird Morgan

Dear Cory,

Enclosed are the results of the sample(s) submitted to our laboratory October 04, 2025
For your reference, these analyses have been assigned our service request number **R2512668**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

ADDRESS

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

PHONE +1 585 288 5380 | **FAX** +1 585 288 8475

ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan
Sample Matrix: Drinking Water

Service Request: R2512668
Date Received: 10/04/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty four drinking water samples were received for analysis at ALS Environmental on 10/04/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by _____

Date 10/23/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: BM-A105-1		Lab ID: R2512668-001					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.2			1.0	ug/L	200.8	
CLIENT ID: BM-B112-1		Lab ID: R2512668-004					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.3			1.0	ug/L	200.8	
CLIENT ID: BM-114-1		Lab ID: R2512668-006					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	8.9			1.0	ug/L	200.8	
CLIENT ID: BM-B116-1		Lab ID: R2512668-008					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.6			1.0	ug/L	200.8	
CLIENT ID: BM-B104-1		Lab ID: R2512668-012					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.4			1.0	ug/L	200.8	
CLIENT ID: BM-BOO3B-1		Lab ID: R2512668-013					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.6			1.0	ug/L	200.8	
CLIENT ID: BM-BOO3B-2		Lab ID: R2512668-014					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	8.7			1.0	ug/L	200.8	
CLIENT ID: BM-B009-1		Lab ID: R2512668-017					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.3			1.0	ug/L	200.8	
CLIENT ID: BM-B008-1		Lab ID: R2512668-019					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.6			1.0	ug/L	200.8	
CLIENT ID: BM-B006-1		Lab ID: R2512668-020					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.9			1.0	ug/L	200.8	
CLIENT ID: BM-M009-1		Lab ID: R2512668-025					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.7			1.0	ug/L	200.8	
CLIENT ID: BM-M011-2		Lab ID: R2512668-027					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.11			0.50	ug/L	200.8	



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: BM-M016-1	Lab ID: R2512668-029					
-----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	26.3			1.0	ug/L	200.8

CLIENT ID: BM-M016A-1	Lab ID: R2512668-031					
------------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.8			1.0	ug/L	200.8

CLIENT ID: BM-M016A-2	Lab ID: R2512668-032					
------------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.6			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288

Service Request:R2512668

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2512668-001	BM-A105-1	10/2/2025	0600
R2512668-002	BM-A105A-1	10/2/2025	0601
R2512668-003	BM-A105A-2	10/2/2025	0602
R2512668-004	BM-B112-1	10/2/2025	0604
R2512668-005	BM-B112-2	10/2/2025	0605
R2512668-006	BM-114-1	10/2/2025	0608
R2512668-007	BM-D-1	10/2/2025	0609
R2512668-008	BM-B116-1	10/2/2025	0610
R2512668-009	BM-B109-1	10/2/2025	0612
R2512668-010	BM-B110-1	10/2/2025	0614
R2512668-011	BM-B111-1	10/2/2025	0615
R2512668-012	BM-B104-1	10/2/2025	0620
R2512668-013	BM-BOO3B-1	10/2/2025	0624
R2512668-014	BM-BOO3B-2	10/2/2025	0625
R2512668-016	BM-A-1	10/2/2025	0630
R2512668-017	BM-B009-1	10/2/2025	0632
R2512668-018	BM-A-2	10/2/2025	0634
R2512668-019	BM-B008-1	10/2/2025	0636
R2512668-020	BM-B006-1	10/2/2025	0637
R2512668-021	BM-ACAF-2	10/2/2025	0641
R2512668-022	BM-ACAF-1	10/2/2025	0640
R2512668-023	BM-M007-1	10/2/2025	0642
R2512668-024	BM-J-1	10/2/2025	0645
R2512668-025	BM-M009-1	10/2/2025	0647
R2512668-026	BM-M011-1	10/2/2025	0649
R2512668-027	BM-M011-2	10/2/2025	0650
R2512668-028	BM-L-1	10/2/2025	0651
R2512668-029	BM-M016-1	10/2/2025	0658
R2512668-030	BM-M016-2	10/2/2025	0659
R2512668-031	BM-M016A-1	10/2/2025	0656
R2512668-032	BM-M016A-2	10/2/2025	0657
R2512668-033	BM-N-1	10/2/2025	0654
R2512668-034	BM-M-1	10/2/2025	0653



ALS Environmental

Laboratory location:
Rochester NY

Chain of Custody Form

Page 1 of

ALS Project Manager:						Work Order #:													
Customer Information			Project Information				Parameter/Method Request for Analysis												
Purchase Order			Project Name	Monroe 1 BOCES		A	EPA 200.8 Lead in Drinking Water												
Work Order			Project Number	2254288		B													
Company Name	LaBella Associates		Bill To Company	LaBella Associates		C													
Send Report To	Cory Stamp		Invoice Attn:	Cory Stamp		D													
Address	300 State Street, Suite 200		Address	300 State Street, Suite 200		E													
						F													
City/State/Zip	Rochester, NY 14614		City/State/Zip	Rochester, NY 14614		G													
Phone	(607) 591-7516		Phone	(607) 591-7516		H													
Fax			Fax			I													
e-Mail Address	cstamp@labellapc.com		e-Mail Address	cstamp@labellapc.com		J													
No.	Sample Description		Date	Time	Matrix	Pres.	# Bottles	A	B	C	D	E	F	G	H	I	J	Hold	
1	See attached spreadsheets for sample					N/A		X											
2	descriptions. All samples are 250 mL					N/A		X											
3	plastic bottles, drinking water, with					N/A		X											
4	no preservative																		
5																			
6																			
7																			
8																			
9																			
10																			
Sampler(s): Please Print & Sign <i>Cory Stamp</i>			Shipment Method: Delivered		Required Turnaround Time: <input checked="" type="checkbox"/> STD 10 Wk Days <input type="checkbox"/> 5 Wk Days <input type="checkbox"/> 2 Wk Days <input type="checkbox"/> 24 Hour				Results Due Date:										
Relinquished by:		Date:	Time:	Received by:		Notes:													
Relinquished by: <i>[Signature]</i>		Date: 10/4/25	Time: 9:22	Received by (Laboratory): <i>[Signature]</i>		Cooler Temp.	QC Package: (Check Box Below)												
Logged by (Laboratory):		Date:	Time:	Checked by (Laboratory):			Level II: Standard QC		TRRP-Checklist		Level III: Std QC + Raw Data		TRRP Level IV		Level IV: SW846 CLP-Like				
Preservative Key: 1-HCL 2-HNO3 3-H2SO4 4-NaOH 5-Na2S2O3 6-NaHSO4 7-Other 8-4 degrees C 9-5035						Other:													

Note: Any changes must be made in writing once samples and COC Form have been submitted to ALS Laboratory Group.
 Signature denotes acceptance of ALS Group USA, Corp. Terms and Conditions - Please click the link below for detailed Terms & Conditions:
<https://www.alsglobal.com/ALSGroupUSACorpTC>
 ALS copyright © 2024. All rights reserved.

R2512668 **5**
 LaBella Associates, PC
 Monroe 1 BOCES Bldg Morgan

**Monroe One BOCES
Bird Morgan School
108-120 East Ave, East Rochester, NY 14445**

NYS Action Level
> 5 ppb

Testing
Date:
10/2/2025

Building	Bldg Area	Room	Room Description	Fixture	Fixture Class	Test	Chain of Custody Sample Number	Result Lead ppb	Lab Sample ID	Report Page #	Time Sampled
Bird Morgan	1	A105	Conference Rm	Kitchen Sink	Drink	1	BM-A105-1				6:00:00 AM
Bird Morgan	1	A105A	Office Work Area	Kitchen Sink	Drink	1	BM-A105A-1				6:01:00 AM
Bird Morgan	1	A105A	Office Work Area	Water Dispenser	Drink	1	BM-A105A-2				6:02:00 AM
Bird Morgan	1	B112	Health Suite Front	Kitchen sink, 1 Faucet	Drink	1	BM-B112-1				6:04:00 AM
Bird Morgan	1	B112	Health Suite Side	Kitchen sink, 1 Faucet	Drink	1	BM-B112-2				6:05:00 AM
Bird Morgan	1	B114	Classroom	Bathroom Sink	Drink	1	BM-B114-1				6:08:00 AM
Bird Morgan	1	D Hall	D Hall by B115	Drinking Fountain	Drink	1	BM-D-1				6:09:00 AM
Bird Morgan	1	B116	Classroom	Kitchen Sink	Drink	1	BM-B116-1				6:10:00 AM
Bird Morgan	1	B109	Classroom	Kitchen Sink	Drink	1	BM-B109-1				6:12:00 AM
Bird Morgan	1	B110	Classroom	Kitchen Sink	Drink	1	BM-B110-1				6:14:00 AM
Bird Morgan	1	B111	Classroom	Kitchen Sink	Drink	1	BM-B111-1				6:15:00 AM
Bird Morgan	1	B104	Classroom	Kitchen Sink	Drink	1	BM-B104-1				6:20:00 AM

A105



Cooler Receipt and Preservation Check Form

R2512668

5

Labella Associates, PC
Monroe 1 BOCES Bird Morgan



Project/Client _____ Folder Number _____

Cooler received on 10/4/25 by: MM COURIER: ALS UPS FEDEX VELOCITY CLIENT

1. Were Custody seals on outside of cooler?	Y <input checked="" type="radio"/> N <input type="radio"/>	5a Did VOA vials have sig* bubbles?	Y <input type="radio"/> N <input checked="" type="radio"/> NA <input type="radio"/>
2. Custody papers properly completed (ink, signed)?	Y <input checked="" type="radio"/> N <input type="radio"/>	5b Sig* bubbles: Alk? Y <input type="radio"/> N <input checked="" type="radio"/> NA <input type="radio"/> Sulfide? Y <input type="radio"/> N <input checked="" type="radio"/> NA <input type="radio"/>	
3. Did all bottles arrive in good condition (unbroken)?	Y <input checked="" type="radio"/> N <input type="radio"/>	6 Where did the bottles originate?	<u>ALS/ROC</u> <u>CLIENT</u>
4. Circle: Wet Ice Dry Ice Gel packs present?	Y <input type="radio"/> N <input checked="" type="radio"/>	7 Soil VOA received as:	Bulk Encore 5035set <u>NA</u>

8. Temperature Readings Date: 10/4/25 Time: 9:28 ID: IR#12 IR#11 From: Temp Blank Sample Bottle

Temp (°C)	<u>17.3</u>						
Within 0-6°C?	Y <input checked="" type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>
If <0°C, were samples frozen?	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>

If out of Temperature, note packing/ice condition: No Ice Packed Ice melted Poorly Packed (described below) Same Day Rule
& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMA by MM on 10/4/25 at 9:35
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 10/7/25 Time: 0835 by: TOP

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO N/A
- 13. Were dissolved metals filtered in the field? YES NO N/A
- 14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
<2	<u>202325</u>	HNO ₃	<input checked="" type="checkbox"/>				<u>911</u>	<u>4mL</u>		<u>2.2</u>
<2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: 051225-2ADD
Explain all Discrepancies/ Other Comments:

9,10) sample - 015 missing; canceled

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: TOP *significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288

Service Request: R2512668

Sample Name: BM-A105-1
Lab Code: R2512668-001
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-A105A-1
Lab Code: R2512668-002
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-A105A-2
Lab Code: R2512668-003
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-B112-1
Lab Code: R2512668-004
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-B112-2
Lab Code: R2512668-005
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288

Service Request: R2512668

Sample Name: BM-114-1
Lab Code: R2512668-006
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-D-1
Lab Code: R2512668-007
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-B116-1
Lab Code: R2512668-008
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-B109-1
Lab Code: R2512668-009
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-B110-1
Lab Code: R2512668-010
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288

Service Request: R2512668

Sample Name: BM-B111-1
Lab Code: R2512668-011
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-B104-1
Lab Code: R2512668-012
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-BOO3B-1
Lab Code: R2512668-013
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-BOO3B-2
Lab Code: R2512668-014
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-A-1
Lab Code: R2512668-016
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288

Service Request: R2512668

Sample Name: BM-B009-1
Lab Code: R2512668-017
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-A-2
Lab Code: R2512668-018
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-B008-1
Lab Code: R2512668-019
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-B006-1
Lab Code: R2512668-020
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-ACAF-2
Lab Code: R2512668-021
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288

Service Request: R2512668

Sample Name: BM-ACAF-1
Lab Code: R2512668-022
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-M007-1
Lab Code: R2512668-023
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-J-1
Lab Code: R2512668-024
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-M009-1
Lab Code: R2512668-025
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-M011-1
Lab Code: R2512668-026
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288

Service Request: R2512668

Sample Name: BM-M011-2
Lab Code: R2512668-027
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By
GCONSTANTINO

Analyzed By
NMANSEN

Sample Name: BM-L-1
Lab Code: R2512668-028
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-M016-1
Lab Code: R2512668-029
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-M016-2
Lab Code: R2512668-030
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-M016A-1
Lab Code: R2512668-031
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288

Service Request: R2512668

Sample Name: BM-M016A-2
Lab Code: R2512668-032
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-N-1
Lab Code: R2512668-033
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-M-1
Lab Code: R2512668-034
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-A105-1
Lab Code: R2512668-001

Service Request: R2512668
Date Collected: 10/02/25 06:00
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.2	ug/L	1.0	1	10/20/25 16:32	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-A105A-1
Lab Code: R2512668-002

Service Request: R2512668
Date Collected: 10/02/25 06:01
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 16:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-A105A-2
Lab Code: R2512668-003

Service Request: R2512668
Date Collected: 10/02/25 06:02
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 16:34	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-B112-1
Lab Code: R2512668-004

Service Request: R2512668
Date Collected: 10/02/25 06:04
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	10/20/25 16:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-B112-2
Lab Code: R2512668-005

Service Request: R2512668
Date Collected: 10/02/25 06:05
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 16:48	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-114-1
Lab Code: R2512668-006

Service Request: R2512668
Date Collected: 10/02/25 06:08
Date Received: 10/04/25 09:22

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	8.9	ug/L	1.0	1	10/20/25 16:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-D-1
Lab Code: R2512668-007

Service Request: R2512668
Date Collected: 10/02/25 06:09
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 16:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-B116-1
Lab Code: R2512668-008

Service Request: R2512668
Date Collected: 10/02/25 06:10
Date Received: 10/04/25 09:22

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.6	ug/L	1.0	1	10/20/25 16:52	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-B109-1
Lab Code: R2512668-009

Service Request: R2512668
Date Collected: 10/02/25 06:12
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 16:54	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-B110-1
Lab Code: R2512668-010

Service Request: R2512668
Date Collected: 10/02/25 06:14
Date Received: 10/04/25 09:22

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 16:58	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-B111-1
Lab Code: R2512668-011

Service Request: R2512668
Date Collected: 10/02/25 06:15
Date Received: 10/04/25 09:22

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 16:59	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-B104-1
Lab Code: R2512668-012

Service Request: R2512668
Date Collected: 10/02/25 06:20
Date Received: 10/04/25 09:22

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.4	ug/L	1.0	1	10/20/25 17:01	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-BOO3B-1
Lab Code: R2512668-013

Service Request: R2512668
Date Collected: 10/02/25 06:24
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.6	ug/L	1.0	1	10/20/25 17:02	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-BOO3B-2
Lab Code: R2512668-014

Service Request: R2512668
Date Collected: 10/02/25 06:25
Date Received: 10/04/25 09:22

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	8.7	ug/L	1.0	1	10/20/25 17:04	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-A-1
Lab Code: R2512668-016

Service Request: R2512668
Date Collected: 10/02/25 06:30
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 17:05	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-B009-1
Lab Code: R2512668-017

Service Request: R2512668
Date Collected: 10/02/25 06:32
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.3	ug/L	1.0	1	10/20/25 17:06	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-A-2
Lab Code: R2512668-018

Service Request: R2512668
Date Collected: 10/02/25 06:34
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 17:08	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-B008-1
Lab Code: R2512668-019

Service Request: R2512668
Date Collected: 10/02/25 06:36
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.6	ug/L	1.0	1	10/20/25 17:09	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-B006-1
Lab Code: R2512668-020

Service Request: R2512668
Date Collected: 10/02/25 06:37
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.9	ug/L	1.0	1	10/20/25 17:11	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-ACAF-2
Lab Code: R2512668-021

Service Request: R2512668
Date Collected: 10/02/25 06:41
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 17:15	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-ACAF-1
Lab Code: R2512668-022

Service Request: R2512668
Date Collected: 10/02/25 06:40
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 17:16	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-M007-1
Lab Code: R2512668-023

Service Request: R2512668
Date Collected: 10/02/25 06:42
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 17:18	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-J-1
Lab Code: R2512668-024

Service Request: R2512668
Date Collected: 10/02/25 06:45
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 17:19	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-M009-1
Lab Code: R2512668-025

Service Request: R2512668
Date Collected: 10/02/25 06:47
Date Received: 10/04/25 09:22

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.7	ug/L	1.0	1	10/20/25 17:29	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-M011-1
Lab Code: R2512668-026

Service Request: R2512668
Date Collected: 10/02/25 06:49
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 17:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-M011-2
Lab Code: R2512668-027

Service Request: R2512668
Date Collected: 10/02/25 06:50
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	2.11	ug/L	0.50	1	10/21/25 14:24	10/20/25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-L-1
Lab Code: R2512668-028

Service Request: R2512668
Date Collected: 10/02/25 06:51
Date Received: 10/04/25 09:22

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 17:34	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-M016-1
Lab Code: R2512668-029

Service Request: R2512668
Date Collected: 10/02/25 06:58
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	26.3	ug/L	1.0	1	10/20/25 17:36	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-M016-2
Lab Code: R2512668-030

Service Request: R2512668
Date Collected: 10/02/25 06:59
Date Received: 10/04/25 09:22

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 17:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-M016A-1
Lab Code: R2512668-031

Service Request: R2512668
Date Collected: 10/02/25 06:56
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.8	ug/L	1.0	1	10/20/25 17:39	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-M016A-2
Lab Code: R2512668-032

Service Request: R2512668
Date Collected: 10/02/25 06:57
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.6	ug/L	1.0	1	10/20/25 17:43	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-N-1
Lab Code: R2512668-033

Service Request: R2512668
Date Collected: 10/02/25 06:54
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 17:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-M-1
Lab Code: R2512668-034

Service Request: R2512668
Date Collected: 10/02/25 06:53
Date Received: 10/04/25 09:22

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 17:46	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2512668-MB1

Service Request: R2512668
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	0.50 U	ug/L	0.50	1	10/21/25 14:21	10/20/25	
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 15:57	NA	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2512668-MB2

Service Request: R2512668
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 16:41	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2512668-MB3

Service Request: R2512668
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 17:26	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water

Service Request: R2512668
Date Collected: 10/02/25
Date Received: 10/04/25
Date Analyzed: 10/20/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: BM-A105A-2
Lab Code: R2512668-003
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2512668-003MS		Result	Duplicate Matrix Spike R2512668-003DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.0 U	18.5	20.0	93	18.1	20.0	91	70-130	2	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water

Service Request: R2512668
Date Collected: 10/02/25
Date Received: 10/04/25
Date Analyzed: 10/20/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: BM-B112-1
Lab Code: R2512668-004
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2512668-004MS		Result	Duplicate Matrix Spike R2512668-004DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.3	19.7	20.0	92	21.3	20.0	100	70-130	8	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water

Service Request: R2512668
Date Collected: 10/02/25
Date Received: 10/04/25
Date Analyzed: 10/20/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: BM-J-1
Lab Code: R2512668-024
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2512668-024MS		Duplicate Matrix Spike R2512668-024DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	1.0 U	20.9	20.0	104	20.0	20.0	100	70-130	4	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water

Service Request: R2512668
Date Collected: 10/02/25
Date Received: 10/04/25
Date Analyzed: 10/20/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: BM-M009-1
Lab Code: R2512668-025
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2512668-025MS		Result	Duplicate Matrix Spike R2512668-025DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	2.7	22.5	20.0	99	21.8	20.0	96	70-130	3	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water

Service Request: R2512668
Date Analyzed: 10/20/25 - 10/21/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2512668-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.7	20.0	103	85-115
Lead, Total	200.8	19.4	20.0	97	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water

Service Request: R2512668
Date Analyzed: 10/20/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2512668-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	18.8	20.0	94	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water

Service Request: R2512668

Date Analyzed: 10/20/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample
R2512668-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	22.1	20.0	110	85-115



October 23, 2025

Service Request No:R2512669

Cory Stamp
Labella Associates, PC
300 State Street, 2nd Floor
Suite 201
Rochester, NY 14614

Laboratory Results for: Monroe 1 BOCES Bird Morgan

Dear Cory,

Enclosed are the results of the sample(s) submitted to our laboratory October 04, 2025
For your reference, these analyses have been assigned our service request number **R2512669**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

ADDRESS

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

PHONE +1 585 288 5380 | **FAX** +1 585 288 8475

ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan
Sample Matrix: Drinking Water

Service Request: R2512669
Date Received: 10/04/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Fifteen drinking water samples were received for analysis at ALS Environmental on 10/04/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by _____

Date 10/23/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: BM-M109-1	Lab ID: R2512669-002					
-----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	4.9			1.0	ug/L	200.8

CLIENT ID: BM-M209-1	Lab ID: R2512669-007					
-----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.4			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288

Service Request:R2512669

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2512669-001	BM-R-1	10/2/2025	0730
R2512669-002	BM-M109-1	10/2/2025	0731
R2512669-003	BM-Q-1	10/2/2025	0723
R2512669-004	BM-P-1	10/2/2025	0721
R2512669-005	BM-M104-1	10/2/2025	0720
R2512669-006	BM-W-1	10/2/2025	0734
R2512669-007	BM-M209-1	10/2/2025	0732
R2512669-008	BM-V-1	10/2/2025	0736
R2512669-009	BM-M204-1	10/2/2025	0739
R2512669-010	BM-U-1	10/2/2025	0738
R2512669-011	BM-B204-1	10/2/2025	0707
R2512669-012	BM-H-1	10/2/2025	0710
R2512669-013	BM-B208-1	10/2/2025	0716
R2512669-014	BM-B209-1	10/2/2025	0713
R2512669-015	BM-I-1	10/2/2025	0711



ALS Environmental

Laboratory location: Rochester NY

Chain of Custody Form

Page 1 of

ALS Project Manager:						Work Order #:											
Customer Information			Project Information			Parameter/Method Request for Analysis											
Purchase Order		Project Name	Monroe 1 BOCES			A	EPA 200.8 Lead in Drinking Water										
Work Order		Project Number	2254288			B											
Company Name	LaBella Associates	Bill To Company	LaBella Associates			C											
Send Report To	Cory Stamp	Invoice Attn:	Cory Stamp			D											
Address	300 State Street, Suite 200	Address	300 State Street, Suite 200			E											
						F											
City/State/Zip	Rochester, NY 14614	City/State/Zip	Rochester, NY 14614			G											
Phone	(607) 591-7516	Phone	(607) 591-7516			H											
Fax		Fax				I											
e-Mail Address	cstamp@labellapc.com	e-Mail Address	cstamp@labellapc.com			J											
No.	Sample Description	Date	Time	Matrix	Pres.	# Bottles	A	B	C	D	E	F	G	H	I	J	Hold
1	See attached spreadsheets for sample descriptions. All samples are 250 mL plastic bottles, drinking water, with no preservative				N/A		X										
2					N/A		X										
3						N/A		X									
4																	
5																	
6																	
7																	
8																	
9																	
10																	
Sampler(s): Please Print & Sign <i>Cory Stamp</i>			Shipment Method: Delivered		Required Turnaround Time: <input checked="" type="checkbox"/> STD 10 Wk Days <input type="checkbox"/> 5 Wk Days <input type="checkbox"/> 2 Wk Days <input type="checkbox"/> 24 Hour				Other _____				Results Due Date:				
Relinquished by:		Date:	Time:	Received by:		Notes:											
Relinquished by:		Date:	Time:	Received by (Laboratory):		Cooler Temp.		QC Package: (Check Box Below)									
Signed by (Laboratory):		Date:	Time:	Checked by (Laboratory):				Level II: Standard QC			Level III: Std QC + Raw Data			Level IV: SW846 CLP-Like			
Preservative Key: 1-HCL 2-HNO3 3-H2SO4 4-NaOH 5-Na2S2O3 6-NaHSO4 7-Other 8-4 degrees C 9-8038						Otl		R2512669				5					

Note: Any changes must be made in writing once samples and COC Form have been submitted to ALS Laboratory Group.
 Signature denotes acceptance of ALS Group USA, Corp. Terms and Conditions - Please click the link below for detailed Terms & Conditions:
<https://www.alsglobal.com/ALSGroupUSACorpTC>
 ALS copyright © 2024. All rights reserved.

Labella Associates, PC
 Monroe 1 BOCES Blvd Morgan

Monroe One BOCES Bird Morgan School 108-120 East Ave, East Rochester, NY 14445							NYS Action Level > 5 ppb			Testing Date: 10/2/2025	
Building	Bldg Area	Room	Room Description	Fixture	Fixture Class	Test	Chain of Custody Sample Number	Result Lead ppb	Lab Sample ID	Report Page #	Time Sampled
Bird Morgan	1	R Hall	R Hall by M108	Drinking Fountain	Drink	1	BM-R-1				7:30:00 AM
Bird Morgan	1	M109	Classroom	Kitchen Sink	Drink	1	BM-M109-1				7:31:00 AM
Bird Morgan	1	Q Hall	Q Hall by M106	Drinking Fountain	Drink	1	BM-Q-1				7:23:00 AM
Bird Morgan	1	P Hall	P Hall by M-T12	Drinking Fountain	Drink	1	BM-P-1				7:21:00 AM
Bird Morgan	1	M104	Classroom	Kitchen Sink	Drink	1	BM-M104-1				7:20:00 AM
Bird Morgan	2	W Hall	W Hall outside M210	Drinking Fountain	Drink	1	BM-W-1				7:34:00 AM
Bird Morgan	2	M209	Classroom	Kitchen Sink	Drink	1	BM-M209-1				7:32:00 AM
Bird Morgan	2	V Hall	V Hall outside M-T21	Drinking Fountain	Drink	1	BM-V-1				7:36:00 AM
Bird Morgan	2	M204	Classroom	Kitchen Sink	Drink	1	BM-M204-1				7:39:00 AM
Bird Morgan	2	U Hall	U Hall outside M205	Drinking Fountain	Drink	1	BM-U-1				7:38:00 AM
Bird Morgan	2	B204	Classroom	Kitchen Sink	Drink	1	BM-B204-1				7:07:00 AM
Bird Morgan	2	H Hall	H Hall across B211W	Drinking Fountain	Drink	1	BM-H-1				7:10:00 AM
Bird Morgan	2	B208	Classroom	Kitchen Sink	Drink	1	BM-B208-1				7:16:00 AM
Bird Morgan	2	B209	Classroom	Kitchen Sink	Drink	1	BM-B209-1				7:13:00 AM
Bird Morgan	2	I-Hall	I-Hall by B-T22	Drinking Fountain	Drink	1	BM-I-1				7:11:00 AM



R2512669

5

Labella Associates, PC
Monroe 1 BOCES Bird Morgan

Cooler Receipt and Preservation



Project/Client Labella Folder Number _____

Cooler received on 10/4/25 by: MM

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1. Were Custody seals on outside of cooler?	Y <input checked="" type="radio"/> N <input type="radio"/>	5a Did VOA vials have sig* bubbles?	Y N <input checked="" type="radio"/> NA <input type="radio"/>
2 Custody papers properly completed (ink, signed)?	Y <input checked="" type="radio"/> N <input type="radio"/>	5b Sig* bubbles: Alk? Y N <input checked="" type="radio"/> NA <input type="radio"/> Sulfide? Y N <input checked="" type="radio"/> NA <input type="radio"/>	
3 Did all bottles arrive in good condition (unbroken)?	Y <input checked="" type="radio"/> N <input type="radio"/>	6 Where did the bottles originate?	<u>ALS/ROC</u> <u>CLIENT</u>
4 Circle: Wet Ice Dry Ice Gel packs present?	Y <input checked="" type="radio"/> N <input type="radio"/>	7 Soil VOA received as: Bulk Encore 5035set	<input checked="" type="radio"/> NA <input type="radio"/>

8. Temperature Readings Date: 10/4/25 Time: 9:28 ID: IR#12 IR#11 From: Temp Blank Sample Bottle

Temp (°C)	<u>17.3</u>						
Within 0-6°C?	Y <input checked="" type="radio"/> N <input type="radio"/>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: No Ice needed Ice melted Poorly Packed (described below) Same Day Rule
& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMD by MM on 10/4/25 at 9:35
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 10/6 Time: 2:17 by: AG

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO N/A
- 13. Were dissolved metals filtered in the field? YES NO N/A
- 14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2		HNO ₃								
≤2	<u>202325</u>	H ₂ SO ₄		<u>x</u>			<u>All</u>	<u>4mL</u>		<u>≤2</u>
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: 051225-2A00
Explain all Discrepancies/ Other Comments:

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: AG *significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288

Service Request: R2512669

Sample Name: BM-R-1
Lab Code: R2512669-001
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-M109-1
Lab Code: R2512669-002
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-Q-1
Lab Code: R2512669-003
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-P-1
Lab Code: R2512669-004
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-M104-1
Lab Code: R2512669-005
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288

Service Request: R2512669

Sample Name: BM-W-1
Lab Code: R2512669-006
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-M209-1
Lab Code: R2512669-007
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-V-1
Lab Code: R2512669-008
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-M204-1
Lab Code: R2512669-009
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-U-1
Lab Code: R2512669-010
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288

Service Request: R2512669

Sample Name: BM-B204-1
Lab Code: R2512669-011
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-H-1
Lab Code: R2512669-012
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-B208-1
Lab Code: R2512669-013
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: BM-B209-1
Lab Code: R2512669-014
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By
GCONSTANTINO

Analyzed By
NMANSEN

Sample Name: BM-I-1
Lab Code: R2512669-015
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-R-1
Lab Code: R2512669-001

Service Request: R2512669
Date Collected: 10/02/25 07:30
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 17:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-M109-1
Lab Code: R2512669-002

Service Request: R2512669
Date Collected: 10/02/25 07:31
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.9	ug/L	1.0	1	10/20/25 17:48	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-Q-1
Lab Code: R2512669-003

Service Request: R2512669
Date Collected: 10/02/25 07:23
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 17:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-P-1
Lab Code: R2512669-004

Service Request: R2512669
Date Collected: 10/02/25 07:21
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 17:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-M104-1
Lab Code: R2512669-005

Service Request: R2512669
Date Collected: 10/02/25 07:20
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 17:53	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-W-1
Lab Code: R2512669-006

Service Request: R2512669
Date Collected: 10/02/25 07:34
Date Received: 10/04/25 09:22

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 17:54	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-M209-1
Lab Code: R2512669-007

Service Request: R2512669
Date Collected: 10/02/25 07:32
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.4	ug/L	1.0	1	10/20/25 17:55	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-V-1
Lab Code: R2512669-008

Service Request: R2512669
Date Collected: 10/02/25 07:36
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 18:00	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-M204-1
Lab Code: R2512669-009

Service Request: R2512669
Date Collected: 10/02/25 07:39
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 18:01	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-U-1
Lab Code: R2512669-010

Service Request: R2512669
Date Collected: 10/02/25 07:38
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 18:02	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-B204-1
Lab Code: R2512669-011

Service Request: R2512669
Date Collected: 10/02/25 07:07
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 18:04	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-H-1
Lab Code: R2512669-012

Service Request: R2512669
Date Collected: 10/02/25 07:10
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 18:14	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-B208-1
Lab Code: R2512669-013

Service Request: R2512669
Date Collected: 10/02/25 07:16
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 18:18	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-B209-1
Lab Code: R2512669-014

Service Request: R2512669
Date Collected: 10/02/25 07:13
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	0.50 U	ug/L	0.50	1	10/21/25 14:25	10/20/25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: BM-I-1
Lab Code: R2512669-015

Service Request: R2512669
Date Collected: 10/02/25 07:11
Date Received: 10/04/25 09:22
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 18:19	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2512669-MB1

Service Request: R2512669
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	0.50 U	ug/L	0.50	1	10/21/25 14:21	10/20/25	
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 17:26	NA	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2512669-MB2

Service Request: R2512669
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	10/20/25 18:11	

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water

Service Request: R2512669
Date Collected: 10/02/25
Date Received: 10/04/25
Date Analyzed: 10/20/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: BM-B204-1
Lab Code: R2512669-011
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2512669-011MS		Duplicate Matrix Spike R2512669-011DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	1.0 U	19.9	20.0	99	25.0	20.0	125	70-130	23*	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water

Service Request: R2512669
Date Collected: 10/02/25
Date Received: 10/04/25
Date Analyzed: 10/20/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: BM-H-1
Lab Code: R2512669-012
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2512669-012MS		Result	Duplicate Matrix Spike R2512669-012DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.0 U	19.7	20.0	98	23.3	20.0	116	70-130	17	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water

Service Request: R2512669
Date Analyzed: 10/20/25 - 10/21/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2512669-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.7	20.0	103	85-115
Lead, Total	200.8	22.1	20.0	110	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Labella Associates, PC
Project: Monroe 1 BOCES Bird Morgan/2254288
Sample Matrix: Drinking Water

Service Request: R2512669
Date Analyzed: 10/20/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2512669-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.0	20.0	100	85-115