Stohl ENVIRONMENTAL
BUFFALO ROCHESTER

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

December 10, 2025

Mr. Stephen Olson
Southwestern CSD
600 County Touring Rte 32
Jamestown, New York 14701

Re: Lead Testing in School Drinking Water

Dear Mr. Stephen Olson:

Included with this letter is Stohl Environmental LLC's report for the Lead in Drinking Water Sampling performed for Southwestern CSD, including:

- **Southwestern Elementary School – 600 County Touring Rte 32 #1, Jamestown, New York 14701**

This report is prepared to assist school districts in complying with the requirements of 10 NYCRR Subpart 67-4: *Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 5 parts per billion (ppb)".

Sampling was performed on October 30, 2025. As detailed in Section 1.2 *(Executive Summary)* of the accompanying report, based upon the sampling and analysis performed, 17 sources of potable water in Southwestern Elementary School have been identified as having lead concentrations in water above the NYS Action Level of 5 parts per billion. To comply with NYS regulations, response actions by the district are required. Response actions are outlined in Section 1.3 *(Response Actions Required Under NYS Regulations)*.

Thank you for the opportunity to be of service to Southwestern CSD.

Sincerely,
Stohl Environmental, LLC.

M. Scinta

Michael Scinta
EPA Lead Risk Assessor

Lead Testing in School Drinking Water

Prepared for:

Southwestern Central School District

Prepared by:

3860 California Road
Orchard Park, New York 14127

Conditions as of October 31, 2025

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

Summary Tabulation

Lead in Drinking Water Investigation

1.1. Scope of Work and Sampling Protocol

1.2. Executive Summary of Sampling and Analysis

1.3. Response Actions Required Under NYS Regulations

1.4. Laboratory Analytical Reports and Chain of Custody Documents

1.5. Laboratory Certifications

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Southwestern CSD to perform sampling and analysis of potable water for lead concentrations. Sampling was performed in the following building:

- **Southwestern Elementary School – 600 County Touring Rte 32 #1, Jamestown, New York 14701**

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within Southwestern Elementary School. Outlets are defined in NYS regulations as: "a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets".

Sampling Protocol:

In accordance with NYS regulations, ***Subpart 67-4: Lead Testing in School Drinking Water***, and the EPA guidance document, ***3Ts for Reducing Lead in Drinking Water in Schools***, Stohl Environmental's protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.

- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health's Environmental Laboratory Approval Program (ELAP).

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

1.2 Executive Summary of Sampling and Analysis:

Summary of Samples Collected at Southwestern Elementary School:

Building Name	Date of Sampling	Total Samples	At or Below Action Level*	Above Action Level*
Southwestern Elementary School	10/31/2025	137	120	17

**NYS Action Level is 5 parts per billion*

Listing of Outlets Requiring Remediation

The following outlets were analyzed above the NYS Action Level:

Sample #	Location	Fixture/Outlet type	Laboratory Analysis (in ppb)
173.3-7	C108 DF	DF	5.3
173.3-10	C111 DF	DF	8.2
173.3-30	D140 DF	DF	7.3
173.3-57	D161-Hall L Drinking Fountain near Restroom 162	DF	22.8
173.3-58	D161-Hall R DF	DF	52.8
173.3-62	C210 Nurse Rear Restroom	Sink	5.9
173.3-71	A309 DF	DF	13.4
173.3-72	A312 Music Classroom	Sink	5.7
173.3-116	D263 Art Classroom DF	DF	6.0
173.3-118	D266 DF	DF	5.9
173.3-123	D269 DF	DF	5.2
173.3-124	D270 Classroom	Sink	5.1
173.3-125	D270 DF	DF	9.7
173.3-126	D271 Classroom	Sink	6.4
173.3-130	D277 Classroom	Sink	8.0
173.3-132	A-120 Maintenance Breakroom	Sink	8.3
173.3-133	A-119-Hall Left Drinking Fountain Outside A119	DF	5.1

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration more than the NYS Action Level, regulations require:

(a) Prohibit use of the outlet until:

(1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and

(2) test results indicate that the lead levels are at or below the action level;

(b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;

(c) Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and

(d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

1.4 Laboratory Analytical Reports and Chain of Custody Documents

December 01, 2025 Service Request No:R2514810

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Southwestern CSD - Southwestern Elementary

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory November 05, 2025
For your reference, these analyses have been assigned our service request number **R2514810.**

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
PHONE +1 585 288 5380 | FAX +1 585 288 8475
ALS Group USA, Corp.
dba ALS Environmental

Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

1565 Jefferson Rd, Building 300, Rochester, NY 14623 | 585-288-5380 | www.alsglobal.com

Client: Stohl Environmental
Project: Southwestern CSD - Southwestern Elementary
Sample Matrix: Drinking Water

Service Request: R2514810
Date Received: 11/05/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty six drinking water samples were received for analysis at ALS Environmental on 11/05/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

Approved by Meghan Pedro Date 12/01/2025

SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 173.3-2			Lab ID: R2514810-002			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	3.8			1.0	ug/L	200.8

CLIENT ID: 173.3-3			Lab ID: R2514810-003			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	2.5			1.0	ug/L	200.8

CLIENT ID: 173.3-7			Lab ID: R2514810-007			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	5.3			1.0	ug/L	200.8

CLIENT ID: 173.3-8			Lab ID: R2514810-008			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	1.7			1.0	ug/L	200.8

CLIENT ID: 173.3-9			Lab ID: R2514810-009			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	1.1			1.0	ug/L	200.8

CLIENT ID: 173.3-10			Lab ID: R2514810-010			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	8.2			1.0	ug/L	200.8

CLIENT ID: 173.3-17			Lab ID: R2514810-017			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	3.2			1.0	ug/L	200.8

CLIENT ID: 173.3-19			Lab ID: R2514810-019			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	4.9			1.0	ug/L	200.8

CLIENT ID: 173.3-20			Lab ID: R2514810-020			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	1.2			1.0	ug/L	200.8

CLIENT ID: 173.3-23			Lab ID: R2514810-023			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	5.0			1.0	ug/L	200.8

CLIENT ID: 173.3-24			Lab ID: R2514810-024			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	1.1			1.0	ug/L	200.8

CLIENT ID: 173.3-25			Lab ID: R2514810-025			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	4.2			1.0	ug/L	200.8

SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 173.3-28			Lab ID: R2514810-028			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	2.6			1.0	ug/L	200.8

CLIENT ID: 173.3-29			Lab ID: R2514810-029			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	1.3			1.0	ug/L	200.8

CLIENT ID: 173.3-30			Lab ID: R2514810-030			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	7.3			1.0	ug/L	200.8

CLIENT ID: 173.3-31			Lab ID: R2514810-031			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	3.3			1.0	ug/L	200.8

CLIENT ID: 173.3-32			Lab ID: R2514810-032			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	4.5			1.0	ug/L	200.8

CLIENT ID: 173.3-36			Lab ID: R2514810-036			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	4.7			1.0	ug/L	200.8

Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental **Service Request:**R2514810
Project: Southwestern CSD - Southwestern Elementary/2023L-173.3

SAMPLE CROSS-REFERENCE

SAMPLE #	CLIENT SAMPLE ID	DATE	TIME
R2514810-001	173.3-1	10/31/2025	
R2514810-002	173.3-2	10/31/2025	
R2514810-003	173.3-3	10/31/2025	
R2514810-004	173.3-4	10/31/2025	
R2514810-005	173.3-5	10/31/2025	
R2514810-006	173.3-6	10/31/2025	
R2514810-007	173.3-7	10/31/2025	
R2514810-008	173.3-8	10/31/2025	
R2514810-009	173.3-9	10/31/2025	
R2514810-010	173.3-10	10/31/2025	
R2514810-011	173.3-11	10/31/2025	
R2514810-012	173.3-12	10/31/2025	
R2514810-013	173.3-13	10/31/2025	
R2514810-014	173.3-14	10/31/2025	
R2514810-015	173.3-15	10/31/2025	
R2514810-016	173.3-16	10/31/2025	
R2514810-017	173.3-17	10/31/2025	
R2514810-018	173.3-18	10/31/2025	
R2514810-019	173.3-19	10/31/2025	
R2514810-020	173.3-20	10/31/2025	
R2514810-021	173.3-21	10/31/2025	
R2514810-022	173.3-22	10/31/2025	
R2514810-023	173.3-23	10/31/2025	
R2514810-024	173.3-24	10/31/2025	
R2514810-025	173.3-25	10/31/2025	
R2514810-026	173.3-26	10/31/2025	
R2514810-027	173.3-27	10/31/2025	
R2514810-028	173.3-28	10/31/2025	
R2514810-029	173.3-29	10/31/2025	
R2514810-030	173.3-30	10/31/2025	
R2514810-031	173.3-31	10/31/2025	
R2514810-032	173.3-32	10/31/2025	
R2514810-033	173.3-33	10/31/2025	
R2514810-034	173.3-34	10/31/2025	
R2514810-035	173.3-35	10/31/2025	
R2514810-036	173.3-36	10/31/2025	

Stohl ENVIRONMENTAL

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-173.3

Client: Southwestern CSD

Contact: Stephen Olson

Building: Southwestern Elementary

Location: 600 County Touring Rte 32 #1, Jamestown, NY 14701

LEAD		Turnaround
Water by 200.8	X	10 Days

Sample #	Location	Outlet Type	Time
173.3-1	Kitchen Prep Sink Under Windows	Sink	5:30
173.3-2	Kitchen Kettle Filler	Pot Filler	5:31
173.3-3	C99 Kitchenette near Rm 107	Sink	5:32
173.3-4	C100-Hall L Drinking Fountain	DF	5:33
173.3-5	C100-Hall R DF	DF	5:34
173.3-6	C108 Classroom	Sink	5:35
173.3-7	C108 DF	DF	5:37
173.3-8	C110 Classroom	Sink	5:38
173.3-9	C111 Classroom	Sink	5:39
173.3-10	C111 DF	DF	5:40
173.3-11	C112 Classroom	Sink	5:41
173.3-12	C113 Classroom	Sink	5:42
173.3-13	C114 Classroom	Sink	5:44
173.3-14	C115 Classroom	Sink	5:45
173.3-15	C115 DF	DF	5:46
173.3-16	C116 Classroom	Sink	5:47
173.3-17	C116 DF	DF	5:48
173.3-18	C118 Classroom	Sink	5:49

Notes:
Please e-mail lab results to labs@stohlenv.com ☑ If checked, also e-mail results to: Mscinta@stohlenvironmental.com

Sampled By:	Jared Rider	Print Name	Stohl Env: Jared Rider	Date:	10/31/2025
Relinquished By:		Print Name	Stohl Env: Connor Crilly	Date:	11/4/2025
Received (Name / Lab):			Date: 11/5/25	Time:	15:00
Sample Login (Name / Lab):			Date:	Time:	
Analysis (Name / Lab):			Date:	Time:	
QA/QC Review (Name / Lab):			Date:		
Archived / Released:		QA/QC InterLAB Use:	Date:		

R2514810 5
Stohl Environmental
Southwestern CSD - Southwestern Elementary

Page 1 of 8

Chain of Custody Document

Stohl ENVIRONMENTAL
3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-173.3

Client: Southwestern CSD

Contact: Stephen Olson

Building: Southwestern Elementary

Location: 600 County Touring Rte 32 #1, Jamestown, NY 14701

LEAD		Turnaround
Water by 200.8	X	10 Days

Sample #	Location	Outlet Type	Time
173.3-19	C118 DF	DF	5:51
173.3-20	C119 Classroom	Sink	5:52
173.3-21	C119 DF	DF	5:53
173.3-22	C120 Classroom	Sink	5:54
173.3-23	C120 DF	DF	5:55
173.3-24	C121 Classroom	Sink	5:56
173.3-25	C121 DF	DF	5:58
173.3-26	C122 Classroom, Sensory	Sink	5:59
173.3-27	C122 DF	DF	6:00
173.3-28	C131 Library Office	Sink	6:01
173.3-29	D140 Classroom	Sink	6:02
173.3-30	D140 DF	DF	6:03
173.3-31	D141 Classroom	Sink	6:05
173.3-32	D141 DF	DF	6:06
173.3-33	D142 Classroom	Sink	6:07
173.3-34	D142 DF	DF	6:08
173.3-35	D143 Classroom	Sink	6:09
173.3-36	D143 DF	DF	6:10

Notes:
Please e-mail lab results to labs@stohlenv.com

Mscinta@stohlenvironmental.com

Sampled By:	Jared Rider	Print Name	Stohl Env:	Jared Rider	Date: 10/31/2025
Relinquished By:		Print Name	Stohl Env:	Connor Crilly	Date: 11/4/2025
Received (Name / Lab):			Date:	11/5/23	Time: 15:00
Sample Login (Name / Lab):			Date:		Time:
Analysis (Name / Lab):			Date:		Time:
QA/QC Review (Name / Lab):			Date:		Time:
Archived / Released:		QA/QC InterLAB Use:	Date:		

R2514810 5
Stohl Environmental
Southwestern CSD - Southwestern Elementary

Page 2 of 8

R2514810 5
Stohl Environmental
Southwestern CSD - Southwestern Elementary

Cooler Receipt and Preservation Check

Project/Client Stohl Environmental Folder Number _____

Cooler received on 11/5/25 by: KE COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y N		5a	Did VOA vials have sig* bubbles?		Y N NA
2	Custody papers properly completed (ink, signed)?	Y N		5b	Sig* bubbles: Alk?	Y N NA	Sulfide? Y N NA
3	Did all bottles arrive in good condition (unbroken)?	Y N		6	Where did the bottles originate?	ALS/ROC CLIENT	
4	Circle: Wet Ice Dry Ice Gel packs present?	Y N		7	Soil VOA received as:	Bulk Encore 5035set NA	

8. Temperature Readings Date: 11/5/25 Time: 05:40 ID: IR#12 IR#11 From: Temp Blank Sample Bottle

Temp (°C)	18.4						
Within 0-6°C?	Y N	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: _____ Ice melted Poorly Packed (described below) Same Day Rule

&Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMO by KE on 11/5/25 at 05:50
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 11/11 Time: 1630 by: AG

9. Were all bottle labels complete (*i.e.* analysis, preservation, etc.)? YES NO
10. Did all bottle labels and tags agree with custody papers? YES NO
11. Were correct containers used for the tests indicated? YES NO
12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO N/A
13. Were dissolved metals filtered in the field? YES NO N/A
14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved? Yes	Preserved? No	Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
≥12		NaOH								
≤2	202325	HNO_3	✓		24017806	7/27				
≤2		H_2SO_4								
<4		$NaHSO_4$								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add $Na_2S_2O_3$ (625, 608, CN), ascorbic (phenol).					
		$Na_2S_2O_3$								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: _____

Explain all Discrepancies/ Other Comments:

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: AG *significant air bubbles: VOA > 5-6 mm : WC >1 in. diameter

P:\INTRANET\QAQC\Forms Controlled\Cooler Receipt r21.doc 05/17/2024

Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

REPORT QUALIFIERS AND DEFINITIONS

U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.

J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Arclors).

B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.

E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.

E Organics- Concentration has exceeded the calibration range for that specific analysis.

D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.

* Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.

H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.

Spike was diluted out.

+ Correlation coefficient for MSA is <0.995.

N Inorganics- Matrix spike recovery was outside laboratory limits.

N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.

S Concentration has been determined using Method of Standard Additions (MSA).

W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.

P Concentration >40% difference between the two GC columns.

C Confirmed by GC/MS

Q DoD reports: indicates a pesticide/Aroclor is not confirmed (≥100% Difference between two GC columns).

X See Case Narrative for discussion.

MRL Method Reporting Limit. Also known as:
LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.

MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).

LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.

ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations[1]

NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

[1] Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx.

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

Client: Stohl Environmental **Service Request:** R2514810
Project: Southwestern CSD - Southwestern Elementary/2023L-173.3

Sample Name: 173.3-1 **Date Collected:** 10/31/25
Lab Code: R2514810-001 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-2 **Date Collected:** 10/31/25
Lab Code: R2514810-002 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-3 **Date Collected:** 10/31/25
Lab Code: R2514810-003 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-4 **Date Collected:** 10/31/25
Lab Code: R2514810-004 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-5 **Date Collected:** 10/31/25
Lab Code: R2514810-005 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Client: Stohl Environmental **Service Request:** R2514810
Project: Southwestern CSD - Southwestern Elementary/2023L-173.3

Sample Name: 173.3-6 **Date Collected:** 10/31/25
Lab Code: R2514810-006 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-7 **Date Collected:** 10/31/25
Lab Code: R2514810-007 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-8 **Date Collected:** 10/31/25
Lab Code: R2514810-008 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-9 **Date Collected:** 10/31/25
Lab Code: R2514810-009 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-10 **Date Collected:** 10/31/25
Lab Code: R2514810-010 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Client: Stohl Environmental **Service Request:** R2514810
Project: Southwestern CSD - Southwestern Elementary/2023L-173.3

Sample Name: 173.3-11 **Date Collected:** 10/31/25
Lab Code: R2514810-011 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-12 **Date Collected:** 10/31/25
Lab Code: R2514810-012 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-13 **Date Collected:** 10/31/25
Lab Code: R2514810-013 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-14 **Date Collected:** 10/31/25
Lab Code: R2514810-014 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-15 **Date Collected:** 10/31/25
Lab Code: R2514810-015 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Client: Stohl Environmental **Service Request:** R2514810
Project: Southwestern CSD - Southwestern Elementary/2023L-173.3

Sample Name: 173.3-16 **Date Collected:** 10/31/25
Lab Code: R2514810-016 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-17 **Date Collected:** 10/31/25
Lab Code: R2514810-017 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-18 **Date Collected:** 10/31/25
Lab Code: R2514810-018 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-19 **Date Collected:** 10/31/25
Lab Code: R2514810-019 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-20 **Date Collected:** 10/31/25
Lab Code: R2514810-020 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Client: Stohl Environmental **Service Request:** R2514810
Project: Southwestern CSD - Southwestern Elementary/2023L-173.3

Sample Name: 173.3-21 **Date Collected:** 10/31/25
Lab Code: R2514810-021 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-22 **Date Collected:** 10/31/25
Lab Code: R2514810-022 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-23 **Date Collected:** 10/31/25
Lab Code: R2514810-023 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-24 **Date Collected:** 10/31/25
Lab Code: R2514810-024 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-25 **Date Collected:** 10/31/25
Lab Code: R2514810-025 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Client: Stohl Environmental **Service Request:** R2514810
Project: Southwestern CSD - Southwestern Elementary/2023L-173.3

Sample Name: 173.3-26 **Date Collected:** 10/31/25
Lab Code: R2514810-026 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-27 **Date Collected:** 10/31/25
Lab Code: R2514810-027 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-28 **Date Collected:** 10/31/25
Lab Code: R2514810-028 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-29 **Date Collected:** 10/31/25
Lab Code: R2514810-029 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-30 **Date Collected:** 10/31/25
Lab Code: R2514810-030 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Client: Stohl Environmental **Service Request:** R2514810
Project: Southwestern CSD - Southwestern Elementary/2023L-173.3

Sample Name: 173.3-31 **Date Collected:** 10/31/25
Lab Code: R2514810-031 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-32 **Date Collected:** 10/31/25
Lab Code: R2514810-032 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-33 **Date Collected:** 10/31/25
Lab Code: R2514810-033 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-34 **Date Collected:** 10/31/25
Lab Code: R2514810-034 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-35 **Date Collected:** 10/31/25
Lab Code: R2514810-035 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3		

Sample Name:	173.3-36	**Date Collected:**	10/31/25
Lab Code:	R2514810-036	**Date Received:**	11/5/25
Sample Matrix:	Drinking Water		

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":
For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.

Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-1	**Basis:**	NA
Lab Code:	R2514810-001		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/25/25 17:35	

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-2	**Basis:**	NA
Lab Code:	R2514810-002		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**3.8**	ug/L	1.0	1	11/25/25 17:36	

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-3	**Basis:**	NA
Lab Code:	R2514810-003		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**2.5**	ug/L	1.0	1	11/25/25 17:38	

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-4	**Basis:**	NA
Lab Code:	R2514810-004		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/25/25 17:42	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-5	**Basis:**	NA
Lab Code:	R2514810-005		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/25/25 17:44	

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-6	**Basis:**	NA
Lab Code:	R2514810-006		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/25/25 17:45	

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-7	**Basis:**	NA
Lab Code:	R2514810-007		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**5.3**	ug/L	1.0	1	11/25/25 17:47	

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-8	**Basis:**	NA
Lab Code:	R2514810-008		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.7**	ug/L	1.0	1	11/25/25 17:49	

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-9	**Basis:**	NA
Lab Code:	R2514810-009		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.1**	ug/L	1.0	1	11/25/25 17:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-10	**Basis:**	NA
Lab Code:	R2514810-010		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**8.2**	ug/L	1.0	1	11/25/25 17:52	

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-11	**Basis:**	NA
Lab Code:	R2514810-011		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/25/25 17:53	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-12	**Basis:**	NA
Lab Code:	R2514810-012		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/25/25 17:55	

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-13	**Basis:**	NA
Lab Code:	R2514810-013		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/25/25 17:56	

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-14	**Basis:**	NA
Lab Code:	R2514810-014		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/25/25 18:01	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-15	**Basis:**	NA
Lab Code:	R2514810-015		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/25/25 18:02	

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-16	**Basis:**	NA
Lab Code:	R2514810-016		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/25/25 18:04	

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-17	**Basis:**	NA
Lab Code:	R2514810-017		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**3.2**	ug/L	1.0	1	11/25/25 18:15	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-18	**Basis:**	NA
Lab Code:	R2514810-018		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/25/25 18:19	

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-19	**Basis:**	NA
Lab Code:	R2514810-019		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**4.9**	ug/L	1.0	1	11/25/25 18:21	

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-20	**Basis:**	NA
Lab Code:	R2514810-020		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.2**	ug/L	1.0	1	11/25/25 18:22	

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-21	**Basis:**	NA
Lab Code:	R2514810-021		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/25/25 18:24	

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-22	**Basis:**	NA
Lab Code:	R2514810-022		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/25/25 18:25	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-23	**Basis:**	NA
Lab Code:	R2514810-023		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**5.0**	ug/L	1.0	1	11/25/25 18:30	

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-24	**Basis:**	NA
Lab Code:	R2514810-024		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.1**	ug/L	1.0	1	11/25/25 18:31	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-25	**Basis:**	NA
Lab Code:	R2514810-025		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**4.2**	ug/L	1.0	1	11/25/25 18:33	

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-26	**Basis:**	NA
Lab Code:	R2514810-026		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/25/25 18:35	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-27	**Basis:**	NA
Lab Code:	R2514810-027		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/25/25 18:36	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-28	**Basis:**	NA
Lab Code:	R2514810-028		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**2.6**	ug/L	1.0	1	11/25/25 18:38	

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-29	**Basis:**	NA
Lab Code:	R2514810-029		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.3**	ug/L	1.0	1	11/25/25 18:39	

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-30	**Basis:**	NA
Lab Code:	R2514810-030		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**7.3**	ug/L	1.0	1	11/25/25 18:41	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-31	**Basis:**	NA
Lab Code:	R2514810-031		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**3.3**	ug/L	1.0	1	11/25/25 18:42	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-32	**Basis:**	NA
Lab Code:	R2514810-032		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**4.5**	ug/L	1.0	1	11/25/25 18:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-33	**Basis:**	NA
Lab Code:	R2514810-033		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/25/25 18:48	

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-34	**Basis:**	NA
Lab Code:	R2514810-034		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/25/25 18:50	

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-35	**Basis:**	NA
Lab Code:	R2514810-035		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/25/25 18:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-36	**Basis:**	NA
Lab Code:	R2514810-036		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**4.7**	ug/L	1.0	1	11/25/25 18:53	

QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	NA
Sample Matrix:	Drinking Water	**Date Received:**	NA
Sample Name:	Method Blank	**Basis:**	NA
Lab Code:	R2514810-MB1		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/25/25 17:24	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	NA
Sample Matrix:	Drinking Water	**Date Received:**	NA
Sample Name:	Method Blank	**Basis:**	NA
Lab Code:	R2514810-MB2		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/25/25 18:12	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25
		Date Analyzed:	11/25/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name:	173.3-16	**Units:**	ug/L
Lab Code:	R2514810-016	**Basis:**	NA
Analysis Method:	200.8		

		Matrix Spike R2514810-016MS			Duplicate Matrix Spike R2514810-016DMS					
Analyte Name	**Sample Result**	**Result**	**Spike Amount**	**% Rec**	**Result**	**Spike Amount**	**% Rec**	**% Rec Limits**	**RPD**	**RPD Limit**
Lead, Total	ND U	21.9	20.0	110	21.8	20.0	109	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25
		Date Analyzed:	11/25/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name:	173.3-17	**Units:**	ug/L
Lab Code:	R2514810-017	**Basis:**	NA
Analysis Method:	200.8		

		Matrix Spike R2514810-017MS			Duplicate Matrix Spike R2514810-017DMS					
Analyte Name	**Sample Result**	**Result**	**Spike Amount**	**% Rec**	**Result**	**Spike Amount**	**% Rec**	**% Rec Limits**	**RPD**	**RPD Limit**
Lead, Total	3.2	25.6	20.0	112	25.6	20.0	112	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25
		Date Analyzed:	11/25/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name:	173.3-36	**Units:**	ug/L
Lab Code:	R2514810-036	**Basis:**	NA
Analysis Method:	200.8		

		Matrix Spike R2514810-036MS			Duplicate Matrix Spike R2514810-036DMS					
Analyte Name	**Sample Result**	**Result**	**Spike Amount**	**% Rec**	**Result**	**Spike Amount**	**% Rec**	**% Rec Limits**	**RPD**	**RPD Limit**
Lead, Total	4.7	26.9	20.0	111	26.7	20.0	110	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Analyzed:**	11/25/25
Sample Matrix:	Drinking Water		

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2514810-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.8	20.0	109	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client:	Stohl Environmental	**Service Request:**	R2514810
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Analyzed:**	11/25/25
Sample Matrix:	Drinking Water		

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2514810-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	22.0	20.0	110	85-115

December 04, 2025 Service Request No:R2514812

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Southwestern CSD - Southwestern Elementary

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory November 05, 2025
For your reference, these analyses have been assigned our service request number **R2514812.**

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
PHONE +1 585 288 5380 | FAX +1 585 288 8475
ALS Group USA, Corp.
dba ALS Environmental

Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

1565 Jefferson Rd, Building 300, Rochester, NY 14623 | 585-288-5380 | www.alsglobal.com

Client: Stohl Environmental
Project: Southwestern CSD - Southwestern Elementary
Sample Matrix: Drinking Water

Service Request: R2514812
Date Received: 11/05/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty six drinking water samples were received for analysis at ALS Environmental on 11/05/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

Approved by Meghan Pedro Date 12/04/2025

SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 173.3-37 — **Lab ID: R2514812-001**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.3			1.0	ug/L	200.8

CLIENT ID: 173.3-38 — **Lab ID: R2514812-002**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.3			1.0	ug/L	200.8

CLIENT ID: 173.3-41 — **Lab ID: R2514812-005**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.2			1.0	ug/L	200.8

CLIENT ID: 173.3-42 — **Lab ID: R2514812-006**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.9			1.0	ug/L	200.8

CLIENT ID: 173.3-44 — **Lab ID: R2514812-008**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.3			1.0	ug/L	200.8

CLIENT ID: 173.3-45 — **Lab ID: R2514812-009**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.7			1.0	ug/L	200.8

CLIENT ID: 173.3-46 — **Lab ID: R2514812-010**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.1			1.0	ug/L	200.8

CLIENT ID: 173.3-47 — **Lab ID: R2514812-011**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.3			1.0	ug/L	200.8

CLIENT ID: 173.3-48 — **Lab ID: R2514812-012**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.7			1.0	ug/L	200.8

CLIENT ID: 173.3-49 — **Lab ID: R2514812-013**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.2			1.0	ug/L	200.8

CLIENT ID: 173.3-50 — **Lab ID: R2514812-014**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.5			1.0	ug/L	200.8

CLIENT ID: 173.3-51 — **Lab ID: R2514812-015**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.4			1.0	ug/L	200.8

SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 173.3-52 — **Lab ID: R2514812-016**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	4.3			1.0	ug/L	200.8

CLIENT ID: 173.3-53 — **Lab ID: R2514812-017**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.2			1.0	ug/L	200.8

CLIENT ID: 173.3-54 — **Lab ID: R2514812-018**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.8			1.0	ug/L	200.8

CLIENT ID: 173.3-56 — **Lab ID: R2514812-020**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.7			1.0	ug/L	200.8

CLIENT ID: 173.3-57 — **Lab ID: R2514812-021**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	22.8			1.0	ug/L	200.8

CLIENT ID: 173.3-58 — **Lab ID: R2514812-022**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	52.8			0.50	ug/L	200.8

CLIENT ID: 173.3-61 — **Lab ID: R2514812-025**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.0			1.0	ug/L	200.8

CLIENT ID: 173.3-62 — **Lab ID: R2514812-026**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	5.9			1.0	ug/L	200.8

CLIENT ID: 173.3-63 — **Lab ID: R2514812-027**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.1			1.0	ug/L	200.8

CLIENT ID: 173.3-67 — **Lab ID: R2514812-032**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.3			1.0	ug/L	200.8

CLIENT ID: 173.3-68 — **Lab ID: R2514812-033**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	4.5			1.0	ug/L	200.8

CLIENT ID: 173.3-69 — **Lab ID: R2514812-034**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.0			1.0	ug/L	200.8

SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 173.3-70			Lab ID: R2514812-035			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	2.6			1.0	ug/L	200.8

CLIENT ID: 173.3-71			Lab ID: R2514812-036			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	13.4			1.0	ug/L	200.8

Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental **Service Request:**R2514812
Project: Southwestern CSD - Southwestern Elementary/2023L-173.3

SAMPLE CROSS-REFERENCE

SAMPLE #	CLIENT SAMPLE ID	DATE	TIME
R2514812-001	173.3-37	10/31/2025	
R2514812-002	173.3-38	10/31/2025	
R2514812-003	173.3-39	10/31/2025	
R2514812-004	173.3-40	10/31/2025	
R2514812-005	173.3-41	10/31/2025	
R2514812-006	173.3-42	10/31/2025	
R2514812-007	173.3-43	10/31/2025	
R2514812-008	173.3-44	10/31/2025	
R2514812-009	173.3-45	10/31/2025	
R2514812-010	173.3-46	10/31/2025	
R2514812-011	173.3-47	10/31/2025	
R2514812-012	173.3-48	10/31/2025	
R2514812-013	173.3-49	10/31/2025	
R2514812-014	173.3-50	10/31/2025	
R2514812-015	173.3-51	10/31/2025	
R2514812-016	173.3-52	10/31/2025	
R2514812-017	173.3-53	10/31/2025	
R2514812-018	173.3-54	10/31/2025	
R2514812-019	173.3-55	10/31/2025	
R2514812-020	173.3-56	10/31/2025	
R2514812-021	173.3-57	10/31/2025	
R2514812-022	173.3-58	10/31/2025	
R2514812-023	173.3-59	10/31/2025	
R2514812-024	173.3-60	10/31/2025	
R2514812-025	173.3-61	10/31/2025	
R2514812-026	173.3-62	10/31/2025	
R2514812-027	173.3-63	10/31/2025	
R2514812-028	173.3-64	10/31/2025	
R2514812-029	173.3-65	10/31/2025	
R2514812-030	173.3-66A	10/31/2025	
R2514812-031	173.3-66B	10/31/2025	
R2514812-032	173.3-67	10/31/2025	
R2514812-033	173.3-68	10/31/2025	
R2514812-034	173.3-69	10/31/2025	
R2514812-035	173.3-70	10/31/2025	
R2514812-036	173.3-71	10/31/2025	

Stohl ENVIRONMENTAL

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-173.3

Client: Southwestern CSD

Contact: Stephen Olson

Building: Southwestern Elementary

Location: 600 County Touring Rte 32 #1, Jamestown, NY 14701

LEAD

Water by 200.8 X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
173.3-37	D144 Classroom	Sink	6:12
173.3-38	D144 DF	DF	6:13
173.3-39	D146 Classroom	Sink	6:14
173.3-40	D146 DF	DF	6:15
173.3-41	D147 Classroom	Sink	6:16
173.3-42	D147 DF	DF	6:17
173.3-43	D148 Classroom	Sink	6:19
173.3-44	D148 DF	DF	6:20
173.3-45	D149 Classroom	Sink	6:21
173.3-46	D149 DF	DF	6:22
173.3-47	D150 Classroom	Sink	6:23
173.3-48	D150 DF	DF	6:24
173.3-49	D151 Classroom	Sink	6:26
173.3-50	D151 DF	DF	6:27
173.3-51	D153 Classroom	Sink	6:28
173.3-52	D153 DF	DF	6:29
173.3-53	D154 Classroom	Sink	6:30
173.3-54	D154 DF	DF	6:31

Notes:
Please e-mail lab results to labs@stohlenv.com

Mscinta@stohlenvironmental.com

Sampled By:	Jared Rider	Print Name	Stohl Env: Jared Rider	Date:	10/31/2025
Relinquished By:		Print Name	Stohl Env: Connor Crilly	Date:	11/4/2025
Received (Name / Lab):			Date: 11/5/25	Time:	15:00
Sample Login (Name / Lab):			Date:	Time:	
Analysis (Name / Lab):			Date:	Time:	
QA/QC Review (Name / Lab):			Date:		
Archived / Released:		QA/QC InterLAB Use:	Date:		

R2514812 5
Stohl Environmental
Southwestern CSD - Southwestern Elementary

Page 3 of 8

Stohl ENVIRONMENTAL

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-173.3

Client: Southwestern CSD

Contact: Stephen Olson

Building: Southwestern Elementary

Location: 600 County Touring Rte 32 #1, Jamestown, NY 14701

LEAD		Turnaround
Water by 200.8	X	10 Days

Sample #	Location	Outlet Type	Time
173.3-55	D155 Classroom	Sink	6:33
173.3-56	D155 DF	DF	6:34
173.3-57	D161-Hall L Drinking Fountain near Restroom 162	DF	6:35
173.3-58	D161-Hall R DF	DF	6:36
173.3-59	C200 Main Office Kitchenette	Sink	6:37
173.3-60	C208 Nurse by Main Door	Sink	6:38
173.3-61	C209 Nurse Isolation Room	Sink	6:40
173.3-62	C210 Nurse Rear Restroom	Sink	6:41
173.3-63	C208 Nurse Kitchenette	Sink	6:42
173.3-64	C211 Nurse Front Restroom	Sink	6:43
173.3-65	Main-Hall L Drinking Fountain Near Top of K Ramp	DF	6:44
173.3-66A	Main-Hall R Drinking Fountain Near Top of K Ramp	DF	6:45
173.3-66B	Main-Hall DFB Near Top of K Ramp	DFB	6:47
173.3-67	A305 Faculty Room	Sink	6:48
173.3-68	A307 Music Classroom	Sink	6:49
173.3-69	A307 DF	DF	6:50
173.3-70	A309 PE Office	Sink	6:51
173.3-71	A309 DF	DF	6:52

Notes:
Please e-mail lab results to labs@stohlenv.com

Mscinta@stohlenvironmental.com

Sampled By:	Jared Rider	Print Name	Stohl Env: Jared Rider	Date:	10/31/2025
Relinquished By:		Print Name	Stohl Env: Connor Crilly	Date:	11/4/2025
Received (Name / Lab):			Date: 11/5/25	Time:	15:00
Sample Login (Name / Lab):			Date:	Time:	
Analysis (Name / Lab):			Date:	Time:	
QA/QC Review (Name / Lab):			Date:	Time:	
Archived / Released:		QA/QC InterLAB Use:	Date:	Time:	

R2514812 5
Stohl Environmental
Southwestern CSD - Southwestern Elementary

Page 4 of 8

R2514812 5
Stohl Environmental
Southwestern CSD - Southwestern Elementary

Cooler Receipt and Preservation C

Project/Client Stohl Environmental Folder Number

Cooler received on 11/5/25 by: AE COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y N		5a	Did VOA vials have sig* bubbles?	Y N NA	
2	Custody papers properly completed (ink, signed)?	Y N		5b	Sig* bubbles: Alk? Y N NA	Sulfide? Y N NA	
3	Did all bottles arrive in good condition (unbroken)?	Y N		6	Where did the bottles originate?	ALS/ROC CLIENT	
4	Circle: Wet Ice Dry Ice Gel packs present?	Y N		7	Soil VOA received as: Bulk Encore 5035set NA		

8. Temperature Readings Date: 11/5/25 Time: 05:40 ID: IR#12 IR#11 From: Temp Blank Sample Bottle

Temp (°C)	18.4						
Within 0-6°C?	Y N	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: _____ Ice melted Poorly Packed (described below) Same Day Rule

&Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SM0 by AE on 11/5/25 at 05:50
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 11/11 Time: 1632 by: AG

9. Were all bottle labels complete (*i.e.* analysis, preservation, etc.)? YES NO
10. Did all bottle labels and tags agree with custody papers? YES NO
11. Were correct containers used for the tests indicated? YES NO
12. Were 5035 vials acceptable (no extra labels; not leaking)? YES NO N/A
13. Were dissolved metals filtered in the field? YES NO N/A
14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved? Yes	Preserved? No	Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
≥12		NaOH								
≤2	202325	HNO_3	x		24017806	11/27				
≤2		H_2SO_4								
<4		$NaHSO_4$								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add $Na_2S_2O_3$ (625, 608, CN), ascorbic (phenol).					
		$Na_2S_2O_3$								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: _____

Explain all Discrepancies/ Other Comments:

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: AG *significant air bubbles: VOA > 5-6 mm : WC >1 in. diameter

P:\INTRANET\QAQC\Forms Controlled\Cooler Receipt r21.doc 05/17/2024

Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

REPORT QUALIFIERS AND DEFINITIONS

U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.

J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Arclors).

B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.

E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.

E Organics- Concentration has exceeded the calibration range for that specific analysis.

D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.

* Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.

H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.

Spike was diluted out.

+ Correlation coefficient for MSA is <0.995.

N Inorganics- Matrix spike recovery was outside laboratory limits.

N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.

S Concentration has been determined using Method of Standard Additions (MSA).

W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.

P Concentration >40% difference between the two GC columns.

C Confirmed by GC/MS

Q DoD reports: indicates a pesticide/Aroclor is not confirmed (≥100% Difference between two GC columns).

X See Case Narrative for discussion.

MRL Method Reporting Limit. Also known as:
LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.

MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).

LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.

ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations[1]

NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

[1] Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx.

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

Client: Stohl Environmental **Service Request:** R2514812
Project: Southwestern CSD - Southwestern Elementary/2023L-173.3

Sample Name: 173.3-37 **Date Collected:** 10/31/25
Lab Code: R2514812-001 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-38 **Date Collected:** 10/31/25
Lab Code: R2514812-002 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-39 **Date Collected:** 10/31/25
Lab Code: R2514812-003 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-40 **Date Collected:** 10/31/25
Lab Code: R2514812-004 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-41 **Date Collected:** 10/31/25
Lab Code: R2514812-005 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Client: Stohl Environmental **Service Request:** R2514812
Project: Southwestern CSD - Southwestern Elementary/2023L-173.3

Sample Name: 173.3-42 **Date Collected:** 10/31/25
Lab Code: R2514812-006 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-43 **Date Collected:** 10/31/25
Lab Code: R2514812-007 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-44 **Date Collected:** 10/31/25
Lab Code: R2514812-008 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-45 **Date Collected:** 10/31/25
Lab Code: R2514812-009 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-46 **Date Collected:** 10/31/25
Lab Code: R2514812-010 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Client: Stohl Environmental **Service Request:** R2514812
Project: Southwestern CSD - Southwestern Elementary/2023L-173.3

Sample Name: 173.3-47 **Date Collected:** 10/31/25
Lab Code: R2514812-011 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-48 **Date Collected:** 10/31/25
Lab Code: R2514812-012 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-49 **Date Collected:** 10/31/25
Lab Code: R2514812-013 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-50 **Date Collected:** 10/31/25
Lab Code: R2514812-014 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-51 **Date Collected:** 10/31/25
Lab Code: R2514812-015 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Client: Stohl Environmental **Service Request:** R2514812
Project: Southwestern CSD - Southwestern Elementary/2023L-173.3

Sample Name: 173.3-52 **Date Collected:** 10/31/25
Lab Code: R2514812-016 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-53 **Date Collected:** 10/31/25
Lab Code: R2514812-017 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-54 **Date Collected:** 10/31/25
Lab Code: R2514812-018 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-55 **Date Collected:** 10/31/25
Lab Code: R2514812-019 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-56 **Date Collected:** 10/31/25
Lab Code: R2514812-020 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Client: Stohl Environmental **Service Request:** R2514812
Project: Southwestern CSD - Southwestern Elementary/2023L-173.3

Sample Name: 173.3-57 **Date Collected:** 10/31/25
Lab Code: R2514812-021 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-58 **Date Collected:** 10/31/25
Lab Code: R2514812-022 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8	GCONSTANTINO	NMANSEN

Sample Name: 173.3-59 **Date Collected:** 10/31/25
Lab Code: R2514812-023 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-60 **Date Collected:** 10/31/25
Lab Code: R2514812-024 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-61 **Date Collected:** 10/31/25
Lab Code: R2514812-025 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Client: Stohl Environmental **Service Request:** R2514812
Project: Southwestern CSD - Southwestern Elementary/2023L-173.3

Sample Name: 173.3-62 **Date Collected:** 10/31/25
Lab Code: R2514812-026 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-63 **Date Collected:** 10/31/25
Lab Code: R2514812-027 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-64 **Date Collected:** 10/31/25
Lab Code: R2514812-028 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-65 **Date Collected:** 10/31/25
Lab Code: R2514812-029 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-66A **Date Collected:** 10/31/25
Lab Code: R2514812-030 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Client: Stohl Environmental **Service Request:** R2514812
Project: Southwestern CSD - Southwestern Elementary/2023L-173.3

Sample Name: 173.3-66B **Date Collected:** 10/31/25
Lab Code: R2514812-031 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-67 **Date Collected:** 10/31/25
Lab Code: R2514812-032 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-68 **Date Collected:** 10/31/25
Lab Code: R2514812-033 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-69 **Date Collected:** 10/31/25
Lab Code: R2514812-034 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-70 **Date Collected:** 10/31/25
Lab Code: R2514812-035 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Analyst Summary report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3		

Sample Name:	173.3-71	**Date Collected:**	10/31/25
Lab Code:	R2514812-036	**Date Received:**	11/5/25
Sample Matrix:	Drinking Water		

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":
For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.

Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-37	**Basis:**	NA
Lab Code:	R2514812-001		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.3**	ug/L	1.0	1	12/01/25 12:57	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-38	**Basis:**	NA
Lab Code:	R2514812-002		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.3**	ug/L	1.0	1	12/01/25 13:02	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-39	**Basis:**	NA
Lab Code:	R2514812-003		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/01/25 13:03	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-40	**Basis:**	NA
Lab Code:	R2514812-004		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/01/25 13:05	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-41	**Basis:**	NA
Lab Code:	R2514812-005		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.2**	ug/L	1.0	1	12/01/25 13:07	

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-42	**Basis:**	NA
Lab Code:	R2514812-006		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**2.9**	ug/L	1.0	1	12/01/25 13:08	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-43	**Basis:**	NA
Lab Code:	R2514812-007		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/01/25 13:13	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-44	**Basis:**	NA
Lab Code:	R2514812-008		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.3**	ug/L	1.0	1	12/01/25 13:14	

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-45	**Basis:**	NA
Lab Code:	R2514812-009		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.7**	ug/L	1.0	1	12/01/25 13:16	

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-46	**Basis:**	NA
Lab Code:	R2514812-010		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.1**	ug/L	1.0	1	12/01/25 13:17	

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-47	**Basis:**	NA
Lab Code:	R2514812-011		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.3**	ug/L	1.0	1	12/01/25 13:19	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-48	**Basis:**	NA
Lab Code:	R2514812-012		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.7**	ug/L	1.0	1	12/01/25 13:20	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-49	**Basis:**	NA
Lab Code:	R2514812-013		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.2**	ug/L	1.0	1	12/01/25 13:22	

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-50	**Basis:**	NA
Lab Code:	R2514812-014		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.5**	ug/L	1.0	1	12/01/25 13:23	

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-51	**Basis:**	NA
Lab Code:	R2514812-015		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.4**	ug/L	1.0	1	12/01/25 13:25	

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-52	**Basis:**	NA
Lab Code:	R2514812-016		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**4.3**	ug/L	1.0	1	12/01/25 13:27	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-53	**Basis:**	NA
Lab Code:	R2514812-017		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.2**	ug/L	1.0	1	12/01/25 13:31	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-54	**Basis:**	NA
Lab Code:	R2514812-018		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**2.8**	ug/L	1.0	1	12/01/25 13:33	

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-55	**Basis:**	NA
Lab Code:	R2514812-019		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/01/25 13:34	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-56	**Basis:**	NA
Lab Code:	R2514812-020		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.7**	ug/L	1.0	1	12/01/25 13:36	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-57	**Basis:**	NA
Lab Code:	R2514812-021		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**22.8**	ug/L	1.0	1	12/01/25 13:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-58	**Basis:**	NA
Lab Code:	R2514812-022		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	**52.8**	ug/L	0.50	1	12/02/25 15:48	12/01/25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-59	**Basis:**	NA
Lab Code:	R2514812-023		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/01/25 13:51	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-60	**Basis:**	NA
Lab Code:	R2514812-024		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/01/25 13:53	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-61	**Basis:**	NA
Lab Code:	R2514812-025		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**2.0**	ug/L	1.0	1	12/01/25 13:54	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-62	**Basis:**	NA
Lab Code:	R2514812-026		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**5.9**	ug/L	1.0	1	12/01/25 13:56	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-63	**Basis:**	NA
Lab Code:	R2514812-027		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.1**	ug/L	1.0	1	12/01/25 13:57	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-64	**Basis:**	NA
Lab Code:	R2514812-028		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/01/25 14:02	

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-65	**Basis:**	NA
Lab Code:	R2514812-029		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/01/25 14:04	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-66A	**Basis:**	NA
Lab Code:	R2514812-030		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/01/25 14:05	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-66B	**Basis:**	NA
Lab Code:	R2514812-031		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/01/25 14:07	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-67	**Basis:**	NA
Lab Code:	R2514812-032		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.3**	ug/L	1.0	1	12/01/25 14:08	

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-68	**Basis:**	NA
Lab Code:	R2514812-033		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**4.5**	ug/L	1.0	1	12/01/25 14:10	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-69	**Basis:**	NA
Lab Code:	R2514812-034		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**3.0**	ug/L	1.0	1	12/01/25 14:11	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-70	**Basis:**	NA
Lab Code:	R2514812-035		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**2.6**	ug/L	1.0	1	12/01/25 14:13	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-71	**Basis:**	NA
Lab Code:	R2514812-036		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**13.4**	ug/L	1.0	1	12/01/25 14:14	

QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	NA
Sample Matrix:	Drinking Water	**Date Received:**	NA
Sample Name:	Method Blank	**Basis:**	NA
Lab Code:	R2514812-MB1		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	ND U	ug/L	0.50	1	12/02/25 15:46	12/01/25	
Lead, Total	200.8	ND U	ug/L	1.0	1	12/01/25 12:54	NA	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	NA
Sample Matrix:	Drinking Water	**Date Received:**	NA
Sample Name:	Method Blank	**Basis:**	NA
Lab Code:	R2514812-MB2		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/01/25 13:44	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25
		Date Analyzed:	12/1/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name:	173.3-37	**Units:**	ug/L
Lab Code:	R2514812-001	**Basis:**	NA
Analysis Method:	200.8		

		Matrix Spike R2514812-001MS			Duplicate Matrix Spike R2514812-001DMS					
Analyte Name	**Sample Result**	**Result**	**Spike Amount**	**% Rec**	**Result**	**Spike Amount**	**% Rec**	**% Rec Limits**	**RPD**	**RPD Limit**
Lead, Total	1.3	23.4	20.0	110	23.0	20.0	109	70-130	1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25
		Date Analyzed:	12/1/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name:	173.3-56	**Units:**	ug/L
Lab Code:	R2514812-020	**Basis:**	NA
Analysis Method:	200.8		

		Matrix Spike R2514812-020MS			Duplicate Matrix Spike R2514812-020DMS					
Analyte Name	**Sample Result**	**Result**	**Spike Amount**	**% Rec**	**Result**	**Spike Amount**	**% Rec**	**% Rec Limits**	**RPD**	**RPD Limit**
Lead, Total	1.7	23.1	20.0	107	23.0	20.0	106	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25
		Date Analyzed:	12/1/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name:	173.3-57	**Units:**	ug/L
Lab Code:	R2514812-021	**Basis:**	NA
Analysis Method:	200.8		

		Matrix Spike R2514812-021MS			Duplicate Matrix Spike R2514812-021DMS					
Analyte Name	**Sample Result**	**Result**	**Spike Amount**	**% Rec**	**Result**	**Spike Amount**	**% Rec**	**% Rec Limits**	**RPD**	**RPD Limit**
Lead, Total	22.8	45.9	20.0	115	46.6	20.0	119	70-130	2	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Analyzed:**	12/01/25 - 12/02/25
Sample Matrix:	Drinking Water		

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2514812-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	18.9	20.0	95	85-115
Lead, Total	200.8	21.3	20.0	106	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client:	Stohl Environmental	**Service Request:**	R2514812
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Analyzed:**	12/01/25
Sample Matrix:	Drinking Water		

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2514812-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.9	20.0	105	85-115

December 03, 2025 Service Request No:R2514813

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Southwestern CSD - Southwestern Elementary

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory November 05, 2025
For your reference, these analyses have been assigned our service request number **R2514813.**

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
PHONE +1 585 288 5380 | FAX +1 585 288 8475
ALS Group USA, Corp.
dba ALS Environmental

Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

1565 Jefferson Rd, Building 300, Rochester, NY 14623 | 585-288-5380 | www.alsglobal.com

Client: Stohl Environmental
Project: Southwestern CSD - Southwestern Elementary
Sample Matrix: Drinking Water

Service Request: R2514813
Date Received: 11/05/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty six drinking water samples were received for analysis at ALS Environmental on 11/05/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

Approved by Meghan Pedro Date 12/03/2025

SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 173.3-72 — **Lab ID: R2514813-001**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	5.7			1.0	ug/L	200.8

CLIENT ID: 173.3-73 — **Lab ID: R2514813-002**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	4.0			1.0	ug/L	200.8

CLIENT ID: 173.3-78 — **Lab ID: R2514813-009**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.4			1.0	ug/L	200.8

CLIENT ID: 173.3-79 — **Lab ID: R2514813-010**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.9			1.0	ug/L	200.8

CLIENT ID: 173.3-80 — **Lab ID: R2514813-011**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.8			1.0	ug/L	200.8

CLIENT ID: 173.3-81 — **Lab ID: R2514813-012**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.9			1.0	ug/L	200.8

CLIENT ID: 173.3-84 — **Lab ID: R2514813-015**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.4			1.0	ug/L	200.8

CLIENT ID: 173.3-85 — **Lab ID: R2514813-016**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.1			1.0	ug/L	200.8

CLIENT ID: 173.3-86 — **Lab ID: R2514813-017**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.1			1.0	ug/L	200.8

CLIENT ID: 173.3-87 — **Lab ID: R2514813-018**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.8			1.0	ug/L	200.8

CLIENT ID: 173.3-91 — **Lab ID: R2514813-022**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.0			1.0	ug/L	200.8

CLIENT ID: 173.3-93 — **Lab ID: R2514813-024**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.7			1.0	ug/L	200.8

SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 173.3-95 — **Lab ID: R2514813-026**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.5			1.0	ug/L	200.8

CLIENT ID: 173.3-96 — **Lab ID: R2514813-027**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.2			1.0	ug/L	200.8

CLIENT ID: 173.3-97 — **Lab ID: R2514813-028**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.2			1.0	ug/L	200.8

CLIENT ID: 173.3-98 — **Lab ID: R2514813-029**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.1			1.0	ug/L	200.8

CLIENT ID: 173.3-100 — **Lab ID: R2514813-031**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.1			1.0	ug/L	200.8

CLIENT ID: 173.3-101 — **Lab ID: R2514813-032**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.2			1.0	ug/L	200.8

CLIENT ID: 173.3-102 — **Lab ID: R2514813-033**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.9			1.0	ug/L	200.8

CLIENT ID: 173.3-103 — **Lab ID: R2514813-034**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	4.9			1.0	ug/L	200.8

CLIENT ID: 173.3-104 — **Lab ID: R2514813-035**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.0			1.0	ug/L	200.8

CLIENT ID: 173.3-105 — **Lab ID: R2514813-036**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.1			1.0	ug/L	200.8

Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental **Service Request:**R2514813
Project: Southwestern CSD - Southwestern Elementary/2023L-173.3

SAMPLE CROSS-REFERENCE

SAMPLE #	CLIENT SAMPLE ID	DATE	TIME
R2514813-001	173.3-72	10/31/2025	
R2514813-002	173.3-73	10/31/2025	
R2514813-003	173.3-74	10/31/2025	
R2514813-004	173.3-75A	10/31/2025	
R2514813-005	173.3-75B	10/31/2025	
R2514813-006	173.3-76	10/31/2025	
R2514813-007	173.3-77A	10/31/2025	
R2514813-008	173.3-77B	10/31/2025	
R2514813-009	173.3-78	10/31/2025	
R2514813-010	173.3-79	10/31/2025	
R2514813-011	173.3-80	10/31/2025	
R2514813-012	173.3-81	10/31/2025	
R2514813-013	173.3-82	10/31/2025	
R2514813-014	173.3-83	10/31/2025	
R2514813-015	173.3-84	10/31/2025	
R2514813-016	173.3-85	10/31/2025	
R2514813-017	173.3-86	10/31/2025	
R2514813-018	173.3-87	10/31/2025	
R2514813-019	173.3-88	10/31/2025	
R2514813-020	173.3-89	10/31/2025	
R2514813-021	173.3-90	10/31/2025	
R2514813-022	173.3-91	10/31/2025	
R2514813-023	173.3-92	10/31/2025	
R2514813-024	173.3-93	10/31/2025	
R2514813-025	173.3-94	10/31/2025	
R2514813-026	173.3-95	10/31/2025	
R2514813-027	173.3-96	10/31/2025	
R2514813-028	173.3-97	10/31/2025	
R2514813-029	173.3-98	10/31/2025	
R2514813-030	173.3-99	10/31/2025	
R2514813-031	173.3-100	10/31/2025	
R2514813-032	173.3-101	10/31/2025	
R2514813-033	173.3-102	10/31/2025	
R2514813-034	173.3-103	10/31/2025	
R2514813-035	173.3-104	10/31/2025	
R2514813-036	173.3-105	10/31/2025	

Chain of Custody Document

Stohl ENVIRONMENTAL
3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-173.3

Client: Southwestern CSD

Contact: Stephen Olson

Building: Southwestern Elementary

Location: 600 County Touring Rte 32 #1, Jamestown, NY 14701

LEAD		Turnaround
Water by 200.8	X	10 Days

Sample #	Location	Outlet Type	Time
173.3-72	A312 Music Classroom	Sink	6:54
173.3-73	A312 DF	DF	6:55
173.3-74	A320 L Cafeteria Drinking Fountain	DF	6:56
173.3-75A	A320 R Cafeteria Drinking Fountain	DF	6:57
173.3-75B	A320 DFB Cafeteria	DFB	6:58
173.3-76	A333-Hall L Drinking Fountiain Near Pool	DF	6:59
173.3-77A	A333-Hall R Drinking Fountain Near Pool	DF	7:01
173.3-77B	A333-Hall DFB Near pool	DFB	7:02
173.3-78	A337-Hall L Drinking Fountain Outside Boys LockerRm	Sink	7:03
173.3-79	A337-Hall R Drinking Fountain Outside Boys LockerRm	DF	7:04
173.3-80	A339-Hall L Drinking Fountain Outside Girls LockerRm	DF	7:05
173.3-81	A339-Hall R Drinking Fountain Outside Girls LockerRm	DF	7:06
173.3-82	C222-Hall L Drinking Fountain Near Girls RR 222	DF	7:08
173.3-83	C222-Hall R Drinking Fountain Near Girls RR 223	DF	7:09
173.3-84	C230 Classroom	Sink	7:10
173.3-85	C230 DF	DF	7:11
173.3-86	C231 Classroom	Sink	7:12
173.3-87	C231 DF	DF	7:13

Notes:
Please e-mail lab results to labs@stohlenv.com

Mscinta@stohlenvironmental.com

Sampled By:	Jared Rider	Print Name	Stohl Env: Jared Rider	Date:	10/31/2025
Relinquished By:		Print Name	Stohl Env: Connor Crilly	Date:	11/4/2025
Received (Name / Lab):			Date: 11/5/25	Time:	15:00
Sample Login (Name / Lab):			Date:	Time:	
Analysis (Name / Lab):			Date:	Time:	
QA/QC Review (Name / Lab):			Date:	Time:	
Archived / Released:		QA/QC InterLAB Use:	Date:		

R2514813 5
Stohl Environmental
Southwestern CSD - Southwestern Elementary

Page 5 of 8

Chain of Custody Document

Stohl ENVIRONMENTAL
3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-173.3

Client: Southwestern CSD

Contact: Stephen Olson

Building: Southwestern Elementary

Location: 600 County Touring Rte 32 #1, Jamestown, NY 14701

LEAD		Turnaround
Water by 200.8	X	10 Days

Sample #	Location	Outlet Type	Time
173.3-88	C232 Classroom	Sink	7:15
173.3-89	C232 DF	DF	7:16
173.3-90	C233 Classroom	Sink	7:17
173.3-91	C233 DF	DF	7:18
173.3-92	C234 Classroom	Sink	7:19
173.3-93	C234 DF	DF	7:20
173.3-94	C235 Classroom	Sink	7:22
173.3-95	C235 DF	DF	7:23
173.3-96	C236 Classroom	Sink	7:24
173.3-97	C236 DF	DF	7:25
173.3-98	C237 Classroom	Sink	7:26
173.3-99	C237 DF	DF	7:27
173.3-100	C238 Classroom	Sink	7:29
173.3-101	C238 DF	DF	7:30
173.3-102	C241 Classroom	Sink	7:31
173.3-103	C241 DF	DF	7:32
173.3-104	C242 Classroom	Sink	7:33
173.3-105	C242 DF	DF	7:34

Notes:
Please e-mail lab results to labs@stohlenv.com

Mscinta@stohlenvironmental.com

Sampled By:	Jared Rider	Print Name	Stohl Env: Jared Rider	Date:	10/31/2025
Relinquished By:		Print Name	Stohl Env: Connor Crilly	Date:	11/4/2025
Received (Name / Lab):			Date: 11/5/25	Time:	15:00
Sample Login (Name / Lab):			Date:	Time:	
Analysis (Name / Lab):			Date:	Time:	
QA/QC Review (Name / Lab):			Date:	Time:	
Archived / Released:		QA/QC InterLAB Use:	Date:		

R2514813 5
Stohl Environmental
Southwestern CSD - Southwestern Elementary

Page 6 of 8

R2514813 5
Stohl Environmental
Southwestern CSD - Southwestern Elementary

Cooler Receipt and Preservation Check

Project/Client Stohl Environmental Folder Number _____

Cooler received on 11/5/25 by: KE COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y N		5a	Did VOA vials have sig* bubbles?	Y N NA	
2	Custody papers properly completed (ink, signed)?	Y N		5b	Sig* bubbles: Alk? Y N NA	Sulfide? Y N NA	
3	Did all bottles arrive in good condition (unbroken)?	Y N		6	Where did the bottles originate?	ALS/ROC CLIENT	
4	Circle: Wet Ice Dry Ice Gel packs present?	Y N		7	Soil VOA received as:	Bulk Encore 5035set NA	

8. Temperature Readings Date: 11/5/25 Time: 05:40 ID: IR#12 IR#11 From: Temp Blank Sample Bottle

Temp (°C)	18.4						
Within 0-6°C?	Y N	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: _____ Ice melted Poorly Packed (described below) Same Day Rule

&Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SM0 by KE on 11/5/25 at 05:50
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: _____ Time: _____ by: _____

9. Were all bottle labels complete (*i.e.* analysis, preservation, etc.)? YES NO
10. Did all bottle labels and tags agree with custody papers? YES NO
11. Were correct containers used for the tests indicated? YES NO
12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO N/A
13. Were dissolved metals filtered in the field? YES NO N/A
14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved? Yes	Preserved? No	Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
≥12		NaOH								
≤2		HNO_3								
≤2		H_2SO_4								
<4		$NaHSO_4$								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add $Na_2S_2O_3$ (625, 608, CN), ascorbic (phenol).					
		$Na_2S_2O_3$								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: _____

Explain all Discrepancies/ Other Comments:

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: _____ *significant air bubbles: VOA > 5-6 mm : WC >1 in. diameter

P:\INTRANET\QAQC\Forms Controlled\Cooler Receipt r21.doc 05/17/2024

Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

REPORT QUALIFIERS AND DEFINITIONS

U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.

J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Arclors).

B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.

E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.

E Organics- Concentration has exceeded the calibration range for that specific analysis.

D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.

* Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.

H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.

Spike was diluted out.

+ Correlation coefficient for MSA is <0.995.

N Inorganics- Matrix spike recovery was outside laboratory limits.

N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.

S Concentration has been determined using Method of Standard Additions (MSA).

W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.

P Concentration >40% difference between the two GC columns.

C Confirmed by GC/MS

Q DoD reports: indicates a pesticide/Aroclor is not confirmed (≥100% Difference between two GC columns).

X See Case Narrative for discussion.

MRL Method Reporting Limit. Also known as:
LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.

MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).

LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.

ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations[1]

NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

[1] Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx.

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

Client: Stohl Environmental **Service Request:** R2514813
Project: Southwestern CSD - Southwestern Elementary/2023L-173.3

Sample Name: 173.3-72 **Date Collected:** 10/31/25
Lab Code: R2514813-001 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-73 **Date Collected:** 10/31/25
Lab Code: R2514813-002 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-74 **Date Collected:** 10/31/25
Lab Code: R2514813-003 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-75A **Date Collected:** 10/31/25
Lab Code: R2514813-004 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-75B **Date Collected:** 10/31/25
Lab Code: R2514813-005 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Client: Stohl Environmental **Service Request:** R2514813
Project: Southwestern CSD - Southwestern Elementary/2023L-173.3

Sample Name: 173.3-76 **Date Collected:** 10/31/25
Lab Code: R2514813-006 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-77A **Date Collected:** 10/31/25
Lab Code: R2514813-007 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-77B **Date Collected:** 10/31/25
Lab Code: R2514813-008 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-78 **Date Collected:** 10/31/25
Lab Code: R2514813-009 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-79 **Date Collected:** 10/31/25
Lab Code: R2514813-010 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Client: Stohl Environmental **Service Request:** R2514813
Project: Southwestern CSD - Southwestern Elementary/2023L-173.3

Sample Name: 173.3-80 **Date Collected:** 10/31/25
Lab Code: R2514813-011 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-81 **Date Collected:** 10/31/25
Lab Code: R2514813-012 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-82 **Date Collected:** 10/31/25
Lab Code: R2514813-013 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-83 **Date Collected:** 10/31/25
Lab Code: R2514813-014 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-84 **Date Collected:** 10/31/25
Lab Code: R2514813-015 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Client: Stohl Environmental **Service Request:** R2514813
Project: Southwestern CSD - Southwestern Elementary/2023L-173.3

Sample Name: 173.3-85 **Date Collected:** 10/31/25
Lab Code: R2514813-016 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-86 **Date Collected:** 10/31/25
Lab Code: R2514813-017 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-87 **Date Collected:** 10/31/25
Lab Code: R2514813-018 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-88 **Date Collected:** 10/31/25
Lab Code: R2514813-019 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-89 **Date Collected:** 10/31/25
Lab Code: R2514813-020 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Client: Stohl Environmental **Service Request:** R2514813
Project: Southwestern CSD - Southwestern Elementary/2023L-173.3

Sample Name: 173.3-90 **Date Collected:** 10/31/25
Lab Code: R2514813-021 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-91 **Date Collected:** 10/31/25
Lab Code: R2514813-022 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-92 **Date Collected:** 10/31/25
Lab Code: R2514813-023 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-93 **Date Collected:** 10/31/25
Lab Code: R2514813-024 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-94 **Date Collected:** 10/31/25
Lab Code: R2514813-025 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Client: Stohl Environmental **Service Request:** R2514813
Project: Southwestern CSD - Southwestern Elementary/2023L-173.3

Sample Name: 173.3-95 **Date Collected:** 10/31/25
Lab Code: R2514813-026 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-96 **Date Collected:** 10/31/25
Lab Code: R2514813-027 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-97 **Date Collected:** 10/31/25
Lab Code: R2514813-028 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-98 **Date Collected:** 10/31/25
Lab Code: R2514813-029 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-99 **Date Collected:** 10/31/25
Lab Code: R2514813-030 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Client: Stohl Environmental **Service Request:** R2514813
Project: Southwestern CSD - Southwestern Elementary/2023L-173.3

Sample Name: 173.3-100 **Date Collected:** 10/31/25
Lab Code: R2514813-031 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-101 **Date Collected:** 10/31/25
Lab Code: R2514813-032 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-102 **Date Collected:** 10/31/25
Lab Code: R2514813-033 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-103 **Date Collected:** 10/31/25
Lab Code: R2514813-034 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-104 **Date Collected:** 10/31/25
Lab Code: R2514813-035 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Analyst Summary report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3		

Sample Name:	173.3-105	**Date Collected:**	10/31/25
Lab Code:	R2514813-036	**Date Received:**	11/5/25
Sample Matrix:	Drinking Water		

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":
For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.

Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-72	**Basis:**	NA
Lab Code:	R2514813-001		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**5.7**	ug/L	1.0	1	12/01/25 14:16	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-73	**Basis:**	NA
Lab Code:	R2514813-002		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**4.0**	ug/L	1.0	1	12/01/25 14:21	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-74	**Basis:**	NA
Lab Code:	R2514813-003		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/01/25 14:22	

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-75A	**Basis:**	NA
Lab Code:	R2514813-004		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/01/25 14:24	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-75B	**Basis:**	NA
Lab Code:	R2514813-005		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/01/25 14:25	

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-76	**Basis:**	NA
Lab Code:	R2514813-006		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/01/25 14:36	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-77A	**Basis:**	NA
Lab Code:	R2514813-007		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/01/25 14:41	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-77B	**Basis:**	NA
Lab Code:	R2514813-008		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/01/25 14:42	

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-78	**Basis:**	NA
Lab Code:	R2514813-009		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**3.4**	ug/L	1.0	1	12/01/25 14:44	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-79	**Basis:**	NA
Lab Code:	R2514813-010		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**2.9**	ug/L	1.0	1	12/01/25 14:45	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-80	**Basis:**	NA
Lab Code:	R2514813-011		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.8**	ug/L	1.0	1	12/01/25 14:47	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-81	**Basis:**	NA
Lab Code:	R2514813-012		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.9**	ug/L	1.0	1	12/01/25 14:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-82	**Basis:**	NA
Lab Code:	R2514813-013		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/01/25 14:53	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-83	**Basis:**	NA
Lab Code:	R2514813-014		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/01/25 14:55	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-84	**Basis:**	NA
Lab Code:	R2514813-015		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**3.4**	ug/L	1.0	1	12/01/25 14:56	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-85	**Basis:**	NA
Lab Code:	R2514813-016		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**2.1**	ug/L	1.0	1	12/01/25 14:58	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-86	**Basis:**	NA
Lab Code:	R2514813-017		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.1**	ug/L	1.0	1	12/01/25 14:59	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-87	**Basis:**	NA
Lab Code:	R2514813-018		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.8**	ug/L	1.0	1	12/01/25 15:01	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-88	**Basis:**	NA
Lab Code:	R2514813-019		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/01/25 15:02	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-89	**Basis:**	NA
Lab Code:	R2514813-020		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/01/25 15:04	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-90	**Basis:**	NA
Lab Code:	R2514813-021		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/01/25 15:05	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-91	**Basis:**	NA
Lab Code:	R2514813-022		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**3.0**	ug/L	1.0	1	12/01/25 15:10	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-92	**Basis:**	NA
Lab Code:	R2514813-023		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/01/25 15:12	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-93	**Basis:**	NA
Lab Code:	R2514813-024		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.7**	ug/L	1.0	1	12/01/25 15:13	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-94	**Basis:**	NA
Lab Code:	R2514813-025		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/01/25 15:15	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-95	**Basis:**	NA
Lab Code:	R2514813-026		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.5**	ug/L	1.0	1	12/01/25 15:25	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-96	**Basis:**	NA
Lab Code:	R2514813-027		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.2**	ug/L	1.0	1	12/01/25 15:30	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-97	**Basis:**	NA
Lab Code:	R2514813-028		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**2.2**	ug/L	1.0	1	12/01/25 15:32	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-98	**Basis:**	NA
Lab Code:	R2514813-029		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**3.1**	ug/L	1.0	1	12/01/25 15:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-99	**Basis:**	NA
Lab Code:	R2514813-030		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/01/25 15:35	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-100	**Basis:**	NA
Lab Code:	R2514813-031		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.1**	ug/L	1.0	1	12/01/25 15:36	

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-101	**Basis:**	NA
Lab Code:	R2514813-032		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**2.2**	ug/L	1.0	1	12/01/25 15:41	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-102	**Basis:**	NA
Lab Code:	R2514813-033		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.9**	ug/L	1.0	1	12/01/25 15:42	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-103	**Basis:**	NA
Lab Code:	R2514813-034		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**4.9**	ug/L	1.0	1	12/01/25 15:44	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-104	**Basis:**	NA
Lab Code:	R2514813-035		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**2.0**	ug/L	1.0	1	12/01/25 15:45	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-105	**Basis:**	NA
Lab Code:	R2514813-036		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**2.1**	ug/L	1.0	1	12/01/25 15:47	

QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	NA
Sample Matrix:	Drinking Water	**Date Received:**	NA
Sample Name:	Method Blank	**Basis:**	NA
Lab Code:	R2514813-MB1		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/01/25 13:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	NA
Sample Matrix:	Drinking Water	**Date Received:**	NA
Sample Name:	Method Blank	**Basis:**	NA
Lab Code:	R2514813-MB2		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/01/25 14:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	NA
Sample Matrix:	Drinking Water	**Date Received:**	NA
Sample Name:	Method Blank	**Basis:**	NA
Lab Code:	R2514813-MB3		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/01/25 15:22	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25
		Date Analyzed:	12/1/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name:	173.3-75B	**Units:**	ug/L
Lab Code:	R2514813-005	**Basis:**	NA
Analysis Method:	200.8		

		Matrix Spike R2514813-005MS			Duplicate Matrix Spike R2514813-005DMS					
Analyte Name	**Sample Result**	**Result**	**Spike Amount**	**% Rec**	**Result**	**Spike Amount**	**% Rec**	**% Rec Limits**	**RPD**	**RPD Limit**
Lead, Total	ND U	21.3	20.0	107	21.3	20.0	106	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25
		Date Analyzed:	12/1/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name:	173.3-76	**Units:**	ug/L
Lab Code:	R2514813-006	**Basis:**	NA
Analysis Method:	200.8		

		Matrix Spike R2514813-006MS			Duplicate Matrix Spike R2514813-006DMS					
Analyte Name	**Sample Result**	**Result**	**Spike Amount**	**% Rec**	**Result**	**Spike Amount**	**% Rec**	**% Rec Limits**	**RPD**	**RPD Limit**
Lead, Total	ND U	21.2	20.0	106	21.6	20.0	108	70-130	2	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25
		Date Analyzed:	12/1/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name:	173.3-94	**Units:**	ug/L
Lab Code:	R2514813-025	**Basis:**	NA
Analysis Method:	200.8		

		Matrix Spike R2514813-025MS			Duplicate Matrix Spike R2514813-025DMS					
Analyte Name	**Sample Result**	**Result**	**Spike Amount**	**% Rec**	**Result**	**Spike Amount**	**% Rec**	**% Rec Limits**	**RPD**	**RPD Limit**
Lead, Total	ND U	21.7	20.0	109	21.9	20.0	110	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25
		Date Analyzed:	12/1/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name:	173.3-95	**Units:**	ug/L
Lab Code:	R2514813-026	**Basis:**	NA
Analysis Method:	200.8		

		Matrix Spike R2514813-026MS			Duplicate Matrix Spike R2514813-026DMS					
Analyte Name	**Sample Result**	**Result**	**Spike Amount**	**% Rec**	**Result**	**Spike Amount**	**% Rec**	**% Rec Limits**	**RPD**	**RPD Limit**
Lead, Total	1.5	22.5	20.0	105	22.9	20.0	107	70-130	2	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Analyzed:**	12/01/25
Sample Matrix:	Drinking Water		

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2514813-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.9	20.0	105	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Analyzed:**	12/01/25
Sample Matrix:	Drinking Water		

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2514813-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.6	20.0	108	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client:	Stohl Environmental	**Service Request:**	R2514813
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Analyzed:**	12/01/25
Sample Matrix:	Drinking Water		

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2514813-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.8	20.0	104	85-115

December 08, 2025 Service Request No:R2514814

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Southwestern CSD - Southwestern Elementary

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory November 05, 2025
For your reference, these analyses have been assigned our service request number **R2514814.**

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
PHONE +1 585 288 5380 | FAX +1 585 288 8475
ALS Group USA, Corp.
dba ALS Environmental

Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

1565 Jefferson Rd, Building 300, Rochester, NY 14623 | 585-288-5380 | www.alsglobal.com

Client: Stohl Environmental
Project: Southwestern CSD - Southwestern Elementary
Sample Matrix: Drinking Water
Service Request: R2514814
Date Received: 11/05/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Twenty nine drinking water samples were received for analysis at ALS Environmental on 11/05/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

Approved by Meghan Pedro Date 12/08/2025

SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 173.3-106 — **Lab ID: R2514814-001**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.1			1.0	ug/L	200.8

CLIENT ID: 173.3-107 — **Lab ID: R2514814-002**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.5			1.0	ug/L	200.8

CLIENT ID: 173.3-108 — **Lab ID: R2514814-003**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.5			1.0	ug/L	200.8

CLIENT ID: 173.3-109 — **Lab ID: R2514814-004**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.1			1.0	ug/L	200.8

CLIENT ID: 173.3-110 — **Lab ID: R2514814-005**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.1			1.0	ug/L	200.8

CLIENT ID: 173.3-111 — **Lab ID: R2514814-006**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.9			1.0	ug/L	200.8

CLIENT ID: 173.3-113 — **Lab ID: R2514814-008**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.6			1.0	ug/L	200.8

CLIENT ID: 173.3-114 — **Lab ID: R2514814-009**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.2			1.0	ug/L	200.8

CLIENT ID: 173.3-115 — **Lab ID: R2514814-010**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.2			1.0	ug/L	200.8

CLIENT ID: 173.3-116 — **Lab ID: R2514814-011**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	6.0			1.0	ug/L	200.8

CLIENT ID: 173.3-117 — **Lab ID: R2514814-012**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.1			1.0	ug/L	200.8

CLIENT ID: 173.3-118 — **Lab ID: R2514814-013**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	5.9			1.0	ug/L	200.8

SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 173.3-119 — **Lab ID: R2514814-014**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.8			1.0	ug/L	200.8

CLIENT ID: 173.3-120 — **Lab ID: R2514814-015**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.4			1.0	ug/L	200.8

CLIENT ID: 173.3-121 — **Lab ID: R2514814-016**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	4.4			1.0	ug/L	200.8

CLIENT ID: 173.3-122 — **Lab ID: R2514814-017**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.7			1.0	ug/L	200.8

CLIENT ID: 173.3-123 — **Lab ID: R2514814-018**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	5.2			1.0	ug/L	200.8

CLIENT ID: 173.3-124 — **Lab ID: R2514814-019**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	5.1			1.0	ug/L	200.8

CLIENT ID: 173.3-125 — **Lab ID: R2514814-020**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	9.7			1.0	ug/L	200.8

CLIENT ID: 173.3-126 — **Lab ID: R2514814-021**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	6.4			1.0	ug/L	200.8

CLIENT ID: 173.3-127 — **Lab ID: R2514814-022**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	4.6			1.0	ug/L	200.8

CLIENT ID: 173.3-128 — **Lab ID: R2514814-023**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.2			1.0	ug/L	200.8

CLIENT ID: 173.3-129 — **Lab ID: R2514814-024**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.0			1.0	ug/L	200.8

CLIENT ID: 173.3-130 — **Lab ID: R2514814-025**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	8.0			1.0	ug/L	200.8

SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 173.3-131 — **Lab ID: R2514814-026**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.8			1.0	ug/L	200.8

CLIENT ID: 173.3-132 — **Lab ID: R2514814-027**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	8.3			1.0	ug/L	200.8

CLIENT ID: 173.3-133 — **Lab ID: R2514814-028**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	5.1			1.0	ug/L	200.8

CLIENT ID: 173.3-134 — **Lab ID: R2514814-029**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	4.7			1.0	ug/L	200.8

Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental **Service Request:**R2514814
Project: Southwestern CSD - Southwestern Elementary/2023L-173.3

SAMPLE CROSS-REFERENCE

SAMPLE #	CLIENT SAMPLE ID	DATE	TIME
R2514814-001	173.3-106	10/31/2025	
R2514814-002	173.3-107	10/31/2025	
R2514814-003	173.3-108	10/31/2025	
R2514814-004	173.3-109	10/31/2025	
R2514814-005	173.3-110	10/31/2025	
R2514814-006	173.3-111	10/31/2025	
R2514814-007	173.3-112	10/31/2025	
R2514814-008	173.3-113	10/31/2025	
R2514814-009	173.3-114	10/31/2025	
R2514814-010	173.3-115	10/31/2025	
R2514814-011	173.3-116	10/31/2025	
R2514814-012	173.3-117	10/31/2025	
R2514814-013	173.3-118	10/31/2025	
R2514814-014	173.3-119	10/31/2025	
R2514814-015	173.3-120	10/31/2025	
R2514814-016	173.3-121	10/31/2025	
R2514814-017	173.3-122	10/31/2025	
R2514814-018	173.3-123	10/31/2025	
R2514814-019	173.3-124	10/31/2025	
R2514814-020	173.3-125	10/31/2025	
R2514814-021	173.3-126	10/31/2025	
R2514814-022	173.3-127	10/31/2025	
R2514814-023	173.3-128	10/31/2025	
R2514814-024	173.3-129	10/31/2025	
R2514814-025	173.3-130	10/31/2025	
R2514814-026	173.3-131	10/31/2025	
R2514814-027	173.3-132	10/31/2025	
R2514814-028	173.3-133	10/31/2025	
R2514814-029	173.3-134	10/31/2025	

Chain of Custody Document

Stohl ENVIRONMENTAL
3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-173.3

Client: Southwestern CSD

Contact: Stephen Olson

Building: Southwestern Elementary

Location: 600 County Touring Rte 32 #1, Jamestown, NY 14701

LEAD		Turnaround
Water by 200.8	X	10 Days

Sample #	Location	Outlet Type	Time
173.3-106	C243 Classroom	Sink	7:36
173.3-107	C243 DF	DF	7:37
173.3-108	C244 Classroom	Sink	7:38
173.3-109	C244 DF	DF	7:39
173.3-110	C245 Classroom	Sink	7:40
173.3-111	C245 DF	DF	7:41
173.3-112	C251 Office, MakerSpace	Sink	7:43
173.3-113	D260 Classroom	Sink	7:44
173.3-114	D260 DF	DF	7:45
173.3-115	D261 Classroom	Sink	7:46
173.3-116	D263 Art Classroom DF	DF	7:47
173.3-117	D266 Classroom	Sink	7:48
173.3-118	D266 DF	DF	7:50
173.3-119	D267 Classroom	Sink	7:51
173.3-120	D268 Classroom	Sink	7:52
173.3-121	D268 DF	DF	7:53
173.3-122	D269 Classroom	Sink	7:54
173.3-123	D269 DF	DF	7:55

Notes:
Please e-mail lab results to labs@stohlenv.com

Mscinta@stohlenvironmental.com

Sampled By:	Jared Rider	Print Name	Stohl Env: Jared Rider	Date:	10/31/2025
Relinquished By:		Print Name	Stohl Env: Connor Crilly	Date:	11/4/2025
Received (Name / Lab):			Date: 11/5/25	Time:	15:00
Sample Login (Name / Lab):			Date:	Time:	
Analysis (Name / Lab):			Date:	Time:	
QA/QC Review (Name / Lab):			Date:		
Archived / Released:		QA/QC InterLAB Use:	Date:		

R2514814 5
Stohl Environmental
Southwestern CSD - Southwestern Elementary

Page 7 of 8

Chain of Custody Document

Stohl ENVIRONMENTAL
3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-173.3

Client: Southwestern CSD

Contact: Stephen Olson

Building: Southwestern Elementary

Location: 600 County Touring Rte 32 #1, Jamestown, NY 14701

LEAD		Turnaround
Water by 200.8	X	10 Days

Sample #	Location	Outlet Type	Time
173.3-124	D270 Classrom	Sink	7:57
173.3-125	D270 DF	DF	7:58
173.3-126	D271 Classroom	Sink	7:59
173.3-127	D271 DF	DF	8:00
173.3-128	D272 Storage	Sink	8:01
173.3-129	D272 DF	DF	8:02
173.3-130	D277 Classroom	Sink	8:04
173.3-131	D277 DF	DF	8:05
173.3-132	A-120 Maintenance Breakroom	Sink	8:06
173.3-133	A-119-Hall Left Drinking Fountain Outside A119	DF	8:07
173.3-134	A-119-Hall Right DF	DF	8:08

Notes:
Please e-mail lab results to labs@stohlenv.com

Mscinta@stohlenvironmental.com

Sampled By:	Jared Rider	Print Name	Stohl Env:	Jared Rider	Date: 10/31/2025
Relinquished By:		Print Name	Stohl Env:	Connor Crilly	Date: 11/4/2025
Received (Name / Lab):			Date:	11/5/25	Time: 15:00
Sample Login (Name / Lab):			Date:		Time:
Analysis (Name / Lab):			Date:		Time:
QA/QC Review (Name / Lab):			Date:		
Archived / Released:		QA/QC InterLAB Use:	Date:		

R2514814 5
Stohl Environmental
Southwestern CSD - Southwestern Elementary

Page 8 of 8

R2514814 5
Stohl Environmental
Southwestern CSD - Southwestern Elementary

Cooler Receipt and Preservation Che

Project/Client Stohl Environmental Folder Number _____.

Cooler received on 11/5/25 by: KE COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y N	5a	Did VOA vials have sig* bubbles?		Y N NA	
2	Custody papers properly completed (ink, signed)?	Y N	5b	Sig* bubbles: Alk?	Y N NA	Sulfide?	Y N NA
3	Did all bottles arrive in good condition (unbroken)?	Y N	6	Where did the bottles originate?		ALS/ROC	CLIENT
4	Circle: Wet Ice Dry Ice Gel packs present?	Y N	7	Soil VOA received as:	Bulk Encore 5035set		NA

8. Temperature Readings Date: 11/5/25 Time: 05:40 ID: IR#12 IR#11 From: Temp Blank Sample Bottle

Temp (°C)	18.4						
Within 0-6°C?	Y N	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: _____ Ice melted Poorly Packed (described below) Same Day Rule

&Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SM0 by KE on 11/5/25 at 05:50
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 11/11 Time: 1700 by: AG

9. Were all bottle labels complete (*i.e.* analysis, preservation, etc.)? YES NO
10. Did all bottle labels and tags agree with custody papers? YES NO
11. Were correct containers used for the tests indicated? YES NO
12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO N/A
13. Were dissolved metals filtered in the field? YES NO N/A
14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved? Yes	Preserved? No	Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
≥12		NaOH								
≤2	202328	HNO_3	>		24017806	1/27				
≤2		H_2SO_4								
<4		$NaHSO_4$								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add $Na_2S_2O_3$ (625, 608, CN), ascorbic (phenol).					
		$Na_2S_2O_3$								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: _____

Explain all Discrepancies/ Other Comments:

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: AG *significant air bubbles: VOA > 5-6 mm : WC >1 in. diameter

P:\INTRANET\QAQC\Forms Controlled\Cooler Receipt r21.doc 05/17/2024

Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

REPORT QUALIFIERS AND DEFINITIONS

U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.

J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Arclors).

B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.

E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.

E Organics- Concentration has exceeded the calibration range for that specific analysis.

D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.

* Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.

H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.

Spike was diluted out.

+ Correlation coefficient for MSA is <0.995.

N Inorganics- Matrix spike recovery was outside laboratory limits.

N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.

S Concentration has been determined using Method of Standard Additions (MSA).

W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.

P Concentration >40% difference between the two GC columns.

C Confirmed by GC/MS

Q DoD reports: indicates a pesticide/Aroclor is not confirmed (≥100% Difference between two GC columns).

X See Case Narrative for discussion.

MRL Method Reporting Limit. Also known as:
LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.

MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).

LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.

ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations[1]

NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

[1] Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx.

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

Client: Stohl Environmental **Service Request:** R2514814
Project: Southwestern CSD - Southwestern Elementary/2023L-173.3

Sample Name: 173.3-106 **Date Collected:** 10/31/25
Lab Code: R2514814-001 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-107 **Date Collected:** 10/31/25
Lab Code: R2514814-002 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-108 **Date Collected:** 10/31/25
Lab Code: R2514814-003 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-109 **Date Collected:** 10/31/25
Lab Code: R2514814-004 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-110 **Date Collected:** 10/31/25
Lab Code: R2514814-005 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Client: Stohl Environmental **Service Request:** R2514814
Project: Southwestern CSD - Southwestern Elementary/2023L-173.3

Sample Name: 173.3-111 **Date Collected:** 10/31/25
Lab Code: R2514814-006 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-112 **Date Collected:** 10/31/25
Lab Code: R2514814-007 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-113 **Date Collected:** 10/31/25
Lab Code: R2514814-008 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-114 **Date Collected:** 10/31/25
Lab Code: R2514814-009 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-115 **Date Collected:** 10/31/25
Lab Code: R2514814-010 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Client: Stohl Environmental **Service Request:** R2514814
Project: Southwestern CSD - Southwestern Elementary/2023L-173.3

Sample Name: 173.3-116 **Date Collected:** 10/31/25
Lab Code: R2514814-011 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-117 **Date Collected:** 10/31/25
Lab Code: R2514814-012 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-118 **Date Collected:** 10/31/25
Lab Code: R2514814-013 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-119 **Date Collected:** 10/31/25
Lab Code: R2514814-014 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-120 **Date Collected:** 10/31/25
Lab Code: R2514814-015 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Client: Stohl Environmental **Service Request:** R2514814
Project: Southwestern CSD - Southwestern Elementary/2023L-173.3

Sample Name: 173.3-121 **Date Collected:** 10/31/25
Lab Code: R2514814-016 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-122 **Date Collected:** 10/31/25
Lab Code: R2514814-017 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-123 **Date Collected:** 10/31/25
Lab Code: R2514814-018 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-124 **Date Collected:** 10/31/25
Lab Code: R2514814-019 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-125 **Date Collected:** 10/31/25
Lab Code: R2514814-020 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Client: Stohl Environmental **Service Request:** R2514814
Project: Southwestern CSD - Southwestern Elementary/2023L-173.3

Sample Name: 173.3-126 **Date Collected:** 10/31/25
Lab Code: R2514814-021 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-127 **Date Collected:** 10/31/25
Lab Code: R2514814-022 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-128 **Date Collected:** 10/31/25
Lab Code: R2514814-023 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-129 **Date Collected:** 10/31/25
Lab Code: R2514814-024 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-130 **Date Collected:** 10/31/25
Lab Code: R2514814-025 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Client: Stohl Environmental **Service Request:** R2514814
Project: Southwestern CSD - Southwestern Elementary/2023L-173.3

Sample Name: 173.3-131 **Date Collected:** 10/31/25
Lab Code: R2514814-026 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-132 **Date Collected:** 10/31/25
Lab Code: R2514814-027 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-133 **Date Collected:** 10/31/25
Lab Code: R2514814-028 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		MKASTAN

Sample Name: 173.3-134 **Date Collected:** 10/31/25
Lab Code: R2514814-029 **Date Received:** 11/5/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":
For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.

Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-106	**Basis:**	NA
Lab Code:	R2514814-001		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.1**	ug/L	1.0	1	12/01/25 15:49	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-107	**Basis:**	NA
Lab Code:	R2514814-002		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.5**	ug/L	1.0	1	12/01/25 15:50	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-108	**Basis:**	NA
Lab Code:	R2514814-003		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.5**	ug/L	1.0	1	12/01/25 15:52	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-109	**Basis:**	NA
Lab Code:	R2514814-004		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.1**	ug/L	1.0	1	12/01/25 15:53	

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-110	**Basis:**	NA
Lab Code:	R2514814-005		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.1**	ug/L	1.0	1	12/01/25 15:55	

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-111	**Basis:**	NA
Lab Code:	R2514814-006		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.9**	ug/L	1.0	1	12/01/25 15:59	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-112	**Basis:**	NA
Lab Code:	R2514814-007		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/01/25 16:01	

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-113	**Basis:**	NA
Lab Code:	R2514814-008		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.6**	ug/L	1.0	1	12/01/25 16:02	

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-114	**Basis:**	NA
Lab Code:	R2514814-009		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**2.2**	ug/L	1.0	1	12/01/25 16:04	

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-115	**Basis:**	NA
Lab Code:	R2514814-010		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.2**	ug/L	1.0	1	12/01/25 16:15	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-116	**Basis:**	NA
Lab Code:	R2514814-011		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**6.0**	ug/L	1.0	1	12/01/25 16:19	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-117	**Basis:**	NA
Lab Code:	R2514814-012		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.1**	ug/L	1.0	1	12/01/25 16:21	

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-118	**Basis:**	NA
Lab Code:	R2514814-013		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**5.9**	ug/L	1.0	1	12/01/25 16:22	

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-119	**Basis:**	NA
Lab Code:	R2514814-014		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**3.8**	ug/L	1.0	1	12/01/25 16:24	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-120	**Basis:**	NA
Lab Code:	R2514814-015		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.4**	ug/L	1.0	1	12/01/25 16:25	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-121	**Basis:**	NA
Lab Code:	R2514814-016		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**4.4**	ug/L	1.0	1	12/01/25 16:30	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-122	**Basis:**	NA
Lab Code:	R2514814-017		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.7**	ug/L	1.0	1	12/01/25 16:32	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-123	**Basis:**	NA
Lab Code:	R2514814-018		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**5.2**	ug/L	1.0	1	12/01/25 16:33	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-124	**Basis:**	NA
Lab Code:	R2514814-019		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**5.1**	ug/L	1.0	1	12/01/25 16:35	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-125	**Basis:**	NA
Lab Code:	R2514814-020		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**9.7**	ug/L	1.0	1	12/01/25 16:36	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-126	**Basis:**	NA
Lab Code:	R2514814-021		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**6.4**	ug/L	1.0	1	12/01/25 16:38	

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-127	**Basis:**	NA
Lab Code:	R2514814-022		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**4.6**	ug/L	1.0	1	12/01/25 16:39	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-128	**Basis:**	NA
Lab Code:	R2514814-023		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**2.2**	ug/L	1.0	1	12/01/25 16:41	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-129	**Basis:**	NA
Lab Code:	R2514814-024		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**3.0**	ug/L	1.0	1	12/01/25 16:42	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-130	**Basis:**	NA
Lab Code:	R2514814-025		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**8.0**	ug/L	1.0	1	12/01/25 16:44	

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-131	**Basis:**	NA
Lab Code:	R2514814-026		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**3.8**	ug/L	1.0	1	12/01/25 16:49	

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-132	**Basis:**	NA
Lab Code:	R2514814-027		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**8.3**	ug/L	1.0	1	12/01/25 16:50	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-133	**Basis:**	NA
Lab Code:	R2514814-028		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**5.1**	ug/L	1.0	1	12/01/25 16:52	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25 15:00
Sample Name:	173.3-134	**Basis:**	NA
Lab Code:	R2514814-029		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**4.7**	ug/L	1.0	1	12/03/25 13:51	

QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	NA
Sample Matrix:	Drinking Water	**Date Received:**	NA
Sample Name:	Method Blank	**Basis:**	NA
Lab Code:	R2514814-MB1		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/01/25 15:22	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	NA
Sample Matrix:	Drinking Water	**Date Received:**	NA
Sample Name:	Method Blank	**Basis:**	NA
Lab Code:	R2514814-MB2		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/01/25 16:12	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	NA
Sample Matrix:	Drinking Water	**Date Received:**	NA
Sample Name:	Method Blank	**Basis:**	NA
Lab Code:	R2514814-MB3		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/03/25 13:45	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25
		Date Analyzed:	12/1/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name:	173.3-114	**Units:**	ug/L
Lab Code:	R2514814-009	**Basis:**	NA
Analysis Method:	200.8		

		Matrix Spike R2514814-009MS			Duplicate Matrix Spike R2514814-009DMS					
Analyte Name	**Sample Result**	**Result**	**Spike Amount**	**% Rec**	**Result**	**Spike Amount**	**% Rec**	**% Rec Limits**	**RPD**	**RPD Limit**
Lead, Total	2.2	24.0	20.0	109	23.7	20.0	107	70-130	1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Collected:**	10/31/25
Sample Matrix:	Drinking Water	**Date Received:**	11/05/25
		Date Analyzed:	12/1/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name:	173.3-115	**Units:**	ug/L
Lab Code:	R2514814-010	**Basis:**	NA
Analysis Method:	200.8		

		Matrix Spike R2514814-010MS			Duplicate Matrix Spike R2514814-010DMS					
Analyte Name	**Sample Result**	**Result**	**Spike Amount**	**% Rec**	**Result**	**Spike Amount**	**% Rec**	**% Rec Limits**	**RPD**	**RPD Limit**
Lead, Total	1.2	22.9	20.0	108	23.1	20.0	110	70-130	1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Analyzed:**	12/01/25
Sample Matrix:	Drinking Water		

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2514814-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.8	20.0	104	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Analyzed:**	12/01/25
Sample Matrix:	Drinking Water		

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2514814-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.9	20.0	110	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client:	Stohl Environmental	**Service Request:**	R2514814
Project:	Southwestern CSD - Southwestern Elementary/2023L-173.3	**Date Analyzed:**	12/03/25
Sample Matrix:	Drinking Water		

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2514814-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.1	20.0	106	85-115

1.5 Laboratory Certifications

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER

Expires 12:01 AM April 01, 2026
Issued April 01, 2025

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE
Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. CHRISTINE KUTZER
ALS ENVIRONMENTAL - ROCHESTER
1565 JEFFERSON ROAD BUILDING 300, SUITE 360
ROCHESTER, NY 14623

NY Lab Id No: 10145

is hereby APPROVED as an Environmental Laboratory in conformance with the National Environmental Laboratory Accreditation Conference Standards (2016) for the category ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:

Bacteriology	
Coliform, Total / E. coli (Qualitative)	SM 20, 21-23 9223B (-04) (Colilert)
Dissolved Gases	
Acetylene	RSK-175
Ethane	RSK-175
Ethene (Ethylene)	RSK-175
Methane	RSK-175
Propane	RSK-175
Fuel Additives	
Methyl tert-butyl ether	EPA 524.2
Naphthalene	EPA 524.2
Metals I	
Arsenic, Total	EPA 200.8 Rev. 5.4
Barium, Total	EPA 200.8 Rev. 5.4
Cadmium, Total	EPA 200.8 Rev. 5.4
Chromium, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Copper, Total	EPA 200.8 Rev. 5.4
Iron, Total	EPA 200.7 Rev. 4.4
Lead, Total	EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Mercury, Total	EPA 245.1 Rev. 3.0
Selenium, Total	EPA 200.8 Rev. 5.4
Silver, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Zinc, Total	EPA 200.7 Rev. 4.4

Serial No.: 70111

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at https://apps.health.ny.gov/pubdoh/applinks/wc/elappublicweb/, by phone (518) 485-5570 or by email to elap@health.ny.gov.

Page 1 of 5