

Lead in Drinking Water Report



Date of Sample		6/1/2023	
Sampled by		WSDOH	
Sample ID	Fixture Location	Lead Test Result (ppb)	Final Remediation
046-36021	BHS Floor 1 - Kitchen-E-Faucet-B1	ND	
046-36022	BHS Floor 1 - Kitchen-F-Sprayer-B2	4.80	
046-36024	BHS Floor 1 - Kitchen-H-Faucet	6.00	Handwashing only
046-36027	BHS Floor 1 - Main office: nurse office-A-Faucet-B5	3.30	
046-36028	BHS Floor 1 - Main office: cot room-A-Faucet-B4	ND	
046-36029	BHS Floor 1 - Main office: copy room-A-Faucet-B6	1.30	
046-36032	BHS Floor 1 - Student store-A-Faucet-B7	1.50	
046-36033	BHS Floor 1 - Commons hallway (Right)-A-Fountain-B8	ND	
046-36034	BHS Floor 1 - Commons hallway (Left)-B-Fountain-B9	ND	
046-36035	BHS Floor 1 - Room 115-A-Faucet-B10	2.10	
046-36036	BHS Floor 1 - Classroom-A-Faucet-B11	ND	

046-36038	BHS Floor 1 - Hallway off main entry (behind kitchen) -B-Fountain (middle)-B12	ND	
046-36039	BHS Floor 1 - Hallway off main entry (behind kitchen)-C-Water bottle filling station-B13	ND	
046-36040	BHS Floor 1 - Hallway off main entry (behind kitchen)-D-Fountain (left)-B14	1.60	
046-36041	BHS Floor 1 - Community transitions classroom-A-Faucet-B15	ND	
046-36043	BHS Floor 1 - Gym hallway by weight room (left)-A-Fountain-B16	ND	
046-36044	BHS Floor 1 - Gym hallway by weight room (right)-B-Fountain-B17	ND	
046-36045	BHS Floor 1 - Hallway by stage (right)-A-Fountain-B18	ND	
046-36046	BHS Floor 1 - Hallway by stage (left)-B-Fountain-B19	ND	
046-36051	BHS Floor 1 - Room 145-A-Faucet-B20	ND	
046-36052	BHS Floor 1 - Room 145-B-Faucet-B21	ND	
046-36053	BHS Floor 1 - Room 145-C-Faucet-B22	ND	
046-36054	BHS Floor 1 - Room 147-A-Faucet-B23	ND	
046-36055	BHS Floor 1 - Room 147-B-Faucet-B24	ND	
046-36056	BHS Floor 1 - Room 147-C-Faucet-B25	ND	
046-36057	BHS Floor 2 - Hallway outside bathrooms (right)-A-Fountain -B26	ND	
046-36058	BHS Floor 2 - Hallway outside bathrooms (left)-C-Fountain-B28	ND	

046-36059	BHS Floor 2 - Hallway outside bathrooms (right)-B-Water bottle filling station-B27	ND	
046-36062	BHS Floor 2 - Room 208-A-Faucet-B30	10.40	Handwashing only
046-36063	BHS Floor 2 - Room 203-A-Faucet-B29	ND	
046-36065	BHS Floor 3 - Outside girls' and boys' bathrooms-A-Fountain-B31	ND	
046-36066	BHS Floor 3 - Outside girls' and boys' bathrooms-B-Water bottle filling station-B32	ND	
046-36067	BHS Floor 3 - Room 315-A-Faucet-B33	ND	
046-36068	BHS Floor 3 - Room 315-B-Faucet-B34	ND	
046-36069	BHS Floor 3 - Room 315-C-Faucet-B35	1.10	
046-36070	BHS Floor 3 - Room 315-D-Faucet-B36	1.30	
046-36071	BHS Floor 3 - Room 315-E-Faucet-B37	2.00	
046-36072	BHS Floor 3 - Room 315-F-Faucet-B38	1.70	
046-36073	BHS Floor 3 - Room 315-G-Faucet-B39	<1	
046-36076	BHS Floor 3 - Room 312-A-Faucet-B42	1.00	
046-36077	BHS Floor 3 - Room 308-A-Faucet-B41	ND	
046-36078	BHS Floor 3 - Room 303-A-Faucet-B40	3.30	