



2150 Smithtown Ave., Suite 3, Ronkonkoma, NY 11779
T: 631.580.3191 • F: 631.580.3195 • W: envirohealth.org

December 10, 2025

Mr. Ray Renda
Edgemont UFSD
300 White Oak Lane
Scarsdale, NY 10583

Re: **Lead in Drinking Water Sampling & Analysis 2023-2025**

Dear Mr. Renda,

On December 9, 2025, Enviroscience Consultants performed a limited sampling event at Greenville Elementary School, located at 100 Glendale Rd, Scarsdale, NY 10583. Samples were collected from newly installed kitchen fixtures:

New Kitchen Prep Sink
New Kitchen 3-Bay Dish Wash Sink (Left)
New Kitchen 3-Bay Dish Wash Sink (Right)
New Kitchen 3-Bay Dish Wash Sink Spray

First draw samples were collected in wide-mouth 250 milliliter containers and during the early morning, prior to any water sources being used. The samples were transported to New York Environmental Laboratory and were analyzed for lead concentration. The current limit for lead in drinking water is 5 parts per billion (ppb). Any locations that were above the limit were taken out of service pending remediation.

There were no exceedances.

Please see the attached lab report for detailed results at each location. These locations have satisfied the requirement for the 2023-2025 Lead in Drinking Water sampling period.

Should you have any questions, please feel free to contact me.

Sincerely,

A handwritten signature in black ink, appearing to read "Casey Lee".

Casey Lee
Environmental Project Manager

Laboratory Report

December 10, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Ave.
Ronkonkoma, NY, 11779

Project: Edgemont UFSD
Project Address: Greenville Elementary School
Report ID: 251209021
Sample IDs: 251209021-372 - 251209021-375

New York Environmental is a NELAC accredited laboratory. Attached reported results meet the requirements of the NELAC standard unless otherwise noted.

Samples' analytical results relate only to the parameters tested for the samples received in the condition received by the laboratory, as noted on the Chain of Custody. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	9-Dec-25
Date Received:	9-Dec-25
Date Analyzed:	10-Dec-25

Analytical Method:	EPA 200.9
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
251209021-372	1	New Kitchen, Prep Sink - SK; initial	0.001	0.001	mg/L	
251209021-373	2	New Kitchen, 3-Bay Dish Wash Sink - Left - SK; initial	0.001	0.001	mg/L	
251209021-374	3	New Kitchen, 3-Bay Dish Wash Sink - Right - SK; initial	0.001	0.003	mg/L	
251209021-375	4	New kitchen , 3-Bay Dish Wash - Spray - SPY; initial	0.001	0.002	mg/L	

Comment(s):

LOQ: Limit of Quantitation

CID: Client ID

