

Lead in Drinking Water Report Squalicum High School



Date of Sample		11/22/2023	10/18/2024	
Sampled by		WSDOH	Terracon	
Sample ID	Fixture Location	Lead Test Result (ppb)	Lead Test Result (ppb)	Final Remediation
386363	Kitchen Pot Filler	34.00	7.10	Out of service
386361	Kitchen center island	3.00		
386362	Kitchen left of stand mixer	2.00		
386360	Kitchen Sink right of white board	<1		
386364	Kitchen Sprayer	<1		
386365	Hallway outside rm F119 water bottle filler	<1		
386366	Hallway outside rm F119 Water fountain	<1		
386367	Lower mountain house hallway water fountain	<1		
386368	Lower sky house 1 of 2 water fountain	<1		
386369	Lower sky house 2 of 2 water fountain	<1		
386370	Lower bay house water bottle filler	<1		
386371	Library bathroom hallway water bottle filler	<1		

386372	Library bathroom hallway 1 of 2, water fountain	<1		
386373	Library bathroom 2 of 2, water fountain	<1		
386374	main office bathrooms- water bottle filler	<1		
386375	Main office bathrooms- water fountain	<1		
386376	Upper bay house water fountain	<1		
386377	B-215 teacher station 1 of 7- tap	<1		
386378	B-215 station 2 of 7 -tap	<1		
386379	B-215 station 3 of 7 -tap	<1		
386380	B-215 station 4 of 7 -tap	<1		
386381	B-215 station 5 of 7 -tap	<1		
386382	B-215 station 6 of 7 -tap	<1		
386383	B-215 station 7 of 7 -tap	<1		
386384	Upper sky house 1 of 2- water fountain	<1		
386385	Upper sky house 2 of 2- water fountain	<1		
386386	upper mountain house water fountain	<1		
386387	weight room bathrooms 1 of 2 water fountain	<1		
386388	weight room bathrooms 2 of 2 water fountain	<1		