Cell Fill Color Legend	
Cell Fill Color Legend	
Input is REQUIRED	
Do NOT enter data	
Error - MUST correct prior to submission	

Entity ID #:	1976	**Schl ID #:**	249
Entity Name:	Bend-La Pine Administrative SD 1		
School Name:	Pilot Butte Middle School		

Building ID # (BIN):	19760600
Building Name:	Building Gymnasium

Min Report Level:	1

GYM

	Fixture Location / Expense Description	Fixture ID # (FIN)	Initial Test Date	Initial Test Result (ppb)	Number of Retests	Final Test Result (ppb)
*	Gym Girls RR Left	19760600-001BF	06/13/24	1	[retests]	[result]
	Gym Girls RR Right	19760600-002BF	06/13/24	ND		
	Gym Lobby Left	19760600-003DW	06/13/24	ND		
	Gym Lobby Right-Fountain	19760600-004DW	06/13/24	ND		
	Gym Lobby Right Bottle Filler	19760600-005WB	06/13/24	ND		
	Bym Boys RR Left	19760600-006BF	06/13/24	ND		
	Gym Boys RR Right	19760600-007BF	06/13/24	Nd		
	B Locker Entry Bottle Filler	19760600-008WB	06/13/24	ND		
	B Locker Entry Fountain	19760600-009DW	06/13/24	ND		
	Locker Entry RR Left	19760600-010BF	06/13/24	ND		
	Boys Lockr Main Right	19760600-011BF	06/13/24	ND		
	Boys Coach RR	19760600-012BF	06/13/24	1.8		
	Boys Storage Sink	19760600-013SF	06/13/24	9		
	Girls Locker Entry Bottle	19760600-014WB	06/13/24	ND		
	Girls Locker Entry Fountain	19760600-015DW	06/13/24	ND		
	Girls Coach RR	19760600-016BF	06/13/24	ND		

Girls Storage Sink	19760600-017SF	06/13/24	**22.1**	1	ND
Girls Locker Main Left	19760600-018BF	06/13/24	ND		
Girls Locker Main Right	19760600-019BF	06/13/24	ND		
Gym Girls RR Middle Left	19760600-020BF	06/13/24	ND		
Gym Girls RR Middle Right	19760600-021BF	06/13/24	ND		
Gym Boys RR Middle Left	19760600-022SF	06/13/24	ND		
Gym Boys RR Middle Right	19760600-023BF	06/13/24	ND		
Boys Locker Room Main Middle Left	19760600-024BF	06/13/24	ND		
Boys Locker Room Main Middle Right	19760600-025BF	06/13/24	ND		
Girls Locker Room Main Middle Left	19760600-026BF	06/13/24	ND		
Girls Locker Room Main Middle Right	19760600-027BF	06/13/24	ND		
B BUILDING					
B7 Faucet	19760601-001CF	06/13/24	ND		
B8 RR	19760601-003BF	06/13/24	9.5		
BE Faucet	19760601-003CF	06/13/24	ND		
B Hall East Left Fountain	19760601-004DW	06/13/24	ND		
B Hall East Right Filler	19760604-005WB	06/13/24	ND		
B Hall East Right Fountain	19760601-006DW	06/13/24	ND		
B Boys RR Left	19760601-007BF	06/13/24	ND		
B Boys RR Left middle	19760601-008BF	06/13/24	ND		
B Boys RR Right Middle	19760601-009BF	06/13/24	ND		
BBoys RR Right	19760601-010BF	06/13/24	ND		
B5 Faucet	19760601-011CF	06/13/24	ND		
B6 Faucet	19760601-012CF	06/13/24	ND		
B3 Faucet	19760601-013CF	06/13/24	ND		
B4 Faucet	197606001-014CF	06/13/24	ND		

B Hall West Left Fountain	19760601-015DW	06/13/24	ND
B Hall West Right Filler	19760601-016WB	06/13/24	ND
B HAll West Right Fountain	19760601-017DW	06/13/24	ND
B HAll Girls RR Left	19760601-018BF	06/13/24	ND
B Haall Girls RR Left Middle	19760601-019BF	06/13/24	ND
B Hall Girls RR Right Middle	19760601-020BF	06/13/24	ND
B Hall Girls RR Right	19760601-021BF	06/13/24	ND
B1 East Faucet	19760601-022CF	06/13/24	ND
B1 North Faucet- REMOVED - NO FAUCET TO TEST	19760601-023CF	06/13/24	
B1 WEst Faucet	197606001-024CF	06/13/24	ND
B1 Teacher Office	19760601-025CF	06/13/24	ND
B Hall Staff Room	19760601-026SF	06/13/24	ND
B2 Faucet	19760601-027CF	06/13/24	ND
C BUILDING			
C Hall West Fountain	19760602-021DW	06/13/24	ND
C9 Faucet	19760602-022CF	06/13/24	ND
C11 Faucet	19760602-023CF	06/13/24	ND
C10 Faucet	19760602-024CF	06/13/24	ND
C12 Faucet	197606002-025CF	06/13/24	ND
C13 Faucet	19760602-026CF	06/13/24	ND
D BUILDING			
D2 Faucet	19760603-016CF		ND
D Girls RR Middle Right	19760603-017BF		ND
D Boys RR Middle Right	19760603-018BF		ND
D Hall Left Fountain	19760603-019DW		ND
D Hall Right Fountain	19760603-020DW		ND
D Hall Filler	19760603-021WB		ND
E BUILDING			

E grils RR Left	19760604-021BF	06/13/24	ND
East Girls RR Right	19760604-022BF	06/13/24	ND
East Back Entry Right Fountain	19760604-023DW	06/13/24	ND
East Back Entry Left Filler	19760604-024WB	06/13/24	ND
E Back Entry Left Fountain	19760604-025DW	06/13/24	ND
E Boys RR Left	19760604-026BF	06/13/24	ND
E Boys RR Right	19760604-027BF	06/13/24	ND
E West Entry Right Founain	19760604-028DW	06/13/24	ND
E West Entry Left Fountain	19760604-029DW	06/13/24	ND
E WEst Entry Filler	19760604-030WB	06/13/24	ND
E Girls RR Middle	19760604-031BF	06/13/24	ND
E Boys RR Middle-DECOMMISSIONED	19760604-032BF	06/13/24	

CAFÉ BUILDING

Band Room Faucet	19760605-001CF	06/13/24	ND
Mens Staff RR Left	19760605-002BF	06/13/24	1.5
Mens Staff RR Right	19760605-003BF	06/13/24	5
Womens Staff RR Left	19760605-004BF	06/13/24	1.5
Womens Staff RR Right	19760605-005BF	06/13/24	ND
Cafe Fountain	19760605-006DW	06/13/24	ND
Cafe Filler	19760605-007WB	06/13/24	ND
Kitchen Sink	19760605-009KF	06/13/24	ND
Custodial Office	19760605-010SF	06/13/24	ND
Band Room Fountain	19760605-011DW	06/13/24	ND
Choir Room Sink	19760605-012CF	06/13/24	1.1
Choir Room Fountain	19760605-013DW	06/13/24	ND

G BUILDING

G1 Faucet	19760606-001CF	06/13/24	1.5
G2 Faucet	19760606-002CF	06/13/24	ND
G3 Faucet	19760606-003CF	06/13/24	ND

G Boys RR Left	19760606-004BF	06/13/24	
G Boys RR Middle	19760606-005BF	06/13/24	1.7
G Boys RR Right	19760606-006BF	06/13/24	7.1
G Hall Left Fountain	19760606-007DW	06/13/24	ND
G Hall Right Fountain	19760606-008DW	06/13/24	ND
G Girls RR Left	19760606-009BF	06/13/24	ND
G Girls RR Middle	19760606-010BF	06/13/24	
G Girls RR Right	19760606-011BF	06/13/24	ND
G Art Left Faucet	19760606-012CF	06/13/24	ND
G Art Right Faucet	19760606-013CF	06/13/24	ND