Cell Fill Color Legend	
Cell Fill Color Legend	
Input is REQUIRED	
Do NOT enter data	
Error - MUST correct prior to submission	

Entity ID #:	1976	**Schl ID #:**	3217
Entity Name:	Bend-LaPine Administrative SD 1		
School Name:	Sky View Middle School		

Building ID # (BIN):	19761900
Building Name:	Sky View Middle School

Min Report Level:	1

	Fixture Location / Expense Description	Fixture ID # (FIN)	Initial Test Date	Initial Test Result (ppb)	Number of Retests	Final Test Result (ppb)
*	Kitchen Snack Bar	19761900-001KF	06/13/24	ND	[retests]	[result]
	Kitchen Hand Wash	19761900-002KF	06/13/24	ND		
	Kitchen Sink - Cooler	19761900-003KF	06/13/24	ND		
	Prep Sink Left	19761900-004KF	06/13/24	23.4	1	ND
	Prep Sink Right	19761900-005KF	06/13/24	36	1	7.3
	Hand Sink East	19761900-006KF	06/13/24	ND		
	Kettle Faucet	19761900-007OT	06/13/24	2.1		
	Kitchen RR	19760900-008BF	06/13/24	ND		
	Cafe Fountain	19761900-009DW	06/13/24	ND		
	Cafe Bottle Filler	19761900-010WB	06/13/24	ND		
	Band Faucet	19761900-011CF	06/13/24	ND		
	Band Fountain	19761900-012DW	06/13/24	ND		
	Boys LR Coach RR	19761900-013BF	06/13/24	ND		
	Boys LR RR Right	19761900-014BF	06/13/24	ND		
	Boys LR RR Left	19761900-015BF	06/13/24	ND		
	Girls LR RR Right	19761900-016BF	06/13/24	ND		
	Girls LR RR LEft	19761900-017BF	06/13/24	ND		
	Girls LR RR Coach	19761900-018BF	06/13/24	ND		
	Athletic HAll Left	19761900-019DW	06/13/24	ND		

Athletic Hall Right	19761900-020DW	06/13/24	ND
Music Hall Staff RR	19761900-021BF	06/13/24	ND
Music Hall Girls RR Left	19761900-022BF	06/13/24	6.1
Music Hall Girls RR Middle Left	19761900-023BF	06/13/24	ND
Music Hall Girls RR Middle Right	19761900-024BF	06/13/24	ND
Music Hall Girls RR Right	19761900-025BF	06/13/24	ND
Music Hall Boys RR Left	19761900-026BF	06/13/24	ND
Music Hall boys RR Middle Left	19761900-027BF	06/13/24	ND
Music Hall Boys RR Middle Right	19761900-028BF	06/13/24	ND
Music Hall Boys RR Right	19761900-029BF	06/13/24	1
Gym Lobby Fountain Left	19761900-030DW	06/13/24	ND
Gym Lobby Fountain Right	19761900-031DW	06/13/24	ND
Gym Lobby Bottle Filler	19761900-032WB	06/13/24	ND
Concession Sink	19761900-033SF	06/13/24	3.1
502 Faucet	19761900-034CF	06/13/24	ND
502 Fountain	19761900-035DW	06/13/24	ND
501 Faucet	19761900-036CF	06/13/24	ND
510 Fountain	19761900-037DW	06/13/24	ND
Staff Lounge	19761900-038SF	06/13/24	ND
Office RR Left	19761900-039BF	06/13/24	ND
Office RR Right	19761900-040BF	06/13/24	ND
Like Skills WEst Faucet	19761900-041CF	06/13/24	ND
Life Skills East Faucet	19761900-042CF	06/13/24	ND
Life Skills East RR	19761900-043BF	06/13/24	ND
Media Work Room	19761900-044SF	06/13/24	ND
Art West Faucet	19761900-045CF	06/13/24	ND
Art South Faucet	19761900-046CF	06/13/24	ND
Art SE Faucet	19761900-047CF	06/13/24	ND

Tech Storage	19761900-048CF	06/13/24	ND		
Shop Left Faucet	19761900-049CF	06/13/24	ND		
Shop Right Faucet	19761900-050CF	06/13/24	ND		
200 Boys RR Left	19761900-051BF	06/13/24	ND		
200 Boys RR Right	19761900-052BF	06/13/24	ND		
200 Girls RR Left	19761900-053BF	06/13/24	ND		
200 Girls RR Right	19761900-054BF	06/13/24	ND		
201 Faucet	19761900-055CF	06/13/24	1.1		
201 Fountain	19761900-056DW	06/13/24	ND		
202 Faucet	19761900-057CF	06/13/24	ND		
202 Fountain	19761900-058DW	06/13/24	ND		
203 Faucet	19761900-059CF	06/13/24	ND		
203 Fountain	19761900-060DW	06/13/24	ND		
204 Faucet	19761900-061CF	06/13/24	ND		
204 Fountain	19761900-062DW	06/13/24	ND		
205 Fuacet	19761900-063CF	06/13/24	ND		
205 Fountain	19761900-064DW	06/13/24	ND		
206 North Faucet	19761900-065CF	06/13/24	2.8		
206 East Left Faucet	19761900-066CF	06/13/24	ND		
	19761900-067CF	06/13/24	ND		
206 South Faucet	19761900-068CF	06/13/24	**13.4**		
206 West Left Faucet	19761900-069CF	06/13/24	1.2		
206 West Right	19761900-070CF	06/13/24	1.1		
200 Commons Filler	19761900-071WB	06/13/24	ND		
200 Work room Faucet	19761900-072CF	06/13/24	ND		
200 Work Room Fountain	19761900-073DW	06/13/24	1.3		
200 Staff RR Faucet	19761900-074BF	06/13/24	ND		
200 Hall Left Fountain	19761900-075DW	06/13/24	ND		
200 Hall Right Fountain	19761900-076DW	06/13/24	ND		
100-200 Science prep sink	19761900-077SF	06/13/24	ND		
100 Staff RR	19761900-078BF	06/13/24	ND		
106 North	19761900-079CF	06/13/24	**184**	1	4
106 East Left Faucet	19761900-080CF	06/13/24	ND		
106 E Right Faucet	19761900-081CF	06/13/24	1.6		
106 South Faucet	19761900-082CF	06/13/24	ND		

106 West Left Faucet	19761900-083CF	06/13/24	1.6
106 West Right Faucet	19761900-084CF	06/13/24	1.6
105 Faucet	19761900-085CF	06/13/24	ND
105 Fountain	19761900-086DW	06/13/24	ND
104 Faucet	19761900-087CF	06/13/24	1.6
104 Fountain	19761900-088DW	06/13/24	ND
103 Faucet	19761900-089CF	06/13/24	1.6
103 Fountain	19761900-090DW	06/13/24	ND
102 Faucet	19761900-091CF	06/13/24	ND
102 Fountain	19761900-092DW	06/13/24	ND
101 Faucet	19761900-093CF	06/13/24	ND
101 Fountain	19761900-094DW	06/13/24	ND
100 Commons Filler	19761900-095WB	06/13/24	ND
100 Work Room Faucet	19761900-096CF	06/13/24	3.5
100 Work Room Fountain	19761900-097DW	06/13/24	3
100 Boys RR Left	19761900-098BF	06/13/24	ND
100 Boys RR Right	19761900-099BF	06/13/24	ND
100 Girls RR Left	19761900-100BF	06/13/24	ND
100 Gils RR Right	19761900-101BF	06/13/24	ND
300 Girls RR Left	19761900-102BF	06/13/24	ND
300 Gilrs RR Right	19761900-103BF	06/13/24	ND
300 Boys RR Left	19761900-104BF	06/13/24	ND
300 oys RR Right	19761900-105BF	06/13/24	ND
300 Staff RR	19761900-106BF	06/13/24	ND
301 Faucet	19761900-107CF	06/13/24	ND
301 Fountain	19761900-108DW	06/13/24	10.9
302 Faucet	19761900-109CF	06/13/24	ND
302 Fountain	19761900-110DW	06/13/24	ND
300 Commons Filler	19761900-111WB	06/13/24	ND
303 Faucet	19761900-112CF	06/13/24	ND
303 Fountain	19761900-113DW	06/13/24	1
304 Faucet	19761900-114CF	06/13/24	ND
304 Fountain	19761900-115DW	06/13/24	ND
305 Faucet	19761900-116CF	06/13/24	ND
305 fountain	19761900-117DW	06/13/24	ND
306 North Faucet	19761900-118CF	06/13/24	1.2
306 E Left Faucet	19761900-119CF	06/13/24	3.3

306 E Right Faucet	19761900-120CF	06/13/24	ND		
306 South Faucet	19761900-121CF	06/13/24	6		
306 W Left Faucet	19761900-122CF	06/13/24	2.5		
306 W Right Faucet	19761900-123CF	06/13/24	ND		
300 Work Room Faucet	19761900-124CF	06/13/24	ND		
300 Work Room Fountain	19761900-125DW	06/13/24	1.8		
300-400 Scienc Prep Sink	19761900-126SF	06/13/24	ND		
400 Hall R Fountain	19761900-127DW	06/13/24	ND		
400 Hall L Fountain	19761900-128DW	06/13/24	ND		
406 N Faucet	19761900-129CF	06/13/24	1.6		
406 E Left Faucet	19761900-130CF	06/13/24	1.1		
406 E Right Faucet	19761900-131CF	06/13/24	ND		
406 S Faucet	19761900-132CF	06/13/24	**54.4**	1	1.3
406 W Left Faucet	19761900-133CF	06/13/24	2.8		
406 W Right Faucet	19761900-134CF	06/13/24	ND		
405 Faucet	19761900-135CF	06/13/24	1.8		
405 Fountain	19761900-136DW	06/13/24	3.5		
404 Fuacet	19761900-137CF	06/13/24	ND		
404 Fountain	19761900-138DW	06/13/24	ND		
403 Faucet	19761900-139CF	06/13/24	ND		
403 Fountain	19761900-140DW	06/13/24	ND		
402 Faucet	19761900-141CF	06/13/24	ND		
402 Fountain	19761900-142DW	06/13/24	ND		
400Commons Filler	19761900-143WB	06/13/24	ND		
401 Faucet	19761900-144CF	06/13/24	1.5		
401 Fountain	19761900-145DW	06/13/24	ND		
400 Work Room	19761900-146SF	06/13/24	**18.8**	1	ND
400 ork Room Fountain	19761900-147DW	06/13/24	5		
400 Staff RR	19761900-148BF	06/13/24	ND		
400 Boys RR Left	19761900-149BF	06/13/24	ND		
400 Boys RR Right	19761900-150BF	06/13/24	ND		
400 Girls RR Left	19761900-151BF	06/13/24	ND		
400 Girls RR Right	19761900-152BF	06/13/24	ND		