Entity ID #:	1976	**Schl ID #:**	241
Entity Name:	Bend-La Pine Administrative SD 1		
School Name:	Bear Creek Elementary		

Cell Fill Color Legend
Input is REQUIRED
Do NOT enter data
Error - MUST correct prior to submission

Building ID # (BIN):	19760100
Building Name:	Bear Creek Elementary

Min Report Level:	1

Fixture Location / Expense Description	Fixture ID # (FIN)	Initial Test Date	Initial Test Result (ppb)	Number of Retests	Final Test Result (ppb)
Lobby Fountain	19760100-001DW	06/06/24	ND	[retests]	[result]
Lobby II Bottle Filler	19760100-002WB	06/06/24	ND		
Nurse's Room	19760100-003NS	06/06/24	1.9		
Nurse RR	19760100-004BF	06/06/24	1.2		
B1 Faucet	19760100-005CF	06/06/24	**13**		
B1 Fountain	19760100-006DW	06/06/24	1.8		
B2 Faucet	19760100-007CF	06/06/24	**23.8**	1	4.6
B2 Fountain	19760100-008DW	06/06/24	2		
B3 Faucet	19760100-009CF	06/06/24	2.8		
B3 Fountain	19760100-010DW	06/06/24	1.5		
B Girls RR Left	19760100-011BF	06/06/24	2.3		
B Girls RR Right	19760100-012BF	06/06/24	2.6		
B6 Faucet	19760100-013CF	06/06/24	1.9		
B6 Fountain	19760100-014DW	06/06/24	3.7		
B5 Faucet	19760100-015CF	06/06/24	4		
B5 Fountain	19760100-016DW	06/06/24	1.7		
B4 Faucet	19760100-017CF	06/06/24	1.6		
B4 Fountain	19760100-018DW	06/06/24	3.6		
Staff Lounge	19760100-019SF	06/06/24	3.6		
B Boys RR Left	19760100-020BF	06/06/24			
B Boys RR Right	19760100-021BF	06/06/24	2.2		
B Staff RR	19760100-022BF	06/06/24	1.7		
C1 Faucet	19760100-023CF	06/06/24	1.6		
C1 Fountain	19760100-024DW	06/06/24	1.2		
C Girls RR Left	19760100-024BF	06/06/24	2.4		
C Girls RR Right	19760100-026BF	06/06/24	2.1		
C Boys RR Left	19760100-027BF	06/06/24	2.1		
C Boys RR Right	19760100-028BF	06/06/24	2.5		
C2 Faucet	19760100-029CF	06/06/24	2		
C2 Fountain	19760100-030DW	06/06/24	2.3		

C3 Faucet	19760100-031CF	06/06/24	2.7
C3 Fountain	19760100-032DW	06/06/24	3.2
C4 Facuet	19760100-033CF	06/06/24	6.3
C4 Fountain	19760100-034DW	06/06/24	3.7
C Instruction	19760100-035CF	06/06/24	2.2
Library Office	19760100-036CF	06/06/24	1.2
D Staff RR	19760100-037BF	06/06/24	1.8
D Boys RR Left	19760100-038BF	06/06/24	5.6
D Boys RR Right	19760100-039BF	06/06/24	3.3
D Instruction	19760100-040CF	06/06/24	2.6
D4 Faucet	19760100-041CF	06/06/24	3.6
D4 Fountain	19760100-042DW	06/06/24	1.6
D5 Faucet	19760100-043CF	06/06/24	5.1
D5 Fountain	19760100-044DW	06/06/24	2.8
D6 Fuacet	19760100-045CF	06/06/24	2
D6 Fountain	19760100-046DW	06/06/24	4.7
D Work Room	19760100-047SF	06/06/24	**14**
D Girls RR Left	19760100-048BF	06/06/24	2.8
D Girls RR Right	19760100-049BF	06/06/24	2.3
D3 Faucet	19760100-050CF	06/06/24	2.2
D3 Fountain	19760100-051DW	06/06/24	1.5
D2 Faucet	19760100-052CF	06/06/24	7.4
D2 Fountain	19760100-053DW	06/06/24	3.1
D1 Faucet	19760100-054CF	06/06/24	8.7
D1 Fountain	19760100-055DW	06/06/24	2.5
E Commons Faucet	19760100-056CF	06/06/24	1.4
E Commons Fountain	19760100-057DW	06/06/24	1
Staff Room	19760100-058SF	06/06/24	ND
A9 Faucet	19760100-059CF	06/06/24	1.5
A9 Fountain	19760100-060DW	06/06/24	5.2
Kitchen Hand sink East	19760100-061KF	06/06/24	ND
Kitchen Prep Sink	19760100-062KF	06/06/24	ND
Kitchen Hand sink West	197600100-063KF	06/06/24	ND
Café RR Left	19760100-064BF	06/06/24	ND
Café RR Right	19760100-065BF	06/06/24	ND
A Hall RR Left	19760100-066BF	06/06/24	ND
A Hall RR Mid	19760100-067BF	06/06/24	ND
A Hall RR Right Mid	19760100-068BF	06/06/24	ND
A Hall RR Right	19760100-069BF	06/06/24	ND

A8 Faucet	19760100-070CF	06/06/24	ND		
A8 Fountain	19760100-071DW	06/06/24	ND		
A7 Faucet	19760100-072CF	06/06/24	ND		
A7 Fountain	19760100-073DW	06/06/24	ND		
A Hall Water Bottle	197600100-074WB	06/06/24	ND		
A Hall fountain	19760100-075DW	06/06/24	ND		
A Boys RR Left	19760100-076BF	06/06/24	ND		
A Boys RR Right	19760100-077BF	06/06/24	ND		
A Girls RR Left	19760100-078BF	06/06/24	ND		
A Girls RR Right	19760100-079BF	06/06/24	ND		
A6 Faucet	19760100-080CF	06/06/24	1		
A6 Fountain	19760100-081DW	06/06/24	ND		
A5 Faucet	19760100-082CF	06/06/24	ND		
A5 Fountain	19760100-083DW	06/06/24	ND		
A4 Faucet	19760100-084CF	06/06/24	1.1		
A4 Fountain	19760100-085DW	06/06/24	ND		
A Faucet	19760100-086CF	06/06/24	ND		
A3 Fountain	19760100-087DW	06/06/24	ND		
A2 Faucet	19760100-088CF	06/06/24	1.4		
A2 Fountain	19760100-089DW	06/06/24	ND		
A1 Faucet	19760100-090CF	06/06/24	1.5		
A1 Fountain	19760100-091DW	06/06/24	ND		
West Commons Staff RR	19760100-092SF	06/06/24	ND		
Music Faucet	19760100-093CF	06/06/24	**27.6**	1	3.6
Music Fountain	19760100-094DW	06/06/24	2.3		
Gym Fountain	19760100-095DW	06/06/24	ND		
Gym Water Bottle Filler	19760100-096WB	06/06/24	ND		
Gym Boys RR	19760100-097BF	06/06/24	4.6		
Gym Girls RR	19760100-098BF	06/06/24	2.5		
Life Skills Faucet	19760100-099CF	06/06/24	ND		
Life Skills RR	19760100-100BF	06/06/24	ND		
Staff workroom	19760100-101SF	06/06/24	11.9		