

Lead in Drinking Water Report Fairhaven Middle School



Date of Sample		6/22/2023	10/18/2024	
Sampled by		Edge Analytical	Terracon	
Sample ID	Fixture Location	Lead Test Result (ppb)	Lead Test Result (ppb)	Final Remediation
046-36085	FMS - Floor 1 -Kitchen-E-Dishwasher sprayer	5.5		Cleaning only sign
046-36086	FMS - Floor 1 - Kitchen-F-Faucet	4		
046-36091	FMS - Floor 1 - Main office: health room	ND		
046-36092	FMS - Floor 1 - Main office: health room	ND		
046-36093	FMS - Floor 1 - Main entrance foyer-A-Water	ND		
046-36094	FMS - Floor 1 - Main entrance foyer-B-Bubbler	ND		
046-36096	FMS - Floor 1 - Room 100-A-Faucet	ND		
046-36097	FMS - Floor 1 - Room 103-A-Faucet	3.3		
046-36098	FMS - Floor 1 - Room 103-B-Bubbler	3.3		
046-36099	FMS-Floor 1- room 101-A	5.4		Hand Washing Only
046-36100	FMS - Floor 1 - Room 101-B-Bubbler	2		
046-36102	FMS - Floor 2 - Room 201-A-Faucet	4.2		
046-36103	FMS - Floor 2 - Room 201-B-Bubbler	1.5		
046-36104	FMS - Floor 2 - Room 202-A-Faucet	5		
046-36105	FMS - Floor 2 - Room 202-B-Bubbler	1.2		
046-36106	FMS - Floor 2 - Room 203-A-Faucet	5.8		Hand Washing Only

046-36107	FMS - Floor 2 - Room 203-B-Bubbler	1.5		
046-36108	FMS - Floor 2 - Room 204-A-Faucet	3		
046-36109	FMS - Floor 2 - Room 204-B-Bubbler	2		
046-36110	FMS - Floor 2 - Hallway-A-Bubbler	ND		
046-36111	FMS - Floor 2 - Room 205-A-Faucet	4.5		
046-36112	FMS - Floor 2 - Room 205-B-Bubbler	1.4		
046-36113	FMS - Floor 2 - Room 206-A-Faucet	8.2		Hand Washing Only
046-36114	FMS - Floor 2 - Room 206-B-Bubbler	1.4		
046-36115	FMS - Floor 2 - Room 206-C-Faucet	20.9	17	Hand Washing Only
046-36116	FMS - Floor 2 - Room 207-A-Faucet	4.3		
046-36117	FMS - Floor 2 - Room 207-B-Bubbler	ND		
046-36118	FMS - Floor 2 - Room 208-A-Faucet	4.2		
046-36119	FMS - Floor 2 - Room 208-B-Bubbler	ND		
046-36120	FMS - Floor 1 - Room 104-A-Faucet	2.6		
046-36121	FMS - Floor 1 - Room 104-B-Bubbler	1.8		
046-36122	FMS - Floor 1 - Room 105-A-Faucet	2.4		
046-36123	FMS - Floor 1 - Room 105-B-Bubbler	1.7		
046-36124	FMS - Floor 1 - Room 311-A-Faucet	5.3		Hand Washing Only
046-36125	FMS - Floor 1 - Room 311-B-Bubbler	ND		
046-36126	FMS - Floor 1 - Room 312-A-Faucet	3.3		
046-36127	FMS - Floor 1 - Room 312-B-Bubbler	ND		
046-36128	FMS - Floor 1 - Room 315-A-Faucet	4.8		
046-36129	FMS - Floor 1 - Room 315-B-Bubbler	ND		
046-36130	FMS - Floor 1 - Room 314-A-Faucet	3.2		
046-36131	FMS - Floor 1 - Room 314-B-Bubbler	1.7		
046-36133	FMS - Floor 1 - Room 317-B-Faucet	1.2		
046-36136	FMS - Floor 1 - Room 310-A-Faucet	3.9		
046-36137	FMS - Floor 1 - Room 310-B-Bubbler	3.9		
046-36138	FMS - Floor 1 - Room 309-A-Faucet	3.9		
046-36139	FMS - Floor 1 - Room 309-B-Bubbler	2.2		
046-36140	FMS - Floor 1 - Room 308-A-Faucet	5		
046-36141	FMS - Floor 1 - Room 308-B-Bubbler	1.3		
046-36142	FMS - Floor 1 - Upper foyer-A-Bubbler	ND		

046-36143	FMS - Floor 1 - Room 305/307-A-Faucet	ND		
046-36144	FMS - Floor 1 - Room 305/307-B-Bubbler	ND		
046-36145	FMS - Floor 1 - Room 306-A-Faucet	5.6		Hand Washing Only
046-36146	FMS - Floor 1 - Room 306-B-Faucet	6.4		Hand Washing Only
046-36148	FMS - Floor 1 - Room-306-D-Faucet	10.8		Hand Washing Only
046-36149	FMS - Floor 1 - Room 306-E-Faucet	10.2		Hand Washing Only
046-36150	FMS - Floor 1 - Room-306-F-Faucet	8.7		Hand Washing Only
046-36151	FMS - Floor 1 - Room 306-G-Bubbler	ND		
046-36152	FMS - Floor 1 - Room 304-A-Faucet	4.8		
046-36153	FMS - Floor 1 - Room 304-B-Faucet	3.9		
046-36154	FMS - Floor 1 - Room 304-C-Faucet	9.9		Hand Washing Only
046-36155	FMS - Floor 1 - Room 304-D-Faucet	12.4		Hand Washing Only
046-36156	FMS - Floor 1 - Room 304-E-Faucet	13.8		Hand Washing Only
046-36157	FMS - Floor 1 - Room 304-F-Bubbler	1.2		
046-36158	FMS - Floor 1 - Room 303-A-Faucet	3.7		
046-36159	FMS - Floor 1 - Room 303-B-Bubbler	1.6		
046-36160	FMS - Floor 1 - Room 301-A-Faucet	1.6		
046-36161	FMS - Floor 1 - Room 301-B-Bubbler	1.5		
046-36162	FMS - Floor 1 - Room 302-A-Faucet	4		
046-36163	FMS - Floor 1 - Room 302-B-Bubbler	1		
046-36164	FMS - Floor 1 - Room 302-C-Faucet	5.8		Hand Washing Only
046-36165	FMS - Floor 1 - Room 302-D Faucet	12.2		Hand Washing Only
046-36167	FMS - Floor 1 - Room 302-F-Faucet	4.3		
046-36168	FMS - Floor 1 - Room 302-G-Faucet	6.8		Hand Washing Only
046-36169	FMS - Floor 1 - Gym-A-Bubbler	ND		
046-36170	FMS - Floor 1 - Gym-B-Water bottle filling station	ND		