

Lead in Drinking Water Report Shuksan Middle School



Date of Sample			10/13/23 & 11/7/23	10/18/2024	
Sampled by			Washington State Department of Health	Terracon	
Sample ID	Fixture Location	Fixture Type	Lead Test Result (ppb)	Lead Test Results	Final Remediation
374306	Kitchen	Sink - Multi-compartment	3		
374307	Kitchen	Sink - Multi-compartment	6		Washing only sign
374308	Ice machine	Ice Machine	<1		
374309	Kitchen	Sink - Multi-compartment	4		
374310	Kitchen	Pot Filler	13	3	
374311	Cafeteria	Sink	2		
374312	Hallway between gy	Fountain - Multi-level with Bottle Filler	<1		
374313	Hallway between gy	Fountain - Multi-level with Bottle Filler	<1		
374314	Hallway between gy	Fountain - Multi-level with Bottle Filler	<1		
374315	Girls locker room	Fountain - Multi-level	<1		
374316	Girls locker room	Fountain - Multi-level	<1		
374317	Boys locker room	Fountain - Multi-level	<1		
374318	Boys locker room	Fountain - Multi-level	<1		
374319	Main hall	Fountain - Multi-level with Bottle Filler	<1		
374320	Main hall	Fountain - Multi-level with Bottle Filler	<1		
374321	Main hall	Fountain - Multi-level with Bottle Filler	<1		

374322	Art room	Sink	3		
374323	Art room	Sink	<1		
374324	Arm room	Sink	<1		
374325	Art room	Sink	<1		
374326	Technology rm102	Sink	<1		
374327	Hallway across from	Fountain - Multi-level	<1		
374328	Rm113 life skills	Sink - Multi-compartment	<1		
374329	Hallway across from	Fountain - Multi-level	<1		
374330	Rm 112 science	Sink	1		
374331	Sixth grade common	Fountain/Tap Combo	<1		
374332	Sixth grade common	Fountain/Tap Combo	2		
374333	Rm107	Fountain/Tap Combo	1		
374334	Rm107	Fountain/Tap Combo	6	1.9	
374335	Rm108	Fountain/Tap Combo	<1		
374336	Rm108	Fountain/Tap Combo	2		
374337	Rm103 science	Sink	<1		
374338	Rm219	Fountain/Tap Combo	2		
374339	In hallway next to st	Fountain - Multi-level	<1		
374380	In hallway next to st	Fountain - Multi-level	<1		
374381	8th grade common a	Fountain/Tap Combo	<1		
374382	8th grade common r	Fountain/Tap Combo	21	3.4	
374383	Rm207	Fountain/Tap Combo	<1		
374384	Rm207	Fountain/Tap Combo	1		
374385	Rm208	Fountain/Tap Combo	<1		
374386	Rm208	Fountain/Tap Combo	4		
374387	Rm208	Fountain/Tap Combo	<1		
374388	Rm208	Fountain/Tap Combo	1		
374389	Rm210	Fountain/Tap Combo	<1		
374390	Rm210	Fountain/Tap Combo	2		
374391	Rm211	Fountain/Tap Combo	<1		
374392	Rm211	Fountain/Tap Combo	5		
374393	Rm212	Fountain/Tap Combo	<1		
374394	Rm212	Fountain/Tap Combo	<1		

374395	Rm213 science	Sink	<1		
374396	Rm214 science	Sink	1		
374397	Rm215	Fountain/Tap Combo	<1		
374398	Rm215	Fountain/Tap Combo	<1		
374399	Rm216	Fountain/Tap Combo	<1		
374400	Rm216	Fountain/Tap Combo	2		
374401	Rm217	Fountain/Tap Combo	1		
374402	Rm217	Fountain/Tap Combo	3		
374403	Rm218	Fountain/Tap Combo	<1		
374404	Rm218	Fountain/Tap Combo	6	5.3	Fountain turned off
374405	Rm201	Fountain/Tap Combo	<1		
374406	Rm201	Fountain/Tap Combo	2		
374407	Rm202	Fountain/Tap Combo	<1		
374408	Rm202	Fountain/Tap Combo	2		
374409	Rm204 science	Sink	<1		
374410	Rm205	Fountain/Tap Combo	<1		
374411	Rm206	Fountain/Tap Combo	<1		
374412	Rm206	Fountain/Tap Combo	1		
374413	Rm104	Fountain/Tap Combo	<1		
374414	Rm104	Fountain/Tap Combo	<1		
374415	Rm105	Fountain/Tap Combo	<1		
374416	Rm105	Fountain/Tap Combo	1		
374417	Rm106	Fountain/Tap Combo	<1		
374418	Rm106	Fountain/Tap Combo	<1		
374419	Rm109	Fountain/Tap Combo	<1		
385980	Rm109	Fountain/Tap Combo	<1		
386131	Rm111	Fountain/Tap Combo	<1		
386133	Rm111	Fountain/Tap Combo	<1		
386135	Rm110	Fountain/Tap Combo	<1		
386137	Rm110	Fountain/Tap Combo	<1		