

Lead in School Drinking Water Report

Alderwood MS - Old (New-In-Lieu'd)



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-10-09

Date(s) analyzed: 2025-10-15, 2025-10-24

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	412222	Building B	Sink	Kitchen Workroom	1 of 1	Tap	center	396
2	412221	Building B	Pot Filler	Kitchen	3 of 3	Tap	center	212
3	412219	Building B	Sink	Kitchen	1 of 3 wall countertop	Sprayer	center	60
4	412244	Building C	Sink	Rm19	1 of 3 left counter	Tap	center	58
5	412238	Building D	Fountain/Tap Combo	Hub	1 of 1	Tap	left	36
6	412246	Building C	Sink	Rm19	3 of 3 right counter right	Tap	center	25
7	412248	Building A	Fountain	Music Hallway	1 of 1	Water Fountain	center	21
8	412220	Building B	Sink	Kitchen	2 of 3 middle island	Tap	center	18
9	412232	Building C	Sink	Rm5	1 of 1	Tap	right	10

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
10	412234	Building C	Sink	Rm6	1 of 2 left	Tap	center	10
11	412236	Building C	Sink - Multi-Compartment	Rm14	1 of 1	Tap	center	9
12	412239	Building D	Fountain/Tap Combo	Hub	1 of 1	Tap	center	8
13	412242	Building C	Sink	Rm17	1 of 1	Tap	center	5
14	412247	Building C	Fountain	Right Of Rm22	1 of 1	Water Fountain	center	5
15	412223	Building B	Fountain with Bottle Filler	Cafeteria	1 of 1	Water Fountain	center	4
16	412228	Building C	Sink	Health Room	1 of 1	Tap	center	4
17	412229	Building C	Sink	Staff Lounge	1 of 1	Tap	center	4
18	412233	Building C	Fountain	Right Of Rm6	1 of 1	Water Fountain	center	4
19	412235	Building C	Sink	Rm6	2 of 2 right	Tap	center	4
20	412240	Building D	Fountain/Tap Combo	Hub	1 of 1	Water Fountain	right	4
21	412249	Building A	Fountain	Boys Locker Room	1 of 1	Water Fountain	center	4
22	412226	Building A	Fountain	Gym	1 of 2 foyer side	Water Fountain	center	3

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
23	412237	Building C	Sink	Rm14 Laundry Room	1 of 1	Tap	center	3
24	412241	Building C	Fountain	Left Of Rm17	1 of 1	Water Fountain	center	3
25	412218	Building B	Sink	Kitchen	1 of 3 wall countertop	Tap	center	2
26	412227	Building A	Fountain	Gym	2 of 2 boys locker room side	Water Fountain	center	2
27	412243	Building C	Fountain	Right Of Rm19	1 of 1	Water Fountain	center	2
28	412230	Building C	Fountain	Left Of Counseling Center	1 of 1	Water Fountain	center	1
29	412224	Building B	Fountain with Bottle Filler	Cafeteria	1 of 1	Water Bottle Filler	center	<1
30	412225	Building A	Fountain	Gym Foyer	1 of 1	Water Fountain	center	<1
31	412231	Building C	Sink	Library Office	1 of 1	Tap	center	<1
32	412245	Building C	Sink	Rm19	2 of 3 right counter left	Tap	center	<1

