

Lead in Drinking Water Report Whatcom Middle School



Date of Sample			10/12/2022	3/10/2023 & 4/4/23	6/18/2024	
Sampled by			Washington State Department of Health	Terracon	Washington State Department of Health	Final Remediation
Sample ID	Fixture Location	Fixture Type/Location Detail	Lead Test Result (ppb)	Lead Test Results	Lead Test Results	
375161	Kitchen	Sink - Multi-compartment	3	2.3		
375162	Kitchen	Sink - Multi-compartment	1	3.5		
375163	Kitchen	Pot Filler	5	<1		
375164	Kitchen	Pot Filler	1	<1		
375165	Kitchen	Sink	1	<1		
375166	Kitchen	Pot Filler	1	<1		
375167	Kitchen	Sink	1	<1		
375168	Kitchen	Pot Filler	1	<1		
375169	Kitchen	Sink	1	<1		
375170	Kitchen	Sink	1	<1		
375171	Kitchen	Sink	<1	<1		
375172	Cafeteria	Fountain with Cooler	<1	<1		
375173	Cafeteria	Fountain - Multi-level with Bottle Filler	<1	<1		

375174	Cafeteria	Fountain - Multi-level with Bottle Filler	<1	<1		
375175	B/n b21 and b19	Fountain - Multi-level	<1	<1		
375176	Hall	Fountain - Multi-level	<1	<1		
375177	B22 N wall	Sink	5			
375178	B22 wrk rm	Sink	8			Handwashing Only
375179	B22 SE wall	Sink	2			
375180	B22	Sink	2			
375181	B22	Sink	3			
375182	B22	Sink	11			Handwashing Only
375183	B22	Sink	2			
375184	B22	Sink	2			
375185	B22	Sink	2			
375186	B22	Sink	2			
375187	B21	Fountain/Tap Combo	1			
375188	B21	Fountain/Tap Combo	2			
375189	B19	Fountain/Tap Combo	1			
375190	B 18	Fountain/Tap Combo	1			
375191	B15	Fountain/Tap Combo	2			
375192	B15	Fountain/Tap Combo	1			
375193	B14	Fountain/Tap Combo	1			
375194	B14	Fountain/Tap Combo	5			
375195	b09	Fountain/Tap Combo	1			
375196	B11	Fountain/Tap Combo	1			
375197	B13	Sink	2			
375198	B13	Sink	2			
375199	B13 s wall	Sink	1			
375200	B13	Sink	4			
375201	B13	Sink	1			
375202	B13	Sink	2			
375203	B13 n wall	Sink	2			
375204	B13 n wall	Sink	2			

375205	B13 n wall	Sink	2			
375206	N wall b13	Sink	1			
375207	Main office	Sink	<1			
375208	Main office	Sink	<1			
375209	B/n 109 and elevato	Fountain - Multi-level	<1	<1		
375210	B/n 109 and elevato	Fountain - Multi-level	1	<1		
375211	Rm 118	Sink	1	2.4		
375212	Rm 117	Fountain/Tap Combo	2	1.1		
375213	Rm 112	Fountain/Tap Combo	1	<1		
375214	114	Fountain/Tap Combo	<1	<1		
375215	115	Sink	1	1.6		
375216	115	Sink	1	1.9		
375217	115	Sink	2	1.7		
375218	Wrk rm	Sink	9	3.8		
375219	115	Sink	3	1.3		
375220	115	Sink	2	1.7		
375221	115	Sink	2	1.6		
375222	115	Sink	2	1.6		
375223	115	Sink	2	2.9		
375225	115	Sink	2	2.2		
375226	104	Fountain/Tap Combo	1	<1		
375227	103	Fountain/Tap Combo	1	1.4		
375228	103	Fountain/Tap Combo	1	1.1		
375229	102	Fountain/Tap Combo	1	1.1		
375230	102	Fountain/Tap Combo	1	1.4		
375231	101	Fountain/Tap Combo	1	1.1		
375232	101	Fountain/Tap Combo	3	2.4		
375233	135	Fountain/Tap Combo	1	<1		
375234	135	Fountain/Tap Combo	2	<1		
375235	136	Sink	2	1.6		
375236	136	Sink	3	1.8		
375237	136	Sink	2	2.3		
375238	136	Sink	4	2.3		

375239	136	Sink	6	2.4		
375240	136	Sink	3	1.5		
375241	136	Sink	3	2.4		
375242	136	Sink	3	1.8		
375243	136	Sink	2	1.6		
375244	136	Sink	6	2.5		
375245	220	Sink	3			
375246	220	Sink	3			
375247	220	Sink	5			
375248	220	Sink	2			
375249	220	Sink	5			
375250	220	Sink	4			
375251	220.1	Sink	12			Handwashing Only
375252	220	Sink	3			
375253	220	Sink	2			
375254	220	Sink	3			
375255	219	Fountain/Tap Combo	1			
230310-01	1st Floor Teacher Lo	Primary Faucet		<1.0		
230310-02	1st Floor Teacher Lo	Hot Water Faucet		<1.0		
230310-03	1st Floor Teacher Lo	Espresso machine hot water dispenser		12		Out of Service
230310-04	Women's Staff Restro	Room 134		<1.0		
230310-05	Men's Staff Restroom	Room 133		<1.0		
230310-06	Boy's Student Restro	Room 109. West sink		<1.0		
230310-07	Boy's Student Restro	Room 109. Center sink		<1.0		
230310-08	Boy's Student Restro	Room 109. East sink		<1.0		
230310-09	Girl's Student Restro	Room 110. West sink		<1.0		
230310-10	Girl's Student Restro	Room 110. Center sink		<1.0		
230310-11	Girl's Student Restro	Room 110. East sink		<1.0		
230310-12	Boy's Student Restro	Room 206. West sink		<1.0		
230310-13	Boy's Student Restro	Room 206. Center sink		<1.0		
230310-14	Boy's Student Restro	Room 206. East sink		<1.0		
230310-15	Girl's Student Restro	Room 207. West sink		<1.0		

230310-16	Girl's Student Restro	Room 207. Center sink		<1.0		
230310-17	Girl's Student Restro	Room 207. East sink		<1.0		
230310-18*	All gender Restroom	Next too Room 210. Western Restroom		<1.0		
230310-19	All gender Restroom	Next too Room 210. Eastern Restroom		<1.0		
230310-32	1st Floor Classroom	Room 136 (Science Lab). Storage room		1.9		
230310-40*	1st Floor Classroom	Room 104. Attached restroom sink		<1.0		
230310-42	1st Floor Nurse Offic	Room 127. Sink faucet		<1.0		
230310-43	1st Floor Nurse offic	Room 127.1. Sink faucet		<1.0		
230310-45	1st Floor Custodial	Room 111- sink		1		
230310-46	1st Floor Custodial	Room 111- spigot		<1.0		
230310-48	Rm 112	Room 112. Fountain attached to Sink		12		Handwashing Only
230310-60	1st Floor Classroom	Room 116 Sink Faucet		<1		
230310-61	1st Floor Classroom	Room 116. Fountain attached to Sink		2.4		
230310-63	Basement. Boys Res	Room B05. West Sink		<1.0		
230310-64	Basement. Boys Res	Room B05. East Sink		<1.0		
230310-65	Basement. Girls Res	Room B07. West sink		<1.0		
230310-66	Basement. Girls Res	Room B07. East sink		<1.0		
230310-79	Kitchen Staff Restro	Restroom attached to southeast corner of kitchen		<1.0		
230310-80	Cafeteria	Storage room B25		9.1		Handwashing Only
230404-01	Basement Locker Ro	B08 Girls Locker - upper fountain		<1		
230404-02	Basement Locker Ro	B08 Girls locker - lower fountain		<1		
230404-03	Basement Locker Ro	B04 Boys locker - upper fountain		<1		
230404-04	Basement Locker Ro	B04 Boys locker - lower fountain		<1		
230404-05	Second Floor Classr	Room 201 - Tap (df inoperable)		<1		
230404-06	Second Floor Classr	Room 203 Fountain		<1		
230404-07	Second Floor Classr	Room 203 Tap		<1		
230404-08	Second Floor Hallwa	Hallway outside 206 - upper fountain		<1		
230404-09	Second Floor Hallwa	Hallway outside 206 - lower fountain		<1		
230404-10	Second Floor Classr	Room 217 - fountain		8.1		Out of Service
230404-11	Second Floor Classr	Room 217 - tap		<1		

230404-12	Second Floor Classr	Room 216 - fountain		2.4		
230404-13	Second Floor Classr	Room 216 - tap		<1		
230404-14	Second Floor Classr	Room 211 - fountain		12		Out of Service
230404-15	Second Floor Classr	Room 211 - tap		<1		
230404-16	Second Floor Classr	Room 213 - fountain		1.2		
230404-17	Second Floor Classr	Room 213 - tap		<1		
230404-18	Older Building	Room S2 off wood shop		5.1		Handwashing Only
230404-19	Older Building	Wood shop - center faucet		1.8	1	
230404-20	Older Building	Wood shop - fountain		350		Out of Service
230404-21	Older Building	Wood shop - left faucet		67	<1	
230404-22	Older Building	Music building - fountain		4.1		