

Lead in School Drinking Water Report

Crestwood Elementary School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-11-20

Date(s) analyzed: 2025-11-25

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	415722	Main Building	Fountain/Tap Combo	Room 2	1 of 2	Tap	left	88
2	415730	Main Building	Fountain/Tap Combo	Room 5	1 of 1	Tap	center	79
3	415720	Main Building	Fountain/Tap Combo	Room 1	2 of 2	Tap	right	73
4	415724	Main Building	Fountain/Tap Combo	Room 2	2 of 2	Tap	right	53
5	415726	Main Building	Fountain/Tap Combo	Room 3	1 of 1	Tap	center	52
6	415740	Main Building	Fountain with Bottle Filler	Main Entrance Foyer	1 of 1	Water Bottle Filler	center	50
7	415752	Main Building	Fountain/Tap Combo	Room 22	1 of 1	Tap	center	50
8	415728	Main Building	Fountain/Tap Combo	Room 4	1 of 1	Tap	center	49
9	415697	Main Building	Fountain/Tap Combo	Pod Sink Next To Room 14	1 of 1	Tap	center	46
10	415731	Main Building	Fountain/Tap Combo	Room 5	1 of 1	Water Fountain	right	37

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
11	415714	Main Building	Fountain/Tap Combo	Room 9	1 of 2	Tap	left	34
12	415729	Main Building	Fountain/Tap Combo	Room 4	1 of 1	Water Fountain	right	34
13	415718	Main Building	Fountain/Tap Combo	Room 1	1 of 2	Tap	left	33
14	415699	Main Building	Fountain/Tap Combo	Room 14	1 of 1	Tap	center	32
15	415721	Main Building	Fountain/Tap Combo	Room 1	2 of 2	Water Fountain	right	31
16	415701	Main Building	Fountain/Tap Combo	Room 13	1 of 1	Tap	center	30
17	415733	Main Building	Fountain/Tap Combo	Pod Sink Outside Of Room 5	1 of 1	Water Fountain	right	29
18	415746	Main Building	Fountain/Tap Combo	Room 20	1 of 1	Tap	center	29
19	415703	Main Building	Fountain/Tap Combo	Room 15	1 of 1	Tap	center	27
20	415723	Main Building	Fountain/Tap Combo	Room 2	1 of 2	Water Fountain	left	26
21	415705	Main Building	Fountain/Tap Combo	Room 16	1 of 1	Tap	center	25

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
22	415710	Main Building	Fountain/Tap Combo	Room 17	1 of 1	Tap	center	24
23	415738	Main Building	Fountain/Tap Combo	Room 7	1 of 1	Water Fountain	right	24
24	415750	Main Building	Fountain/Tap Combo	Room 21	1 of 1	Tap	center	24
25	415742	Main Building	Fountain/Tap Combo	Room 18	1 of 1	Tap	center	23
26	415754	Main Building	Fountain/Tap Combo	Room 23	1 of 1	Tap	center	23
27	415683	Main Building	Fountain/Tap Combo	Music Room	1 of 1	Tap	center	20
28	415708	Main Building	Fountain/Tap Combo	Room 12	1 of 1	Tap	center	19
29	415687	Main Building	Sink	Nurses Office	1 of 1	Tap	center	18
30	415716	Main Building	Fountain/Tap Combo	Room 9	2 of 2	Tap	right	16
31	415735	Main Building	Fountain/Tap Combo	Room 6	1 of 1	Water Fountain	right	16
32	415748	Main Building	Fountain/Tap Combo	Pod Sink Outside Of Room 20	1 of 1	Tap	center	16

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
33	415725	Main Building	Fountain/Tap Combo	Room 2	2 of 2	Water Fountain	right	15
34	415712	Main Building	Fountain/Tap Combo	Room 11	1 of 1	Tap	center	14
35	415717	Main Building	Fountain/Tap Combo	Room 9	2 of 2	Water Fountain	right	12
36	415719	Main Building	Fountain/Tap Combo	Room 1	1 of 2	Water Fountain	left	11
37	415685	Main Building	Sink - Multi-Compartment	Staff Lounge	1 of 2	Tap	center	10
38	415709	Main Building	Fountain/Tap Combo	Room 12	1 of 1	Water Fountain	right	9
39	415698	Main Building	Fountain/Tap Combo	Pod Sink Next To Room 14	1 of 1	Water Fountain	right	8
40	415713	Main Building	Fountain/Tap Combo	Room 11	1 of 1	Water Fountain	right	8
41	415715	Main Building	Fountain/Tap Combo	Room 9	1 of 2	Water Fountain	left	8
42	415732	Main Building	Fountain/Tap Combo	Pod Sink Outside Of Room 5	1 of 1	Tap	center	8
43	415741	Main Building	Fountain with Bottle Filler	Main Entrance Foyer	1 of 1	Water Fountain	right	8

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
44	415745	Main Building	Fountain/Tap Combo	Room 19	1 of 1	Water Fountain	right	8
45	415753	Main Building	Fountain/Tap Combo	Room 22	1 of 1	Water Fountain	right	8
46	415711	Main Building	Fountain/Tap Combo	Room 17	1 of 1	Water Fountain	right	7
47	415736	Main Building	Fountain/Tap Combo	Room 7	1 of 1	Tap	center	7
48	415749	Main Building	Fountain/Tap Combo	Pod Sink Outside Of Room. 20	1 of 1	Water Fountain	right	7
49	415734	Main Building	Fountain/Tap Combo	Room 6	1 of 1	Tap	center	6
50	415747	Main Building	Fountain/Tap Combo	Room 20	1 of 1	Water Fountain	right	6
51	415700	Main Building	Fountain/Tap Combo	Room 14	1 of 1	Water Fountain	right	5
52	415727	Main Building	Fountain/Tap Combo	Room 3	1 of 1	Water Fountain	right	5
53	415739	Main Building	Fountain/Tap Combo	Room 8	1 of 1	Tap	center	5
54	415751	Main Building	Fountain/Tap Combo	Room 21	1 of 1	Water Fountain	right	5

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
55	415684	Main Building	Fountain/Tap Combo	Music Room	1 of 1	Water Fountain	right	4
56	415686	Main Building	Sink	Work Room	1 of 1	Tap	center	4
57	415702	Main Building	Fountain/Tap Combo	Room 13	1 of 1	Water Fountain	right	4
58	415704	Main Building	Fountain/Tap Combo	Room 15	1 of 1	Water Fountain	right	4
59	415706	Main Building	Fountain/Tap Combo	Room 16	1 of 1	Water Fountain	right	4
60	415743	Main Building	Fountain/Tap Combo	Room 18	1 of 1	Water Fountain	right	4
61	415755	Main Building	Fountain/Tap Combo	Room 23	1 of 1	Water Fountain	right	4
62	415680	Main Building	Sink	Kitchen	1 of 1	Tap	center	2
63	415696	Portable	Sink	Room 1	1 of 1	Tap	center	2
64	415681	Main Building	Sink	Kitchen	1 of 1	Sprayer	center	<1
65	415682	Main Building	Fountain	Across From Main Office	1 of 1	Water Fountain	right	<1
66	415744	Main Building	Fountain/Tap Combo	Room 19	1 of 1	Tap	center	<1
67	415756	Main Building	Ice Machine	Staff Lounge	2 of 2	Ice Machine	center	<1

