

# J.C. Broderick & Associates, Inc.

Environmental / Construction Consulting & Testing



December 17, 2025

Mr. Anthony Gagliano  
East Islip Union Free School District  
Administrative Office  
1 Craig B. Gariepy Avenue  
Islip Terrace, New York 11752

**Re: Summary of Lead in Drinking Water Sampling and  
Remedial Action Plan**

Dear Mr. Gagliano:

J.C. Broderick & Associates, Inc. has been retained to provide environmental compliance services associated with New York State Department of Health's (NYSDOH) regulation 10 NYCRR Subpart 67-4; Lead Testing in School Drinking Water. The East Islip Union Free School District is in full compliance with this regulation.

The sampling for the 2023-25 compliance period occurred in June 2024. Ahead of the sampling, a comprehensive inventory of all potential water outlets was performed through each of the school buildings. These outlets were evaluated to determine their use, and any outlet which may be used for cooking or drinking was designated as applicable to sampling. Various controls, including signage, have been placed at all outlets which are non-applicable to sampling, meaning they are not to be used for cooking or drinking.

All samples for applicable outlets were submitted to an Environmental Laboratory Approval Program (ELAP) accredited laboratory for analysis. Results from the laboratory analysis were compared with the Action Level as defined by Subpart 67-4 of 5 parts per billion (ppb). Outlets which did not exceed the action level do not require further testing or remediation. Any outlet which exceeded this level was addressed in accordance with the District's Remedial Action Plan.

Remedial actions included redesignating some of these outlets as non-drinking locations, permanently removing fixtures which were determined to be no longer needed, and the servicing and retesting of outlets the district intends to maintain as drinking water locations. Outlets are only returned to service after remediation has been completed, and retest results show concentrations of lead are below the action level.

All reports and results have been notified to the Department of Health, parents and building occupants, and posted to the district's website, as applicable. The school district is due for their next cycle of compliance testing in 2027. Until then it is recommended that they continue with their water outlet and filtration service schedule, monthly flushing program, and upkeep of the education and signage practices.

For more details, please reference the complete testing report and remedial action plan located on the district's website. If you have any questions, or if more information is needed, please contact our office.

Sincerely,

A handwritten signature in black ink, appearing to read 'Tara Ricker', is written over a horizontal line.

Tara Ricker  
**J C Broderick & Associates, Inc.**