



Drinking Water Results Report

Order ID: 5K03590

Suburban Water Technology
1697A Swamp Pike
Gilbertsville, PA 19525

Project: BASD- Middle School West
380 S. Madison Street
Boyertown, PA 19512

Attn: Jeremy Crum

PWSID:

Sample Number: 5K03590-01

Site: Sample 1- Kitchen Hand Sink

Sample ID:

Collector: DH

Collect Date: 11/06/2025 1:00 pm

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	MRL	MDL	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	-----	-----	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 11/07/25 RPV 11/10/25 15:29 RPV

Sample Number: 5K03590-02

Site: Sample 2- Men's Bathroom Sink

Sample ID:

Collector: DH

Collect Date: 11/06/2025 1:10 pm

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	MRL	MDL	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	-----	-----	-----------	----	---------------	----

Metals

Lead 0.001 mg/L EPA 200.8 0.015 Pass 0.001 11/07/25 RPV 11/10/25 15:31 RPV

Sample Number: 5K03590-03

Site: Sample 3- Bottle Fill Hallway

Sample ID:

Collector: DH

Collect Date: 11/06/2025 1:20 pm

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	MRL	MDL	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	-----	-----	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 11/07/25 RPV 11/10/25 15:32 RPV

Sample Footnotes:

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

Units P/A = Present/Absent

Units P/F = Pass/Fail

Laboratory Accreditations:

SPL - Reading

Regulatory Authority	Program	Certification ID	Expires
US EPA	Federal	PA00072	N/A
New Jersey DEP	NELAP	PA081	06/30/2026
New York DOH	NELAP	12209	04/01/2026
Pennsylvania DEP	NELAP	06-00208	09/30/2026
Texas CEQ	NELAP	T10474585	03/31/2026
Colorado DPHE	State	PA00072	10/31/2026
Delaware ODW	State	N/A	09/30/2026
Maryland DE	State	347	12/31/2025



All analyses were performed at SPL - Reading unless otherwise noted.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of SPL's NELAP Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL" / "SPL", samples have been collected in accordance with SPL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of SPL.

Results have been peer reviewed unless marked with an asterisk (*). Results with an asterisk have been analyst reviewed and meet all quality system requirements.

Reviewed and Released By:

Paige Seitz

Associate Project Manager

A handwritten signature in cursive script that reads 'Paige Seitz'.



5K03590
Rachel Luckhart

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

TAT(Check One): ☒ Standard ☐ 24hr ☐ 48hr ☐ 72hr ☐ Other _____
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: <u>Suburban Water Technology</u> Address: <u>1697 Swamp Pike</u> <u>Gilbertsville, Pa 19525</u> Contact Name: <u>Jeremy Crum</u>	Project Name: <u>BASD: Middle School West</u> Address: <u>380 S. Madison Street</u> <u>Boyetown, Pa 19512</u> Regulatory ID (SDWA/Permit #): <u>N/A</u>
Phone: <u>610-367-6464</u> Email: <u>jeremy@wefixwater.com</u> P.O. Info: _____	

Comments:

Added line to label to reflect COC mg 11/6/25

STL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
<i>1312 Swamp</i>											
<i>X</i>	Sample 1- <i>Kitchen Hand Sink</i>	11/6/25	<i>1 pm</i>	DH	LEAD	1	PW	G	P		
<i>X</i>	Sample 2- <i>mens Bathroom Sink</i>	11/6/25	<i>1:10 pm</i>	DH	LEAD	1	PW	G	P		
<i>X</i>	Sample 3- <i>Bottle fill Hall way</i>	11/6/25	<i>1:20 pm</i>	DH	LEAD	1	PW	G	P		

Xc +1ml of HNO3 added at 1327 11/07/2025
pH<2 Standard ID S5J2998 Completed by DMH2

Relinquished By: <i>[Signature]</i>	Count: <i>3</i>	Date: <i>11-6-25</i>	Temp °C: _____	Sample Conditions Submitted with COC? <i>Y / N</i>	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	Bottle Type Key P = Plastic G = Glass GA = Glass Amber VOA = 40mL G or GA PP = Sterile Polypropylene PS = Sterile Polystyrene HDPE = High Density Polyethylene O = Other
		Time: <i>1500</i>	Acceptable: Y / N			
Received By: <i>[Signature]</i>	Count: <i>3</i>	Date: <i>11-6-25</i>	Temp °C: _____	Number of containers match number on COC? <i>Y / N</i>	Sample Type Key G = Grab C = Composite 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	SDWA Sample Types D=Distribution E=Entry Point R=Raw C=Check S=Special M=Maximum Residence
		Time: <i>1600</i>	Acceptable: Y / N			
Relinquished By: <i>[Signature]</i>	Count: <i>3</i>	Date: <i>11-6-25</i>	Temp °C: _____	All containers in tact? <i>Y / N</i>	Preservative Key A = Ascorbic Acid C = HCl H = HNO3 N = Sodium Thiosulfate OH = NaOH S = H2SO4 O = Other NA = None Required	
		Time: <i>1615</i>	Acceptable: Y / N			
Received in Lab By: <i>[Signature]</i>	Count: <i>3</i>	Date: <i>11/6/25</i>	Temp °C: <i>15</i>	Tests within holding times? <i>Y / N</i>	40 mL VOA vials free of headspace? <i>Y / N</i>	
		Time: <i>1910</i>	Acceptable: Y / N			

Signing this form indicates your agreement with STL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.5 Effective April 24, 2020.
Shaded areas are for STL use only.