



Drinking Water Results Report

Order ID: 5K03594

Suburban Water Technology
1697A Swamp Pike
Gilbertsville, PA 19525

Attn: Jeremy Crum

Project: BASD: Colebrookdale Elementary
1001 Montgomery Avenue
Boyertown, PA 19512

PWSID:

Sample Number: 5K03594-01

Site: Sample 1- Health- Fill

Sample ID:

Collector: DH

Collect Date: 11/06/2025 12:20 pm

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	MRL	MDL	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	-----	-----	-----------	----	---------------	----

Metals

Lead	0.002	mg/L	EPA 200.8	0.015	Pass	0.001		11/12/25	RPV	11/13/25 21:57	RJS
------	-------	------	-----------	-------	------	-------	--	----------	-----	----------------	-----

Sample Number: 5K03594-02

Site: Sample 2- Cafe- 3 Bay Sink

Sample ID:

Collector: DH

Collect Date: 11/06/2025 12:30 pm

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	MRL	MDL	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	-----	-----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001		11/12/25	RPV	11/13/25 22:01	RJS
------	---------	------	-----------	-------	------	-------	--	----------	-----	----------------	-----

Sample Number: 5K03594-03

Site: Sample 3- Teachers Lounge

Sample ID:

Collector: DH

Collect Date: 11/06/2025 12:35 pm

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	MRL	MDL	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	-----	-----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001		11/12/25	RPV	11/13/25 22:15	RJS
------	---------	------	-----------	-------	------	-------	--	----------	-----	----------------	-----

Sample Number: 5K03594-04

Site: Sample 4- Lirdary Office

Sample ID:

Collector: DH

Collect Date: 11/06/2025 12:40 pm

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	MRL	MDL	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	-----	-----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001		11/18/25	OYK	11/18/25 20:34	RJS
------	---------	------	-----------	-------	------	-------	--	----------	-----	----------------	-----

Sample Number: 5K03594-05

Site: Sample 5- Room 210

Sample ID:

Collector: DH

Collect Date: 11/06/2025 12:40 pm

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	MRL	MDL	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	-----	-----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001		11/18/25	OYK	11/18/25 20:46	RJS
------	---------	------	-----------	-------	------	-------	--	----------	-----	----------------	-----

Sample Number: 5K03594-06

Site: Sample 6- Room 212

Sample ID:

Collector: DH

Collect Date: 11/06/2025 12:45 pm

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	MRL	MDL	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	-----	-----	-----------	----	---------------	----

Report Generated On: WO:
STL_DW_Results Rev 6.0 Effective 09/02/2025



Sample Number: 5K03594-06

Site: Sample 6- Room 212

Sample ID:

Collector: DH

Collect Date: 11/06/2025 12:45 pm

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	MRL	MDL	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	-----	-----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001		11/18/25	OYK	11/18/25 20:48	RJS
------	---------	------	-----------	-------	------	-------	--	----------	-----	----------------	-----

Sample Number: 5K03594-07

Site: Sample 7- Room 301

Sample ID:

Collector: DH

Collect Date: 11/06/2025 12:50 pm

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	MRL	MDL	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	-----	-----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001		11/18/25	OYK	11/18/25 20:50	RJS
------	---------	------	-----------	-------	------	-------	--	----------	-----	----------------	-----

Sample Footnotes:**Sample Receipt Conditions:**

All samples met the sample receipt requirements for the relevant analyses.

Units P/A = Present/Absent

Units P/F = Pass/Fail

Laboratory Accreditations:**SPL - Reading**

Regulatory Authority	Program	Certification ID	Expires
US EPA	Federal	PA00072	N/A
New Jersey DEP	NELAP	PA081	06/30/2026
New York DOH	NELAP	12209	04/01/2026
Pennsylvania DEP	NELAP	06-00208	09/30/2026
Texas CEQ	NELAP	T10474585	03/31/2026
Colorado DPHE	State	PA00072	10/31/2026
Delaware ODW	State	N/A	09/30/2026
Maryland DE	State	347	12/31/2026

All analyses were performed at SPL - Reading unless otherwise noted.

The test *pH*, *Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.**pH*, *Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of SPL's NELAP Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL" / "SPL", samples have been collected in accordance with SPL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of SPL.


Results have been peer reviewed unless marked with an asterisk (*). Results with an asterisk have been analyst reviewed and meet all quality system requirements.

Reviewed and Released By:

Paige Seitz

Associate Project Manager

Report Generated On: WO:
STL_DW_Results Rev 6.0 Effective 09/02/2025



5K03594
Rachel Luckhart

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

TAT(Check One): ☒ Standard ☐ 24hr ☐ 48hr ☐ 72hr ☐ Other _____
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: <u>Suburban Water Technology</u> Address: <u>1697 Swamp Pike</u> <u>Gilbertsville, Pa 19525</u> Contact Name: <u>Jeremy Crum</u>	Project Name: <u>BASD: Colebrookdale Elementary</u> Address: <u>1001 Montgomery Avenue</u> <u>Boyertown, PA 19512</u> Regulatory ID (SDWA/Permit #): <u>N/A</u>
Phone: <u>610-367-6464</u> Email: <u>jeremy@wefixwater.com</u> P.O. Info: _____	

Comments:

STL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
(7) 25ml											
X	Sample 1- Health - 211	11/6/25	12:20pm	DH	LEAD	1	PW	G	P		
X	Sample 2- Cope - 3 Bay Sink	11/6/25	12:30pm	DH	LEAD	1	PW	G	P		
X	Sample 3- Teachers Lounge	11/6/25	12:35pm	DH	LEAD	1	PW	G	P		
X	Sample 4- Library office	11/6/25	12:40pm	DH	LEAD	1	PW	G	P		
X	Sample 5- Room - 210	11/6/25	12:40pm	DH	LEAD	1	PW	G	P		
X	Sample 6- Room - 212	11/6/25	12:45pm	DH	LEAD	1	PW	G	P		
X	Sample 7- Room - 301	11/6/25	12:50pm	DH	LEAD	1	PW	G	P		

Relinquished By:	Count: 7	Date: 11-6-25	Temp °C: _____	Sample Conditions Submitted with COC? Y / N	NPW = Non Potable Water Solid = Raw (rep) PW = Potable Water	SDWA = Safe Drinking Water Act Potable Sample	+1ml of HNO3 added at 1327 11/07/2025 pH<2 Standard ID S5J2998 Completed by DMH2
		Time: 1500					
Received By:	7	Date: 11-6-25	Temp °C: _____	Number of containers match number on COC? Y / N			
		Time: 1600	Acceptable: Y / N				
Relinquished By:	7	Date: 11-6-25	Temp °C: _____	All containers in tact? Y / N			
		Time: 1815	Acceptable: Y / N				
Received in Lab By:	7	Date: 11/06/25	Temp °C: 10	Tests within holding times? Y / N			
		Time: 1908	Acceptable: Y / N				
				40 mL VOA vials free of headspace? Y / N			

Sample Type Key
 G = Grab
 C = Composite
 8HC = 8 Hr. Composite
 24HC = 24 Hr. Composite

SDWA Sample Types
 D=Distribution
 E=Entry Point
 R=Raw
 C=Check
 S=Special
 M=Maximum Residence

Preservative Key
 A = Ascorbic Acid
 C = HCl
 H = HNO3
 N = Sodium Thiosulfate
 OH = NaOH
 S = H2SO4
 O = Other
 NA = None Required

Signing this form indicates your agreement with STL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.5 Effective April 24, 2020.
Shaded areas are for STL use only.