



Drinking Water Results Report

Order ID: 5K03596

Suburban Water Technology
1697A Swamp Pike
Gilbertsville, PA 19525

Project: BASD: Middle School East
2020 Big Rd
Gilbertsville, PA 19525

Attn: Jeremy Crum

PWSID:

Sample Number: 5K03596-01

Site: Sample 1- 238 Room

Sample ID:

Collector: DH

Collect Date: 11/06/2025 9:21 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	MRL	MDL	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	-----	-----	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 11/18/25 OYK 11/18/25 20:53 RJS

Sample Number: 5K03596-02

Site: Sample 2- Kitchen Hand Sink

Sample ID:

Collector: DH

Collect Date: 11/06/2025 9:27 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	MRL	MDL	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	-----	-----	-----------	----	---------------	----

Metals

Lead 0.003 mg/L EPA 200.8 0.015 Pass 0.001 11/18/25 OYK 11/18/25 21:00 RJS

Sample Number: 5K03596-03

Site: Sample 3- 401 Room

Sample ID:

Collector: DH

Collect Date: 11/06/2025 9:30 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	MRL	MDL	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	-----	-----	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 11/18/25 OYK 11/18/25 21:02 RJS

Sample Number: 5K03596-04

Site: Sample 4- 208 Room

Sample ID:

Collector: DH

Collect Date: 11/06/2025 9:32 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	MRL	MDL	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	-----	-----	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 11/18/25 OYK 11/18/25 21:04 RJS

Sample Number: 5K03596-05

Site: Sample 5- 503 Room

Sample ID:

Collector: DH

Collect Date: 11/06/2025 9:41 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	MRL	MDL	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	-----	-----	-----------	----	---------------	----

Metals

Lead 0.001 mg/L EPA 200.8 0.015 Pass 0.001 11/18/25 OYK 11/18/25 21:07 RJS

Sample Number: 5K03596-06

Site: Sample 6- 130 Room

Sample ID:

Collector: DH

Collect Date: 11/06/2025 9:45 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	MRL	MDL	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	-----	-----	-----------	----	---------------	----

Report Generated On: WO:
STL_DW_Results Rev 6.0 Effective 09/02/2025



Sample Number: 5K03596-06

Site: Sample 6- 130 Room

Sample ID:

Collector: DH

Collect Date: 11/06/2025 9:45 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	MRL	MDL	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	-----	-----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001		11/18/25	OYK	11/18/25 21:09	RJS
------	---------	------	-----------	-------	------	-------	--	----------	-----	----------------	-----

Sample Footnotes:

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

Units P/A = Present/Absent

Units P/F = Pass/Fail

Laboratory Accreditations:**SPL - Reading**

<u>Regulatory Authority</u>	<u>Program</u>	<u>Certification ID</u>	<u>Expires</u>
US EPA	Federal	PA00072	N/A
New Jersey DEP	NELAP	PA081	06/30/2026
New York DOH	NELAP	12209	04/01/2026
Pennsylvania DEP	NELAP	06-00208	09/30/2026
Texas CEQ	NELAP	T10474585	03/31/2026
Colorado DPHE	State	PA00072	10/31/2026
Delaware ODW	State	N/A	09/30/2026
Maryland DE	State	347	12/31/2026

All analyses were performed at SPL - Reading unless otherwise noted.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of SPL's NELAP Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL" / "SPL", samples have been collected in accordance with SPL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of SPL.

Results have been peer reviewed unless marked with an asterisk (*). Results with an asterisk have been analyst reviewed and meet all quality system requirements.

Reviewed and Released By:

Paige Seitz

Associate Project Manager



5K03596
Rachel Luckhart

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

TAT(Check One): ☒ Standard ☐ 24hr ☐ 48hr ☐ 72hr ☐ Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: <u>Suburban Water Technology</u> Address: <u>1697 Swamp Pike</u> <u>Gilbertsville, Pa 19525</u> Contact Name: <u>Jeremy Crum</u> Comments: _____	Project Name: <u>BASD: MIDDLE SCHOOL EAST</u> Address: <u>2020 BIR Rd. 6</u> <u>Gilbertsville, PA 19525</u> Regulatory ID (SDWA/Permit #): <u>N/A</u>
Phone: <u>610-367-6464</u> Email: <u>jeremy@wefixwater.com</u> P.O. Info: _____	

** = adjusted sample descrip. to reflect col call over into not led 11/16/25*

STL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
X	Sample 1- 238 Room	11/6/25	9.21 AM	DH	LEAD	1	PW	G	P		
X	Sample 2- Kitchen Hand Sink	11/6/25	9.27 AM	DH	LEAD	1	PW	G	P		
X	Sample 3- 401 - Room	11/6/25	9.30 AM	DH	LEAD	1	PW	G	P		
X	Sample 4- 208 - Room	11/6/25	9.32 AM	DH	LEAD	1	PW	G	P		
X	Sample 5- 503 - Room	11/6/25	9.41 AM	DH	LEAD	1	PW	G	P		
X	Sample 6- 130 - Room	11/6/25	9.43 AM	DH	LEAD	1	PW	G	P		

Relinquished By: Received By: Relinquished By: Received in Lab By:	Count: <u>6</u> <u>6</u> <u>6</u> <u>6</u>	Date: <u>11-6-25</u> Time: <u>1505</u> <u>11-6-25</u> Time: <u>1600</u> <u>11-6-25</u> Time: <u>1815</u> <u>11-6-25</u> Time: <u>1905</u>	Temp °C: _____ Temp °C: _____ Acceptable: Y / N Temp °C: _____ Acceptable: Y / N Temp °C: _____ Acceptable: Y / N	Sample Conditions Submitted with COC? <u>Y / N</u> Number of containers match number on COC? <u>Y / N</u> All containers in tact? <u>Y / N</u> Tests within holding times? <u>Y / N</u> 40 mL VOA vials free of headspace? <u>Y / N</u>	NPW = Non-Potable Water Solid = Raw S (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample Sample Type Key G = Grab C = Composite 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	GA = Glass Amber VOA = 40mL G or GA HDPE = High Density Polyethylene O = Other SDWA Sample Types D=Distribution E=Entry Point R=Raw C=Check S=Special M=Maximum Residence Preservative Key A = Ascorbic Acid C = HCl H = HNO ₃ N = Sodium Thiosulfate OH = NaOH S = H ₂ SO ₄ O = Other NA = None Required
---	---	--	---	---	--	---

+1ml of HNO3 added at 1327 11/07/2025
pH<2 Standard ID S5J2998 Completed by DMH2

Signing this form indicates your agreement with STL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.5 Effective April 24, 2020.
Shaded areas are for STL use only.