



Experience is the solution

314 North Pearl Street ♦ Albany, New York 12207
(800) 848-4983 ♦ (518) 434-4546 ♦ Fax (518) 434-0891

November 18, 2025

Mr. Ed Martin
Ballston Spa Central School District
70 Malta Avenue
Ballston Spa, NY 12020
TEL: (518) 884-7195

Work Order No: 251111039

RE:
Gordon Creek

Adirondack Environmental Services, Inc received 60 samples on 11/11/2025 for the analyses presented in the following report.

Please see case narrative for specifics on analysis.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

ELAP#: 10709

Tara Daniels
Laboratory Director

Adirondack Environmental Services, Inc

CASE NARRATIVE

Ballston Spa Central School District

Date: 18-Nov-25

Gordon Creek

Lab WorkOrder: 251111039

Sample containers were supplied by Adirondack Environmental Services.

Definitions - RL: Reporting Limit DF: Dilution factor

Qualifiers:	ND : Not Detected at reporting limit	C: CCV below acceptable Limits
	J: Analyte detected below quantitation limit	C+: CCV above acceptable Limits
	B: Analyte detected in Blank	S: LCS Spike recovery is below acceptable limits
	X : Exceeds maximum contamination limit	S+: LCS Spike recovery is above acceptable limits
	H: Hold time exceeded	Z: Duplication outside acceptable limits
	N: Matrix Spike below acceptable limits	T : Tentatively Identified Compound-Estimated
	N+: Matrix Spike is above acceptable limits	E :Above quantitation range-Estimated

Note : All Results are reported as wet weight unless noted

The results relate only to the items tested. Information supplied by the client is assumed to be correct.

Adirondack Environmental Services, Inc

Date: 18-Nov-25

CLIENT: Ballston Spa Central School District
Project: Gordon Creek

LabWork Order: 251111039
PO#:

Lab SampleID: 251111039-001 **Collection Date:** 11/11/2025 7:20:00 AM
Client Sample ID: Kitchen 002 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: KH

(Prep: - 11/12/2025 12:17:04 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 2:56:03 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-002 **Collection Date:** 11/11/2025 7:21:00 AM
Client Sample ID: Kitchen 003 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: KH

(Prep: - 11/12/2025 12:17:04 PM)

Lead	4.6	1.0		µg/L	1	11/17/2025 3:06:53 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-003 **Collection Date:** 11/11/2025 7:22:00 AM
Client Sample ID: Kitchen 004 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: KH

(Prep: - 11/12/2025 12:17:04 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 3:10:29 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-004 **Collection Date:** 11/11/2025 7:23:00 AM
Client Sample ID: Kitchen 005 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: KH

(Prep: - 11/12/2025 12:17:04 PM)

Lead	3.1	1.0		µg/L	1	11/17/2025 3:14:06 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-005 **Collection Date:** 11/11/2025 7:24:00 AM
Client Sample ID: Kitchen 006 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: KH

(Prep: - 11/12/2025 12:17:04 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 3:24:52 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 18-Nov-25

CLIENT: Ballston Spa Central School District**LabWork Order:** 251111039**Project:**
Gordon Creek**PO#:****Lab SampleID:** 251111039-006**Collection Date:** 11/11/2025 7:25:00 AM**Client Sample ID:** Kitchen 007**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:04 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 3:28:29 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-007**Collection Date:** 11/11/2025 7:26:00 AM**Client Sample ID:** Kitchen 008**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:04 PM)

Lead	1.2	1.0		µg/L	1	11/17/2025 3:32:05 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-008**Collection Date:** 11/11/2025 7:27:00 AM**Client Sample ID:** 009 Fountain Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:04 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 3:35:42 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-009**Collection Date:** 11/11/2025 7:29:00 AM**Client Sample ID:** 010 Fountain Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:04 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 3:39:19 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-010**Collection Date:** 11/11/2025 7:31:00 AM**Client Sample ID:** 017 Sinks**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:04 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 3:42:56 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 18-Nov-25

CLIENT: Ballston Spa Central School District**LabWork Order:** 251111039**Project:**
Gordon Creek**PO#:****Lab SampleID:** 251111039-011**Collection Date:** 11/11/2025 7:32:00 AM**Client Sample ID:** 018 Sinks**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:04 PM)

Lead	3.5	1.0		µg/L	1	11/17/2025 3:46:33 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-012**Collection Date:** 11/11/2025 7:36:00 AM**Client Sample ID:** 022 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:04 PM)

Lead	1.1	1.0		µg/L	1	11/17/2025 3:57:23 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-013**Collection Date:** 11/11/2025 7:37:00 AM**Client Sample ID:** 025 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:04 PM)

Lead	2.9	1.0		µg/L	1	11/17/2025 4:08:10 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-014**Collection Date:** 11/11/2025 7:39:00 AM**Client Sample ID:** 028 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:07 PM)

Lead	1.2	1.0		µg/L	1	11/17/2025 4:19:00 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-015**Collection Date:** 11/11/2025 7:43:00 AM**Client Sample ID:** 029 Sink**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:07 PM)

Lead	10.5	1.0	X	µg/L	1	11/17/2025 4:22:37 PM
------	------	-----	---	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 18-Nov-25

CLIENT: Ballston Spa Central School District
Project: Gordon Creek

LabWork Order: 251111039
PO#:

Lab SampleID: 251111039-016 **Collection Date:** 11/11/2025 7:28:00 AM

Client Sample ID: 009 Fountin Bottle Fill **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:07 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 4:26:14 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-017

Collection Date: 11/11/2025 7:30:00 AM

Client Sample ID: 010 Fountain Bottle Fill

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:07 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 4:29:51 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-018

Collection Date: 11/11/2025 7:42:00 AM

Client Sample ID: 034 Sink

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:07 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 4:33:28 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-019

Collection Date: 11/11/2025 7:41:00 AM

Client Sample ID: 035 Bubbler

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:07 PM)

Lead	3.0	1.0		µg/L	1	11/17/2025 4:37:05 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-020

Collection Date: 11/11/2025 7:41:00 AM

Client Sample ID: 037 Nurse for Meds

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:07 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 4:40:42 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 18-Nov-25

CLIENT: Ballston Spa Central School District
Project: Gordon Creek

LabWork Order: 251111039
PO#:

Lab SampleID: 251111039-021 **Collection Date:** 11/11/2025 7:38:00 AM

Client Sample ID: 038 Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:07 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 4:51:30 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-022 **Collection Date:** 11/11/2025 7:35:00 AM

Client Sample ID: 041 Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:07 PM)

Lead	1.3	1.0		µg/L	1	11/17/2025 5:02:21 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-023 **Collection Date:** 11/11/2025 7:52:00 AM

Client Sample ID: 052 Fountain Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:07 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 5:05:58 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-024 **Collection Date:** 11/11/2025 7:53:00 AM

Client Sample ID: 053 Fountain **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:07 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 5:09:35 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-025 **Collection Date:** 11/11/2025 7:54:00 AM

Client Sample ID: 055 Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:07 PM)

Lead	1.5	1.0		µg/L	1	11/17/2025 5:13:13 PM
------	-----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 18-Nov-25

CLIENT: Ballston Spa Central School District

LabWork Order: 251111039

Project: Gordon Creek

PO#:

Lab SampleID: 251111039-026

Collection Date: 11/11/2025 7:56:00 AM

Client Sample ID: 057 Bubbler

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:07 PM)

Lead	2.6	1.0		µg/L	1	11/17/2025 5:16:50 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-027

Collection Date: 11/11/2025 7:59:00 AM

Client Sample ID: 059 Bubbler

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:07 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 5:20:27 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-028

Collection Date: 11/11/2025 8:00:00 AM

Client Sample ID: 062 Bubbler

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:07 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 5:24:05 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-029

Collection Date: 11/11/2025 8:02:00 AM

Client Sample ID: 065 Bubbler

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:07 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 5:34:52 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-030

Collection Date: 11/11/2025 8:03:00 AM

Client Sample ID: 067 Bubbler

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:07 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 5:38:29 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 18-Nov-25

CLIENT: Ballston Spa Central School District**LabWork Order:** 251111039**Project:**
Gordon Creek**PO#:****Lab SampleID:** 251111039-031**Collection Date:** 11/11/2025 8:01:00 AM**Client Sample ID:** 070 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:07 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 5:42:07 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-032**Collection Date:** 11/11/2025 7:58:00 AM**Client Sample ID:** 073 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:07 PM)

Lead	2.0	1.0		µg/L	1	11/17/2025 5:52:59 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-033**Collection Date:** 11/11/2025 7:57:00 AM**Client Sample ID:** 077 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:07 PM)

Lead	5.1	1.0	X	µg/L	1	11/17/2025 5:56:37 PM
------	-----	-----	---	------	---	-----------------------

Lab SampleID: 251111039-034**Collection Date:** 11/11/2025 7:55:00 AM**Client Sample ID:** 079 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:10 PM)

Lead	1.7	1.0		µg/L	1	11/17/2025 6:07:29 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-035**Collection Date:** 11/11/2025 7:52:00 AM**Client Sample ID:** 052 Fountain Bottle Fill**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:10 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 6:18:17 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 18-Nov-25

CLIENT: Ballston Spa Central School District**LabWork Order:** 251111039**Project:**
Gordon Creek**PO#:****Lab SampleID:** 251111039-036**Collection Date:** 11/11/2025 8:22:00 AM**Client Sample ID:** 084 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:10 PM)

Lead	2.0	1.0		µg/L	1	11/17/2025 6:21:54 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-037**Collection Date:** 11/11/2025 8:24:00 AM**Client Sample ID:** 086 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:10 PM)

Lead	1.2	1.0		µg/L	1	11/17/2025 6:25:32 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-038**Collection Date:** 11/11/2025 8:26:00 AM**Client Sample ID:** 088 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:10 PM)

Lead	1.2	1.0		µg/L	1	11/17/2025 6:29:10 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-039**Collection Date:** 11/11/2025 8:28:00 AM**Client Sample ID:** 090 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:10 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 6:32:48 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-040**Collection Date:** 11/11/2025 8:29:00 AM**Client Sample ID:** 092 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:10 PM)

Lead	2.0	1.0		µg/L	1	11/17/2025 6:36:25 PM
------	-----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 18-Nov-25

CLIENT: Ballston Spa Central School District**LabWork Order:** 251111039**Project:**
Gordon Creek**PO#:****Lab SampleID:** 251111039-041**Collection Date:** 11/11/2025 8:27:00 AM**Client Sample ID:** 094 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:10 PM)

Lead	1.9	1.0		µg/L	1	11/17/2025 6:47:18 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-042**Collection Date:** 11/11/2025 8:25:00 AM**Client Sample ID:** 096 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:10 PM)

Lead	1.1	1.0		µg/L	1	11/17/2025 7:05:22 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-043**Collection Date:** 11/11/2025 8:23:00 AM**Client Sample ID:** 098 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:10 PM)

Lead	1.2	1.0		µg/L	1	11/17/2025 7:09:00 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-044**Collection Date:** 11/11/2025 8:19:00 AM**Client Sample ID:** 099 Fountain Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:10 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 7:12:39 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-045**Collection Date:** 11/11/2025 8:20:00 AM**Client Sample ID:** 100 Fountain**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:10 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 7:16:17 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 18-Nov-25

CLIENT: Ballston Spa Central School District**LabWork Order:** 251111039**Project:**
Gordon Creek**PO#:****Lab SampleID:** 251111039-046**Collection Date:** 11/11/2025 8:10:00 AM**Client Sample ID:** 111 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:10 PM)

Lead	4.7	1.0		µg/L	1	11/17/2025 7:19:55 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-047**Collection Date:** 11/11/2025 8:12:00 AM**Client Sample ID:** 113 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:10 PM)

Lead	1.9	1.0		µg/L	1	11/17/2025 7:23:33 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-048**Collection Date:** 11/11/2025 8:14:00 AM**Client Sample ID:** 115 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:10 PM)

Lead	4.7	1.0		µg/L	1	11/17/2025 7:27:11 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-049**Collection Date:** 11/11/2025 8:15:00 AM**Client Sample ID:** 117 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:10 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 7:30:50 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-050**Collection Date:** 11/11/2025 8:16:00 AM**Client Sample ID:** 119 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:17:10 PM)

Lead	1.1	1.0		µg/L	1	11/17/2025 7:34:28 PM
------	-----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 18-Nov-25

CLIENT: Ballston Spa Central School District**LabWork Order:** 251111039**Project:**
Gordon Creek**PO#:****Lab SampleID:** 251111039-051**Collection Date:** 11/11/2025 8:17:00 AM**Client Sample ID:** 121 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **KH**

(Prep: - 11/12/2025 12:17:10 PM)

Lead	1.1	1.0		µg/L	1	11/17/2025 7:45:16 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-052**Collection Date:** 11/11/2025 8:13:00 AM**Client Sample ID:** 123 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **KH**

(Prep: - 11/12/2025 12:17:10 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 7:56:11 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-053**Collection Date:** 11/11/2025 8:11:00 AM**Client Sample ID:** 125 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **KH**

(Prep: - 11/12/2025 12:17:10 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 7:59:49 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-054**Collection Date:** 11/11/2025 8:40:00 AM**Client Sample ID:** 128 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **KH**

(Prep: - 11/12/2025 12:20:20 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 8:10:45 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-055**Collection Date:** 11/11/2025 8:06:00 AM**Client Sample ID:** 131**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **KH**

(Prep: - 11/12/2025 12:20:20 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 8:14:23 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 18-Nov-25

CLIENT: Ballston Spa Central School District
Project: Gordon Creek

LabWork Order: 251111039
PO#:

Lab SampleID: 251111039-056 **Collection Date:** 11/11/2025 8:08:00 AM
Client Sample ID: 132 Fountain Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:20:20 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 8:18:02 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-057 **Collection Date:** 11/11/2025 8:09:00 AM
Client Sample ID: 133 Fountain **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:20:20 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 8:28:50 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-058 **Collection Date:** 11/11/2025 8:19:00 AM
Client Sample ID: 099 Fountain Bottle Fill **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:20:20 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 8:32:29 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-059 **Collection Date:** 11/11/2025 8:43:00 AM
Client Sample ID: 136 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:20:20 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 8:36:07 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111039-060 **Collection Date:** 11/11/2025 8:08:00 AM
Client Sample ID: 132 Fountain Bottle Fill **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:20:20 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 8:39:46 PM
------	----	-----	--	------	---	-----------------------



14 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

251111039

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: Ballston Spa Schools		Address:							
Send Report to:		Project Name (Location) Gordon Creek			Samplers Name: <i>David Cameron 16</i>				
Client Phone #:		Client PO #:			Samplers Signature: <i>[Signature]</i>				
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
001	Kitchen 002	11/11/25	0720	PW		X	1	0	Lead
002	Kitchen 003		0721	PW		X	1	0	Lead
003	Kitchen 004		0722	PW		X	1	0	Lead
004	Kitchen 005		0723	PW		X	1	0	Lead
005	Kitchen 006		0724	PW		X	1	0	Lead
006	Kitchen 007		0725	PW		X	1	0	Lead
007	Kitchen 008		0726	PW		X	1	0	Lead
008	009 Fountain Bubbler		0727	PW		X	1	0	Lead
009	010 Fountain Bubbler		0729	PW		X	1	0	Lead
010	017 Sinks		0731	PW		X	1	0	Lead
011	018 Sinks		0732	PW		X	1	0	Lead
012	022 Bubbler		0736	PW		X	1	0	Lead
013	025 Bubbler		0737	PW		X	1	0	Lead
014	028 Bubbler		0739	PW		X	1	0	Lead
015	029 Sink		0743	PW		X	1	0	Lead
016	009 Fountain Bottle Fill		0728	PW		X	1	0	Lead
Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other:				Special Instructions/Remarks:					
Turnaround Time Requested: ④ 1 Day ④ 2 Day 3 Day 5 Day <u>Standard</u>				PLEASE FILL ALL PINK SHADED AREAS					
NOTE: Samples received after 3:30pm are considered next business day.									
Relinquished by: (Signature)				Received by: (Signature)				Date	Time
Relinquished by: (Signature)				Received by: (Signature)				Date	Time
Relinquished by: (Signature)				Received for Laboratory by:				Date	Time
								8m 11/11/25	14740
Sample Temperature Ambient		Properly Preserved: <u>Y</u> / N		Received Within Holding Times: <u>Y</u> / N					
Notes: Ice preservation not required		0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃		5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH nH>9 9=NaOH pH> 10=Other					
Bottles AES: <u>Y</u> / N				Notes:					



251111039



214
14 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

CHAIN OF CUSTODY RECORD

AES Work Order#:

251111039

COC Reference:

1378

EXPERIENCE IS THE SOLUTION

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: Ballston Spa Schools	Address:	
Send Report to:	Project Name (Location) Gordon Creek	Samplers Name: <i>David Cameron</i>
Client Phone #:	Client PO #:	Samplers Signature: <i>[Signature]</i>
Client Email:		

AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
017	010 Fountain Bottle Fill	11/11/25	0730	PW		X	1	0	Lead
018	034 Sink		0742	PW		X	1	0	Lead
019	035 Bubbler		0741	PW		X	1	0	Lead
020	037 Nurse For Meds		0741	PW		X	1	0	Lead
021	038 Bubbler		0738	PW		X	1	0	Lead
022	041 Bubbler		0735	PW		X	1	0	Lead
023	052 Fountain Bubbler		0752	PW		X	1	0	Lead
024	053 Fountain		0753	PW		X	1	0	Lead
025	055 Bubbler		0754	PW		X	1	0	Lead
026	057 Bubbler		0756	PW		X	1	0	Lead
027	059 Bubbler		0759	PW		X	1	0	Lead
028	062 Bubbler		0800	PW		X	1	0	Lead
029	065 Bubbler		0802	PW		X	1	0	Lead
030	067 Bubbler		0803	PW		X	1	0	Lead
031	070 Bubbler		0801	PW		X	1	0	Lead
032	073 Bubbler		0758	PW		X	1	0	Lead

Shipment Arrived Via:
FedEx UPS Client AES Other: _____

Special Instructions/Remarks:

Turnaround Time Requested:

④ 1 Day ④ 2 Day 3 Day 5 Day Standard

NOTE: Samples received after 3:30pm are considered next business day.

PLEASE FILL ALL PINK SHADED AREAS

Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by:	Date <i>11/11/25</i>	Time <i>14:40</i>

Sample Temperature Ambient Notes: Ice preservation not required	Properly Preserved: <u>Y</u> / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other _____	Received Within Holding Times: <u>Y</u> / N Notes:
Bottles AES: <u>Y</u> / N		



14 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

3/4

CHAIN OF CUSTODY RECORD

AES Work Order#:

25111039

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: Ballston Spa Schools		Address:							
Send Report to:		Project Name (Location) Gordon Creek				Samplers Name: <i>David Camarillo</i>			
Client Phone #:		Client PO #:				Samplers Signature: <i>[Signature]</i>			
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
033	077 Bubbler	11/11/25	0757	PW		X	1	0	Lead
034	079 Bubbler		0755	PW		X	1	0	Lead
035	052 Fountain Bottle Fill		0752	PW		X	1	0	Lead
036	084 Bubbler		0822	PW		X	1	0	Lead
037	086 Bubbler		0824	PW		X	1	0	Lead
038	088 Bubbler		0826	PW		X	1	0	Lead
039	090 Bubbler		0828	PW		X	1	0	Lead
040	092 Bubbler		0829	PW		X	1	0	Lead
041	094 Bubbler		0827	PW		X	1	0	Lead
042	096 Bubbler		0825	PW		X	1	0	Lead
043	098 Bubbler		0823	PW		X	1	0	Lead
044	099 Fountain Bubbler		0819	PW		X	1	0	Lead
045	100 Fountain		0820	PW		X	1	0	Lead
046	111 Bubbler		0810	PW		X	1	0	Lead
047	113 Bubbler		0812	PW		X	1	0	Lead
048	115 Bubbler		0814	PW		X	1	0	Lead
Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other:				Special Instructions/Remarks:					
Turnaround Time Requested: ④ 1 Day ④ 2 Day 3 Day 5 Day <u>Standard</u>				PLEASE FILL ALL PINK SHADED AREAS					
NOTE: Samples received after 3:30pm are considered next business day.									
Relinquished by: (Signature)				Received by: (Signature)				Date	Time
Relinquished by: (Signature)				Received by: (Signature)				Date	Time
Relinquished by: (Signature)				Received for Laboratory by:				Date	Time
								<i>gm</i>	11/11/25 14:40
Sample Temperature Ambient		Properly Preserved: <u>Y</u> / N				Received Within Holding Times: <u>Y</u> / N			
Notes: Ice preservation not required		0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other				Notes:			
Bottles AES: <u>Y</u> / N									



14 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

25111039

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: Ballston Spa Schools		Address:							
Send Report to:		Project Name (Location) Gordon Creek			Samplers Name: <i>David Camarillo</i>				
Client Phone #:		Client PO #:			Samplers Signature: <i>[Signature]</i>				
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
049	117 Bubbler	11/12/25	0815	PW		X	1	0	Lead
050	119 Bubbler		0816	PW		X	1	0	Lead
051	121 Bubbler		0817	PW		X	1	0	Lead
052	123 Bubbler		0813	PW		X	1	0	Lead
053	125 Bubbler		0811	PW		X	1	0	Lead
054	128 Bubbler		0840	PW		X	1	0	Lead
055	131		0806	PW		X	1	0	Lead
056	132 Fountain Bubbler		0808	PW		X	1	0	Lead
057	133 Fountain		0809	PW		X	1	0	Lead
058	099 Fountain Bottle Fill		0819	PW		X	1	0	Lead
059	136		0843	PW		X	1	0	Lead
060	132 Fountain Bottle Fill		0808						
Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other: _____									
Turnaround Time Requested: ④ 1 Day ④ 2 Day 3 Day 5 Day <u>Standard</u>				Special Instructions/Remarks:					
NOTE: Samples received after 3:30pm are considered next business day.				PLEASE FILL ALL PINK SHADED AREAS					
Relinquished by: (Signature)				Received by: (Signature)				Date	Time
Relinquished by: (Signature)				Received by: (Signature)				Date	Time
Relinquished by: (Signature)				Received for Laboratory by:				Date	Time
								11/11/25	14:40
Sample Temperature Ambient		Properly Preserved: <u>Y</u> / <u>N</u>				Received Within Holding Times: <u>Y</u> / <u>N</u>			
Notes: Ice preservation not required		0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other _____				Notes:			
Bottles AES: <u>Y</u> / <u>N</u>									



Experience is the solution

314 North Pearl Street • Albany, New York 12207 • (518) 434-4546 • Fax (518) 434-0891

TERMS, CONDITIONS & LIMITATIONS

All service rendered by the **Adirondack Environmental Services, Inc.** are undertaken and all rates are based upon the following terms:

- (a) Neither **Adirondack Environmental Services, Inc.**, nor any of its employees, agents or sub-contractors shall be liable for any loss or damage arising out of **Adirondack Environmental Services, Inc.**'s performance or nonperformance, whether by way of negligence or breach of contract, or otherwise, in any amount greater than twice the amount billed to the customer for the work leading to the claim of the customer. Said remedy shall be the sole and exclusive remedy against **Adirondack Environmental Services, Inc.** arising out of its work.
- (b) All claims made must be in writing within forty-five (45) days after delivery of the **Adirondack Environmental Services, Inc.** report regarding said work or such claim shall be deemed or irrevocably waived.
- (c) **Adirondack Environmental Services, Inc.** reports are submitted in writing and are for our customers only. Our customers are considered to be only those entities being billed for our services. Acquisition of an **Adirondack Environmental Services, Inc.** report by other than our customer does not constitute a representation of **Adirondack Environmental Services, Inc.** as to the accuracy of the contents thereof.
- (d) In no event shall **Adirondack Environmental Services, Inc.**, its employees, agents or sub-contractors be responsible for consequential or special damages of any kind or in any amount.
- (e) No deviation from the terms set forth herein shall bind **Adirondack Environmental Services, Inc.** unless in writing and signed by a Director of **Adirondack Environmental Services, Inc.**
- (f) Results pertain only to items analyzed. Information supplied by client is assumed to be correct. This information may be used on reports and in calculations and **Adirondack Environmental Services, Inc.** is not responsible for the accuracy of this information.
- (g) Payments by Credit Card/Purchase Cards are subject to a 3% additional charge.