



Experience is the solution

314 North Pearl Street ♦ Albany, New York 12207
(800) 848-4983 ♦ (518) 434-4546 ♦ Fax (518) 434-0891

November 18, 2025

Mr. Ed Martin
Ballston Spa Central School District
70 Malta Avenue
Ballston Spa, NY 12020
TEL: (518) 884-7195

Work Order No: 251111033

RE:
Middle School

Adirondack Environmental Services, Inc received 30 samples on 11/11/2025 for the analyses presented in the following report.

Please see case narrative for specifics on analysis.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

ELAP#: 10709

Tara Daniels
Laboratory Director

Adirondack Environmental Services, Inc

CASE NARRATIVE

Ballston Spa Central School District

Date: 18-Nov-25

Middle School

Lab WorkOrder: 251111033

Sample containers were supplied by Adirondack Environmental Services.

Definitions - RL: Reporting Limit DF: Dilution factor

Qualifiers:	ND : Not Detected at reporting limit	C: CCV below acceptable Limits
	J: Analyte detected below quantitation limit	C+: CCV above acceptable Limits
	B: Analyte detected in Blank	S: LCS Spike recovery is below acceptable limits
	X : Exceeds maximum contamination limit	S+: LCS Spike recovery is above acceptable limits
	H: Hold time exceeded	Z: Duplication outside acceptable limits
	N: Matrix Spike below acceptable limits	T : Tentatively Identified Compound-Estimated
	N+: Matrix Spike is above acceptable limits	E :Above quantitation range-Estimated

Note : All Results are reported as wet weight unless noted

The results relate only to the items tested. Information supplied by the client is assumed to be correct.

Adirondack Environmental Services, Inc

Date: 18-Nov-25

CLIENT: Ballston Spa Central School District

LabWork Order: 251111033

Project: Middle School

PO#:

Lab SampleID: 251111033-001

Collection Date: 11/11/2025 9:15:00 AM

Client Sample ID: 7 Bubbler

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/11/2025 4:01:40 PM)

Lead	ND	1.0		µg/L	1	11/14/2025 5:15:35 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111033-002

Collection Date: 11/11/2025 9:15:00 AM

Client Sample ID: 8 Bottle Fill

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/11/2025 4:01:40 PM)

Lead	ND	1.0		µg/L	1	11/14/2025 5:33:31 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111033-003

Collection Date: 11/11/2025 9:22:00 AM

Client Sample ID: 016A Bubbler

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/11/2025 4:01:40 PM)

Lead	ND	1.0		µg/L	1	11/14/2025 5:37:07 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111033-004

Collection Date: 11/11/2025 9:22:00 AM

Client Sample ID: 16B Bottle Fill

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/11/2025 4:01:40 PM)

Lead	ND	1.0		µg/L	1	11/14/2025 5:40:43 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111033-005

Collection Date: 11/11/2025 8:51:00 AM

Client Sample ID: 38 Bubbler

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/11/2025 4:01:40 PM)

Lead	ND	1.0		µg/L	1	11/14/2025 5:44:19 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 18-Nov-25

CLIENT: Ballston Spa Central School District**LabWork Order:** 251111033**Project:**
Middle School**PO#:****Lab SampleID:** 251111033-006**Collection Date:** 11/11/2025 8:51:00 AM**Client Sample ID:** 39 Bottle Fill**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/11/2025 4:01:40 PM)

Lead	ND	1.0		µg/L	1	11/14/2025 5:47:56 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111033-007**Collection Date:** 11/11/2025 8:54:00 AM**Client Sample ID:** 73 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/11/2025 4:01:40 PM)

Lead	ND	1.0		µg/L	1	11/14/2025 5:51:32 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111033-008**Collection Date:** 11/11/2025 8:54:00 AM**Client Sample ID:** 74 Bottle Fill**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/11/2025 4:01:40 PM)

Lead	ND	1.0		µg/L	1	11/14/2025 5:55:07 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111033-009**Collection Date:** 11/11/2025 8:56:00 AM**Client Sample ID:** 76 Faculty**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/11/2025 4:01:40 PM)

Lead	2.3	1.0		µg/L	1	11/14/2025 5:58:43 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111033-010**Collection Date:** 11/11/2025 8:58:00 AM**Client Sample ID:** 87A Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/11/2025 4:01:40 PM)

Lead	ND	1.0		µg/L	1	11/14/2025 6:02:19 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 18-Nov-25

CLIENT: Ballston Spa Central School District**LabWork Order:** 251111033**Project:**
Middle School**PO#:****Lab SampleID:** 251111033-011**Collection Date:** 11/11/2025 8:58:00 AM**Client Sample ID:** 87B Bottle Fill**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **KH**

(Prep: - 11/11/2025 4:01:40 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 12:21:26 PM
------	----	-----	--	------	---	------------------------

Lab SampleID: 251111033-012**Collection Date:** 11/11/2025 9:00:00 AM**Client Sample ID:** 98**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **KH**

(Prep: - 11/11/2025 4:01:40 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 12:39:22 PM
------	----	-----	--	------	---	------------------------

Lab SampleID: 251111033-013**Collection Date:** 11/11/2025 9:18:00 AM**Client Sample ID:** 100**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **KH**

(Prep: - 11/11/2025 4:01:40 PM)

Lead	2.9	1.0		µg/L	1	11/17/2025 12:42:58 PM
------	-----	-----	--	------	---	------------------------

Lab SampleID: 251111033-014**Collection Date:** 11/11/2025 9:18:00 AM**Client Sample ID:** 101**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **KH**

(Prep: - 11/11/2025 4:01:40 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 12:46:34 PM
------	----	-----	--	------	---	------------------------

Lab SampleID: 251111033-015**Collection Date:** 11/11/2025 9:19:00 AM**Client Sample ID:** 102**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **KH**

(Prep: - 11/11/2025 4:01:40 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 12:50:10 PM
------	----	-----	--	------	---	------------------------

Adirondack Environmental Services, Inc

Date: 18-Nov-25

CLIENT: Ballston Spa Central School District**LabWork Order:** 251111033**Project:**
Middle School**PO#:****Lab SampleID:** 251111033-016**Collection Date:** 11/11/2025 9:19:00 AM**Client Sample ID:** 103**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/11/2025 4:01:40 PM)

Lead	3.6	1.0		µg/L	1	11/17/2025 12:53:46 PM
------	-----	-----	--	------	---	------------------------

Lab SampleID: 251111033-017**Collection Date:** 11/11/2025 9:19:00 AM**Client Sample ID:** 104**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/11/2025 4:01:40 PM)

Lead	4.2	1.0		µg/L	1	11/17/2025 12:57:22 PM
------	-----	-----	--	------	---	------------------------

Lab SampleID: 251111033-018**Collection Date:** 11/11/2025 9:12:00 AM**Client Sample ID:** 108 Nurse**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/11/2025 4:01:40 PM)

Lead	18.1	1.0	X	µg/L	1	11/17/2025 1:00:57 PM
------	------	-----	---	------	---	-----------------------

Lab SampleID: 251111033-019**Collection Date:** 11/11/2025 9:13:00 AM**Client Sample ID:** 109 Nurse**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/11/2025 4:01:40 PM)

Lead	2.0	1.0		µg/L	1	11/17/2025 1:04:33 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111033-020**Collection Date:** 11/11/2025 9:02:00 AM**Client Sample ID:** 123 Bottle Fill**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/11/2025 4:01:40 PM)

Lead	ND	1.0		µg/L	1	11/17/2025 1:15:18 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 18-Nov-25

CLIENT: Ballston Spa Central School District

LabWork Order: 251111033

Project: Middle School

PO#:

Lab SampleID: 251111033-021

Collection Date: 11/11/2025 9:10:00 AM

Client Sample ID: 128A Bubbler

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 11:26:52 AM)

Lead	ND	1.0		µg/L	1	11/17/2025 1:26:05 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111033-022

Collection Date: 11/11/2025 9:10:00 AM

Client Sample ID: 128B Bottle Fill

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 11:26:52 AM)

Lead	ND	1.0		µg/L	1	11/17/2025 1:36:52 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111033-023

Collection Date: 11/11/2025 9:08:00 AM

Client Sample ID: 130 3Bay Sink

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 11:26:52 AM)

Lead	195	1.0	X	µg/L	1	11/17/2025 1:40:28 PM
------	-----	-----	---	------	---	-----------------------

Lab SampleID: 251111033-024

Collection Date: 11/11/2025 9:07:00 AM

Client Sample ID: 131 3Bay Sink

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 11:26:52 AM)

Lead	3.7	1.0		µg/L	1	11/17/2025 1:44:05 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111033-025

Collection Date: 11/11/2025 9:07:00 AM

Client Sample ID: 132 Sink

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 11:26:52 AM)

Lead	5.7	1.0	X	µg/L	1	11/17/2025 1:47:40 PM
------	-----	-----	---	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 18-Nov-25

CLIENT: Ballston Spa Central School District**LabWork Order:** 251111033**Project:** Middle School**PO#:****Lab SampleID:** 251111033-026**Collection Date:** 11/11/2025 9:05:00 AM**Client Sample ID:** 135 Sink**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 11:26:52 AM)

Lead	2.7	1.0		µg/L	1	11/17/2025 1:58:26 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111033-027**Collection Date:** 11/11/2025 9:05:00 AM**Client Sample ID:** 136 Spicket**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 11:26:52 AM)

Lead	ND	1.0		µg/L	1	11/17/2025 2:02:02 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111033-028**Collection Date:** 11/11/2025 9:01:00 AM**Client Sample ID:** 143 Bottle Fill**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 11:26:52 AM)

Lead	ND	1.0		µg/L	1	11/17/2025 2:05:38 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111033-029**Collection Date:** 11/11/2025 9:29:00 AM**Client Sample ID:** 150 Sink**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 11:26:52 AM)

Lead	ND	1.0		µg/L	1	11/17/2025 2:09:14 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111033-030**Collection Date:** 11/11/2025 9:30:00 AM**Client Sample ID:** 151 Slop Sink**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 11:26:52 AM)

Lead	1.1	1.0		µg/L	1	11/17/2025 2:12:50 PM
------	-----	-----	--	------	---	-----------------------



14 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

25111033

3

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: Ballston Spa Schools		Address:							
Send Report to:		Project Name (Location) Middle School				Samplers Name: <i>Jan Rohac</i>			
Client Phone #:		Client PO #:				Samplers Signature: <i>[Signature]</i>			
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
001	7 Buubler	11/1/25	0915	PW		X	1	0	Lead
002	8 Bottle Fill		0915	PW		X	1	0	Lead
003	016A Bubblers		0922	PW		X	1	0	Lead
004	016B Bottle Fill		0922	PW		X	1	0	Lead
005	38 Bubblers		0851	PW		X	1	0	Lead
006	39 Bottle Fill		0851	PW		X	1	0	Lead
007	73 Bubblers		0854	PW		X	1	0	Lead
008	74 Bottle Fill		0854	PW		X	1	0	Lead
009	76 Faculty		0856	PW		X	1	0	Lead
010	87A Bubblers		0858	PW		X	1	0	Lead
011	87B Bottle Fill		0858	PW		X	1	0	Lead
012	98		0900	PW		X	1	0	Lead
013	100		0918	PW		X	1	0	Lead
014	101		0918	PW		X	1	0	Lead
015	102		0919	PW		X	1	0	Lead
016	103	✓	0919	PW		X	1	0	Lead
Bottles AES: Y / N FedEx UPS Client: <u>AES</u> Other: _____				Special Instructions/Remarks:					
Turnaround Time Requested: ④ 1 Day ④ 2 Day 3 Day 5 Day Standard NOTE: Samples received after 3:30pm are considered next business day.									
Relinquished by: (Signature)				Received by: (Signature)				Date	Time
Relinquished by: (Signature)				Received by: (Signature)				Date	Time
Relinquished by: (Signature)				Received for Laboratory by:				Date	Time
Sample Temperature <u>Ambient</u>				Properly Preserved: <u>Y</u> / N				Received Within Holding Times: <u>Y</u> / N	
Notes: Ice preservation not required				0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other _____				Notes:	
Bottles AES: <u>Y</u> / N									



251111033



14 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

25111033 2/3

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: Ballston Spa Schools		Address:							
Send Report to:		Project Name (Location) Middle School				Samplers Name: <i>Jan Redgarc</i>			
Client Phone #:		Client PO #:				Samplers Signature: <i>[Signature]</i>			
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
017	104	11/1/25	0919	PW		X	1	0	Lead
018	108 Nurse		0912	PW		X	1	0	Lead
019	109 Nurse		0913	PW		X	1	0	Lead
020	123 Bottle fill		0902	PW		X	1	0	Lead
021	128A Bubbler		0910	PW		X	1	0	Lead
022	128B Bottle Fill		0910	PW		X	1	0	Lead
023	130 3Bay Sink		0908	PW		X	1	0	Lead
024	131 3Bay Sink		0907	PW		X	1	0	Lead
025	132 Sink		0907	PW		X	1	0	Lead
~~026~~	~~133~~			~~PW~~		~~X~~	~~1~~	~~0~~	~~Lead~~
~~027~~	~~134 Kitchen~~			~~PW~~		~~X~~	~~1~~	~~0~~	~~Lead~~
~~028~~	~~135 Sink~~		0905	~~PW~~		~~X~~	~~1~~	~~0~~	~~Lead~~
~~029~~	~~136 Spicket~~		0905	~~PW~~		~~X~~	~~1~~	~~0~~	~~Lead~~
~~030~~	~~143 Bottle Fill~~		0901	~~PW~~		~~X~~	~~1~~	~~0~~	~~Lead~~
~~031~~	~~148A Water Fountain~~		~~Frozen~~	~~PW~~		~~X~~	~~1~~	~~0~~	~~Lead~~
~~032~~	~~148B Water Fountain~~		~~Frozen~~	~~PW~~		~~X~~	~~1~~	~~0~~	~~Lead~~

Shipment Arrived Via: ☒ FedEx ☐ UPS ☒ Client ☒ AES ☐ Other: _____

Turnaround Time Requested: ☒ 1 Day ☐ 2 Day ☐ 3 Day ☐ 5 Day ☐ Standard
NOTE: Samples received after 3:30pm are considered next business day.

Special Instructions/Remarks: *Steamer units - no tap access* (TR)

PLEASE FILL ALL PINK SHADED AREAS

Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by:	Date	Time

Sample Temperature: Ambient

Notes: Ice preservation not required

Bottles AES: Y / N

Properly Preserved: Y / N

Received Within Holding Times: Y / N

Notes:

0=None
1=H₂SO₄ pH<2
2=HNO₃ pH<2
3=HCl pH<2
4=Na₂S₂O₃
5=NH₄Cl
6=Ascorbic Acid
7=FAS
8=ZnAc/NaOH pH>9
9=NaOH pH>10
10=Other _____



CHAIN OF CUSTODY RECORD

AES Work Order#:

2S111033 3/3

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

[illegible]



Experience is the solution

314 North Pearl Street • Albany, New York 12207 • (518) 434-4546 • Fax (518) 434-0891

TERMS, CONDITIONS & LIMITATIONS

All service rendered by the **Adirondack Environmental Services, Inc.** are undertaken and all rates are based upon the following terms:

- (a) Neither **Adirondack Environmental Services, Inc.**, nor any of its employees, agents or sub-contractors shall be liable for any loss or damage arising out of **Adirondack Environmental Services, Inc.**'s performance or nonperformance, whether by way of negligence or breach of contract, or otherwise, in any amount greater than twice the amount billed to the customer for the work leading to the claim of the customer. Said remedy shall be the sole and exclusive remedy against **Adirondack Environmental Services, Inc.** arising out of its work.
- (b) All claims made must be in writing within forty-five (45) days after delivery of the **Adirondack Environmental Services, Inc.** report regarding said work or such claim shall be deemed or irrevocably waived.
- (c) **Adirondack Environmental Services, Inc.** reports are submitted in writing and are for our customers only. Our customers are considered to be only those entities being billed for our services. Acquisition of an **Adirondack Environmental Services, Inc.** report by other than our customer does not constitute a representation of **Adirondack Environmental Services, Inc.** as to the accuracy of the contents thereof.
- (d) In no event shall **Adirondack Environmental Services, Inc.**, its employees, agents or sub-contractors be responsible for consequential or special damages of any kind or in any amount.
- (e) No deviation from the terms set forth herein shall bind **Adirondack Environmental Services, Inc.** unless in writing and signed by a Director of **Adirondack Environmental Services, Inc.**
- (f) Results pertain only to items analyzed. Information supplied by client is assumed to be correct. This information may be used on reports and in calculations and **Adirondack Environmental Services, Inc.** is not responsible for the accuracy of this information.
- (g) Payments by Credit Card/Purchase Cards are subject to a 3% additional charge.