



Experience is the solution

314 North Pearl Street ♦ Albany, New York 12207
(800) 848-4983 ♦ (518) 434-4546 ♦ Fax (518) 434-0891

November 19, 2025

Mr. Ed Martin
Ballston Spa Central School District
70 Malta Avenue
Ballston Spa, NY 12020
TEL: (518) 884-7195

Work Order No: 251111036

RE:
Malta Ave

Adirondack Environmental Services, Inc received 49 samples on 11/11/2025 for the analyses presented in the following report.

Please see case narrative for specifics on analysis.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

ELAP#: 10709

Tara Daniels
Laboratory Director

Adirondack Environmental Services, Inc

CASE NARRATIVE

Ballston Spa Central School District

Date: 19-Nov-25

Malta Ave

Lab WorkOrder: 251111036

Sample containers were supplied by Adirondack Environmental Services.

Definitions - RL: Reporting Limit DF: Dilution factor

Qualifiers:	ND : Not Detected at reporting limit	C: CCV below acceptable Limits
	J: Analyte detected below quantitation limit	C+: CCV above acceptable Limits
	B: Analyte detected in Blank	S: LCS Spike recovery is below acceptable limits
	X : Exceeds maximum contamination limit	S+: LCS Spike recovery is above acceptable limits
	H: Hold time exceeded	Z: Duplication outside acceptable limits
	N: Matrix Spike below acceptable limits	T : Tentatively Identified Compound-Estimated
	N+: Matrix Spike is above acceptable limits	E :Above quantitation range-Estimated

Note : All Results are reported as wet weight unless noted

The results relate only to the items tested. Information supplied by the client is assumed to be correct.

Adirondack Environmental Services, Inc

Date: 19-Nov-25

CLIENT: Ballston Spa Central School District**LabWork Order:** 251111036**Project:**
Malta Ave**PO#:****Lab SampleID:** 251111036-001**Collection Date:** 11/11/2025 10:04:00 AM**Client Sample ID:** 7A Bubbler Hi**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:00 PM)

Lead	ND	1.0		µg/L	1	11/18/2025 12:10:36 PM
------	----	-----	--	------	---	------------------------

Lab SampleID: 251111036-002**Collection Date:** 11/11/2025 10:04:00 AM**Client Sample ID:** 7B Bubbler Bottle Fill**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:00 PM)

Lead	ND	1.0		µg/L	1	11/18/2025 12:21:25 PM
------	----	-----	--	------	---	------------------------

Lab SampleID: 251111036-003**Collection Date:** 11/11/2025 10:04:00 AM**Client Sample ID:** 7C Bubbler Low**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:00 PM)

Lead	ND	1.0		µg/L	1	11/18/2025 12:32:11 PM
------	----	-----	--	------	---	------------------------

Lab SampleID: 251111036-004**Collection Date:** 11/11/2025 10:03:00 AM**Client Sample ID:** 11 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:00 PM)

Lead	8.5	1.0	X	µg/L	1	11/18/2025 12:35:48 PM
------	-----	-----	---	------	---	------------------------

Lab SampleID: 251111036-005**Collection Date:** 11/11/2025 10:01:00 AM**Client Sample ID:** 13 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:00 PM)

Lead	ND	1.0		µg/L	1	11/18/2025 12:39:26 PM
------	----	-----	--	------	---	------------------------

Adirondack Environmental Services, Inc

Date: 19-Nov-25

CLIENT: Ballston Spa Central School District**LabWork Order:** 251111036**Project:**
Malta Ave**PO#:****Lab SampleID:** 251111036-006**Collection Date:** 11/11/2025 10:00:00 AM**Client Sample ID:** 16 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:00 PM)

Lead	ND	1.0		µg/L	1	11/18/2025 12:42:59 PM
------	----	-----	--	------	---	------------------------

Lab SampleID: 251111036-007**Collection Date:** 11/11/2025 10:26:00 AM**Client Sample ID:** 20 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:00 PM)

Lead	ND	1.0		µg/L	1	11/18/2025 12:46:33 PM
------	----	-----	--	------	---	------------------------

Lab SampleID: 251111036-008**Collection Date:** 11/11/2025 10:25:00 AM**Client Sample ID:** 23 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:00 PM)

Lead	ND	1.0		µg/L	1	11/18/2025 12:50:07 PM
------	----	-----	--	------	---	------------------------

Lab SampleID: 251111036-009**Collection Date:** 11/11/2025 10:25:00 AM**Client Sample ID:** 26 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:00 PM)

Lead	ND	1.0		µg/L	1	11/18/2025 12:53:41 PM
------	----	-----	--	------	---	------------------------

Lab SampleID: 251111036-010**Collection Date:** 11/11/2025 10:11:00 AM**Client Sample ID:** 29A WtCoolerHall Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:00 PM)

Lead	ND	1.0		µg/L	1	11/18/2025 12:57:16 PM
------	----	-----	--	------	---	------------------------

Adirondack Environmental Services, Inc

Date: 19-Nov-25

CLIENT: Ballston Spa Central School District
Project: Malta Ave

LabWork Order: 251111036
PO#:

Lab SampleID: 251111036-011 **Collection Date:** 11/11/2025 10:11:00 AM
Client Sample ID: 29B WtCoolerHall Bottle Fill **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:00 PM)

Lead	ND	1.0		µg/L	1	11/18/2025 1:00:51 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111036-012 **Collection Date:** 11/11/2025 10:23:00 AM
Client Sample ID: 33A Faculty Rm Sink **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:00 PM)

Lead	ND	1.0		µg/L	1	11/18/2025 1:18:47 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111036-013 **Collection Date:** 11/11/2025 10:23:00 AM
Client Sample ID: 33B Faculty RM Sink **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:00 PM)

Lead	ND	1.0		µg/L	1	11/18/2025 1:22:23 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111036-014 **Collection Date:** 11/11/2025 10:13:00 AM
Client Sample ID: 34A WtCoolerHall Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:00 PM)

Lead	ND	1.0		µg/L	1	11/18/2025 1:25:59 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111036-015 **Collection Date:** 11/11/2025 10:13:00 AM
Client Sample ID: 34B WtCoolerHall Bottle Fill **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:00 PM)

Lead	ND	1.0		µg/L	1	11/18/2025 1:29:36 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 19-Nov-25

CLIENT: Ballston Spa Central School District**LabWork Order:** 251111036**Project:**
Malta Ave**PO#:****Lab SampleID:** 251111036-016**Collection Date:** 11/11/2025 10:20:00 AM**Client Sample ID:** 36 Nurses Sink**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:00 PM)

Lead	ND	1.0		µg/L	1	11/18/2025 1:33:09 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111036-017**Collection Date:** 11/11/2025 10:12:00 AM**Client Sample ID:** 38 Water Fountain**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:00 PM)

Lead	ND	1.0		µg/L	1	11/18/2025 1:36:43 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111036-018**Collection Date:** 11/11/2025 10:16:00 AM**Client Sample ID:** 39 Fill hose**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:00 PM)

Lead	1.0	1.0		µg/L	1	11/18/2025 1:40:17 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111036-019**Collection Date:** 11/11/2025 10:17:00 AM**Client Sample ID:** 40 3Bay Sink**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:00 PM)

Lead	1.7	1.0		µg/L	1	11/18/2025 1:43:51 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111036-020**Collection Date:** 11/11/2025 10:17:00 AM**Client Sample ID:** 41 3Bay Sink**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:00 PM)

Lead	1.2	1.0		µg/L	1	11/18/2025 1:47:26 PM
------	-----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 19-Nov-25

CLIENT: Ballston Spa Central School District**LabWork Order:** 251111036**Project:**
Malta Ave**PO#:****Lab SampleID:** 251111036-021**Collection Date:** 11/11/2025 10:18:00 AM**Client Sample ID:** 42 Sink**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:03 PM)

Lead	ND	1.0		µg/L	1	11/18/2025 2:05:21 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111036-022**Collection Date:** 11/11/2025 10:18:00 AM**Client Sample ID:** 43 Kettle**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:03 PM)

Lead	25.7	1.0	X	µg/L	1	11/18/2025 2:16:09 PM
------	------	-----	---	------	---	-----------------------

Lab SampleID: 251111036-023**Collection Date:** 11/11/2025 10:36:00 AM**Client Sample ID:** 44B Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:03 PM)

Lead	2.9	1.0		µg/L	1	11/18/2025 2:19:45 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111036-024**Collection Date:** 11/11/2025 10:35:00 AM**Client Sample ID:** 45B Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:03 PM)

Lead	6.9	1.0	X	µg/L	1	11/18/2025 2:23:19 PM
------	-----	-----	---	------	---	-----------------------

Lab SampleID: 251111036-025**Collection Date:** 11/11/2025 10:30:00 AM**Client Sample ID:** 48A Water Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:03 PM)

Lead	ND	1.0		µg/L	1	11/18/2025 2:26:53 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 19-Nov-25

CLIENT: Ballston Spa Central School District**LabWork Order:** 251111036**Project:**
Malta Ave**PO#:****Lab SampleID:** 251111036-026**Collection Date:** 11/11/2025 10:30:00 AM**Client Sample ID:** 48B Water Bottle Fill**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:03 PM)

Lead	ND	1.0		µg/L	1	11/18/2025 2:30:27 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111036-027**Collection Date:** 11/11/2025 10:33:00 AM**Client Sample ID:** 54A Hallway Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:03 PM)

Lead	ND	1.0		µg/L	1	11/18/2025 2:41:11 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111036-028**Collection Date:** 11/11/2025 10:33:00 AM**Client Sample ID:** 54B Hallway Bottle Fill**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:03 PM)

Lead	ND	1.0		µg/L	1	11/18/2025 2:44:46 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111036-029**Collection Date:** 11/11/2025 10:39:00 AM**Client Sample ID:** 55 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:03 PM)

Lead	1.7	1.0		µg/L	1	11/18/2025 2:48:21 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111036-030**Collection Date:** 11/11/2025 10:41:00 AM**Client Sample ID:** 57 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:03 PM)

Lead	1.1	1.0		µg/L	1	11/18/2025 2:51:56 PM
------	-----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 19-Nov-25

CLIENT: Ballston Spa Central School District**LabWork Order:** 251111036**Project:**
Malta Ave**PO#:****Lab SampleID:** 251111036-031**Collection Date:** 11/11/2025 10:41:00 AM**Client Sample ID:** 60 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:03 PM)

Lead	ND	1.0		µg/L	1	11/18/2025 2:55:31 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111036-032**Collection Date:** 11/11/2025 10:42:00 AM**Client Sample ID:** 62 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:03 PM)

Lead	ND	1.0		µg/L	1	11/18/2025 3:06:19 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111036-033**Collection Date:** 11/11/2025 10:38:00 AM**Client Sample ID:** 65A Hallway Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:03 PM)

Lead	ND	1.0		µg/L	1	11/18/2025 3:09:55 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111036-034**Collection Date:** 11/11/2025 10:38:00 AM**Client Sample ID:** 65B Hallway Bottle Fill**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:03 PM)

Lead	ND	1.0		µg/L	1	11/18/2025 3:13:30 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111036-035**Collection Date:** 11/11/2025 10:46:00 AM**Client Sample ID:** 71 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:03 PM)

Lead	1.2	1.0		µg/L	1	11/18/2025 3:24:14 PM
------	-----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 19-Nov-25

CLIENT: Ballston Spa Central School District**LabWork Order:** 251111036**Project:**
Malta Ave**PO#:****Lab SampleID:** 251111036-036**Collection Date:** 11/11/2025 10:46:00 AM**Client Sample ID:** 74 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:03 PM)

Lead	ND	1.0		µg/L	1	11/18/2025 3:27:49 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111036-037**Collection Date:** 11/11/2025 10:47:00 AM**Client Sample ID:** 79 Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:03 PM)

Lead	ND	1.0		µg/L	1	11/18/2025 3:31:23 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111036-038**Collection Date:** 11/11/2025 10:50:00 AM**Client Sample ID:** 80B Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:03 PM)

Lead	2.6	1.0		µg/L	1	11/18/2025 3:34:58 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111036-039**Collection Date:** 11/11/2025 10:51:00 AM**Client Sample ID:** 81B Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:03 PM)

Lead	5.0	1.0		µg/L	1	11/18/2025 3:38:33 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111036-040**Collection Date:** 11/11/2025 10:52:00 AM**Client Sample ID:** 86A Hallway Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:03 PM)

Lead	ND	1.0		µg/L	1	11/18/2025 3:42:08 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 19-Nov-25

CLIENT: Ballston Spa Central School District
Project: Malta Ave

LabWork Order: 251111036
PO#:

Lab SampleID: 251111036-041 **Collection Date:** 11/11/2025 10:51:00 AM
Client Sample ID: 86B Hallway Bottle Fill **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:06 PM)

Lead	ND	1.0		µg/L	1	11/18/2025 3:52:55 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111036-042 **Collection Date:** 11/11/2025 10:52:00 AM
Client Sample ID: 87B Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:06 PM)

Lead	2.8	1.0		µg/L	1	11/18/2025 4:10:52 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111036-043 **Collection Date:** 11/11/2025 10:53:00 AM
Client Sample ID: 88B Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:06 PM)

Lead	2.2	1.0		µg/L	1	11/18/2025 4:14:27 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111036-044 **Collection Date:** 11/11/2025 10:55:00 AM
Client Sample ID: 89A Hallway Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:06 PM)

Lead	ND	1.0		µg/L	1	11/18/2025 4:18:02 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 251111036-045 **Collection Date:** 11/11/2025 10:55:00 AM
Client Sample ID: 89B Hallway Bottle Fill **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:06 PM)

Lead	ND	1.0		µg/L	1	11/18/2025 4:21:37 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 19-Nov-25

CLIENT: Ballston Spa Central School District**LabWork Order:** 251111036**Project:**
Malta Ave**PO#:****Lab SampleID:** 251111036-046**Collection Date:** 11/11/2025 10:56:00 AM**Client Sample ID:** 90B Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:06 PM)

Lead	4.5	1.0		µg/L	1	11/18/2025 4:25:12 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111036-047**Collection Date:** 11/11/2025 10:57:00 AM**Client Sample ID:** 91B Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:06 PM)

Lead	4.8	1.0		µg/L	1	11/18/2025 4:28:47 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111036-048**Collection Date:** 11/11/2025 10:59:00 AM**Client Sample ID:** 92B Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:06 PM)

Lead	3.3	1.0		µg/L	1	11/18/2025 4:32:23 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 251111036-049**Collection Date:** 11/11/2025 11:00:00 AM**Client Sample ID:** 93B Bubbler**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 11/12/2025 12:54:06 PM)

Lead	4.4	1.0		µg/L	1	11/18/2025 4:35:58 PM
------	-----	-----	--	------	---	-----------------------



14 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

25111036

1/4

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: Ballston Spa Schools		Address:							
Send Report to:		Project Name (Location) Malta Ave				Samplers Name: <i>Jan Rohac</i>			
Client Phone #:		Client PO #:				Samplers Signature: <i>[Signature]</i>			
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
001	007A Bubbler Hi	11/11/25	1004	PW		X	1	0	Lead
002	007B Bubbler Bottle Fill		1004	PW		X	1	0	Lead
003	007C Bubbler Low		1004	PW		X	1	0	Lead
004	011 Bubbler		1003	PW		X	1	0	Lead
005	013 Bubbler		1001	PW		X	1	0	Lead
006	016 Bubbler		1000	PW		X	1	0	Lead
007	020 Bubbler		1026	PW		X	1	0	Lead
008	023 Bubbler		1025	PW		X	1	0	Lead
009	026 Bubbler		1025	PW		X	1	0	Lead
010	029A WtCoolerHall Bubbler		1011	PW		X	1	0	Lead
011	029B WtCoolerHall Bottle Fill		1011	PW		X	1	0	Lead
012	033A Faculty Rm Sink		1023	PW		X	1	0	Lead
013	033B Faculty RM Sink		1023	PW		X	1	0	Lead
014	034A WtCoolerHall Bubbler		1013	PW		X	1	0	Lead
015	034B WtCoolerHall Bottle Fill		1013	PW		X	1	0	Lead
016	036 Nurses Sink	✓	1020	PW		X	1	0	Lead
Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other: _____				Special Instructions/Remarks:					
Turnaround Time Requested: ④ 1 Day ④ 2 Day 3 Day 5 Day Standard NOTE: Samples received after 3:30pm are considered next business day.									
PLEASE FILL ALL PINK SHADED AREAS									
Relinquished by: (Signature)				Received by: (Signature)				Date	Time
Relinquished by: (Signature)				Received by: (Signature)				Date	Time
Relinquished by: (Signature) <i>[Signature]</i>				Received for Laboratory by: <i>CF</i>				Date 11/11	Time 2:00
Sample Temperature <u>Ambient</u>				Properly Preserved: <u>Y</u> N				Received Within Holding Times: <u>Y</u> N	
Notes: Ice preservation not required				0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other				Notes:	
Bottles AES: <u>Y</u> N									



25111036



14 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

25111036 2/4

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: Ballston Spa Schools		Address:							
Send Report to:		Project Name (Location) Malta Ave				Samplers Name: <i>Jan R. R. R.</i>			
Client Phone #:		Client PO #:				Samplers Signature: <i>[Signature]</i>			
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
017	038 Water Fountain	1/11/25	1012	PW		X	1	0	Lead
018	039 Fill Hose		1016	PW		X	1	0	Lead
019	040 3Bay Sink		1017	PW		X	1	0	Lead
020	041 3Bay Sink		1017	PW		X	1	0	Lead
021	042 Sink		1018	PW		X	1	0	Lead
022	043 Kettle		1018	PW		X	1	0	Lead
023	044B Bubblers		1036	PW		X	1	0	Lead
024	045B Bubblers		1035	PW		X	1	0	Lead
025	048A Water Bubblers		1030	PW		X	1	0	Lead
026	048B Water Bottle Fill		1030	PW		X	1	0	Lead
027	054A Hallway Bubblers		1033	PW		X	1	0	Lead
028	054B Hallway Bottle Fill		1033	PW		X	1	0	Lead
029	055 Bubblers		1039	PW		X	1	0	Lead
030	057 Bubblers		1041	PW		X	1	0	Lead
031	060 Bubblers		1041	PW		X	1	0	Lead
032	062 Bubblers		1042	PW		X	1	0	Lead
Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other: _____				Special Instructions/Remarks:					
Turnaround Time Requested: ④ 1 Day ④ 2 Day 3 Day 5 Day Standard NOTE: Samples received after 3:30pm are considered next business day.				PLEASE FILL ALL PINK SHADED AREAS					
Relinquished by: (Signature)				Received by: (Signature)				Date	Time
Relinquished by: (Signature)				Received by: (Signature)				Date	Time
Relinquished by: (Signature) <i>[Signature]</i>				Received for Laboratory by: <i>CF</i>				Date 11/11	Time 2:00
Sample Temperature <u>Ambient</u>				Properly Preserved: <u>Y</u> / <u>N</u>				Received Within Holding Times: <u>Y</u> / <u>N</u>	
Notes: Ice preservation not required				0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other _____				Notes:	
Bottles AES: <u>Y</u> / <u>N</u>									



14 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#: 25111036 3/4

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: Ballston Spa Schools		Address:							
Send Report to:		Project Name (Location) Malta Ave				Samplers Name: <i>Jan Rohac</i>			
Client Phone #:		Client PO #:				Samplers Signature: <i>[Signature]</i>			
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
033	065A Hallway Bubbler	11/1/25	1038	PW		X	1	0	Lead
034	065B Hallway Bottle Fill		1038	PW		X	1	0	Lead
035	071 Bubbler		1046	PW		X	1	0	Lead
036	074 Bubbler		1046	PW		X	1	0	Lead
037	079 Bubbler		1047	PW		X	1	0	Lead
038	080B Bubbler		1050	PW		X	1	0	Lead
039	081B Bubbler		1051	PW		X	1	0	Lead
040	086A Hallway Bubbler		1052	PW		X	1	0	Lead
041	086B Hallway Bottle Fill		1051	PW		X	1	0	Lead
042	087B Bubbler		1052	PW		X	1	0	Lead
043	088B Bubbler		1053	PW		X	1	0	Lead
044	089A Hallway Bubbler		1055	PW		X	1	0	Lead
045	089B Hallway Bottle Fill		1055	PW		X	1	0	Lead
046	090B Bubbler		1056	PW		X	1	0	Lead
047	091B Bubbler		1057	PW		X	1	0	Lead
048	092B Bubbler		1059	PW		X	1	0	Lead
Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other: _____				Special Instructions/Remarks:					
Turnaround Time Requested: ④ 1 Day ④ 2 Day 3 Day 5 Day Standard NOTE: Samples received after 3:30pm are considered next business day.				PLEASE FILL ALL PINK SHADED AREAS					
Relinquished by: (Signature)				Received by: (Signature)				Date	Time
Relinquished by: (Signature)				Received by: (Signature)				Date	Time
Relinquished by: (Signature) <i>[Signature]</i>				Received for Laboratory by: <i>CF</i>				Date 11/1	Time 2:00
Sample Temperature <u>Ambient</u>				Properly Preserved: <u>Y</u> N				Received Within Holding Times: <u>Y</u> N	
Notes: Ice preservation not required				0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other _____				Notes:	
Bottles AES: <u>Y</u> N									



14 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

AES Work Order#:

25111036 4/4

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

[illegible]



Experience is the solution

314 North Pearl Street • Albany, New York 12207 • (518) 434-4546 • Fax (518) 434-0891

TERMS, CONDITIONS & LIMITATIONS

All service rendered by the **Adirondack Environmental Services, Inc.** are undertaken and all rates are based upon the following terms:

- (a) Neither **Adirondack Environmental Services, Inc.**, nor any of its employees, agents or sub-contractors shall be liable for any loss or damage arising out of **Adirondack Environmental Services, Inc.**'s performance or nonperformance, whether by way of negligence or breach of contract, or otherwise, in any amount greater than twice the amount billed to the customer for the work leading to the claim of the customer. Said remedy shall be the sole and exclusive remedy against **Adirondack Environmental Services, Inc.** arising out of its work.
- (b) All claims made must be in writing within forty-five (45) days after delivery of the **Adirondack Environmental Services, Inc.** report regarding said work or such claim shall be deemed or irrevocably waived.
- (c) **Adirondack Environmental Services, Inc.** reports are submitted in writing and are for our customers only. Our customers are considered to be only those entities being billed for our services. Acquisition of an **Adirondack Environmental Services, Inc.** report by other than our customer does not constitute a representation of **Adirondack Environmental Services, Inc.** as to the accuracy of the contents thereof.
- (d) In no event shall **Adirondack Environmental Services, Inc.**, its employees, agents or sub-contractors be responsible for consequential or special damages of any kind or in any amount.
- (e) No deviation from the terms set forth herein shall bind **Adirondack Environmental Services, Inc.** unless in writing and signed by a Director of **Adirondack Environmental Services, Inc.**
- (f) Results pertain only to items analyzed. Information supplied by client is assumed to be correct. This information may be used on reports and in calculations and **Adirondack Environmental Services, Inc.** is not responsible for the accuracy of this information.
- (g) Payments by Credit Card/Purchase Cards are subject to a 3% additional charge.