Experience is the solution
314 North Pearl Street ♦ Albany, New York 12207
(800) 848-4983 ♦ (518) 434-4546 ♦ Fax (518) 434-0891

November 20, 2025

Mr. Ed Martin
Ballston Spa Central School District
70 Malta Avenue
Ballston Spa, NY 12020

TEL: (518) 884-7195

Work Order No: 251111041
PO#: 26-00260

RE:
Milton Terrace

Adirondack Environmental Services, Inc received 28 samples on 11/11/2025 for the analyses presented in the following report.

Please see case narrative for specifics on analysis.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

ELAP#: 10709

Tara Daniels
Laboratory Director

Adirondack Environmental Services, Inc — CASE NARRATIVE

Ballston Spa Central School District

Date: *20-Nov-25*

Milton Terrace

Lab WorkOrder: **251111041**

Sample containers were supplied by Adirondack Environmental Services.

Definitions - RL: Reporting Limit DF: Dilution factor

Qualifiers:

- ND : Not Detected at reporting limit
- J: Analyte detected below quantitation limit
- B: Analyte detected in Blank
- X : Exceeds maximum contamination limit
- H: Hold time exceeded
- N: Matrix Spike below acceptable limits
- N+: Matrix Spike is above acceptable limits
- C: CCV below acceptable Limits
- C+: CCV above acceptable Limits
- S: LCS Spike recovery is below acceptable limits
- S+: LCS Spike recovery is above acceptable limits
- Z: Duplication outside acceptable limits
- T : Tentatively Identified Compound-Estimated
- E :Above quantitation range-Estimated

Note : All Results are reported as wet weight unless noted

The results relate only to the items tested. Information supplied by the client is assumed to be correct.

Lab SampleID: 251111041-001 **Collection Date:** 11/11/2025 9:32:00 AM
Client Sample ID: 001 Cafe Fountain Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
(Prep: - 11/12/2025 10:15:48 AM)						
Lead	**ND**	1.0		µg/L	1	11/19/2025 2:47:15 PM

Lab SampleID: 251111041-002 **Collection Date:** 11/11/2025 9:19:00 AM
Client Sample ID: 004 Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
(Prep: - 11/12/2025 10:15:48 AM)						
Lead	**ND**	1.0		µg/L	1	11/19/2025 2:57:58 PM

Lab SampleID: 251111041-003 **Collection Date:** 11/11/2025 9:21:00 AM
Client Sample ID: 007 Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
(Prep: - 11/12/2025 10:15:48 AM)						
Lead	**ND**	1.0		µg/L	1	11/19/2025 3:01:32 PM

Lab SampleID: 251111041-004 **Collection Date:** 11/11/2025 9:23:00 AM
Client Sample ID: 011 Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
(Prep: - 11/12/2025 10:15:48 AM)						
Lead	**ND**	1.0		µg/L	1	11/19/2025 3:05:08 PM

Lab SampleID: 251111041-005 **Collection Date:** 11/11/2025 9:24:00 AM
Client Sample ID: 014 Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
(Prep: - 11/12/2025 10:15:48 AM)						
Lead	**1.3**	1.0		µg/L	1	11/19/2025 3:15:53 PM

CLIENT: Ballston Spa Central School District **LabWork Order:** **251111041**
Project: Milton Terrace **PO#:** 26-00260

Lab SampleID: 251111041-006 **Collection Date:** 11/11/2025 9:26:00 AM
Client Sample ID: 017 Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
(Prep: - 11/12/2025 10:15:48 AM)						
Lead	**ND**	1.0		µg/L	1	11/19/2025 3:19:28 PM

Lab SampleID: 251111041-007 **Collection Date:** 11/11/2025 9:22:00 AM
Client Sample ID: 020 Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
(Prep: - 11/12/2025 10:15:48 AM)						
Lead	**1.0**	1.0		µg/L	1	11/19/2025 3:23:04 PM

Lab SampleID: 251111041-008 **Collection Date:** 11/11/2025 9:20:00 AM
Client Sample ID: 024 Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
(Prep: - 11/12/2025 10:15:48 AM)						
Lead	**4.9**	1.0		µg/L	1	11/19/2025 3:26:40 PM

Lab SampleID: 251111041-009 **Collection Date:** 11/11/2025 9:18:00 AM
Client Sample ID: 027 Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
(Prep: - 11/12/2025 10:15:48 AM)						
Lead	**ND**	1.0		µg/L	1	11/19/2025 3:30:17 PM

Lab SampleID: 251111041-010 **Collection Date:** 11/11/2025 9:17:00 AM
Client Sample ID: 029 Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
(Prep: - 11/12/2025 10:15:48 AM)						
Lead	**2.0**	1.0		µg/L	1	11/19/2025 3:33:51 PM

CLIENT: Ballston Spa Central School District **LabWork Order:** **251111041**
Project: Milton Terrace **PO#:** 26-00260

Lab SampleID: 251111041-011 **Collection Date:** 11/11/2025 9:16:00 AM
Client Sample ID: 033 Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
	(Prep: - 11/12/2025 10:15:48 AM)					
Lead	**2.8**	1.0		µg/L	1	11/19/2025 3:37:25 PM

Lab SampleID: 251111041-012 **Collection Date:** 11/11/2025 9:14:00 AM
Client Sample ID: 038 Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
	(Prep: - 11/12/2025 10:15:48 AM)					
Lead	**1.9**	1.0		µg/L	1	11/19/2025 3:48:07 PM

Lab SampleID: 251111041-013 **Collection Date:** 11/11/2025 9:13:00 AM
Client Sample ID: 042 Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
	(Prep: - 11/12/2025 10:15:48 AM)					
Lead	**1.2**	1.0		µg/L	1	11/19/2025 3:58:52 PM

Lab SampleID: 251111041-014 **Collection Date:** 11/11/2025 9:07:00 AM
Client Sample ID: 046 Lounge Sink **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
	(Prep: - 11/12/2025 10:15:48 AM)					
Lead	**1.6**	1.0		µg/L	1	11/19/2025 4:02:27 PM

Lab SampleID: 251111041-015 **Collection Date:** 11/11/2025 9:02:00 AM
Client Sample ID: 052 Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
	(Prep: - 11/12/2025 10:15:48 AM)					
Lead	**1.7**	1.0		µg/L	1	11/19/2025 4:06:03 PM

CLIENT: Ballston Spa Central School District **LabWork Order:** **251111041**
Project: Milton Terrace **PO#:** 26-00260

Lab SampleID: 251111041-016 **Collection Date:** 11/11/2025 9:03:00 AM
Client Sample ID: 055 Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
(Prep: - 11/12/2025 10:15:48 AM)						
Lead	**ND**	1.0		µg/L	1	11/19/2025 4:09:38 PM

Lab SampleID: 251111041-017 **Collection Date:** 11/11/2025 9:11:00 AM
Client Sample ID: 057 Fountain **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
(Prep: - 11/12/2025 10:15:48 AM)						
Lead	**8.2**	1.0	X	µg/L	1	11/19/2025 4:13:14 PM

Lab SampleID: 251111041-018 **Collection Date:** 11/11/2025 9:00:00 AM
Client Sample ID: 059 Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
(Prep: - 11/12/2025 10:15:48 AM)						
Lead	**ND**	1.0		µg/L	1	11/19/2025 4:16:51 PM

Lab SampleID: 251111041-019 **Collection Date:** 11/11/2025 8:59:00 AM
Client Sample ID: 062 Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
(Prep: - 11/12/2025 10:15:48 AM)						
Lead	**ND**	1.0		µg/L	1	11/19/2025 4:20:27 PM

Lab SampleID: 251111041-020 **Collection Date:** 11/11/2025 8:50:00 AM
Client Sample ID: 065 Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
(Prep: - 11/12/2025 10:15:48 AM)						
Lead	**ND**	1.0		µg/L	1	11/19/2025 4:24:01 PM

Lab SampleID: 251111041-021 **Collection Date:** 11/11/2025 8:55:00 AM
Client Sample ID: 071 Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
	(Prep: - 11/12/2025 10:23:00 AM)					
Lead	**1.6**	1.0		µg/L	1	11/19/2025 4:41:54 PM

Lab SampleID: 251111041-022 **Collection Date:** 11/11/2025 8:51:00 AM
Client Sample ID: 074 Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
	(Prep: - 11/12/2025 10:23:00 AM)					
Lead	**3.0**	1.0		µg/L	1	11/19/2025 4:52:38 PM

Lab SampleID: 251111041-023 **Collection Date:** 11/11/2025 8:50:00 AM
Client Sample ID: 077 Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
	(Prep: - 11/12/2025 10:23:00 AM)					
Lead	**1.5**	1.0		µg/L	1	11/19/2025 4:56:13 PM

Lab SampleID: 251111041-024 **Collection Date:** 11/11/2025 8:52:00 AM
Client Sample ID: 085 Fountain Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
	(Prep: - 11/12/2025 10:23:00 AM)					
Lead	**ND**	1.0		µg/L	1	11/19/2025 4:59:49 PM

Lab SampleID: 251111041-025 **Collection Date:** 11/11/2025 9:08:00 AM
Client Sample ID: 096 Fountain Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
	(Prep: - 11/12/2025 10:23:00 AM)					
Lead	**ND**	1.0		µg/L	1	11/19/2025 5:03:25 PM

CLIENT: Ballston Spa Central School District
Project: Milton Terrace

LabWork Order: **251111041**
PO#: 26-00260

Lab SampleID: 251111041-026 **Collection Date:** 11/11/2025 9:32:00 AM
Client Sample ID: 001 Cafe Fountain Bottle Fill **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
	(Prep: - 11/12/2025 10:23:00 AM)					
Lead	**ND**	1.0		µg/L	1	11/19/2025 5:07:01 PM

Lab SampleID: 251111041-027 **Collection Date:** 11/11/2025 8:52:00 AM
Client Sample ID: 085 Fountain Bottle Fill **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
	(Prep: - 11/12/2025 10:23:00 AM)					
Lead	**ND**	1.0		µg/L	1	11/19/2025 5:10:38 PM

Lab SampleID: 251111041-028 **Collection Date:** 11/11/2025 8:52:00 AM
Client Sample ID: 096 Fountain Bottle Fill **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
	(Prep: - 11/12/2025 10:23:00 AM)					
Lead	**ND**	1.0		µg/L	1	11/19/2025 5:14:12 PM

Adirondack Environmental Services, Inc.
14 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891
EXPERIENCE IS THE SOLUTION

1/2

LM

CHAIN OF CUSTODY RECORD

AES Work Order#: 25111041

COC Reference: 1378

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: **Ballston Spa Schools**	Address:	
Send Report to:	Project Name (Location) **Milton Terrace**	Samplers Name: David Cameron
Client Phone #:	Client PO #:	Samplers Signature:
Client Email:		

AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type Matrix	C	G	# of Cont's	Preser-vative	Analysis
001	001 Cafe Fountain Bubbler	11/11/25	0932	PW		X	1	0	Lead
002	004 Bubbler		0919	PW		X	1	0	Lead
003	007 Bubbler		0921	PW		X	1	0	Lead
004	011 Bubbler		0923	PW		X	1	0	Lead
005	014 Bubbler		0924	PW		X	1	0	Lead
006	017 Bubbler		0926	PW		X	1	0	Lead
007	020 Bubbler		0922	PW		X	1	0	Lead
008	024 Bubbler		0920	PW		X	1	0	Lead
009	027 Bubbler		0918	PW		X	1	0	Lead
010	029 Bubbler		0917	PW		X	1	0	Lead
011	033 Bubbler		0916	PW		X	1	0	Lead
012	038 Bubbler		0914	PW		X	1	0	Lead
013	042 Bubbler		0913	PW		X	1	0	Lead
014	046 Lounge Sink		0907	PW		X	1	0	Lead
015	052 Bubbler		0902	PW		X	1	0	Lead
016	055 Bubbler	↓	0903	PW		X	1	0	Lead

Shipment Arrived Via:
FedEx UPS Client AES Other:_____

Turnaround Time Requested:
④ 1 Day ④ 2 Day 3 Day 5 Day Standard
NOTE: Samples received after 3:30pm are considered next business day.

Special Instructions/Remarks:

PLEASE FILL ALL PINK SHADED AREAS

Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by: JM	Date 11/11/25	Time 14:50

Sample Temperature
Ambient
Notes: Ice preservation not required

Bottles AES: Y / N

Properly Preserved: Y / N
0=None
1=H_2SO_4 pH<2
2=HNO_3 pH<2
3=HCl pH<2
4=$Na_2S_2O_3$
5=NH_4Cl
6=Ascorbic Acid
7=FAS
8=ZnAc/NaOH pH>9
9=NaOH pH>
10=Other

Received Within Holding Times: Y / N
Notes:

Demo
251111041

2/2

Adirondack Environmental Services, Inc.
14 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#: 25111104 1

COC Reference: 1378

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: **Ballston Spa Schools**	Address:
Send Report to:	Project Name (Location) **Milton Terrace**
Client Phone #:	Client PO #:
Client Email:	

Samplers Name: David Carmen Mo

Samplers Signature:

AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type Matrix	C	G	# of Cont's	Preservative	Analysis
017	057 Fountain	11/11/25	0911	PW		X	1	0	Lead
018	059 Bubbler		0900	PW		X	1	0	Lead
019	062 Bubbler		0859	PW		X	1	0	Lead
020	065 Bubbler		0850	PW		X	1	0	Lead
021	071 Bubbler		0855	PW		X	1	0	Lead
022	074 Bubbler		0851	PW		X	1	0	Lead
023	077 Bubbler		0850	PW		X	1	0	Lead
024	085 Fountain Bubbler		0852	PW		X	1	0	Lead
025	096 Fountain Bubbler		0908	PW		X	1	0	Lead
026	001 Cafe Fountain Bottle Fill		0932	PW		X	1	0	Lead
027	085 Fountain Bottle Fill		0852	PW		X	1	0	Lead
028	096 Fountain Bottle Fill	↓	0852	PW		X	1	0	Lead

Shipment Arrived Via:
FedEx UPS Client AES Other:_____

Turnaround Time Requested:
④ 1 Day ④ 2 Day 3 Day 5 Day Standard
NOTE: Samples received after 3:30pm are considered next business day.

Special Instructions/Remarks:

PLEASE FILL ALL PINK SHADED AREAS

Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by: JM	Date 11/11/25	Time 14:50

Sample Temperature
Ambient
Notes: Ice preservation not required

Bottles AES: Y / N

Properly Preserved: Y / N

0=None
1=H_2SO_4 pH<2
2=HNO_3 pH<2
3=HCl pH<2
4=$Na_2S_2O_3$
5=NH_4Cl
6=Ascorbic Acid
7=FAS
8=ZnAc/NaOH pH>9
9=NaOH pH>10
10=Other_____

Received Within Holding Times: Y / N

Notes:

Adirondack Environmental Services Inc.®
Experience is the solution
314 North Pearl Street • Albany, New York 12207 • (518) 434-4546 • Fax (518) 434-0891

TERMS, CONDITIONS & LIMITATIONS

All service rendered by the **Adirondack Environmental Services, Inc.** are undertaken and all rates are based upon the following terms:

(a) Neither **Adirondack Environmental Services, Inc.,** nor any of its employees, agents or sub-contractors shall be liable for any loss or damage arising out of **Adirondack Environmental Services, Inc.'s** performance or nonperformance, whether by way of negligence or breach of contract, or otherwise, in any amount greater than twice the amount billed to the customer for the work leading to the claim of the customer. Said remedy shall be the sole and exclusive remedy against **Adirondack Environmental Services, Inc.** arising out of its work.

(b) All claims made must be in writing within forty-five (45) days after delivery of the **Adirondack Environmental Services, Inc.** report regarding said work or such claim shall be deemed or irrevocably waived.

(c) **Adirondack Environmental Services, Inc.** reports are submitted in writing and are for our customers only. Our customers are considered to be only those entities being billed for our services. Acquisition of an **Adirondack Environmental Services, Inc.** report by other than our customer does not constitute a representation of **Adirondack Environmental Services, Inc.** as to the accuracy of the contents thereof.

(d) In no event shall **Adirondack Environmental Services, Inc.,** its employees, agents or sub-contractors be responsible for consequential or special damages of any kind or in any amount.

(e) No deviation from the terms set forth herein shall bind **Adirondack Environmental Services, Inc.** unless in writing and signed by a Director of **Adirondack Environmental Services, Inc.**

(f) Results pertain only to items analyzed. Information supplied by client is assumed to be correct. This information may be used on reports and in calculations and **Adirondack Environmental Services, Inc.** is not responsible for the accuracy of this information.

(g) Payments by Credit Card/Purchase Cards are subject to a 3% additional charge.