Lead in School Drinking Water Report

Daffodil Valley Elementary School

Washington State Department of HEALTH

EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per RCW 28A.210.410 sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

RCW 28A.210.410 does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing Location	Room/space where fixture is located (i.e. room number, gym, playground)
Fixture Housing Type	Structure that contains the individual fixtures where water samples were collected from. Fixture housing may contain one or more individual fixture for sampling.
Fixture Location Details	Location within a room or space where fixture housing is located, starting to the left of the entrance and rotating clockwise, of the total number of fixture housings in a room or space (e.g. 1/5, 2/5)
Fixture Type	Tap, Sprayer, Water Fountain, Water Bottle Filler, Icemaker
Fixture Position	Left, Center, Right

Date(s) collected: 2025-11-21
Date(s) analyzed: 2025-12-02

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	405451	Main Building	Sink	Room 128	1 of 2	Tap	left	20
2	405424	Portable 1	Fountain/Tap Combo	Room 4	1 of 1	Water Fountain	left	16
3	410890	Main Building	Sink	Library	1 of 1	Tap	center	14
4	405423	Portable 1	Fountain/Tap Combo	Room 4	1 of 1	Tap	center	8
5	410887	Main Building	Fountain/Tap Combo	Room 127	1 of 1	Tap	center	8
6	410886	Main Building	Sink	Room 301	1 of 1	Tap	center	6
7	405422	Portable 1	Sink	Room 5	1 of 1	Tap	center	5
8	405437	Main Building	Sink	Pod Sink Outside Of Room 2. Yellow Pod	1 of 1	Tap	center	5
9	405443	Main Building	Sink	Room 401	1 of 1	Tap	center	5
10	405447	Main Building	Fountain/Tap Combo	Room 141	1 of 1	Tap	center	5
11	410891	Main Building	Sink - Multi-Compartment	Staff Lounge	1 of 1	Tap	center	5
12	410908	Main Building	Sink	Room 201	1 of 1	Tap	center	5

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
13	410897	Main Building	Sink	Pod Sink Outside Of Room 204	1 of 1	Tap	center	4
14	405420	Main Building	Sink	Kitchen	1 of 1	Tap	center	3
15	405448	Main Building	Fountain/Tap Combo	Room 131	1 of 1	Tap	right	3
16	405452	Main Building	Fountain/Tap Combo	Room 128	2 of 2	Tap	right	3
17	410884	Main Building	Fountain/Tap Combo	Room 310	1 of 1	Tap	center	3
18	410888	Main Building	Fountain/Tap Combo	Speech Room	1 of 1	Tap	center	3
19	405427	Portable 2 ECEAP	Sink	Room 3	3 of 4	Tap	right	2
20	405442	Main Building	Fountain/Tap Combo	Room 410	1 of 1	Water Fountain	right	2
21	405444	Main Building	Fountain - Multi-Level	Hallway Across From Gym	1 of 1	Water Fountain	left	2
22	405446	Main Building	Fountain/Tap Combo	Room 134	1 of 1	Tap	center	2
23	405453	Main Building	Fountain/Tap Combo	Room 128	2 of 2	Water Fountain	right	2
24	405456	Main Building	Sink	Pod Sink Outside Of Room 304	1 of 1	Tap	center	2

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
25	410881	Main Building	Fountain/Tap Combo	Room 308	1 of 1	Tap	center	2
26	410883	Main Building	Fountain/Tap Combo	Room 309	1 of 1	Tap	center	2
27	410889	Main Building	Fountain/Tap Combo	Speech Room	1 of 1	Water Fountain	right	2
28	410895	Main Building	Fountain/Tap Combo	Room 203	1 of 1	Tap	center	2
29	410900	Main Building	Fountain/Tap Combo	Room 205	1 of 1	Tap	center	2
30	405421	Main Building	Sink	Kitchen	1 of 1	Sprayer	center	1
31	405425	Portable 2 ECEAP	Sink	Room 3	1 of 4. Smallest sinks first	Tap	left	1
32	405429	Main Building	Fountain/Tap Combo	Room 409	1 of 1	Tap	center	1
33	405430	Main Building	Fountain/Tap Combo	Room 409	1 of 1	Water Fountain	right	1
34	405432	Main Building	Fountain/Tap Combo	Room 408	1 of 1	Water Fountain	right	1
35	405433	Main Building	Fountain/Tap Combo	Room 405	1 of 1	Tap	center	1

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
36	405434	Main Building	Fountain/Tap Combo	Room 405	1 of 1	Water Fountain	right	1
37	405435	Main Building	Fountain/Tap Combo	Room 404	1 of 1	Tap	center	1
38	405436	Main Building	Fountain/Tap Combo	Room 404	1 of 1	Water Fountain	right	1
39	405440	Main Building	Fountain/Tap Combo	Room 410	1 of 1	Tap	center	1
40	405454	Main Building	Fountain/Tap Combo	Room 303	1 of 1	Tap	center	1
41	405455	Main Building	Fountain/Tap Combo	Room 303	1 of 1	Water Fountain	right	1
42	405457	Main Building	Fountain/Tap Combo	Room 304	1 of 1	Tap	center	1
43	405458	Main Building	Fountain/Tap Combo	Room 304	1 of 1	Water Fountain	right	1
44	405459	Main Building	Fountain/Tap Combo	Room 305	1 of 1	Tap	center	1
45	410882	Main Building	Fountain/Tap Combo	Room 308	1 of 1	Water Fountain	right	1
46	410892	Main Building	Fountain - Multi-Level	Hallway Across From Main Office	1 of 1	Water Fountain	left	1

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
47	410894	Main Building	Sink	Nurses Office	1 of 1	Tap	center	1
48	410896	Main Building	Fountain/Tap Combo	Room 203	1 of 1	Water Fountain	right	1
49	410898	Main Building	Fountain/Tap Combo	Room 204	1 of 1	Tap	center	1
50	410899	Main Building	Fountain/Tap Combo	Room 204	1 of 1	Water Fountain	right	1
51	410901	Main Building	Fountain/Tap Combo	Room 205	1 of 1	Water Fountain	right	1
52	410902	Main Building	Fountain/Tap Combo	Room 208	1 of 1	Tap	center	1
53	410904	Main Building	Fountain/Tap Combo	Room 209	1 of 1	Tap	center	1
54	410906	Main Building	Fountain/Tap Combo	Room 210	1 of 1	Tap	center	1
55	405426	Portable 2 ECEAP	Sink	Room 3	2 of 4	Tap	center	<1
56	405428	Portable 2 ECEAP	Sink - Multi-Compartment	Room 3	4 of 4. Kitchen sink	Tap	center	<1
57	405431	Main Building	Fountain/Tap Combo	Room 408	1 of 1	Tap	center	<1

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
58	405438	Main Building	Fountain/Tap Combo	Room 403	1 of 1	Tap	center	<1
59	405439	Main Building	Fountain/Tap Combo	Room 403	1 of 1	Water Fountain	right	<1
60	405445	Main Building	Fountain - Multi-Level	Hallway Across From Gym	1 of 1	Water Fountain	right	<1
61	405449	Main Building	Fountain with Bottle Filler	Hallway Across From Room 128	1 of 1	Water Bottle Filler	center	<1
62	405450	Main Building	Fountain with Bottle Filler	Hallway Across From Room 128	1 of 1	Water Fountain	right	<1
63	410880	Main Building	Fountain/Tap Combo	Room 305	1 of 1	Water Fountain	right	<1
64	410885	Main Building	Fountain/Tap Combo	Room 310	1 of 1	Water Fountain	right	<1
65	410893	Main Building	Fountain - Multi-Level	Hallway Across From Main Office	1 of 1	Water Fountain	right	<1
66	410903	Main Building	Fountain/Tap Combo	Room 208	1 of 1	Water Fountain	right	<1
67	410905	Main Building	Fountain/Tap Combo	Room 209	1 of 1	Water Fountain	right	<1
68	410907	Main Building	Fountain/Tap Combo	Room 210	1 of 1	Water Fountain	right	<1