

Site Radon Inspection Report

Date : 12/09/2025

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Oak Grove E.S.
Test Location: 2838 West Main Street
Medford, OR 97501-

Individual Canister Results

Canister ID# : 4882405 Test Start : 12/01/2025 @ 06:26
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2025 @ 06:46
Location : 1st FL = Rm 14 Received: 12/09/2025 @ 16:57
Radon Level : 1.6 pCi/L Analyzed: 12/10/2025 @ 10:22
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 4882385 Test Start : 12/01/2025 @ 06:28
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2025 @ 06:46
Location : 1st FL = Rm 15 Received: 12/09/2025 @ 16:57
Radon Level : 0.7 pCi/L Analyzed: 12/10/2025 @ 10:34
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 4883588 Test Start : 12/01/2025 @ 06:28
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2025 @ 06:48
Location : 1st FL = Main Office Received: 12/09/2025 @ 16:57
Radon Level : 1.4 pCi/L Analyzed: 12/10/2025 @ 10:33
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 4882438 Test Start : 12/01/2025 @ 06:29
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2025 @ 06:46
Location : 1st FL = Rm 15/BL Received: 12/09/2025 @ 16:57
Radon Level : 1.7 pCi/L Analyzed: 12/10/2025 @ 10:36
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 4882407 Test Start : 12/01/2025 @ 06:31
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2025 @ 06:50
Location : 1st FL = Health Rm Received: 12/09/2025 @ 16:57
Radon Level : 1.4 pCi/L Analyzed: 12/10/2025 @ 10:12
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 4882412 Test Start : 12/01/2025 @ 06:32
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2025 @ 06:47
Location : 1st FL = Rm 16/DP Received: 12/09/2025 @ 16:57
Radon Level : 2.9 pCi/L Analyzed: 12/10/2025 @ 10:34
Error for Measurement is: ± 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/09/2025

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Oak Grove E.S.
Test Location: 2838 West Main Street
Medford, OR 97501-

Individual Canister Results

Canister ID# :	4882413	Test Start :	12/01/2025 @ 06:32
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/03/2025 @ 06:47
Location :	1st FL = Rm 16/DP	Received:	12/09/2025 @ 16:57
Radon Level :	0.8 pCi/L	Analyzed:	12/10/2025 @ 11:06

Average of Side by Side Canisters 1.9 pCi/L

Error for Measurement is: \pm 0.5 pCi/L

Canister ID# :	4882472	Test Start :	12/01/2025 @ 06:33
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/03/2025 @ 06:51
Location :	1st FL = Principal's Office	Received:	12/09/2025 @ 16:57
Radon Level :	1.6 pCi/L	Analyzed:	12/10/2025 @ 11:33

Error for Measurement is: \pm 0.6 pCi/L

Canister ID# :	4882312	Test Start :	12/01/2025 @ 06:34
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/03/2025 @ 06:47
Location :	1st FL = Rm 17	Received:	12/09/2025 @ 16:57
Radon Level :	1.0 pCi/L	Analyzed:	12/10/2025 @ 10:22

Error for Measurement is: \pm 0.5 pCi/L

Canister ID# :	4882329	Test Start :	12/01/2025 @ 06:35
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/03/2025 @ 06:48
Location :	1st FL = Rm 18	Received:	12/09/2025 @ 16:57
Radon Level :	0.7 pCi/L	Analyzed:	12/10/2025 @ 11:06

Error for Measurement is: \pm 0.4 pCi/L

Canister ID# :	4882357	Test Start :	12/01/2025 @ 06:36
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/03/2025 @ 06:48
Location :	1st FL = Rm 18/BL	Received:	12/09/2025 @ 16:57
Radon Level :	0.2 pCi/L	Analyzed:	12/10/2025 @ 10:34

Error for Measurement is: \pm 0.5 pCi/L

Canister ID# :	4883564	Test Start :	12/01/2025 @ 06:36
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/03/2025 @ 06:53
Location :	1st FL = Conf. Rm-A	Received:	12/09/2025 @ 16:57
Radon Level :	1.0 pCi/L	Analyzed:	12/10/2025 @ 10:57



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/09/2025

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Oak Grove E.S.
Test Location: 2838 West Main Street
Medford, OR 97501-

Individual Canister Results

Error for Measurement is: \pm 0.5 pCi/L

Canister ID# :	4882401	Test Start :	12/01/2025 @ 06:37
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/03/2025 @ 06:49
Location :	1st FL = Rm 19	Received:	12/09/2025 @ 16:57
Radon Level :	0.7 pCi/L	Analyzed:	12/10/2025 @ 10:45
Error for Measurement is:	\pm 0.4 pCi/L		

Canister ID# :	4883579	Test Start :	12/01/2025 @ 06:37
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/03/2025 @ 06:54
Location :	1st FL = Conf. Rm-B	Received:	12/09/2025 @ 16:57
Radon Level :	1.8 pCi/L	Analyzed:	12/10/2025 @ 10:14
Error for Measurement is:	\pm 0.5 pCi/L		

Canister ID# :	4882313	Test Start :	12/01/2025 @ 06:38
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/03/2025 @ 06:50
Location :	1st FL = Rm 20	Received:	12/09/2025 @ 16:57
Radon Level :	0.6 pCi/L	Analyzed:	12/10/2025 @ 11:12
Error for Measurement is:	\pm 0.5 pCi/L		

Canister ID# :	4882406	Test Start :	12/01/2025 @ 06:39
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/03/2025 @ 06:51
Location :	1st FL = Rm 21	Received:	12/09/2025 @ 16:57
Radon Level :	0.4 pCi/L	Analyzed:	12/10/2025 @ 10:56
Error for Measurement is:	\pm 0.6 pCi/L		

Canister ID# :	4883526	Test Start :	12/01/2025 @ 06:39
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/03/2025 @ 06:55
Location :	1st FL = Staff Work Rm	Received:	12/09/2025 @ 16:57
Radon Level :	1.5 pCi/L	Analyzed:	12/10/2025 @ 11:18
Error for Measurement is:	\pm 0.5 pCi/L		

Canister ID# :	4882364	Test Start :	12/01/2025 @ 06:40
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/03/2025 @ 06:52
Location :	1st FL = Rm 22/DP	Received:	12/09/2025 @ 16:57
Radon Level :	0.6 pCi/L	Analyzed:	12/10/2025 @ 11:06
Error for Measurement is:	\pm 0.4 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/09/2025

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Oak Grove E.S.
Test Location: 2838 West Main Street
Medford, OR 97501-

Individual Canister Results

Canister ID# :	4882440	Test Start :	12/01/2025 @ 06:40
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/03/2025 @ 06:52
Location :	1st FL = Rm 22/DP	Received:	12/09/2025 @ 16:57
Radon Level :	2.8 pCi/L	Analyzed:	12/10/2025 @ 10:55

Average of Side by Side Canisters 1.7 pCi/L

Error for Measurement is: \pm 0.6 pCi/L

Canister ID# :	4883548	Test Start :	12/01/2025 @ 06:40
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/03/2025 @ 06:56
Location :	1st FL = Staff Break Rm	Received:	12/09/2025 @ 16:57
Radon Level :	1.4 pCi/L	Analyzed:	12/10/2025 @ 10:45

Error for Measurement is: \pm 0.5 pCi/L

Canister ID# :	4882424	Test Start :	12/01/2025 @ 06:41
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/03/2025 @ 06:53
Location :	1st FL = Rm 23	Received:	12/09/2025 @ 16:57
Radon Level :	2.3 pCi/L	Analyzed:	12/10/2025 @ 10:36

Error for Measurement is: \pm 0.5 pCi/L

Canister ID# :	4882362	Test Start :	12/01/2025 @ 06:42
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/03/2025 @ 06:54
Location :	1st FL = Rm 24	Received:	12/09/2025 @ 16:57
Radon Level :	2.4 pCi/L	Analyzed:	12/10/2025 @ 10:36

Error for Measurement is: \pm 0.5 pCi/L

Canister ID# :	4882432	Test Start :	12/01/2025 @ 06:43
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/03/2025 @ 06:54
Location :	1st FL = Rm 25	Received:	12/09/2025 @ 16:57
Radon Level :	0.3 pCi/L	Analyzed:	12/10/2025 @ 11:22

Error for Measurement is: \pm 0.4 pCi/L

Canister ID# :	4882384	Test Start :	12/01/2025 @ 06:43
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/03/2025 @ 06:58
Location :	1st FL = Cafeteria-1	Received:	12/09/2025 @ 16:57
Radon Level :	0.5 pCi/L	Analyzed:	12/10/2025 @ 10:56



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/09/2025

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Oak Grove E.S.
Test Location: 2838 West Main Street
Medford, OR 97501-

Individual Canister Results

Error for Measurement is: \pm 0.6 pCi/L

Canister ID# :	4882356	Test Start :	12/01/2025 @ 06:44
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/03/2025 @ 06:56
Location :	1st FL = Rm 26	Received:	12/09/2025 @ 16:57
Radon Level :	0.8 pCi/L	Analyzed:	12/10/2025 @ 10:34
Error for Measurement is: \pm	0.6 pCi/L		

Canister ID# :	4883883	Test Start :	12/01/2025 @ 06:45
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/03/2025 @ 06:59
Location :	1st FL = Cafeteria-2	Received:	12/09/2025 @ 16:57
Radon Level :	4.0 pCi/L	Analyzed:	12/10/2025 @ 10:55
Error for Measurement is: \pm	0.7 pCi/L		

Canister ID# :	4882435	Test Start :	12/01/2025 @ 06:46
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/03/2025 @ 06:57
Location :	1st FL = Rm 11	Received:	12/09/2025 @ 16:57
Radon Level :	0.3 pCi/L	Analyzed:	12/10/2025 @ 10:12
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	4882426	Test Start :	12/01/2025 @ 06:46
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/03/2025 @ 06:57
Location :	1st FL = Rm 11/BL	Received:	12/09/2025 @ 16:57
Radon Level :	0.2 pCi/L	Analyzed:	12/10/2025 @ 10:58
Error for Measurement is: \pm	0.5 pCi/L		

Canister ID# :	4882439	Test Start :	12/01/2025 @ 06:46
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/03/2025 @ 07:01
Location :	1st FL = Cafe. Off.-C	Received:	12/09/2025 @ 16:57
Radon Level :	3.9 pCi/L	Analyzed:	12/10/2025 @ 10:34
Error for Measurement is: \pm	0.7 pCi/L		

Canister ID# :	4882353	Test Start :	12/01/2025 @ 06:48
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/03/2025 @ 06:58
Location :	1st FL = Rm 12/DP	Received:	12/09/2025 @ 16:57
Radon Level :	2.9 pCi/L	Analyzed:	12/10/2025 @ 10:34
Error for Measurement is: \pm	0.5 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/09/2025

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Oak Grove E.S.
Test Location: 2838 West Main Street
Medford, OR 97501-

Individual Canister Results

Canister ID# : 4882465 Test Start : 12/01/2025 @ 06:54
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2025 @ 07:02
Location : 1st FL = LaClinica-2 Received: 12/09/2025 @ 16:57
Radon Level : 0.6 pCi/L Analyzed: 12/10/2025 @ 11:18
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 4882429 Test Start : 12/01/2025 @ 06:55
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2025 @ 07:02
Location : 1st FL = LaClinica-3 Received: 12/09/2025 @ 16:57
Radon Level : 0.6 pCi/L Analyzed: 12/10/2025 @ 11:13
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 4882380 Test Start : 12/01/2025 @ 06:55
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2025 @ 07:02
Location : 1st FL = LaClinica-3/BL Received: 12/09/2025 @ 16:57
Radon Level : 0.4 pCi/L Analyzed: 12/10/2025 @ 10:14
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 4883562 Test Start : 12/01/2025 @ 06:55
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2025 @ 07:06
Location : 1st FL = Gym-1 Received: 12/09/2025 @ 16:57
Radon Level : 1.6 pCi/L Analyzed: 12/10/2025 @ 11:13
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 4882478 Test Start : 12/01/2025 @ 06:56
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2025 @ 07:07
Location : 1st FL = Gym-2 Received: 12/09/2025 @ 16:57
Radon Level : 1.0 pCi/L Analyzed: 12/10/2025 @ 10:34
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 4882391 Test Start : 12/01/2025 @ 06:57
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2025 @ 07:03
Location : 1st FL = LaClinica-4 Received: 12/09/2025 @ 16:57
Radon Level : 2.6 pCi/L Analyzed: 12/10/2025 @ 10:55
Error for Measurement is: ± 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/09/2025

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Oak Grove E.S.
Test Location: 2838 West Main Street
Medford, OR 97501-

Individual Canister Results

Canister ID# : 4882476 Test Start : 12/01/2025 @ 06:57
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2025 @ 07:07
Location : 1st FL = Gym-3 Received: 12/09/2025 @ 16:57
Radon Level : 1.2 pCi/L Analyzed: 12/10/2025 @ 10:58
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 4882430 Test Start : 12/01/2025 @ 06:58
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2025 @ 07:04
Location : 1st FL = LaClinica-5 Received: 12/09/2025 @ 16:57
Radon Level : 0.6 pCi/L Analyzed: 12/10/2025 @ 10:12
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 4882423 Test Start : 12/01/2025 @ 06:59
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2025 @ 07:05
Location : 1st FL = LaClinica-6 Received: 12/09/2025 @ 16:57
Radon Level : 0.8 pCi/L Analyzed: 12/10/2025 @ 10:56
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 4882416 Test Start : 12/01/2025 @ 06:59
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2025 @ 07:05
Location : 1st FL = LaClinica-7 Received: 12/09/2025 @ 16:57
Radon Level : 0.2 pCi/L Analyzed: 12/10/2025 @ 10:58
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 4882433 Test Start : 12/01/2025 @ 07:00
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2025 @ 07:06
Location : 1st FL = Rm 41 Received: 12/09/2025 @ 16:57
Radon Level : 41.8 pCi/L Analyzed: 12/10/2025 @ 10:14
Error for Measurement is: ± 1.2 pCi/L

Canister ID# : 4883902 Test Start : 12/01/2025 @ 07:01
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2025 @ 07:07
Location : 1st FL = Rm 42 Received: 12/09/2025 @ 16:57
Radon Level : 40.3 pCi/L Analyzed: 12/10/2025 @ 10:36
Error for Measurement is: ± 1.1 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/09/2025

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Oak Grove E.S.
Test Location: 2838 West Main Street
Medford, OR 97501-

Individual Canister Results

Canister ID# : 4882431 Test Start : 12/01/2025 @ 07:03
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2025 @ 07:12
Location : 1st FL = Media Ctr. Off. Received: 12/09/2025 @ 16:57
Radon Level : 1.3 pCi/L Analyzed: 12/10/2025 @ 11:22
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 4883587 Test Start : 12/01/2025 @ 07:05
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2025 @ 07:13
Location : 1st FL = Media Ctr.-1 Received: 12/09/2025 @ 16:57
Radon Level : 1.4 pCi/L Analyzed: 12/10/2025 @ 10:57
Error for Measurement is: ± 0.8 pCi/L

Canister ID# : 4882359 Test Start : 12/01/2025 @ 07:06
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2025 @ 07:13
Location : 1st FL = Media Ctr.-2/DP Received: 12/09/2025 @ 16:57
Radon Level : 1.3 pCi/L Analyzed: 12/10/2025 @ 10:33
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 4882437 Test Start : 12/01/2025 @ 07:06
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2025 @ 07:13
Location : 1st FL = Media Ctr.-2/DP Received: 12/09/2025 @ 16:57
Radon Level : 0.3 pCi/L Analyzed: 12/10/2025 @ 10:12

Average of Side by Side Canisters 0.8 pCi/L
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 4883850 Test Start : 12/01/2025 @ 07:08
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2025 @ 07:14
Location : 1st FL=Media Ctr./Comp. Rm Received: 12/09/2025 @ 16:57
Radon Level : 1.7 pCi/L Analyzed: 12/10/2025 @ 11:12
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 4882458 Test Start : 12/01/2025 @ 07:10
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2025 @ 07:15
Location : 1st FL = Office B-1 Received: 12/09/2025 @ 16:57
Radon Level : 4.5 pCi/L Analyzed: 12/10/2025 @ 10:55



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/09/2025

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Oak Grove E.S.
Test Location: 2838 West Main Street
Medford, OR 97501-

Individual Canister Results

Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 4882395
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = Office B-2
Radon Level : 1.1 pCi/L
Error for Measurement is: ± 0.7 pCi/L

Test Start : 12/01/2025 @ 07:11
Test Stop : 12/03/2025 @ 07:15
Received: 12/09/2025 @ 16:57
Analyzed: 12/10/2025 @ 11:33

Canister ID# : 4882427
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = Office B-3
Radon Level : 1.4 pCi/L
Error for Measurement is: ± 0.5 pCi/L

Test Start : 12/01/2025 @ 07:12
Test Stop : 12/03/2025 @ 07:15
Received: 12/09/2025 @ 16:57
Analyzed: 12/10/2025 @ 10:45

Canister ID# : 4882408
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Custodial Off.
Radon Level : 1.6 pCi/L
STORAGE AREA

Test Start : 12/01/2025 @ 07:14
Test Stop : 12/03/2025 @ 07:15
Received: 12/09/2025 @ 16:57
Analyzed: 12/10/2025 @ 11:18

Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 4883506
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = Rm 01
Radon Level : 1.1 pCi/L
Error for Measurement is: ± 0.5 pCi/L

Test Start : 12/01/2025 @ 07:17
Test Stop : 12/03/2025 @ 07:18
Received: 12/09/2025 @ 16:57
Analyzed: 12/10/2025 @ 11:12

Canister ID# : 4883550
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = Rm 02
Radon Level : 1.6 pCi/L
Error for Measurement is: ± 0.6 pCi/L

Test Start : 12/01/2025 @ 07:18
Test Stop : 12/03/2025 @ 07:18
Received: 12/09/2025 @ 16:57
Analyzed: 12/10/2025 @ 10:57



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/09/2025

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Oak Grove E.S.
Test Location: 2838 West Main Street
Medford, OR 97501-

Individual Canister Results

Canister ID# : 4882399 Test Start : 12/01/2025 @ 07:19
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2025 @ 07:19
Location : 1st FL = Rm 03 Received: 12/09/2025 @ 16:57
Radon Level : 1.4 pCi/L Analyzed: 12/10/2025 @ 11:18
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 4882420 Test Start : 12/01/2025 @ 07:20
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2025 @ 07:20
Location : 1st FL = Rm 04 Received: 12/09/2025 @ 16:57
Radon Level : 1.5 pCi/L Analyzed: 12/10/2025 @ 11:06
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 4883484 Test Start : 12/01/2025 @ 07:21
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2025 @ 07:21
Location : 1st FL = Rm 05 Received: 12/09/2025 @ 16:57
Radon Level : 1.6 pCi/L Analyzed: 12/10/2025 @ 11:22
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 4882415 Test Start : 12/01/2025 @ 07:21
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2025 @ 07:22
Location : 1st FL = Rm 06 Received: 12/09/2025 @ 16:57
Radon Level : 1.4 pCi/L Analyzed: 12/10/2025 @ 10:14
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 4882372 Test Start : 12/01/2025 @ 07:22
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2025 @ 07:22
Location : 1st FL = Rm 06/BL Received: 12/09/2025 @ 16:57
Radon Level : 2.1 pCi/L Analyzed: 12/10/2025 @ 10:34
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 4883880 Test Start : 12/01/2025 @ 07:23
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2025 @ 07:23
Location : 1st FL = Rm 07 Received: 12/09/2025 @ 16:57
Radon Level : 1.4 pCi/L Analyzed: 12/10/2025 @ 11:12
Error for Measurement is: ± 0.5 pCi/L



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/09/2025

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Oak Grove E.S.
Test Location: 2838 West Main Street
Medford, OR 97501-

Individual Canister Results

The results indicate that at least one testing device registered at or above the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends mitigation if the average of two short-term tests taken in the lowest level of the building suitable for occupancy show radon levels that are equal to or greater than 4.0 pCi/L.

For information on how to reduce radon levels in your home, please review the EPA booklet: Consumer's Guide to Radon Reduction (www.epa.gov/radon/pdfs/consguid.pdf) and contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.



Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201