

Radon Tests - Oak Grove Elementary School									
#	Location/Type	Placement Description	Serial #	Dated Opened	Time Opened	Date Closed	Time Closed	Radon Test Results pCi/L	Remarks
1	Main Office	Southeast Counter	4883588	12/01/25	6:28 AM	12/03/25	6:48 AM	1.4	
2	Health Room	South Counter	4882407	12/01/25	6:31 AM	12/03/25	6:50 AM	1.4	
3	Principal's Office	East Bookshelf	4882472	12/01/25	6:33 AM	12/03/25	6:51 AM	1.6	
4	Conference Room A	South Counter	4883564	12/01/25	6:36 AM	12/03/25	6:53 AM	1.0	
5	Conference Room B	South Counter	4883579	12/01/25	6:37 AM	12/03/25	6:54 AM	1.8	
6	Staff Work Room	Southeast Counter	4883526	12/01/25	6:39 AM	12/03/25	6:55 AM	1.5	
7	Staff Break Room	East Table	4883548	12/01/25	6:40 AM	12/03/25	6:56 AM	1.4	
8	Cafeteria # 1	Northeast Wall	4882384	12/01/25	6:43 AM	12/03/25	6:58 AM	0.5	
9	Cafeteria # 2	Northwest Wall	4883883	12/01/25	6:45 AM	12/03/25	6:59 AM	4.0	
10	Cafeteria Office "C"	Northeast Counter	4882439	12/01/25	6:46 AM	12/03/25	7:01 AM	3.9	
11	Multi Purpose Room	Northeast Counter	4883577	12/01/25	6:51 AM	12/03/25	7:04 AM	1.7	
12	Gymnasium # 1	Northeast Column	4883562	12/01/25	6:55 AM	12/03/25	7:06 AM	1.6	
13	Gymnasium # 2	Southeast Column	4882478	12/01/25	6:56 AM	12/03/25	7:07 AM	1.0	
14	Gymnasium # 3	West Column	4882476	12/01/25	6:57 AM	12/03/25	7:07 AM	1.2	
15	Media Center - Office	Corner File Cabinet	4882431	12/01/25	7:03 AM	12/03/25	7:12 AM	1.3	Redundant due to B-1 test below?
16	Media Center # 1	Island Countertop	4883587	12/01/25	7:05 AM	12/03/25	7:13 AM	1.4	
17	Media Center # 2	Island Countertop	4882359	12/01/25	7:06 AM	12/03/25	7:13 AM	1.3	
18	Media Center - Duplicate	Island Countertop	4882437	12/01/25	7:06 AM	12/03/25	7:13 AM	0.3	
19	Media Center - Computer Room	Desktop	4883850	12/01/25	7:08 AM	12/03/25	7:14 AM	1.7	Redundant due to B-4 test below?
20	Office B-1	Filing Cabinet	4882458	12/01/25	7:10 AM	12/03/25	7:15 AM	4.5	
	Office B-1	Table	CRM 1	12/15/25	11:00 AM	12/17/25	1:30 PM	0.8	EPA Average
21	Office B-2	Filing Cabinet	4882395	12/01/25	7:11 AM	12/03/25	7:15 AM	1.1	
22	Office B-3	Bookshelf	4882427	12/01/25	7:12 AM	12/03/25	7:15 AM	1.4	
23	B-4, Custodial Office/Storage Area	Filing Cabinet	4882408	12/01/25	7:14 AM	12/03/25	7:15 AM	1.6	
24	Room 1	Bookshelf	4883506	12/01/25	7:17 AM	12/03/25	7:18 AM	1.1	
25	Room 2	Sink Countertop	4883550	12/01/25	7:18 AM	12/03/25	7:18 AM	1.6	
26	Room 3	Filing Cabinet	4882399	12/01/25	7:19 AM	12/03/25	7:19 AM	1.4	
27	Room 4	Left Corner Bookshelf	4882420	12/01/25	7:20 AM	12/03/25	7:20 AM	1.5	
28	Room 5	Countertop	4883484	12/01/25	7:21 AM	12/03/25	7:21 AM	1.6	
29	Room 6	Computer Counter	4882415	12/01/25	7:21 AM	12/03/25	7:22 AM	1.4	
30	Room 6 - Blank	Computer Counter	4882372	12/01/25	7:22 AM	12/03/25	7:22 AM	2.1	High for Blank
31	Room 7	By Sink	4883880	12/01/25	7:23 AM	12/03/25	7:23 AM	1.4	
32	Room 8	Counter Top	4882418	12/01/25	7:24 AM	12/03/25	7:25 AM	0.7	
33	Room 9	West Countertop	4882388	12/01/25	7:26 AM	12/03/25	7:26 AM	0.3	
34	Room 9 - Duplicate	West Countertop	4882417	12/01/25	7:26 AM	12/03/25	7:26 AM	0.6	
35	Room 10	Bookshelf	4882366	12/01/25	7:28 AM	12/03/25	7:28 AM	0.4	
36	Room 14	North Bookcase	4882405	12/01/25	6:26 AM	12/03/25	6:46 AM	1.6	
37	Room 15	Center File Cabinet	4882385	12/01/25	6:28 AM	12/03/25	6:46 AM	0.7	
38	Room 15 - Blank	Center File Cabinet	4882438	12/01/25	6:29 AM	12/03/25	6:46 AM	1.7	High for Blank
39	Room 16	Teachers Countertop	4882413	12/01/25	6:32 AM	12/03/25	6:47 AM	0.8	
40	Room 16 - Duplicate	Teachers Countertop	4882412	12/01/25	6:32 AM	12/03/25	6:47 AM	2.9	
41	Room 17	Counter By Sink	4882312	12/01/25	6:34 AM	12/03/25	6:47 AM	1.0	
42	Room 18	South Counter	4882329	12/01/25	6:35 AM	12/03/25	6:48 AM	0.7	
43	Room 18 - Blank	South Counter	4882357	12/01/25	6:36 AM	12/03/25	6:48 AM	0.2	
44	Room 19	North Counter	4882401	12/01/25	6:37 AM	12/03/25	6:49 AM	0.7	
45	Room 20	East Wall	4882313	12/01/25	6:38 AM	12/03/25	6:50 AM	0.6	
46	Room 21	East Wall - Shelf	4882406	12/01/25	6:39 AM	12/03/25	6:51 AM	0.4	
47	Room 22	West Filing Cabinet	4882364	12/01/25	6:40 AM	12/03/25	6:52 AM	0.6	
48	Room 22 - Duplicate	West Filing Cabinet	4882440	12/01/25	6:40 AM	12/03/25	6:52 AM	2.8	
49	Room 23	East Bookshelf	4882424	12/01/25	6:41 AM	12/03/25	6:53 AM	2.3	
50	Room 24	East Wall	4882362	12/01/25	6:42 AM	12/03/25	6:54 AM	2.4	
51	Room 25	West Wall	4882432	12/01/25	6:43 AM	12/03/25	6:54 AM	0.3	
52	Room 26	Teacher's Desk	4882356	12/01/25	6:44 AM	12/03/25	6:56 AM	0.8	
53	Room 11	Filing Cabinet	4882435	12/01/25	6:46 AM	12/03/25	6:57 AM	0.3	
54	Room 11 - Blank	Filing Cabinet	4882426	12/01/25	6:46 AM	12/03/25	6:57 AM	0.2	
55	Room 12	South Counter	4882353	12/01/25	6:48 AM	12/03/25	6:58 AM	2.9	
56	Room 12 - Duplicate	South Counter	4882389	12/01/25	6:48 AM	12/03/25	6:58 AM	0.7	
57	Room 13	North Filing Cabinet	4882326	12/01/25	6:49 AM	12/03/25	6:59 AM	0.8	
58	La Clinica # 1	West Bookshelf	4882394	12/01/25	6:53 AM	12/03/25	7:01 AM	1.0	
59	La Clinica # 1 - Duplicate	West Bookshelf	4882425	12/01/25	6:53 AM	12/03/25	7:01 AM	0.5	
60	La Clinica # 2	Southeast Counter	4882465	12/01/25	6:54 AM	12/03/25	7:02 AM	0.6	
61	La Clinica # 3	South Printer Shelf	4882429	12/01/25	6:55 AM	12/03/25	7:02 AM	0.6	
62	La Clinica # 3 - Blank	South Printer Shelf	4882380	12/01/25	6:55 AM	12/03/25	7:02 AM	0.4	
63	La Clinica # 4	Southeast Countertop	4882391	12/01/25	6:57 AM	12/03/25	7:03 AM	2.6	
64	La Clinica # 5	Northwest Filing Cabinet	4882430	12/01/25	6:58 AM	12/03/25	7:04 AM	0.6	
65	La Clinica # 6	Refrigerator	4882423	12/01/25	6:59 AM	12/03/25	7:05 AM	0.8	
66	La Clinica # 7	South Filing Cabinet	4882416	12/01/25	6:59 AM	12/03/25	7:05 AM	0.2	
#	Type	Description	Serial #	Dated Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
67	Spikes #1 (Room 41)	KSU Radon Chamber Spike to 44.5	4882433	12/01/25		12/03/25		41.8	
68	Spikes #2 (Room 42)	KSU Radon Chamber Spike to 44.5	4883902	12/01/25		12/03/25		40.3	

Test Results	Average	RPD	Remarks
Initial	0.5	2.25	-156%
Duplicate	4.0		

Test Results	Average	RPD	Remarks
Initial	1.3	0.8	125%
Duplicate	0.3		
Test Results	Average	RPD	Remarks
Initial	4.5	2.65	140%
Duplicate	0.8		

Test Results	Average	RPD	Remarks
Initial	0.3	0.45	-67%
Duplicate	0.6		

Test Results	Average	RPD	Remarks
Initial	0.8	1.85	-114%
Duplicate	2.9		

Test Results	Average	RPD	Remarks
Initial	0.6	1.7	-129%
Duplicate	2.8		

Test Results	Average	RPD	Remarks
Initial	2.9	1.8	122%
Duplicate	0.7		
Test Results	Average	RPD	Remarks
Initial	1.0	0.75	67%
Duplicate	0.5		