

Lead in Drinking Water Report Geneva Elementary School



Date of Sample		11/16/2023	10/18/2024	11/18/2024	4/29/2025	
Sampled by		Washington State Department of Health	Terracon	Terracon	Terracon	Final Remediation
Fixture Location	Fixture Type	Lead Test Results (ppb)	Lead Test Results (ppb)	Lead Test Results (ppb)	Lead Test Results (ppb)	
Rm20-26 bubble	Fountain	5				Out of Service
Kitchen	Sink - Multi-compartment	8	16	14	8.9	Handwashing Only
Kitchen	Sink	2				
Classroom off cafeteria	Tap	26	3	N/A		
Classroom off cafeteria	Fountain	6	1.9	N/A		
Cafeteria	Fountain - Multi-level with Bottle Filler	2				
Cafeteria	Fountain - Multi-level with Bottle Filler	2				
Cafeteria	Tap	23	2.3	N/A		
Cafeteria	Fountain/Tap Combo	2				
Rm1	Tap	17	240	120		Handwashing Only
Rm1	Fountain	5				Out of Service
Rm2	Tap	16	11	5		Handwashing Only
Rm2	Fountain	5				Out of Service
Rm3	Tap	20	16	140		Handwashing Only
Rm3	Fountain	7	14	5.6		Out of Service
Rm4	Tap	14	480	61		Handwashing Only
Rm4	Fountain	6	18			Out of Service
Rm5	Tap	240	1000	910		Handwashing Only
Rm5	Fountain	9	81	8.7		Out of Service
Rm6	Tap	8	24	9		Handwashing Only
Rm6	Fountain	7	6.8	6.7		Out of Service

Rm7	Fountain	27	9.4	5.8		Out of Service
Rm7	Tap	32	76	6.1		Handwashing Only
Bathroom	Fountain - Multi-level with Bottle Filler	<1				
Bathroom	Fountain - Multi-level with Bottle Filler	<1				
Rm8	Tap	16	20	4.6		
Rm8	Fountain	3				Out of Service
Rm9	Tap	17	570			Handwashing Only
Rm9	Fountain	2				Out of Service
Rm10	Tap	16	97	240		Handwashing Only
Rm10	Fountain/Tap Combo	4				Out of Service
Rm11	Tap	20	22	96		Handwashing Only
Rm11	Fountain	6	21	3.2		Out of Service
Rm12	Tap	20	23	6		Handwashing Only
Rm12	Fountain	5				Out of Service
Rm13	Tap	17	95	15		Handwashing Only
Rm13	Fountain	4				Out of Service
Rm14	Fountain/Tap Combo	4				
Rm14	Fountain/Tap Combo	2				
Rm15	Tap	7	18	17		Handwashing Only
Rm15	Fountain	2				Out of Service
Rm20	Tap	4	7.4	4.6		Handwashing Only
Rm20	Fountain	2				Out of Service
Rm21	Tap	4				Handwashing Only
Rm21	Fountain	3				Out of Service
Rm22	Tap	6	2	N/A		
Rm22	Fountain	2				Out of Service
Rm23	Tap	6	2.3	N/A		Handwashing Only
Rm23	Fountain	2				Out of Service
Rm24	Fountain/Tap Combo	4				
Rm26	Fountain/Tap Combo	4				
Rm26	Fountain/Tap Combo	1				
Rm20-26 bubble	Tap	9				Handwashing Only