

November 6, 2025

Mr. Dustin Brisky
Franklinville CSD
31 N Main St,
Franklinville, NY 14737

Re: Lead Testing in School Drinking Water

Dear Mr. Brisky:

Included with this letter is Stohl Environmental LLC's report for the Lead in Drinking Water Sampling performed for Franklinville Central School District, including:

- Franklinville Junior & Senior High School – 31 N Main St, Franklinville, New York

This report is prepared to assist school districts in complying with the requirements of 10 NYCRR Subpart 67-4: *Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 5 parts per billion (ppb)".

Sampling was performed on October 2, 2025. As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 19 sources of potable water in the Franklinville Junior & Senior High School have been identified as having lead concentrations in water above the NYS Action Level of 5 parts per billion. To comply with NYS regulations, response actions by the district are required. Response actions are outlined in Section 1.3 (*Response Actions Required Under NYS Regulations*).

Thank you for the opportunity to be of service to Franklinville Central School District.

Sincerely,
Stohl Environmental, LLC.



Michael Scinta
EPA Lead Risk Assessor

Lead Testing in School Drinking Water

Prepared for:

Franklinville Central School District

Prepared by:



**3860 California Road
Orchard Park, New York 14127**

Conditions as of October 2, 2025

Summary Tabulation

Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports and Chain of Custody Documents
- 1.5. Laboratory Certifications

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Franklinville Central School District to perform sampling and analysis of potable water for lead concentrations. Sampling was performed in the following building:

- Franklinville Junior & Senior High School – 31 N Main St, Franklinville, New York

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within the Franklinville Junior & Senior High School. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

Sampling Protocol:

In accordance with NYS regulations, **Subpart 67-4: Lead Testing in School Drinking Water**, and the EPA guidance document, **3Ts for Reducing Lead in Drinking Water in Schools**, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

1.2 Executive Summary of Sampling and Analysis:

Summary of Samples Collected at the Franklinville Junior & Senior High School

Building Name	Date of Sampling	Total Samples	At or Below Action Level*	Above Action Level*
Franklinville Junior & Senior High School	10/2/25	86	67	19

*NYS Action Level is 5 parts per billion

Listing of Outlets Requiring Remediation

The following outlets were analyzed above the NYS Action Level:

Sample #	Location	Fixture/Outlet type	Laboratory Analysis (in ppb)
216.1-06	Kitchen Triple Sink	Sink	12.1
216.1-07	Kitchen Dish Wand	Sink	13.0
216.1-10	Basement Art Sink Right	Sink	20.2
216.1-11	Basement Men's Restroom	Sink	6.2
216.1-12	Basement Women's Restroom	Sink	5.9
216.1-18	Nurse's Office Main Sink	Sink	8.5
216.1-21	113 Sink	Sink	7.4
216.1-37	Room 009 Left	Sink	9.4
216.1-43	Concession Triple Sink	Sink	20.5
216.1-45	Ag Shop Left	Sink	7.4
216.1-46	Ag Shop Right (Front Desk)	Sink	69.7
216.1-47	Ag Shop Sink Left	Sink	9.3
216.1-48	Ag Shop Sink Right	Sink	6.5
216.1-50	1st Floor Athletic Hall Boys Right	Sink	5.1
216.1-51	1st Floor Athletic Hall Girls Left	Sink	10.1
216.1-53	217 Restroom Sink	Sink	7.4
216.1-57	Boy's Restroom Sink Middle	Sink	16.8
216.1-65	Lg Back Office	Sink	7.2
216.1-66	Faculty Workroom	Sink	8.7

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration more than the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

1.4 Laboratory Analytical Reports and Chain of Custody Documents



October 30, 2025

Service Request No:R2513159

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Franklinville CSD Jr Sr High School

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory October 09, 2025
For your reference, these analyses have been assigned our service request number **R2513159**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7473. You may also contact me via email at Remy.Rubin@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Remy Rubin
Project Manager

CC: Rebecca
Franjoine

ADDRESS

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

PHONE +1 585 288 5380 | **FAX** +1 585 288 8475

ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School
Sample Matrix: Drinking Water

Service Request: R2513159
Date Received: 10/09/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty six drinking water samples were received for analysis at ALS Environmental on 10/09/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink, appearing to read "R. Rubin", is written over a horizontal line.

Approved by _____

Date _____

10/29/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 216.1-1		Lab ID: R2513159-001					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.2			1.0	ug/L	200.8	
CLIENT ID: 216.1-3		Lab ID: R2513159-003					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	4.1			1.0	ug/L	200.8	
CLIENT ID: 216.1-5		Lab ID: R2513159-005					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.7			1.0	ug/L	200.8	
CLIENT ID: 216.1-6		Lab ID: R2513159-006					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	12.1			1.0	ug/L	200.8	
CLIENT ID: 216.1-7		Lab ID: R2513159-007					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	13.0			1.0	ug/L	200.8	
CLIENT ID: 216.1-9		Lab ID: R2513159-010					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	4.4			1.0	ug/L	200.8	
CLIENT ID: 216.1-10		Lab ID: R2513159-011					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	20.2			1.0	ug/L	200.8	
CLIENT ID: 216.1-11		Lab ID: R2513159-012					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	6.2			1.0	ug/L	200.8	
CLIENT ID: 216.1-12		Lab ID: R2513159-013					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	5.9			1.0	ug/L	200.8	
CLIENT ID: 216.1-13		Lab ID: R2513159-014					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	4.1			1.0	ug/L	200.8	
CLIENT ID: 216.1-14		Lab ID: R2513159-015					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.3			1.0	ug/L	200.8	
CLIENT ID: 216.1-15		Lab ID: R2513159-016					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.1			1.0	ug/L	200.8	



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 216.1-16		Lab ID: R2513159-017					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.5			1.0	ug/L	200.8	
CLIENT ID: 216.1-17		Lab ID: R2513159-018					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.3			1.0	ug/L	200.8	
CLIENT ID: 216.1-18		Lab ID: R2513159-019					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	8.5			1.0	ug/L	200.8	
CLIENT ID: 216.1-19		Lab ID: R2513159-020					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.9			1.0	ug/L	200.8	
CLIENT ID: 216.1-20		Lab ID: R2513159-021					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.3			1.0	ug/L	200.8	
CLIENT ID: 216.1-21		Lab ID: R2513159-022					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	7.4			1.0	ug/L	200.8	
CLIENT ID: 216.1-22		Lab ID: R2513159-023					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.4			1.0	ug/L	200.8	
CLIENT ID: 216.1-27		Lab ID: R2513159-029					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.3			1.0	ug/L	200.8	
CLIENT ID: 216.1-28		Lab ID: R2513159-030					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.0			1.0	ug/L	200.8	
CLIENT ID: 216.1-31		Lab ID: R2513159-033					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.3			1.0	ug/L	200.8	
CLIENT ID: 216.1-33		Lab ID: R2513159-035					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.9			1.0	ug/L	200.8	
CLIENT ID: 216.1-34		Lab ID: R2513159-036					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.3			1.0	ug/L	200.8	



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1

Service Request:R2513159

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2513159-001	216.1-1	10/2/2025	
R2513159-002	216.1-2	10/2/2025	
R2513159-003	216.1-3	10/2/2025	
R2513159-004	216.1-4	10/2/2025	
R2513159-005	216.1-5	10/2/2025	
R2513159-006	216.1-6	10/2/2025	
R2513159-007	216.1-7	10/2/2025	
R2513159-008	216.1-8A	10/2/2025	
R2513159-009	216.1-8B	10/2/2025	
R2513159-010	216.1-9	10/2/2025	
R2513159-011	216.1-10	10/2/2025	
R2513159-012	216.1-11	10/2/2025	
R2513159-013	216.1-12	10/2/2025	
R2513159-014	216.1-13	10/2/2025	
R2513159-015	216.1-14	10/2/2025	
R2513159-016	216.1-15	10/2/2025	
R2513159-017	216.1-16	10/2/2025	
R2513159-018	216.1-17	10/2/2025	
R2513159-019	216.1-18	10/2/2025	
R2513159-020	216.1-19	10/2/2025	
R2513159-021	216.1-20	10/2/2025	
R2513159-022	216.1-21	10/2/2025	
R2513159-023	216.1-22	10/2/2025	
R2513159-024	216.1-23A	10/2/2025	
R2513159-025	216.1-23B	10/2/2025	
R2513159-026	216.1-24	10/2/2025	
R2513159-027	216.1-25	10/2/2025	
R2513159-028	216.1-26	10/2/2025	
R2513159-029	216.1-27	10/2/2025	
R2513159-030	216.1-28	10/2/2025	
R2513159-031	216.1-29	10/2/2025	
R2513159-032	216.1-30	10/2/2025	
R2513159-033	216.1-31	10/2/2025	
R2513159-034	216.1-32	10/2/2025	
R2513159-035	216.1-33	10/2/2025	
R2513159-036	216.1-34	10/2/2025	



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-216.1

Client: Franklinville CSD Contact: Mr. Dustin Brisky

Building: Franklinville Jr Sr High School Location: 31 N Main St, Franklinville, NY 14737

LEAD	
Water by 200.8	<u>X</u>
	<u>Tumaround</u> 10 Days

Sample #	Location	Outlet Type	Time
216.1-01	Kitchen Island Prep Sink	Sink	5:05
216.1-02	Serving Area Ice Machine	Ice Machine	5:06
216.1-03	Kitchen Kettle Fill	Sink	5:07
216.1-04	Serving Area Prep Sink	Sink	5:08
216.1-05	Kitchen Back Prep	Sink	5:10
216.1-06	Kitchen Triple Sink	Sink	5:11
216.1-07	Kitchen Dish Wand	Sink	5:12
216.1-08A	Cafe Drinking Fountain	Drinking Fountain	5:13
216.1-08B	Cafe Bottle Fill	Bottle Fill	5:15
216.1-09	Basement Art Sink Left	Sink	5:16
216.1-10	Basement Art Sink Right	Sink	5:17
216.1-11	Basement Men's Restroom	Sink	5:18
216.1-12	Basement Women's Restroom	Sink	5:20
216.1-13	120 Art Sink Left	Sink	5:21
216.1-14	120 Art Sink Right	Sink	5:22
216.1-15	Near Art Women's Restroom	Sink	5:23
216.1-16	Near Art Men's Restroom	Sink	5:25
216.1-17	Nurse's Office Restroom Sink	Sink	5:26

Notes:
 Please e-mail lab results to labs@stohlenv.com If checked, also e-mail results to: mscinta@stohlenvironmental.com

Sampled By: Matthew McCourt Print Name Matthew McCourt Stohl Env: Matthew McCourt Date: 10/2/2025
 Relinquished By: _____ Print Name _____ Stohl Env: Connor Crilly Date: 10/9/2025
 Received (Name / Lab): *Brisky* Date: *10/2/25* Time: *1700*
 Sample Login (Name / Lab): _____ Date: _____ Time: _____
 Analysis (Name / Lab): _____ Date: _____ Time: _____
 QA/QC Review (Name / Lab): _____ Date: _____ Time: _____
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-216.1

Client: Franklinville CSD Contact: Mr. Dustin Brisky

Building: Franklinville Jr Sr High School Location: 31 N Main St, Franklinville, NY 14737

LEAD		Turnaround
Water by 200.8	<u>X</u>	<u>10 Days</u>

Sample #	Location	Outlet Type	Time
216.1-18	Nurse's Office Main Sink	Sink	5:27
216.1-19	115 Sink	Sink	5:28
216.1-20	115 Fountain	Drinking Fountain	5:30
216.1-21	113 Sink	Sink	5:31
216.1-22	113 Fountain	Drinking Fountain	5:32
216.1-23A	Fountain Outside Auditorium	Drinking Fountain	5:33
216.1-23B	Bottle Fill Outside Auditorium	Bottle Fill	5:35
216.1-24	Women's First Floor Sink Left	Sink	5:36
216.1-25	Women's First Floor Sink Right	Sink	5:37
216.1-26	Women's First Floor Staff restroom	Sink	5:38
216.1-27	107 Faculty Main Room Sink	Sink	5:40
216.1-28	107 Faculty Restroom Sink	Sink	5:41
216.1-29	Across From 108 Boy's Restroom Sink Left	Sink	5:42
216.1-30	Across From 108 Boy's Restroom Sink Right	Sink	5:43
216.1-31	Across From 319 Faculty Restroom Sink	Sink	5:45
216.1-32	Girl's Locker Room Left	Sink	5:46
216.1-33	Girl's Locker Room Middle	Sink	5:47
216.1-34	Girl's Locker Room Right	Sink	5:48

Notes:
 Please e-mail lab results to labs@stohlenv.com mscinta@stohlenvironmental.com

Sampled By: Matthew McCourt Print Name Stohl Env: Matthew McCourt Date: 10/2/2025
 Relinquished By: _____ Print Name Stohl Env: Connor Crilly Date: 10/9/2025
 Received (Name / Lab): *body* Date: 10/9/25 Time: 1700
 Sample Login (Name / Lab): _____ Date: _____ Time: _____
 Analysis (Name / Lab): _____ Date: _____ Time: _____
 QA/QC Review (Name / Lab): _____ Date: _____ Time: _____
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



R2513159 5

Stoht Environmental
Franklinville CSD Jr Sr High School



Cooler Receipt and Preservation Check

Project/Client STOHL Folder Number _____

Cooler received on 10/9/25 by: And

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <input checked="" type="checkbox"/> N
2	Custody papers properly completed (ink, signed)?	Y <input checked="" type="checkbox"/> N
3	Did all bottles arrive in good condition (unbroken)?	Y <input checked="" type="checkbox"/> N
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <input checked="" type="checkbox"/> N <input checked="" type="checkbox"/>

5a	Did VOA vials have sig* bubbles?	Y N <input checked="" type="checkbox"/> NA
5b	Sig* bubbles: Alk?	Y N <input checked="" type="checkbox"/> NA
	Sulfide?	Y N <input checked="" type="checkbox"/> NA
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as:	Bulk Encore 5035set <input checked="" type="checkbox"/> NA

8. Temperature Readings Date: 10/9 Time: 1700 ID: IR#12 (R#11) From: Temp Blank Sample Bottle

Temp (°C)	<u>21.1</u>						
Within 0-6°C?	Y <input checked="" type="checkbox"/> N	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: _____ Ice melted Poorly Packed (described below) Same Day Rule
& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: PMO by AG on 10/9 at 1755
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 10/14 Time: 1713 by: AG

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO N/A
- 13. Were dissolved metals filtered in the field? YES NO N/A
- 14. Air Samples: Cassettes / Tubes Intact Y/N with MS Y/N Canisters Pressurized Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2	<u>262325</u>	HNO ₃		X	<u>NO Lot info</u>		<u>All</u>	<u>4mL</u>		<u>4.2</u>
≤2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: _____
Explain all Discrepancies/ Other Comments: _____

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: AG *significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1

Service Request: R2513159

Sample Name: 216.1-1
Lab Code: R2513159-001
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-2
Lab Code: R2513159-002
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-3
Lab Code: R2513159-003
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-4
Lab Code: R2513159-004
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-5
Lab Code: R2513159-005
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1

Service Request: R2513159

Sample Name: 216.1-6
Lab Code: R2513159-006
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-7
Lab Code: R2513159-007
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-8A
Lab Code: R2513159-008
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-8B
Lab Code: R2513159-009
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-9
Lab Code: R2513159-010
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1

Service Request: R2513159

Sample Name: 216.1-10
Lab Code: R2513159-011
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-11
Lab Code: R2513159-012
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-12
Lab Code: R2513159-013
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-13
Lab Code: R2513159-014
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-14
Lab Code: R2513159-015
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1

Service Request: R2513159

Sample Name: 216.1-15
Lab Code: R2513159-016
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-16
Lab Code: R2513159-017
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-17
Lab Code: R2513159-018
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.1-18
Lab Code: R2513159-019
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-19
Lab Code: R2513159-020
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1

Service Request: R2513159

Sample Name: 216.1-20
Lab Code: R2513159-021
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-21
Lab Code: R2513159-022
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-22
Lab Code: R2513159-023
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-23A
Lab Code: R2513159-024
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-23B
Lab Code: R2513159-025
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1

Service Request: R2513159

Sample Name: 216.1-24
Lab Code: R2513159-026
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-25
Lab Code: R2513159-027
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-26
Lab Code: R2513159-028
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-27
Lab Code: R2513159-029
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-28
Lab Code: R2513159-030
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1

Service Request: R2513159

Sample Name: 216.1-29
Lab Code: R2513159-031
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-30
Lab Code: R2513159-032
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-31
Lab Code: R2513159-033
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-32
Lab Code: R2513159-034
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-33
Lab Code: R2513159-035
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1

Service Request: R2513159

Sample Name: 216.1-34
Lab Code: R2513159-036
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-1
Lab Code: R2513159-001

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.2	ug/L	1.0	1	10/22/25 20:52	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-2
Lab Code: R2513159-002

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 20:54	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-3
Lab Code: R2513159-003

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.1	ug/L	1.0	1	10/22/25 20:55	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-4
Lab Code: R2513159-004

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 20:56	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-5
Lab Code: R2513159-005

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.7	ug/L	1.0	1	10/22/25 21:00	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-6
Lab Code: R2513159-006

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	12.1	ug/L	1.0	1	10/22/25 21:01	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-7
Lab Code: R2513159-007

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	13.0	ug/L	1.0	1	10/22/25 21:03	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-8A
Lab Code: R2513159-008

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 21:04	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-8B
Lab Code: R2513159-009

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 21:05	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-9
Lab Code: R2513159-010

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.4	ug/L	1.0	1	10/22/25 21:07	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-10
Lab Code: R2513159-011

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	20.2	ug/L	1.0	1	10/22/25 21:08	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-11
Lab Code: R2513159-012

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	6.2	ug/L	1.0	1	10/22/25 21:09	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-12
Lab Code: R2513159-013

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.9	ug/L	1.0	1	10/22/25 21:10	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-13
Lab Code: R2513159-014

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.1	ug/L	1.0	1	10/22/25 21:12	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-14
Lab Code: R2513159-015

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	10/22/25 21:23	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-15
Lab Code: R2513159-016

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	10/22/25 21:27	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-16
Lab Code: R2513159-017

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.5	ug/L	1.0	1	10/22/25 21:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-17
Lab Code: R2513159-018

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.3	ug/L	1.0	1	10/27/25 13:04	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-18
Lab Code: R2513159-019

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	8.5	ug/L	1.0	1	10/22/25 21:31	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-19
Lab Code: R2513159-020

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.9	ug/L	1.0	1	10/22/25 21:32	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-20
Lab Code: R2513159-021

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	10/22/25 21:36	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-21
Lab Code: R2513159-022

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	7.4	ug/L	1.0	1	10/22/25 21:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-22
Lab Code: R2513159-023

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.4	ug/L	1.0	1	10/22/25 21:39	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-23A
Lab Code: R2513159-024

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 21:40	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-23B
Lab Code: R2513159-025

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 21:41	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-24
Lab Code: R2513159-026

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 21:42	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-25
Lab Code: R2513159-027

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 21:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-26
Lab Code: R2513159-028

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 21:45	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-27
Lab Code: R2513159-029

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	10/22/25 21:46	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-28
Lab Code: R2513159-030

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.0	ug/L	1.0	1	10/22/25 21:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-29
Lab Code: R2513159-031

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 21:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-30
Lab Code: R2513159-032

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 21:53	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-31
Lab Code: R2513159-033

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	10/22/25 21:54	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-32
Lab Code: R2513159-034

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 21:55	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-33
Lab Code: R2513159-035

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.9	ug/L	1.0	1	10/22/25 22:02	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-34
Lab Code: R2513159-036

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	10/22/25 22:08	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513159-MB1

Service Request: R2513159
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 20:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513159-MB2

Service Request: R2513159
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 21:21	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513159-MB3

Service Request: R2513159
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 21:59	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513159-MB4

Service Request: R2513159
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 12:34	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25
Date Analyzed: 10/22/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 216.1-13
Lab Code: R2513159-014
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2513159-014MS		Duplicate Matrix Spike R2513159-014DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	4.1	23.6	20.0	97	25.6	20.0	108	70-130	8	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25
Date Analyzed: 10/22/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 216.1-14
Lab Code: R2513159-015
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2513159-015MS		Duplicate Matrix Spike R2513159-015DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	1.3	21.7	20.0	102	21.2	20.0	100	70-130	2	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25
Date Analyzed: 10/22/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 216.1-32
Lab Code: R2513159-034
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2513159-034MS		Duplicate Matrix Spike R2513159-034DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	20.4	20.0	102	23.1	20.0	116	70-130	13	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water

Service Request: R2513159
Date Collected: 10/02/25
Date Received: 10/09/25
Date Analyzed: 10/22/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 216.1-33
Lab Code: R2513159-035
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2513159-035MS		Result	Duplicate Matrix Spike R2513159-035DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.9	22.2	20.0	101	23.0	20.0	106	70-130	4	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water

Service Request: R2513159
Date Analyzed: 10/22/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2513159-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.9	20.0	110	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water

Service Request: R2513159
Date Analyzed: 10/22/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2513159-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	23.0	20.0	115	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water

Service Request: R2513159
Date Analyzed: 10/22/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2513159-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	22.0	20.0	110	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water

Service Request: R2513159
Date Analyzed: 10/27/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2513159-LCS4

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.3	20.0	102	85-115



October 27, 2025

Service Request No:R2513162

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Franklinville CSD Jr Sr High School

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory October 09, 2025
For your reference, these analyses have been assigned our service request number **R2513162**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7473. You may also contact me via email at Remy.Rubin@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Remy Rubin
Project Manager

CC: Rebecca
Franjoine

ADDRESS

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

PHONE +1 585 288 5380 | **FAX** +1 585 288 8475

ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School
Sample Matrix: Drinking Water

Service Request: R2513162
Date Received: 10/09/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty six drinking water samples were received for analysis at ALS Environmental on 10/09/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink, appearing to read "R. Rubin", is written over a horizontal line.

Approved by _____

Date _____

10/27/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 216.1-36		Lab ID: R2513162-003					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.6			1.0	ug/L	200.8	
CLIENT ID: 216.1-37		Lab ID: R2513162-004					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	9.4			1.0	ug/L	200.8	
CLIENT ID: 216.1-38		Lab ID: R2513162-005					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.9			1.0	ug/L	200.8	
CLIENT ID: 216.1-39		Lab ID: R2513162-006					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.9			1.0	ug/L	200.8	
CLIENT ID: 216.1-40		Lab ID: R2513162-007					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.9			1.0	ug/L	200.8	
CLIENT ID: 216.1-41		Lab ID: R2513162-008					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.6			1.0	ug/L	200.8	
CLIENT ID: 216.1-43		Lab ID: R2513162-011					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	20.5			1.0	ug/L	200.8	
CLIENT ID: 216.1-44		Lab ID: R2513162-012					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.5			1.0	ug/L	200.8	
CLIENT ID: 216.1-45		Lab ID: R2513162-013					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	7.4			1.0	ug/L	200.8	
CLIENT ID: 216.1-46		Lab ID: R2513162-014					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	69.7			1.0	ug/L	200.8	
CLIENT ID: 216.1-47		Lab ID: R2513162-015					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	9.3			1.0	ug/L	200.8	
CLIENT ID: 216.1-48		Lab ID: R2513162-016					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	6.5			1.0	ug/L	200.8	



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 216.1-49		Lab ID: R2513162-017					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	5.0			1.0	ug/L	200.8	
CLIENT ID: 216.1-50		Lab ID: R2513162-018					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	5.1			1.0	ug/L	200.8	
CLIENT ID: 216.1-51		Lab ID: R2513162-019					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	10.1			1.0	ug/L	200.8	
CLIENT ID: 216.1-52		Lab ID: R2513162-020					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	4.2			1.0	ug/L	200.8	
CLIENT ID: 216.1-53		Lab ID: R2513162-021					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	7.4			1.0	ug/L	200.8	
CLIENT ID: 216.1-54		Lab ID: R2513162-022					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.5			1.0	ug/L	200.8	
CLIENT ID: 216.1-55		Lab ID: R2513162-023					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.7			1.0	ug/L	200.8	
CLIENT ID: 216.1-56		Lab ID: R2513162-024					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.0			1.0	ug/L	200.8	
CLIENT ID: 216.1-57		Lab ID: R2513162-025					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	16.8			1.0	ug/L	200.8	
CLIENT ID: 216.1-58		Lab ID: R2513162-026					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.4			1.0	ug/L	200.8	
CLIENT ID: 216.1-64		Lab ID: R2513162-033					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.4			1.0	ug/L	200.8	
CLIENT ID: 216.1-65		Lab ID: R2513162-034					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	7.2			1.0	ug/L	200.8	



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 216.1-66		Lab ID: R2513162-035				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	8.7			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1

Service Request:R2513162

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2513162-001	216.1-35A	10/2/2025	
R2513162-002	216.1-35B	10/2/2025	
R2513162-003	216.1-36	10/2/2025	
R2513162-004	216.1-37	10/2/2025	
R2513162-005	216.1-38	10/2/2025	
R2513162-006	216.1-39	10/2/2025	
R2513162-007	216.1-40	10/2/2025	
R2513162-008	216.1-41	10/2/2025	
R2513162-009	216.1-42A	10/2/2025	
R2513162-010	216.1-42B	10/2/2025	
R2513162-011	216.1-43	10/2/2025	
R2513162-012	216.1-44	10/2/2025	
R2513162-013	216.1-45	10/2/2025	
R2513162-014	216.1-46	10/2/2025	
R2513162-015	216.1-47	10/2/2025	
R2513162-016	216.1-48	10/2/2025	
R2513162-017	216.1-49	10/2/2025	
R2513162-018	216.1-50	10/2/2025	
R2513162-019	216.1-51	10/2/2025	
R2513162-020	216.1-52	10/2/2025	
R2513162-021	216.1-53	10/2/2025	
R2513162-022	216.1-54	10/2/2025	
R2513162-023	216.1-55	10/2/2025	
R2513162-024	216.1-56	10/2/2025	
R2513162-025	216.1-57	10/2/2025	
R2513162-026	216.1-58	10/2/2025	
R2513162-027	216.1-59	10/2/2025	
R2513162-028	216.1-60A	10/2/2025	
R2513162-029	216.1-60B	10/2/2025	
R2513162-030	216.1-61	10/2/2025	
R2513162-031	216.1-62	10/2/2025	
R2513162-032	216.1-63	10/2/2025	
R2513162-033	216.1-64	10/2/2025	
R2513162-034	216.1-65	10/2/2025	
R2513162-035	216.1-66	10/2/2025	
R2513162-036	216.1-67A	10/2/2025	



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-216.1

Client: Franklinville CSD

Contact: Mr. Dustin Brisky

Building: Franklinville Jr Sr High School

Location: 31 N Main St, Franklinville, NY 14737

LEAD

Water by 200.8 X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
216.1-35A	Outside Locker Room Fountain	Drinking Fountain	5:50
216.1-35B	Outside Locker Room Bottle Fill	Bottle Fill	5:51
216.1-36	Room 008 Left	Sink	5:52
216.1-37	Room 009 Left	Sink	5:53
216.1-38	Men's Restroom Left By Gym	Sink	5:55
216.1-39	Men's Restroom Right By Gym	Sink	5:56
216.1-40	Girl's Restroom Left By Gym	Sink	5:57
216.1-41	Girl's Restroom Right By Gym	Aink	5:58
216.1-42A	Drinking Fountain Near Gym	Drinking Fountain	6:00
216.1-42B	Bottle Fill Near Gym	Bottle Fill	6:01
216.1-43	Concession Triple Sink	Sink	6:02
216.1-44	Boiler Room Handsink	Sink	6:03
216.1-45	Ag Shop Left	Sink	6:05
216.1-46	Ag Shop Right (Front Desk)	Sink	6:06
216.1-47	Ag Shop Sink Left	Sink	6:07
216.1-48	Ag Shop Sink Right	Sink	6:08
216.1-49	1st Floor Athletic Hall Boys Left	Sink	6:10
216.1-50	1st Floor Athletic Hall Boys Right	Sink	6:11

Notes:

Please e-mail lab results to labs@stohlenv.com

mrcinta@stohlenvironmental.com

Sampled By: Matthew McCourt Print Name Matthew McCourt Stohl Env: Matthew McCourt Date: 10/2/2025

Relinquished By: _____ Print Name Connor Crilly Stohl Env: Connor Crilly Date: 10/9/2025

Received (Name / Lab): *[Signature]* Date: 10/9/25 Time: 1700

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-216.1

Client: Franklinville CSD Contact: Mr. Dustin Brisky

Building: Franklinville Jr Sr High School Location: 31 N Main St, Franklinville, NY 14737

LEAD		<i>Turnaround</i>
Water by 200.8	<u>X</u>	<u>10 Days</u>

Sample #	Location	Outlet Type	Time
216.1-51	1st Floor Athletic Hall Girls Left	Sink	6:12
216.1-52	1st Floor Athletic Hall Girls Right	Sink	6:13
216.1-53	217 Restroom Sink	Sink	6:15
216.1-54	2nd Floor Single Restroom Right of 217	Sink	6:16
216.1-55	2nd Floor Staff Restroom Right of 217	Sink	6:17
216.1-56	Girl's Restroom Sink Right	Sink	6:18
216.1-57	Boy's Restroom Sink Middle	Sink	6:20
216.1-58	Boy's Restroom Sink Right	Sink	6:21
216.1-59	222 Upper Fountain	Drinking Fountain	6:22
216.1-60A	222 Lower Fountain	Drinking Fountain	6:23
216.1-60B	222 Bottle Fill	Bottle Fill	6:25
216.1-61	Fountain Across From 213	Drinking Fountain	6:26
216.1-62	Staff Restroom Across From 213	Sink	6:27
216.1-63	Girl's Restroom Sink Left Across From 213	Sink	6:28
216.1-64	Girl's Restroom Sink Right Across 213	Sink	6:30
216.1-65	Lg Back Office	Sink	6:31
216.1-66	Faculty Workroom	Sink	6:32
216.1-67A	206 Fountain	Drinking Fountain	6:33

Notes: Please e-mail lab results to labs@stohlenv.com mscinta@stohlenvironmental.com

Sampled By: Matthew McCourt Print Name Matthew McCourt Stohl Env: Matthew McCourt Date: 10/2/2025

Relinquished By: _____ Print Name Connor Crilly Stohl Env: Connor Crilly Date: 10/9/2025

Received (Name / Lab): brady m Date: 10/9/25 Time: 17:20

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



R2513162

5

Stahl Environmental
Franklinville CBD Jr Sr High School



Cooler Receipt and Preservation C

Project/Client STOHL

Folder Number _____

Cooler received on 10/9/25 by: Paul

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <input checked="" type="checkbox"/>
2	Custody papers properly completed (ink, signed)?	<input checked="" type="checkbox"/> N
3	Did all bottles arrive in good condition (unbroken)?	<input checked="" type="checkbox"/> N
4	Circle: Wet Ice Dry Ice Gel packs present?	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/>

5a	Did VOA vials have sig* bubbles?	Y N <input checked="" type="checkbox"/>
5b	Sig* bubbles: Alk?	Y N <input checked="" type="checkbox"/>
	Sulfide?	Y N <input checked="" type="checkbox"/>
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as:	Bulk Encore 5035set <input checked="" type="checkbox"/>

8. Temperature Readings Date: 10/9 Time: 1700 ID: IR#12 IR#11 From: Temp Blank Sample Bottle

Temp (°C)	<u>21.1</u>						
Within 0-6°C?	Y <input checked="" type="checkbox"/>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: _____ Ice melted Poorly Packed (described below) Same Day Rule
& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SW by Paul on 10/9 at 1755
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 10/14 Time: 1714 by: AG

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO N/A
- 13. Were dissolved metals filtered in the field? YES NO N/A
- 14. Air Samples: Cassettes / Tubes Intact Y/N with MS Y/N Canisters Pressurized Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2	<u>202325</u>	HNO ₃		<input checked="" type="checkbox"/>	<u>No lot info</u>		<u>All</u>	<u>4ml</u>		<u>5.2</u>
≤2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: _____

Explain all Discrepancies/ Other Comments: _____

HPRD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: AG *significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- | | |
|---|--|
| <p>U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.</p> <p>J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).</p> <p>B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.</p> <p>E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.</p> <p>E Organics- Concentration has exceeded the calibration range for that specific analysis.</p> <p>D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.</p> <p>* Indicates that a quality control parameter has exceeded laboratory limits. Under the “Notes” column of the Form I, this qualifier denotes analysis was performed out of Holding Time.</p> <p>H Analysis was performed out of hold time for tests that have an “immediate” hold time criteria.</p> <p># Spike was diluted out.</p> | <p>+ Correlation coefficient for MSA is <0.995.</p> <p>N Inorganics- Matrix spike recovery was outside laboratory limits.</p> <p>N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.</p> <p>S Concentration has been determined using Method of Standard Additions (MSA).</p> <p>W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.</p> <p>P Concentration >40% difference between the two GC columns.</p> <p>C Confirmed by GC/MS</p> <p>Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).</p> <p>X See Case Narrative for discussion.</p> <p>MRL Method Reporting Limit. Also known as:</p> <p>LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.</p> <p>MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).</p> <p>LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.</p> <p>ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.</p> |
|---|--|

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory’s NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1

Service Request: R2513162

Sample Name: 216.1-35A
Lab Code: R2513162-001
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-35B
Lab Code: R2513162-002
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-36
Lab Code: R2513162-003
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-37
Lab Code: R2513162-004
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-38
Lab Code: R2513162-005
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1

Service Request: R2513162

Sample Name: 216.1-39
Lab Code: R2513162-006
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-40
Lab Code: R2513162-007
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-41
Lab Code: R2513162-008
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-42A
Lab Code: R2513162-009
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-42B
Lab Code: R2513162-010
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1

Service Request: R2513162

Sample Name: 216.1-43
Lab Code: R2513162-011
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-44
Lab Code: R2513162-012
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-45
Lab Code: R2513162-013
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-46
Lab Code: R2513162-014
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-47
Lab Code: R2513162-015
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1

Service Request: R2513162

Sample Name: 216.1-48
Lab Code: R2513162-016
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-49
Lab Code: R2513162-017
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-50
Lab Code: R2513162-018
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-51
Lab Code: R2513162-019
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-52
Lab Code: R2513162-020
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1

Service Request: R2513162

Sample Name: 216.1-53
Lab Code: R2513162-021
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-54
Lab Code: R2513162-022
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-55
Lab Code: R2513162-023
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-56
Lab Code: R2513162-024
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-57
Lab Code: R2513162-025
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1

Service Request: R2513162

Sample Name: 216.1-58
Lab Code: R2513162-026
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-59
Lab Code: R2513162-027
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-60A
Lab Code: R2513162-028
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-60B
Lab Code: R2513162-029
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-61
Lab Code: R2513162-030
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1

Service Request: R2513162

Sample Name: 216.1-62
Lab Code: R2513162-031
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-63
Lab Code: R2513162-032
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-64
Lab Code: R2513162-033
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-65
Lab Code: R2513162-034
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-66
Lab Code: R2513162-035
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1

Service Request: R2513162

Sample Name: 216.1-67A
Lab Code: R2513162-036
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-35A
Lab Code: R2513162-001

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 22:09	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-35B
Lab Code: R2513162-002

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 22:11	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-36
Lab Code: R2513162-003

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.6	ug/L	1.0	1	10/22/25 22:12	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-37
Lab Code: R2513162-004

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	9.4	ug/L	1.0	1	10/22/25 22:13	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-38
Lab Code: R2513162-005

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.9	ug/L	1.0	1	10/22/25 22:14	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-39
Lab Code: R2513162-006

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.9	ug/L	1.0	1	10/22/25 22:16	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-40
Lab Code: R2513162-007

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.9	ug/L	1.0	1	10/22/25 22:17	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-41
Lab Code: R2513162-008

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.6	ug/L	1.0	1	10/22/25 22:18	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-42A
Lab Code: R2513162-009

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 22:22	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-42B
Lab Code: R2513162-010

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 22:23	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-43
Lab Code: R2513162-011

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	20.5	ug/L	1.0	1	10/22/25 22:25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-44
Lab Code: R2513162-012

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.5	ug/L	1.0	1	10/22/25 22:26	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-45
Lab Code: R2513162-013

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	7.4	ug/L	1.0	1	10/22/25 22:27	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-46
Lab Code: R2513162-014

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	69.7	ug/L	1.0	1	10/22/25 22:29	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-47
Lab Code: R2513162-015

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	9.3	ug/L	1.0	1	10/22/25 22:30	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-48
Lab Code: R2513162-016

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	6.5	ug/L	1.0	1	10/22/25 22:31	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-49
Lab Code: R2513162-017

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.0	ug/L	1.0	1	10/22/25 22:32	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-50
Lab Code: R2513162-018

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.1	ug/L	1.0	1	10/22/25 22:34	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-51
Lab Code: R2513162-019

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	10.1	ug/L	1.0	1	10/22/25 22:45	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-52
Lab Code: R2513162-020

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.2	ug/L	1.0	1	10/22/25 22:49	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-53
Lab Code: R2513162-021

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	7.4	ug/L	1.0	1	10/22/25 22:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-54
Lab Code: R2513162-022

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.5	ug/L	1.0	1	10/22/25 22:52	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-55
Lab Code: R2513162-023

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.7	ug/L	1.0	1	10/22/25 22:53	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-56
Lab Code: R2513162-024

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.0	ug/L	1.0	1	10/22/25 22:54	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-57
Lab Code: R2513162-025

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	16.8	ug/L	1.0	1	10/22/25 22:58	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-58
Lab Code: R2513162-026

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.4	ug/L	1.0	1	10/22/25 22:59	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-59
Lab Code: R2513162-027

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 23:01	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-60A
Lab Code: R2513162-028

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 23:02	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-60B
Lab Code: R2513162-029

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 23:03	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-61
Lab Code: R2513162-030

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 23:05	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-62
Lab Code: R2513162-031

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 23:06	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-63
Lab Code: R2513162-032

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 23:07	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-64
Lab Code: R2513162-033

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.4	ug/L	1.0	1	10/22/25 23:09	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-65
Lab Code: R2513162-034

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	7.2	ug/L	1.0	1	10/22/25 23:10	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-66
Lab Code: R2513162-035

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	8.7	ug/L	1.0	1	10/22/25 23:14	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-67A
Lab Code: R2513162-036

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 23:15	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513162-MB1

Service Request: R2513162
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 21:59	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513162-MB2

Service Request: R2513162
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 22:43	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25
Date Analyzed: 10/22/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 216.1-50
Lab Code: R2513162-018
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2513162-018MS		Duplicate Matrix Spike R2513162-018DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	5.1	25.8	20.0	103	25.1	20.0	100	70-130	3	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water

Service Request: R2513162
Date Collected: 10/02/25
Date Received: 10/09/25
Date Analyzed: 10/22/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 216.1-51
Lab Code: R2513162-019
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2513162-019MS		Result	Duplicate Matrix Spike R2513162-019DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	10.1	31.3	20.0	106	30.5	20.0	102	70-130	3	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water

Service Request: R2513162
Date Analyzed: 10/22/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2513162-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	22.0	20.0	110	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water

Service Request: R2513162
Date Analyzed: 10/22/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2513162-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.2	20.0	101	85-115



October 27, 2025

Service Request No:R2513164

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Franklinville CSD Jr Sr High School

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory October 09, 2025
For your reference, these analyses have been assigned our service request number **R2513164**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7473. You may also contact me via email at Remy.Rubin@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Remy Rubin
Project Manager

CC: Rebecca
Franjoine

ADDRESS

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

PHONE +1 585 288 5380 | **FAX** +1 585 288 8475

ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School
Sample Matrix: Drinking Water

Service Request: R2513164
Date Received: 10/09/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Fourteen drinking water samples were received for analysis at ALS Environmental on 10/09/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads 'R. Rubin'.

Approved by _____

Date 10/27/2025



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1

Service Request:R2513164

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2513164-001	216.1-67B	10/2/2025	
R2513164-002	216.1-68	10/2/2025	
R2513164-003	216.1-69	10/2/2025	
R2513164-004	216.1-70	10/2/2025	
R2513164-005	216.1-71A	10/2/2025	
R2513164-006	216.1-71B	10/2/2025	
R2513164-007	216.1-72	10/2/2025	
R2513164-008	216.1-73	10/2/2025	
R2513164-009	216.1-74	10/2/2025	
R2513164-010	216.1-75A	10/2/2025	
R2513164-011	216.1-75B	10/2/2025	
R2513164-012	216.1-76	10/2/2025	
R2513164-013	216.1-77	10/2/2025	
R2513164-014	216.1-78	10/2/2025	



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-216.1

Client: Franklinville CSD Contact: Mr. Dustin Brisky

Building: Franklinville Jr Sr High School Location: 31 N Main St, Franklinville, NY 14737

LEAD		<u>Tumaround</u>
Water by 200.8	<u>X</u>	<u>10 Days</u>

Sample #	Location	Outlet Type	Time
216.1-67B	206 Bottle Fill	Bottle Fill	6:35
216.1-68	206 Staff Restroom	Sink	6:36
216.1-69	206 Boys Restroom Right	Sink	6:37
216.1-70	206 Boys Restroom Left	Sink	6:38
216.1-71A	319 Fountain	Drinking Fountain	6:40
216.1-71B	319 Bottle Fill	Bottle Fill	6:41
216.1-72	Across From 319 Faculty Restroom	Sink	6:42
216.1-73	Across From 319 Girl's Restroom Sink Left	Sink	6:43
216.1-74	Across From 319 Girl's Restroom Sink Right	Sink	6:45
216.1-75A	Fountain Across From 301	Drinking Fountain	6:46
216.1-75B	Bottle Fill Across From 301	Bottle Fill	6:47
216.1-76	Faculty Bathroom Sink Across From 301	Sink	6:48
216.1-77	Bathroom Left Sink Across From 301	Sink	6:50
216.1-78	Bathroom Right Sink Across From 301	Sink	6:51

Notes: Please e-mail lab results to labs@stohlenv.com mscinta@stohlenvironmental.com

Sampled By: Matthew McCourt Print Name Matthew McCourt Stohl Env: Matthew McCourt Date: 10/2/2025

Relinquished By: _____ Print Name Connor Crilly Stohl Env: Connor Crilly Date: 10/9/2025

Received (Name / Lab): *Andy K* Date: *10/1/25* Time: *1:20*

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



R2513164

5

Stohl Environmental
Franklinville CSD Jr Sr High School



Cooler Receipt and Preservation Ch

Project/Client STOHL Folder Number _____

Cooler received on 10/9/25 by: And

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <input checked="" type="checkbox"/>
2	Custody papers properly completed (ink, signed)?	N <input checked="" type="checkbox"/>
3	Did all bottles arrive in good condition (unbroken)?	N <input checked="" type="checkbox"/>
4	Circle: Wet Ice Dry Ice Gel packs present?	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/>

5a	Did VOA vials have sig* bubbles?	Y N <input checked="" type="checkbox"/>
5b	Sig* bubbles: Alk?	Y N <input checked="" type="checkbox"/>
	Sulfide?	Y N <input checked="" type="checkbox"/>
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as:	Bulk Encore 5035set <input checked="" type="checkbox"/>

8. Temperature Readings Date: 10/9 Time: 1700 ID: IR#12 (R#1) From: Temp Blank Sample Bottle

Temp (°C)	<u>21.1</u>						
Within 0-6°C?	Y <input checked="" type="checkbox"/>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: _____ Ice melted Poorly Packed (described below) Same Day Rule
& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off. Client notified by: _____

All samples held in storage location: SW by And on 10/9 at 1755
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 10/14 Time: 1714 by: AG

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO
- 13. Were dissolved metals filtered in the field? YES NO
- 14. Air Samples: Cassettes / Tubes Intact Y/N with MS Y/N Canisters Pressurized Tedlar® Bags Inflated

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2	<u>20225</u>	HNO ₃		<input checked="" type="checkbox"/>	<u>No Lot in CP</u>		<u>All</u>	<u>4ml</u>		<u>6.2</u>
≤2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: _____
Explain all Discrepancies/ Other Comments: _____

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: AG *significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1

Service Request: R2513164

Sample Name: 216.1-67B
Lab Code: R2513164-001
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-68
Lab Code: R2513164-002
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-69
Lab Code: R2513164-003
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-70
Lab Code: R2513164-004
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-71A
Lab Code: R2513164-005
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1

Service Request: R2513164

Sample Name: 216.1-71B
Lab Code: R2513164-006
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-72
Lab Code: R2513164-007
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-73
Lab Code: R2513164-008
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-74
Lab Code: R2513164-009
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-75A
Lab Code: R2513164-010
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1

Service Request: R2513164

Sample Name: 216.1-75B
Lab Code: R2513164-011
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-76
Lab Code: R2513164-012
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-77
Lab Code: R2513164-013
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.1-78
Lab Code: R2513164-014
Sample Matrix: Drinking Water

Date Collected: 10/2/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-67B
Lab Code: R2513164-001

Service Request: R2513164
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 23:16	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-68
Lab Code: R2513164-002

Service Request: R2513164
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 23:18	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-69
Lab Code: R2513164-003

Service Request: R2513164
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 16:54	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-70
Lab Code: R2513164-004

Service Request: R2513164
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 17:01	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-71A
Lab Code: R2513164-005

Service Request: R2513164
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 17:03	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-71B
Lab Code: R2513164-006

Service Request: R2513164
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 17:05	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-72
Lab Code: R2513164-007

Service Request: R2513164
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 17:07	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-73
Lab Code: R2513164-008

Service Request: R2513164
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 17:09	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-74
Lab Code: R2513164-009

Service Request: R2513164
Date Collected: 10/02/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 17:15	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-75A
Lab Code: R2513164-010

Service Request: R2513164
Date Collected: 10/02/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 17:17	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-75B
Lab Code: R2513164-011

Service Request: R2513164
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 17:19	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-76
Lab Code: R2513164-012

Service Request: R2513164
Date Collected: 10/02/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 17:21	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-77
Lab Code: R2513164-013

Service Request: R2513164
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 17:23	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: 216.1-78
Lab Code: R2513164-014

Service Request: R2513164
Date Collected: 10/02/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 17:25	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513164-MB1

Service Request: R2513164
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 16:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513164-MB2

Service Request: R2513164
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 22:43	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water

Service Request: R2513164
Date Collected: 10/02/25
Date Received: 10/09/25
Date Analyzed: 10/22/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 216.1-68
Lab Code: R2513164-002
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2513164-002MS		Duplicate Matrix Spike R2513164-002DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	20.6	20.0	103	21.2	20.0	106	70-130	3	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water

Service Request: R2513164
Date Collected: 10/02/25
Date Received: 10/09/25
Date Analyzed: 10/22/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 216.1-69
Lab Code: R2513164-003
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2513164-003MS		Duplicate Matrix Spike R2513164-003DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	21.5	20.0	108	21.5	20.0	107	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water

Service Request: R2513164
Date Analyzed: 10/22/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2513164-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.3	20.0	107	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Jr Sr High School/2023L-216.1
Sample Matrix: Drinking Water

Service Request: R2513164
Date Analyzed: 10/22/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2513164-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.2	20.0	101	85-115

1.5 Laboratory Certifications

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2026
Issued April 01, 2025

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE
Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. CHRISTINE KUTZER NY Lab Id No: 10145
ALS ENVIRONMENTAL - ROCHESTER
1565 JEFFERSON ROAD BUILDING 300, SUITE 360
ROCHESTER, NY 14623

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2016) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Bacteriology	
Coliform, Total / E. coli (Qualitative)	SM 20, 21-23 9223B (-04) (Collert)
Dissolved Gases	
Acetylene	RSK-175
Ethane	RSK-175
Ethene (Ethylene)	RSK-175
Methane	RSK-175
Propane	RSK-175
Fuel Additives	
Methyl tert-butyl ether	EPA 524.2
Naphthalene	EPA 524.2
Metals I	
Arsenic, Total	EPA 200.8 Rev. 5.4
Barium, Total	EPA 200.8 Rev. 5.4
Cadmium, Total	EPA 200.8 Rev. 5.4
Chromium, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Copper, Total	EPA 200.8 Rev. 5.4
Iron, Total	EPA 200.7 Rev. 4.4
Lead, Total	EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Mercury, Total	EPA 245.1 Rev. 3.0
Selenium, Total	EPA 200.8 Rev. 5.4
Silver, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Zinc, Total	EPA 200.7 Rev. 4.4

Serial No.: 70111

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elappublicweb/>, by phone (518) 485-6570 or by email to elap@health.ny.gov.



Page 1 of 5