

November 6, 2025

Mr. Dustin Brisky
Franklinville CSD
32 N Main St,
Franklinville, NY 14737

Re: Lead Testing in School Drinking Water

Dear Mr. Brisky:

Included with this letter is Stohl Environmental LLC's report for the Lead in Drinking Water Sampling performed for Franklinville Central School District, including:

- Franklinville Elementary School – 32 N Main St, Franklinville, New York

This report is prepared to assist school districts in complying with the requirements of 10 NYCRR Subpart 67-4: *Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 5 parts per billion (ppb)".

Sampling was performed on October 3, 2025. As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 14 sources of potable water in Franklinville Elementary School have been identified as having lead concentrations in water above the NYS Action Level of 5 parts per billion. To comply with NYS regulations, response actions by the district are required. Response actions are outlined in Section 1.3 (*Response Actions Required Under NYS Regulations*).

Thank you for the opportunity to be of service to Franklinville Central School District.

Sincerely,
Stohl Environmental, LLC.



Michael Scinta
EPA Lead Risk Assessor

Lead Testing in School Drinking Water

Prepared for:

Franklinville Central School District

Prepared by:



**3860 California Road
Orchard Park, New York 14127**

Conditions as of October 3, 2025

Summary Tabulation

Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports and Chain of Custody Documents
- 1.5. Laboratory Certifications

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Franklinville Central School District to perform sampling and analysis of potable water for lead concentrations. Sampling was performed in the following building:

- Franklinville Elementary School – 32 N Main St, Franklinville, New York

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within Franklinville Elementary School. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

Sampling Protocol:

In accordance with NYS regulations, **Subpart 67-4: Lead Testing in School Drinking Water**, and the EPA guidance document, **3Ts for Reducing Lead in Drinking Water in Schools**, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

1.2 Executive Summary of Sampling and Analysis:

Summary of Samples Collected at Franklinville Elementary School

Building Name	Date of Sampling	Total Samples	At or Below Action Level*	Above Action Level*
Franklinville Elementary School	10/2/2025	124	110	14

*NYS Action Level is 5 parts per billion

Listing of Outlets Requiring Remediation

The following outlets were analyzed above the NYS Action Level:

Sample #	Location	Fixture/Outlet type	Laboratory Analysis (in ppb)
216.2-9	Back Kitchen Hand Wash	Sink	6.1
216.2-18	Principals Office Restroom	Sink	8.1
216.2-19	Nurse Main	Sink	5.5
216.2-26	Room 111 Restroom	Sink	6.9
216.2-29	Room 114 Main	Sink	8.0
216.2-33	Room 118 Main	Sink	8.0
216.2-59	Women's Room Across 206 Left	Sink	23.5
216.2-60	Women's Room Across 206 Middle	Sink	1,150
216.2-65	Room 210	Sink	10.1
216.2-86	Room 320	Sink	8.7
216.2-95	Room 312	Sink	14.8
216.2-96	Room 309	Sink	5.4
216.2-98	Room 307	Sink	5.1
216.2-109	Boys Gym Locker	Sink	21.0

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration more than the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

1.4 Laboratory Analytical Reports and Chain of Custody Documents



October 30, 2025

Service Request No:R2513166

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Franklinville CSD Elementary

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory October 09, 2025
For your reference, these analyses have been assigned our service request number **R2513166**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7473. You may also contact me via email at Remy.Rubin@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Remy Rubin
Project Manager

CC: Rebecca
Franjoine

ADDRESS

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

PHONE +1 585 288 5380 | FAX +1 585 288 8475

ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Stohl Environmental
Project: Franklinville CSD Elementary
Sample Matrix: Drinking Water

Service Request: R2513166
Date Received: 10/09/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty six drinking water samples were received for analysis at ALS Environmental on 10/09/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

Approved by 

Date 10/29/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 216.2-2		Lab ID: R2513166-002					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.9			1.0	ug/L	200.8	
CLIENT ID: 216.2-4		Lab ID: R2513166-004					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.9			1.0	ug/L	200.8	
CLIENT ID: 216.2-8		Lab ID: R2513166-008					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.7			1.0	ug/L	200.8	
CLIENT ID: 216.2-9		Lab ID: R2513166-009					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	6.1			1.0	ug/L	200.8	
CLIENT ID: 216.2-10		Lab ID: R2513166-010					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	4.8			1.0	ug/L	200.8	
CLIENT ID: 216.2-11		Lab ID: R2513166-011					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.2			1.0	ug/L	200.8	
CLIENT ID: 216.2-12		Lab ID: R2513166-012					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.4			1.0	ug/L	200.8	
CLIENT ID: 216.2-17		Lab ID: R2513166-018					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.9			1.0	ug/L	200.8	
CLIENT ID: 216.2-18		Lab ID: R2513166-019					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	8.1			1.0	ug/L	200.8	
CLIENT ID: 216.2-19		Lab ID: R2513166-020					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	5.5			1.0	ug/L	200.8	
CLIENT ID: 216.2-20		Lab ID: R2513166-021					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	4.3			1.0	ug/L	200.8	
CLIENT ID: 216.2-21		Lab ID: R2513166-022					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.3			1.0	ug/L	200.8	



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 216.2-23		Lab ID: R2513166-024				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.2			1.0	ug/L	200.8

CLIENT ID: 216.2-24		Lab ID: R2513166-025				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.8			1.0	ug/L	200.8

CLIENT ID: 216.2-25		Lab ID: R2513166-026				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.0			1.0	ug/L	200.8

CLIENT ID: 216.2-26		Lab ID: R2513166-027				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	6.9			1.0	ug/L	200.8

CLIENT ID: 216.2-28		Lab ID: R2513166-029				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.7			1.0	ug/L	200.8

CLIENT ID: 216.2-29		Lab ID: R2513166-030				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	8.0			1.0	ug/L	200.8

CLIENT ID: 216.2-32		Lab ID: R2513166-033				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.1			1.0	ug/L	200.8

CLIENT ID: 216.2-33		Lab ID: R2513166-034				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	8.0			1.0	ug/L	200.8

CLIENT ID: 216.2-34		Lab ID: R2513166-035				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.1			1.0	ug/L	200.8

CLIENT ID: 216.2-35		Lab ID: R2513166-036				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.1			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2

Service Request:R2513166

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2513166-001	216.2-1	10/3/2025	
R2513166-002	216.2-2	10/3/2025	
R2513166-003	216.2-3	10/3/2025	
R2513166-004	216.2-4	10/3/2025	
R2513166-005	216.2-5	10/3/2025	
R2513166-006	216.2-6	10/3/2025	
R2513166-007	216.2-7	10/3/2025	
R2513166-008	216.2-8	10/3/2025	
R2513166-009	216.2-9	10/3/2025	
R2513166-010	216.2-10	10/3/2025	
R2513166-011	216.2-11	10/3/2025	
R2513166-012	216.2-12	10/3/2025	
R2513166-013	216.2-13	10/3/2025	
R2513166-014	216.2-14	10/3/2025	
R2513166-015	216.2-15	10/3/2025	
R2513166-016	216.2-16A	10/3/2025	
R2513166-017	216.2-16B	10/3/2025	
R2513166-018	216.2-17	10/3/2025	
R2513166-019	216.2-18	10/3/2025	
R2513166-020	216.2-19	10/3/2025	
R2513166-021	216.2-20	10/3/2025	
R2513166-022	216.2-21	10/3/2025	
R2513166-023	216.2-22	10/3/2025	
R2513166-024	216.2-23	10/3/2025	
R2513166-025	216.2-24	10/3/2025	
R2513166-026	216.2-25	10/3/2025	
R2513166-027	216.2-26	10/3/2025	
R2513166-028	216.2-27	10/3/2025	
R2513166-029	216.2-28	10/3/2025	
R2513166-030	216.2-29	10/3/2025	
R2513166-031	216.2-30	10/3/2025	
R2513166-032	216.2-31	10/3/2025	
R2513166-033	216.2-32	10/3/2025	
R2513166-034	216.2-33	10/3/2025	
R2513166-035	216.2-34	10/3/2025	
R2513166-036	216.2-35	10/3/2025	



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-216.2

Client: Franklinville CSD

Contact: Mr. Dustin Brisky

Building: Franklinville Elementary

Location: 32 N Main St, Franklinville, NY 14737

LEAD

Water by 200.8 X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
216.2-1	Dish Sink Left	Sink	5:10
216.2-2	Dish Sink Right	Sink	5:10
216.2-3	Kitchen Ice Machine	Ice Machine	5:11
216.2-4	Prep Sink	Sink	5:12
216.2-5	Prep Sprayer	Sink	5:13
216.2-6	Prep Island Hand Wash	Sink	5:14
216.2-7	Steam Kettle	Steam Pot	5:15
216.2-8	Pot Filler	Pot Filler	5:16
216.2-9	Back Kitchen Hand Wash	Sink	5:17
216.2-10	Dish Area Hand Wash	Sink	5:18
216.2-11	E109B Restroom Sink	Sink	5:19
216.2-12	Kitchen Faculty Toilet	Sink	5:20
216.2-13	Cafe Restroom Right	Sink	5:21
216.2-14	Cafe Restroom Left	Sink	5:22
216.2-15	Cafe Drinking Fountain Left	Drinking Fountain	5:23
216.2-16A	Cafe Drinking Fountain Right	Drinking Fountain	5:24
216.2-16B	Cafe Bottle Fill Right	Bottle Fill	5:25
216.2-17	Main Office Kitchenette	Sink	5:26

Notes:

Please e-mail lab results to labs@stohlenv.com If checked, also e-mail results to: mscinta@stohlenvironmental.com

Sampled By: Matthew McCourt Print Name Matthew McCourt Stohl Env: Matthew McCourt Date: 10/3/2025

Relinquished By: _____ Print Name Connor Crilly Stohl Env: Connor Crilly Date: 10/9/2025


Received (Name / Lab): [Signature] Date: 10/9/25 Time: 1722

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____





Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS
 STOHL Job # 2023L-216.2

Client: Franklinville CSD Contact: Mr. Dustin Brisky
 Building: Franklinville Elementary Location: 32 N Main St, Franklinville, NY 14737

LEAD
 Water by 200.8 X Turnaround
10 Days

Sample #	Location	Outlet Type	Time
216.2-18	Principals Office Restroom	Sink	5:27
216.2-19	Nurse Main	Sink	5:28
216.2-20	Nurse Exam/Office	Sink	5:29
216.2-21	Nurse Restroom	Sink	5:29
216.2-22	Staff Restroom Next To 108	Sink	5:30
216.2-23	Room 108	Sink	5:31
216.2-24	Room 109	Sink	5:32
216.2-25	Room 111 Main	Sink	5:33
216.2-26	Room 111 Restroom	Sink	5:34
216.2-27	Room 112	Sink	5:35
216.2-28	Room 113	Sink	5:36
216.2-29	Room 114 Main	Sink	5:37
216.2-30	Room 114 Restroom	Sink	5:38
216.2-31	Room 116 Fountain	Drinking Fountain	5:39
216.2-32	Room 116 Restroom	Sink	5:40
216.2-33	Room 118 Main	Sink	5:41
216.2-34	Room 118 Restroom	Sink	5:42
216.2-35	Room 120 Main	Sink	5:43

Notes:
 Please e-mail lab results to labs@stohlenvironmental.com mscinta@stohlenvironmental.com

Sampled By: Matthew McCourt Print Name Matthew McCourt Stohl Env: Matthew McCourt Date: 10/3/2025
 Relinquished By: _____ Print Name Connor Crilly Stohl Env: Connor Crilly Date: 10/9/2025
 Received (Name / Lab): [Signature] Date: [Signature] Time: 1700
 Sample Login (Name / Lab): _____ Date: _____ Time: _____
 Analysis (Name / Lab): _____ Date: _____ Time: _____
 QA/QC Review (Name / Lab): _____ Date: _____ Time: _____
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



R2513166

5

Stohl Environmental
Franklinville CSD Elementary



Cooler Receipt and Preservation

Project/Client STOHL Folder Number _____

Cooler received on 10/9/25 by: Paul COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <input checked="" type="checkbox"/>
2	Custody papers properly completed (ink, signed)?	N <input checked="" type="checkbox"/>
3	Did all bottles arrive in good condition (unbroken)?	N <input checked="" type="checkbox"/>
4	Circle: Wet Ice Dry Ice Gel packs present?	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/>

5a	Did VOA vials have sig* bubbles?	Y	N	<input checked="" type="checkbox"/> NA
5b	Sig* bubbles: Alk?	Y	N	<input checked="" type="checkbox"/> NA
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT		
7	Soil VOA received as:	Bulk	Encore	5035set <input checked="" type="checkbox"/> NA

8. Temperature Readings Date: 10/9 Time: 1700 ID: IR#12 IR#1 From: Temp Blank Sample Bottle

Temp (°C)	<u>21.1</u>							
Within 0-6°C?	Y <input checked="" type="checkbox"/>	Y	N	Y	N	Y	N	
If <0°C, were samples frozen?	Y	N	Y	N	Y	N	Y	N

If out of Temperature, note packing/ice condition: _____ Ice melted Poorly Packed (described below) Same Day Rule
& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SW by Paul on 10/9 at 1755
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 10/14 Time: 1719 by: AG

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO N/A
- 13. Were dissolved metals filtered in the field? YES NO N/A
- 14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2	<u>20335</u>	HNO ₃		<input checked="" type="checkbox"/>	<u>NO Lot Info</u>		<u>All</u>	<u>4ml</u>		<u>5.2</u>
≤2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: _____
Explain all Discrepancies/ Other Comments: _____

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: AG *significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2

Service Request: R2513166

Sample Name: 216.2-1
Lab Code: R2513166-001
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-2
Lab Code: R2513166-002
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-3
Lab Code: R2513166-003
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-4
Lab Code: R2513166-004
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-5
Lab Code: R2513166-005
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2

Service Request: R2513166

Sample Name: 216.2-6
Lab Code: R2513166-006
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-7
Lab Code: R2513166-007
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-8
Lab Code: R2513166-008
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-9
Lab Code: R2513166-009
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-10
Lab Code: R2513166-010
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2

Service Request: R2513166

Sample Name: 216.2-11
Lab Code: R2513166-011
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-12
Lab Code: R2513166-012
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-13
Lab Code: R2513166-013
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-14
Lab Code: R2513166-014
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-15
Lab Code: R2513166-015
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2

Service Request: R2513166

Sample Name: 216.2-16A
Lab Code: R2513166-016
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-16B
Lab Code: R2513166-017
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-17
Lab Code: R2513166-018
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-18
Lab Code: R2513166-019
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-19
Lab Code: R2513166-020
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2

Service Request: R2513166

Sample Name: 216.2-20
Lab Code: R2513166-021
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-21
Lab Code: R2513166-022
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-22
Lab Code: R2513166-023
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-23
Lab Code: R2513166-024
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-24
Lab Code: R2513166-025
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2

Service Request: R2513166

Sample Name: 216.2-25
Lab Code: R2513166-026
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-26
Lab Code: R2513166-027
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-27
Lab Code: R2513166-028
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-28
Lab Code: R2513166-029
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-29
Lab Code: R2513166-030
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2

Service Request: R2513166

Sample Name: 216.2-30
Lab Code: R2513166-031
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-31
Lab Code: R2513166-032
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-32
Lab Code: R2513166-033
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-33
Lab Code: R2513166-034
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-34
Lab Code: R2513166-035
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2

Service Request: R2513166

Sample Name: 216.2-35
Lab Code: R2513166-036
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-1
Lab Code: R2513166-001

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 17:27	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-2
Lab Code: R2513166-002

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.9	ug/L	1.0	1	10/22/25 17:29	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-3
Lab Code: R2513166-003

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 17:31	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-4
Lab Code: R2513166-004

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.9	ug/L	1.0	1	10/22/25 17:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-5
Lab Code: R2513166-005

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 17:39	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-6
Lab Code: R2513166-006

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 17:41	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-7
Lab Code: R2513166-007

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 17:43	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-8
Lab Code: R2513166-008

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.7	ug/L	1.0	1	10/22/25 17:45	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-9
Lab Code: R2513166-009

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	6.1	ug/L	1.0	1	10/22/25 17:59	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-10
Lab Code: R2513166-010

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.8	ug/L	1.0	1	10/22/25 18:05	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-11
Lab Code: R2513166-011

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.2	ug/L	1.0	1	10/22/25 18:08	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-12
Lab Code: R2513166-012

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.4	ug/L	1.0	1	10/22/25 18:10	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-13
Lab Code: R2513166-013

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 18:12	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-14
Lab Code: R2513166-014

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 18:14	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-15
Lab Code: R2513166-015

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 18:20	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-16A
Lab Code: R2513166-016

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 18:22	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-16B
Lab Code: R2513166-017

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 18:24	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-17
Lab Code: R2513166-018

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.9	ug/L	1.0	1	10/22/25 18:26	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-18
Lab Code: R2513166-019

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	8.1	ug/L	1.0	1	10/22/25 18:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-19
Lab Code: R2513166-020

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.5	ug/L	1.0	1	10/22/25 18:30	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-20
Lab Code: R2513166-021

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.3	ug/L	1.0	1	10/22/25 18:32	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-21
Lab Code: R2513166-022

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.3	ug/L	1.0	1	10/22/25 18:34	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-22
Lab Code: R2513166-023

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 18:36	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-23
Lab Code: R2513166-024

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.2	ug/L	1.0	1	10/22/25 18:38	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-24
Lab Code: R2513166-025

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.8	ug/L	1.0	1	10/22/25 18:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-25
Lab Code: R2513166-026

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.0	ug/L	1.0	1	10/22/25 18:46	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-26
Lab Code: R2513166-027

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	6.9	ug/L	1.0	1	10/22/25 18:48	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-27
Lab Code: R2513166-028

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 18:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-28
Lab Code: R2513166-029

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.7	ug/L	1.0	1	10/27/25 13:05	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-29
Lab Code: R2513166-030

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	8.0	ug/L	1.0	1	10/27/25 13:07	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-30
Lab Code: R2513166-031

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 13:11	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-31
Lab Code: R2513166-032

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 13:13	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-32
Lab Code: R2513166-033

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	10/27/25 13:15	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-33
Lab Code: R2513166-034

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	8.0	ug/L	1.0	1	10/27/25 13:16	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-34
Lab Code: R2513166-035

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	10/27/25 13:27	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-35
Lab Code: R2513166-036

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.1	ug/L	1.0	1	10/27/25 13:32	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513166-MB1

Service Request: R2513166
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 16:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513166-MB2

Service Request: R2513166
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/22/25 17:55	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513166-MB3

Service Request: R2513166
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 12:34	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513166-MB4

Service Request: R2513166
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 13:24	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25
Date Analyzed: 10/22/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 216.2-8
Lab Code: R2513166-008
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2513166-008MS		Duplicate Matrix Spike R2513166-008DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	1.7	21.1	20.0	97	21.2	20.0	98	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25
Date Analyzed: 10/22/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 216.2-9
Lab Code: R2513166-009
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2513166-009MS		Duplicate Matrix Spike R2513166-009DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	6.1	26.8	20.0	103	26.6	20.0	103	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25
Date Analyzed: 10/22/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 216.2-27
Lab Code: R2513166-028
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2513166-028MS		Duplicate Matrix Spike R2513166-028DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	22.4	20.0	112	22.8	20.0	114	70-130	2	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25
Date Analyzed: 10/27/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 216.2-33
Lab Code: R2513166-034
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2513166-034MS		Duplicate Matrix Spike R2513166-034DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	8.0	27.8	20.0	99	28.0	20.0	100	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water

Service Request: R2513166
Date Collected: 10/03/25
Date Received: 10/09/25
Date Analyzed: 10/27/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 216.2-34
Lab Code: R2513166-035
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2513166-035MS		Duplicate Matrix Spike R2513166-035DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	1.1	20.5	20.0	97	20.5	20.0	97	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water

Service Request: R2513166
Date Analyzed: 10/22/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2513166-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.3	20.0	107	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water

Service Request: R2513166
Date Analyzed: 10/22/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2513166-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.2	20.0	106	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water

Service Request: R2513166
Date Analyzed: 10/27/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2513166-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.3	20.0	102	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water

Service Request: R2513166
Date Analyzed: 10/27/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2513166-LCS4

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.5	20.0	103	85-115



November 03, 2025

Service Request No:R2513167

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Franklinville CSD Elementary

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory October 09, 2025
For your reference, these analyses have been assigned our service request number **R2513167**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7473. You may also contact me via email at Remy.Rubin@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Remy Rubin
Project Manager

CC: Rebecca
Franjoine

ADDRESS

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

PHONE +1 585 288 5380 | **FAX** +1 585 288 8475

ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Stohl Environmental
Project: Franklinville CSD Elementary
Sample Matrix: Drinking Water

Service Request: R2513167
Date Received: 10/09/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty six drinking water samples were received for analysis at ALS Environmental on 10/09/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

Approved by 

Date 11/03/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 216.2-38		Lab ID: R2513167-003					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.6			1.0	ug/L	200.8	
CLIENT ID: 216.2-40		Lab ID: R2513167-005					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.9			1.0	ug/L	200.8	
CLIENT ID: 216.2-41		Lab ID: R2513167-006					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.5			1.0	ug/L	200.8	
CLIENT ID: 216.2-42		Lab ID: R2513167-007					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.1			1.0	ug/L	200.8	
CLIENT ID: 216.2-44		Lab ID: R2513167-009					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.6			1.0	ug/L	200.8	
CLIENT ID: 216.2-47		Lab ID: R2513167-012					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.3			1.0	ug/L	200.8	
CLIENT ID: 216.2-48		Lab ID: R2513167-013					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.1			1.0	ug/L	200.8	
CLIENT ID: 216.2-49		Lab ID: R2513167-014					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.2			1.0	ug/L	200.8	
CLIENT ID: 216.2-51		Lab ID: R2513167-016					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.2			1.0	ug/L	200.8	
CLIENT ID: 216.2-53		Lab ID: R2513167-018					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.3			1.0	ug/L	200.8	
CLIENT ID: 216.2-54		Lab ID: R2513167-019					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.3			1.0	ug/L	200.8	
CLIENT ID: 216.2-55		Lab ID: R2513167-020					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.4			1.0	ug/L	200.8	



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 216.2-56		Lab ID: R2513167-021					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	4.7			1.0	ug/L	200.8	
CLIENT ID: 216.2-57		Lab ID: R2513167-022					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.5			1.0	ug/L	200.8	
CLIENT ID: 216.2-58		Lab ID: R2513167-023					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	4.2			1.0	ug/L	200.8	
CLIENT ID: 216.2-59		Lab ID: R2513167-024					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	23.5			1.0	ug/L	200.8	
CLIENT ID: 216.2-60		Lab ID: R2513167-025					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1150			50	ug/L	200.8	
CLIENT ID: 216.2-61		Lab ID: R2513167-026					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.7			1.0	ug/L	200.8	
CLIENT ID: 216.2-63		Lab ID: R2513167-028					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.3			1.0	ug/L	200.8	
CLIENT ID: 216.2-64		Lab ID: R2513167-029					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.1			1.0	ug/L	200.8	
CLIENT ID: 216.2-65		Lab ID: R2513167-030					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	10.1			1.0	ug/L	200.8	
CLIENT ID: 216.2-66		Lab ID: R2513167-031					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.3			1.0	ug/L	200.8	
CLIENT ID: 216.2-68		Lab ID: R2513167-033					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.6			1.0	ug/L	200.8	
CLIENT ID: 216.2-70		Lab ID: R2513167-035					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	4.6			1.0	ug/L	200.8	



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 216.2-71		Lab ID: R2513167-036				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.3			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2

Service Request:R2513167

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2513167-001	216.2-36	10/3/2025	
R2513167-002	216.2-37	10/3/2025	
R2513167-003	216.2-38	10/3/2025	
R2513167-004	216.2-39	10/3/2025	
R2513167-005	216.2-40	10/3/2025	
R2513167-006	216.2-41	10/3/2025	
R2513167-007	216.2-42	10/3/2025	
R2513167-008	216.2-43	10/3/2025	
R2513167-009	216.2-44	10/3/2025	
R2513167-010	216.2-45	10/3/2025	
R2513167-011	216.2-46	10/3/2025	
R2513167-012	216.2-47	10/3/2025	
R2513167-013	216.2-48	10/3/2025	
R2513167-014	216.2-49	10/3/2025	
R2513167-015	216.2-50	10/3/2025	
R2513167-016	216.2-51	10/3/2025	
R2513167-017	216.2-52	10/3/2025	
R2513167-018	216.2-53	10/3/2025	
R2513167-019	216.2-54	10/3/2025	
R2513167-020	216.2-55	10/3/2025	
R2513167-021	216.2-56	10/3/2025	
R2513167-022	216.2-57	10/3/2025	
R2513167-023	216.2-58	10/3/2025	
R2513167-024	216.2-59	10/3/2025	
R2513167-025	216.2-60	10/3/2025	
R2513167-026	216.2-61	10/3/2025	
R2513167-027	216.2-62	10/3/2025	
R2513167-028	216.2-63	10/3/2025	
R2513167-029	216.2-64	10/3/2025	
R2513167-030	216.2-65	10/3/2025	
R2513167-031	216.2-66	10/3/2025	
R2513167-032	216.2-67	10/3/2025	
R2513167-033	216.2-68	10/3/2025	
R2513167-034	216.2-69	10/3/2025	
R2513167-035	216.2-70	10/3/2025	
R2513167-036	216.2-71	10/3/2025	



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS
 STOHL Job # 2023L-216.2


Client: Franklinville CSD Contact: Mr. Dustin Brisky
 Building: Franklinville Elementary Location: 32 N Main St, Franklinville, NY 14737

LEAD
 Water by 200.8 X Turnaround 10 Days

Sample #	Location	Outlet Type	Time
216.2-36	Room 120 Fountain	Drinking Fountain	5:44
216.2-37	Room 120 Restroom	Sink	5:45
216.2-38	Room 121 Main	Sink	5:46
216.2-39	Room 121 Fountain	Drinking Fountain	5:47
216.2-40	Room 121 Sink	Sink	5:48
216.2-41	Room 122 Main	Sink	5:48
216.2-42	Room 122 Fountain	Drinking Fountain	5:49
216.2-43	Room 122 Restroom	Sink	5:50
216.2-44	Room 123 Main	Sink	5:51
216.2-45	Room 123 Fountain	Drinking Fountain	5:52
216.2-46	Room 123 Restroom	Sink	5:53
216.2-47	124 Main	Sink	5:54
216.2-48	124 Restroom	Sink	5:55
216.2-49	125 Main	Sink	5:56
216.2-50	125 Restroom	Sink	5:57
216.2-51	Library	Sink	5:58
216.2-52	Room 206 Left	Sink	5:59
216.2-53	Room 206 Right	Sink	6:00

Notes:
 Please e-mail lab results to labs@stohlenv.com mscinta@stohlenvironmental.com

Sampled By: Matthew McCourt Print Name Matthew McCourt Stohl Env: Matthew McCourt Date: 10/3/2025
 Relinquished By: _____ Print Name _____ Stohl Env: Connor Crilly Date: 10/9/2025
 Received (Name / Lab): *body* Date: *10/1/25* Time: *no*
 Sample Login (Name / Lab): _____ Date: _____ Time: _____
 Analysis (Name / Lab): _____ Date: _____ Time: _____
 QA/QC Review (Name / Lab): _____ Date: _____ Time: _____
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____





Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS
 STOHL Job # 2023L-216.2

Client: Franklinville CSD Contact: Mr. Dustin Brisky
 Building: Franklinville Elementary Location: 32 N Main St, Franklinville, NY 14737

LEAD
 Water by 200.8 X Turnaround 10 Days

Sample #	Location	Outlet Type	Time
216.2-54	Men's Room Across 206 Left	Sink	6:01
216.2-55	Men's Room Across 206 Middle	Sink	6:02
216.2-56	Men's Room Across 206 Right	Sink	6:03
216.2-57	Left Fountain Across 206	Drinking Fountain	6:04
216.2-58	Right Fountain Across 206	Drinking Fountain	6:05
216.2-59	Women's Room Across 206 Left	Sink	6:06
216.2-60	Women's Room Across 206 Middle	Sink	6:07
216.2-61	Women's Room Across 206 Right	Sink	6:07
216.2-62	Staff Restroom Left Across 208	Sink	6:08
216.2-63	Staff Restroom Right Across 208	Sink	6:09
216.2-64	Room 208	Sink	6:10
216.2-65	Room 210	Sink	6:11
216.2-66	Room 213 Right	Sink	6:12
216.2-67	Maple Way Girls Restroom	Sink	6:13
216.2-68	Maple Way Boys Restroom	Sink	6:14
216.2-69	Maple Way Fountain	Drinking Fountain	6:15
216.2-70	Room 219 Main	Sink	6:16
216.2-71	Room 220	Sink	6:17

Notes:
 Please e-mail lab results to labs@stohlenv.com mscinta@stohlenvironmental.com

Sampled By: Matthew McCourt Print Name Matthew McCourt Stohl Env: Matthew McCourt Date: 10/3/2025
 Relinquished By: _____ Print Name Connor Crilly Stohl Env: Connor Crilly Date: 10/9/2025
 Received (Name / Lab): [Signature] Date: 10/9/25 Time: 1700
 Sample Login (Name / Lab): _____ Date: _____ Time: _____
 Analysis (Name / Lab): _____ Date: _____ Time: _____
 QA/QC Review (Name / Lab): _____ Date: _____ Time: _____
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



R2513167

5

Stohl Environmental
Franklinville CSD Elementary



Cooler Receipt and Preservation Ch

Project/Client STOHL Folder Number _____

Cooler received on 10/9/25 by: Paul COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <input checked="" type="checkbox"/>
2	Custody papers properly completed (ink, signed)?	N <input checked="" type="checkbox"/>
3	Did all bottles arrive in good condition (unbroken)?	N <input checked="" type="checkbox"/>
4	Circle: Wet Ice Dry Ice Gel packs present?	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/>

5a	Did VOA vials have sig* bubbles?	Y	N	<input checked="" type="checkbox"/> NA
5b	Sig* bubbles: Alk?	Y	N	<input checked="" type="checkbox"/> NA
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT		
7	Soil VOA received as:	Bulk	Encore	5035set <input checked="" type="checkbox"/> NA

8. Temperature Readings Date: 10/9 Time: 1700 ID: IR#12 IR#11 From: Temp Blank Sample Bottle

Temp (°C)	<u>21.1</u>							
Within 0-6°C?	Y <input checked="" type="checkbox"/>	Y	N	Y	N	Y	N	
If <0°C, were samples frozen?	Y	N	Y	N	Y	N	Y	N

If out of Temperature, note packing/ice condition: _____ Ice melted Poorly Packed (described below) Same Day Rule
& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: PMO by Paul on 10/9 at 1755
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 10/14 Time: 1700 by: AG

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO N/A
- 13. Were dissolved metals filtered in the field? YES NO N/A
- 14. Air Samples: Cassettes / Tubes Intact Y/N with MS Y/N Canisters Pressurized Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2	<u>202325</u>	HNO ₃		<input checked="" type="checkbox"/>	<u>NO Lot into</u>		<u>All</u>	<u>4ml</u>		<u>6.2</u>
≤2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: _____
Explain all Discrepancies/ Other Comments: _____

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: AG *significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2

Service Request: R2513167

Sample Name: 216.2-36
Lab Code: R2513167-001
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-37
Lab Code: R2513167-002
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-38
Lab Code: R2513167-003
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-39
Lab Code: R2513167-004
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-40
Lab Code: R2513167-005
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2

Service Request: R2513167

Sample Name: 216.2-41
Lab Code: R2513167-006
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-42
Lab Code: R2513167-007
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-43
Lab Code: R2513167-008
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-44
Lab Code: R2513167-009
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-45
Lab Code: R2513167-010
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2

Service Request: R2513167

Sample Name: 216.2-46
Lab Code: R2513167-011
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-47
Lab Code: R2513167-012
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-48
Lab Code: R2513167-013
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-49
Lab Code: R2513167-014
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-50
Lab Code: R2513167-015
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2

Service Request: R2513167

Sample Name: 216.2-51
Lab Code: R2513167-016
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-52
Lab Code: R2513167-017
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-53
Lab Code: R2513167-018
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-54
Lab Code: R2513167-019
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-55
Lab Code: R2513167-020
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2

Service Request: R2513167

Sample Name: 216.2-56
Lab Code: R2513167-021
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-57
Lab Code: R2513167-022
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-58
Lab Code: R2513167-023
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-59
Lab Code: R2513167-024
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-60
Lab Code: R2513167-025
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2

Service Request: R2513167

Sample Name: 216.2-61
Lab Code: R2513167-026
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-62
Lab Code: R2513167-027
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-63
Lab Code: R2513167-028
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-64
Lab Code: R2513167-029
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-65
Lab Code: R2513167-030
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2

Service Request: R2513167

Sample Name: 216.2-66
Lab Code: R2513167-031
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-67
Lab Code: R2513167-032
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-68
Lab Code: R2513167-033
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-69
Lab Code: R2513167-034
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-70
Lab Code: R2513167-035
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2

Service Request: R2513167

Sample Name: 216.2-71
Lab Code: R2513167-036
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-36
Lab Code: R2513167-001

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 13:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-37
Lab Code: R2513167-002

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 13:35	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-38
Lab Code: R2513167-003

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.6	ug/L	1.0	1	10/27/25 13:36	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-39
Lab Code: R2513167-004

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 13:38	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-40
Lab Code: R2513167-005

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.9	ug/L	1.0	1	10/27/25 13:42	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-41
Lab Code: R2513167-006

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.5	ug/L	1.0	1	10/27/25 13:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-42
Lab Code: R2513167-007

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.1	ug/L	1.0	1	10/27/25 13:46	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-43
Lab Code: R2513167-008

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 13:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-44
Lab Code: R2513167-009

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.6	ug/L	1.0	1	10/27/25 13:49	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-45
Lab Code: R2513167-010

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 13:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-46
Lab Code: R2513167-011

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 13:52	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-47
Lab Code: R2513167-012

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	10/27/25 13:53	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-48
Lab Code: R2513167-013

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	10/27/25 13:55	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-49
Lab Code: R2513167-014

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.2	ug/L	1.0	1	10/27/25 13:56	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-50
Lab Code: R2513167-015

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 14:01	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-51
Lab Code: R2513167-016

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.2	ug/L	1.0	1	10/27/25 14:02	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-52
Lab Code: R2513167-017

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 14:04	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-53
Lab Code: R2513167-018

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	10/27/25 14:06	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-54
Lab Code: R2513167-019

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.3	ug/L	1.0	1	10/28/25 11:39	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-55
Lab Code: R2513167-020

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.4	ug/L	1.0	1	10/28/25 11:41	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-56
Lab Code: R2513167-021

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.7	ug/L	1.0	1	10/28/25 11:42	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-57
Lab Code: R2513167-022

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.5	ug/L	1.0	1	10/28/25 11:43	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-58
Lab Code: R2513167-023

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.2	ug/L	1.0	1	10/28/25 11:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-59
Lab Code: R2513167-024

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	23.5	ug/L	1.0	1	10/28/25 11:46	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-60
Lab Code: R2513167-025

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1150	ug/L	50	50	10/28/25 11:59	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-61
Lab Code: R2513167-026

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.7	ug/L	1.0	1	10/29/25 18:02	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-62
Lab Code: R2513167-027

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 14:35	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-63
Lab Code: R2513167-028

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	10/28/25 11:52	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-64
Lab Code: R2513167-029

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.1	ug/L	1.0	1	10/28/25 11:53	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-65
Lab Code: R2513167-030

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	10.1	ug/L	1.0	1	10/28/25 12:05	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-66
Lab Code: R2513167-031

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.3	ug/L	1.0	1	10/28/25 12:09	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-67
Lab Code: R2513167-032

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 14:43	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-68
Lab Code: R2513167-033

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.6	ug/L	1.0	1	10/28/25 12:10	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-69
Lab Code: R2513167-034

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 14:46	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-70
Lab Code: R2513167-035

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.6	ug/L	1.0	1	10/27/25 14:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-71
Lab Code: R2513167-036

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	10/27/25 14:52	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513167-MB1

Service Request: R2513167
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 13:24	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513167-MB2

Service Request: R2513167
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 14:13	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513167-MB3

Service Request: R2513167
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/28/25 11:18	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513167-MB4

Service Request: R2513167
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/28/25 12:02	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513167-MB5

Service Request: R2513167
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/29/25 17:16	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25
Date Analyzed: 10/27/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 216.2-53
Lab Code: R2513167-018
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2513167-018MS		Duplicate Matrix Spike R2513167-018DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	1.3	20.6	20.0	97	20.5	20.0	96	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25
Date Analyzed: 10/28/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 216.2-64
Lab Code: R2513167-029
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2513167-029MS		Duplicate Matrix Spike R2513167-029DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	3.1	24.1	20.0	105	24.8	20.0	108	70-130	3	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water

Service Request: R2513167
Date Collected: 10/03/25
Date Received: 10/09/25
Date Analyzed: 10/28/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 216.2-65
Lab Code: R2513167-030
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2513167-030MS		Duplicate Matrix Spike R2513167-030DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	10.1	30.5	20.0	102	34.7	20.0	123	70-130	13	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water

Service Request: R2513167
Date Analyzed: 10/27/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2513167-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.5	20.0	103	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water

Service Request: R2513167
Date Analyzed: 10/27/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2513167-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.0	20.0	105	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water

Service Request: R2513167
Date Analyzed: 10/28/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2513167-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.4	20.0	102	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water

Service Request: R2513167
Date Analyzed: 10/28/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2513167-LCS4

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	22.8	20.0	114	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water

Service Request: R2513167
Date Analyzed: 10/29/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2513167-LCS5

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.4	20.0	102	85-115



November 03, 2025

Service Request No:R2513168

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Franklinville CSD Elementary

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory October 09, 2025
For your reference, these analyses have been assigned our service request number **R2513168**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7473. You may also contact me via email at Remy.Rubin@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Remy Rubin
Project Manager

CC: Rebecca
Franjoine

ADDRESS

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

PHONE +1 585 288 5380 | **FAX** +1 585 288 8475

ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Stohl Environmental
Project: Franklinville CSD Elementary
Sample Matrix: Drinking Water

Service Request: R2513168
Date Received: 10/09/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty six drinking water samples were received for analysis at ALS Environmental on 10/09/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink, appearing to read "R. Rubin", is written over a horizontal line.

Approved by _____

Date 11/03/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 216.2-72		Lab ID: R2513168-001					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	4.4			1.0	ug/L	200.8	
CLIENT ID: 216.2-76		Lab ID: R2513168-005					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.5			1.0	ug/L	200.8	
CLIENT ID: 216.2-79		Lab ID: R2513168-008					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.5			1.0	ug/L	200.8	
CLIENT ID: 216.2-81		Lab ID: R2513168-010					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.3			1.0	ug/L	200.8	
CLIENT ID: 216.2-83		Lab ID: R2513168-013					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.5			1.0	ug/L	200.8	
CLIENT ID: 216.2-84		Lab ID: R2513168-014					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.8			1.0	ug/L	200.8	
CLIENT ID: 216.2-85		Lab ID: R2513168-015					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.8			1.0	ug/L	200.8	
CLIENT ID: 216.2-86		Lab ID: R2513168-016					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	8.7			1.0	ug/L	200.8	
CLIENT ID: 216.2-87		Lab ID: R2513168-017					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.6			1.0	ug/L	200.8	
CLIENT ID: 216.2-88		Lab ID: R2513168-018					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.1			1.0	ug/L	200.8	
CLIENT ID: 216.2-89		Lab ID: R2513168-019					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.8			1.0	ug/L	200.8	
CLIENT ID: 216.2-90		Lab ID: R2513168-020					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.2			1.0	ug/L	200.8	



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 216.2-92		Lab ID: R2513168-022					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.5			1.0	ug/L	200.8	
CLIENT ID: 216.2-94		Lab ID: R2513168-025					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.9			1.0	ug/L	200.8	
CLIENT ID: 216.2-95		Lab ID: R2513168-026					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	14.8			1.0	ug/L	200.8	
CLIENT ID: 216.2-96		Lab ID: R2513168-027					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	5.4			1.0	ug/L	200.8	
CLIENT ID: 216.2-97		Lab ID: R2513168-028					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.2			1.0	ug/L	200.8	
CLIENT ID: 216.2-98		Lab ID: R2513168-029					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	5.1			1.0	ug/L	200.8	
CLIENT ID: 216.2-99		Lab ID: R2513168-030					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.3			1.0	ug/L	200.8	
CLIENT ID: 216.2-100		Lab ID: R2513168-031					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.6			1.0	ug/L	200.8	
CLIENT ID: 216.2-101		Lab ID: R2513168-032					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.5			1.0	ug/L	200.8	
CLIENT ID: 216.2-102		Lab ID: R2513168-033					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.6			1.0	ug/L	200.8	
CLIENT ID: 216.2-103		Lab ID: R2513168-034					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.5			1.0	ug/L	200.8	
CLIENT ID: 216.2-104		Lab ID: R2513168-035					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.7			1.0	ug/L	200.8	



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2

Service Request:R2513168

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2513168-001	216.2-72	10/3/2025	
R2513168-002	216.2-73	10/3/2025	
R2513168-003	216.2-74	10/3/2025	
R2513168-004	216.2-75	10/3/2025	
R2513168-005	216.2-76	10/3/2025	
R2513168-006	216.2-77	10/3/2025	
R2513168-007	216.2-78	10/3/2025	
R2513168-008	216.2-79	10/3/2025	
R2513168-009	216.2-80	10/3/2025	
R2513168-010	216.2-81	10/3/2025	
R2513168-011	216.2-82A	10/3/2025	
R2513168-012	216.2-82B	10/3/2025	
R2513168-013	216.2-83	10/3/2025	
R2513168-014	216.2-84	10/3/2025	
R2513168-015	216.2-85	10/3/2025	
R2513168-016	216.2-86	10/3/2025	
R2513168-017	216.2-87	10/3/2025	
R2513168-018	216.2-88	10/3/2025	
R2513168-019	216.2-89	10/3/2025	
R2513168-020	216.2-90	10/3/2025	
R2513168-021	216.2-91	10/3/2025	
R2513168-022	216.2-92	10/3/2025	
R2513168-023	216.2-93A	10/3/2025	
R2513168-025	216.2-94	10/3/2025	
R2513168-026	216.2-95	10/3/2025	
R2513168-027	216.2-96	10/3/2025	
R2513168-028	216.2-97	10/3/2025	
R2513168-029	216.2-98	10/3/2025	
R2513168-030	216.2-99	10/3/2025	
R2513168-031	216.2-100	10/3/2025	
R2513168-032	216.2-101	10/3/2025	
R2513168-033	216.2-102	10/3/2025	
R2513168-034	216.2-103	10/3/2025	
R2513168-035	216.2-104	10/3/2025	
R2513168-036	216.2-105	10/3/2025	



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-216.2

Client: Franklinville CSD Contact: Mr. Dustin Brisky

Building: Franklinville Elementary Location: 32 N Main St, Franklinville, NY 14737

LEAD		Turnaround
Water by 200.8	<u>X</u>	<u>10 Days</u>

Sample #	Location	Outlet Type	Time
216.2-72	Room 219 Restroom	Sink	6:18
216.2-73	Room 221	Sink	6:19
216.2-74	Room 222	Sink	6:20
216.2-75	Room 223	Sink	6:21
216.2-76	Room 224	Sink	6:22
216.2-77	Room 225	Sink	6:23
216.2-78	Room 226	Sink	6:24
216.2-79	Room 227	Sink	6:25
216.2-80	Girls Restroom By 325	Sink	6:26
216.2-81	Boys Restroom By 325	Sink	6:26
216.2-82A	Fountain Across 325	Drinking Fountain	6:27
216.2-82B	Bottle Fill Across 325	Bottle Fill	6:28
216.2-83	Room 322	Sink	6:29
216.2-84	Room 323	Sink	6:30
216.2-85	Room 321	Sink	6:31
216.2-86	Room 320	Sink	6:32
216.2-87	Room 317 Main	Sink	6:33
216.2-88	Room 317 Fountin	Drinking Fountain	6:34

Notes: Please e-mail lab results to labs@stohlenv.com mscinta@stohlenvironmental.com

Sampled By: Matthew McCourt Print Name Matthew McCourt Stohl Env: Matthew McCourt Date: 10/3/2025

Relinquished By: _____ Print Name Connor Crilly Stohl Env: Connor Crilly Date: 10/9/2025

Received (Name / Lab): [Signature] Date: 10/9/25 Time: 1700

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

R2513168 **5**

Stohl Environmental
Franklinville CSD Elementary



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-216.2

Client: Franklinville CSD Contact: Mr. Dustin Brisky

Building: Franklinville Elementary Location: 32 N Main St, Franklinville, NY 14737

LEAD	
Water by 200.8	<u>X</u>
	<u>Turnaround</u> 10 Days

Sample #	Location	Outlet Type	Time
216.2-89	Room 314 Main	Sink	6:35
216.2-90	Room 314 Fountain	Drinking Fountain	6:36
216.2-91	Staff Restroom Across 313	Sink	6:37
216.2-92	Room 315 Main	Sink	6:38
216.2-93	Bottle Fill Across 312	Bottle Fill	6:39
216.2-93	Room 315 Fountain	Drinking Fountain	6:40
216.2-94	Room 311	Sink	6:41
216.2-95	Room 312	Sink	6:42
216.2-96	Room 309	Sink	6:43
216.2-97	Room 310	Sink	6:44
216.2-98	Room 307	Sink	6:45
216.2-99	Staff Restroom Next To Girls Locker Room	Sink	6:45
216.2-100	Women's Restroom By Girls Locker Room Left	Sink	6:46
216.2-101	Women's Restroom By Girls Locker Room Right	Sink	6:47
216.2-102	Boys Restroom Across Gym Right	Sink	6:48
216.2-103	Room 304	Sink	6:49
216.2-104	Room 302	Sink	6:50
216.2-105A	Main Hall Drinking Fountain	Drinking Fountain	6:51

Notes: Please e-mail lab results to labs@stohlenv.com mscinta@stohlenvironmental.com

Sampled By: Matthew McCourt Print Name Matthew McCourt Stohl Env: Matthew McCourt Date: 10/3/2025

Relinquished By: _____ Print Name Connor Crilly Stohl Env: Connor Crilly Date: 10/9/2025

Received (Name / Lab): Bundy Date: 10/9/25 Time: 1700

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



R2513168 **5**
 Stahl Environmental
 Franklinville CSD Elementary

Cooler Receipt and Preservation

Project/Client STOHL Folder Number _____

Cooler received on 10/9/25 by: And COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <input checked="" type="checkbox"/>
2	Custody papers properly completed (ink, signed)?	<input checked="" type="checkbox"/> N
3	Did all bottles arrive in good condition (unbroken)?	<input checked="" type="checkbox"/> N
4	Circle: Wet Ice Dry Ice Gel packs present?	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/>

5a	Did VOA vials have sig* bubbles?	Y N <input checked="" type="checkbox"/>
5b	Sig* bubbles: Alk? Y N <input checked="" type="checkbox"/> Sulfide? Y N <input checked="" type="checkbox"/>	
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as: Bulk Encore 5035set	<input checked="" type="checkbox"/>

8. Temperature Readings Date: 10/9 Time: 1700 ID: IR#12 (R#11) From: Temp Blank Sample Bottle

Temp (°C)	<u>21.1</u>						
Within 0-6°C?	Y <input checked="" type="checkbox"/>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: _____ Ice melted Poorly Packed (described below) Same Day Rule
 & Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SW by And on 10/9 at 1755
 5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 10/14 Time: 1717 by: AG

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO
- 13. Were dissolved metals filtered in the field? YES NO
- 14. Air Samples: Cassettes / Tubes Intact Y/N with MS Y/N Canisters Pressurized Tedlar® Bags Inflated

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2	<u>202325</u>	HNO ₃		<input checked="" type="checkbox"/>	<u>No Lot in to</u>		<u>All</u>	<u>4ml</u>		<u>5.2</u>
≤2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: _____
 Explain all Discrepancies/ Other Comments: _____

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: AG *significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2

Service Request: R2513168

Sample Name: 216.2-72
Lab Code: R2513168-001
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-73
Lab Code: R2513168-002
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-74
Lab Code: R2513168-003
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-75
Lab Code: R2513168-004
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-76
Lab Code: R2513168-005
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2

Service Request: R2513168

Sample Name: 216.2-77
Lab Code: R2513168-006
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-78
Lab Code: R2513168-007
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-79
Lab Code: R2513168-008
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-80
Lab Code: R2513168-009
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-81
Lab Code: R2513168-010
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2

Service Request: R2513168

Sample Name: 216.2-82A
Lab Code: R2513168-011
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-82B
Lab Code: R2513168-012
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-83
Lab Code: R2513168-013
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-84
Lab Code: R2513168-014
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-85
Lab Code: R2513168-015
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2

Service Request: R2513168

Sample Name: 216.2-86
Lab Code: R2513168-016
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-87
Lab Code: R2513168-017
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-88
Lab Code: R2513168-018
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-89
Lab Code: R2513168-019
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-90
Lab Code: R2513168-020
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2

Service Request: R2513168

Sample Name: 216.2-91
Lab Code: R2513168-021
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-92
Lab Code: R2513168-022
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-93A
Lab Code: R2513168-023
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-94
Lab Code: R2513168-025
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-95
Lab Code: R2513168-026
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2

Service Request: R2513168

Sample Name: 216.2-96
Lab Code: R2513168-027
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-97
Lab Code: R2513168-028
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-98
Lab Code: R2513168-029
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-99
Lab Code: R2513168-030
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-100
Lab Code: R2513168-031
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2

Service Request: R2513168

Sample Name: 216.2-101
Lab Code: R2513168-032
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-102
Lab Code: R2513168-033
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-103
Lab Code: R2513168-034
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-104
Lab Code: R2513168-035
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-105
Lab Code: R2513168-036
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-72
Lab Code: R2513168-001

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.4	ug/L	1.0	1	10/27/25 14:54	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-73
Lab Code: R2513168-002

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 14:55	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-74
Lab Code: R2513168-003

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 15:06	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-75
Lab Code: R2513168-004

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 15:11	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-76
Lab Code: R2513168-005

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.5	ug/L	1.0	1	10/27/25 15:12	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-77
Lab Code: R2513168-006

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 15:14	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-78
Lab Code: R2513168-007

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 15:15	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-79
Lab Code: R2513168-008

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.5	ug/L	1.0	1	10/27/25 15:17	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-80
Lab Code: R2513168-009

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 15:21	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-81
Lab Code: R2513168-010

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	10/27/25 15:23	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-82A
Lab Code: R2513168-011

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 15:25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-82B
Lab Code: R2513168-012

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 15:26	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-83
Lab Code: R2513168-013

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.5	ug/L	1.0	1	10/27/25 15:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-84
Lab Code: R2513168-014

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.8	ug/L	1.0	1	10/27/25 15:29	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-85
Lab Code: R2513168-015

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.8	ug/L	1.0	1	10/27/25 15:31	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-86
Lab Code: R2513168-016

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	8.7	ug/L	1.0	1	10/27/25 15:32	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-87
Lab Code: R2513168-017

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.6	ug/L	1.0	1	10/27/25 15:34	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-88
Lab Code: R2513168-018

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	10/27/25 15:35	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-89
Lab Code: R2513168-019

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.8	ug/L	1.0	1	10/27/25 15:40	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-90
Lab Code: R2513168-020

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.2	ug/L	1.0	1	10/27/25 15:42	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-91
Lab Code: R2513168-021

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 16:03	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-92
Lab Code: R2513168-022

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.5	ug/L	1.0	1	10/27/25 16:04	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-93A
Lab Code: R2513168-023

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 16:15	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-94
Lab Code: R2513168-025

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.9	ug/L	1.0	1	10/27/25 16:20	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-95
Lab Code: R2513168-026

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	14.8	ug/L	1.0	1	10/27/25 16:21	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-96
Lab Code: R2513168-027

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.4	ug/L	1.0	1	10/27/25 16:23	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-97
Lab Code: R2513168-028

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.2	ug/L	1.0	1	10/27/25 16:24	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-98
Lab Code: R2513168-029

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.1	ug/L	1.0	1	10/27/25 16:26	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-99
Lab Code: R2513168-030

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.3	ug/L	1.0	1	10/27/25 16:30	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-100
Lab Code: R2513168-031

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.6	ug/L	1.0	1	10/27/25 16:32	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-101
Lab Code: R2513168-032

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.5	ug/L	1.0	1	10/29/25 17:20	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-102
Lab Code: R2513168-033

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.6	ug/L	1.0	1	10/27/25 16:35	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-103
Lab Code: R2513168-034

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.5	ug/L	1.0	1	10/27/25 16:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-104
Lab Code: R2513168-035

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.7	ug/L	1.0	1	10/27/25 16:38	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-105
Lab Code: R2513168-036

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 16:40	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513168-MB1

Service Request: R2513168
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 14:13	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513168-MB2

Service Request: R2513168
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 15:03	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513168-MB3

Service Request: R2513168
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 16:12	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513168-MB4

Service Request: R2513168
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/29/25 17:16	

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25
Date Analyzed: 10/27/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 216.2-73
Lab Code: R2513168-002
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2513168-002MS		Duplicate Matrix Spike R2513168-002DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	20.4	20.0	102	20.0	20.0	100	70-130	2	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25
Date Analyzed: 10/27/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 216.2-74
Lab Code: R2513168-003
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2513168-003MS		Duplicate Matrix Spike R2513168-003DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	21.1	20.0	105	20.4	20.0	102	70-130	3	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25
Date Analyzed: 10/27/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 216.2-92
Lab Code: R2513168-022
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2513168-022MS		Duplicate Matrix Spike R2513168-022DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	1.5	21.7	20.0	101	21.5	20.0	100	70-130	1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25
Date Analyzed: 10/27/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 216.2-93A
Lab Code: R2513168-023
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2513168-023MS		Duplicate Matrix Spike R2513168-023DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	20.8	20.0	104	20.5	20.0	103	70-130	1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water

Service Request: R2513168
Date Collected: 10/03/25
Date Received: 10/09/25
Date Analyzed: 10/29/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 216.2-101
Lab Code: R2513168-032
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2513168-032MS		Duplicate Matrix Spike R2513168-032DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	3.5	23.5	20.0	100	23.7	20.0	101	70-130	1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water

Service Request: R2513168
Date Analyzed: 10/27/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2513168-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.0	20.0	105	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water

Service Request: R2513168

Date Analyzed: 10/27/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample
R2513168-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.9	20.0	104	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water

Service Request: R2513168
Date Analyzed: 10/27/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2513168-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.4	20.0	102	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water

Service Request: R2513168

Date Analyzed: 10/29/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample
R2513168-LCS4

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.4	20.0	102	85-115



October 30, 2025

Service Request No:R2513169

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Franklinville CSD Elementary

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory October 09, 2025
For your reference, these analyses have been assigned our service request number **R2513169**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7473. You may also contact me via email at Remy.Rubin@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Remy Rubin
Project Manager

CC: Rebecca
Franjoine

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
PHONE +1 585 288 5380 | **FAX** +1 585 288 8475
ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Stohl Environmental
Project: Franklinville CSD Elementary
Sample Matrix: Drinking Water

Service Request: R2513169
Date Received: 10/09/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Seventeen drinking water samples were received for analysis at ALS Environmental on 10/09/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

Approved by 

Date 10/30/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 216.2-109 **Lab ID: R2513169-005**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	21.0			1.0	ug/L	200.8

CLIENT ID: 216.2-110 **Lab ID: R2513169-006**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.2			1.0	ug/L	200.8

CLIENT ID: 216.2-111 **Lab ID: R2513169-007**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.7			1.0	ug/L	200.8

CLIENT ID: 216.2-113 **Lab ID: R2513169-009**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.2			1.0	ug/L	200.8

CLIENT ID: 216.2-115 **Lab ID: R2513169-011**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.7			1.0	ug/L	200.8

CLIENT ID: 216.2-116 **Lab ID: R2513169-012**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.9			1.0	ug/L	200.8

CLIENT ID: 216.2-120 **Lab ID: R2513169-016**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.9			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2

Service Request:R2513169

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2513169-001	216.2-105B	10/3/2025	
R2513169-002	216.2-106	10/3/2025	
R2513169-003	216.2-107	10/3/2025	
R2513169-004	216.2-108	10/3/2025	
R2513169-005	216.2-109	10/3/2025	
R2513169-006	216.2-110	10/3/2025	
R2513169-007	216.2-111	10/3/2025	
R2513169-008	216.2-112	10/3/2025	
R2513169-009	216.2-113	10/3/2025	
R2513169-010	216.2-114	10/3/2025	
R2513169-011	216.2-115	10/3/2025	
R2513169-012	216.2-116	10/3/2025	
R2513169-013	216.2-117	10/3/2025	
R2513169-014	216.2-118	10/3/2025	
R2513169-015	216.2-119	10/3/2025	
R2513169-016	216.2-120	10/3/2025	
R2513169-017	216.2-121	10/3/2025	



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-216.2

Client: Franklinville CSD Contact: Mr. Dustin Brisky

Building: Franklinville Elementary Location: 32 N Main St, Franklinville, NY 14737

LEAD		Turnaround
Water by 200.8	<u>X</u>	<u>10 Days</u>

Sample #	Location	Outlet Type	Time
216.2-105B	Main Hall Bottle Fill	Bottle Fill	6:52
216.2-106	Gym Front Fountain	Drinking Fountain	6:53
216.2-107	Gym Back Fountain	Drinking Fountain	6:54
216.2-108	Boys Gym Coach Office	Sink	6:55
216.2-109	Boys Gym Locker	Sink	6:56
216.2-110	Girls Gym Coach Office	Sink	6:57
216.2-111	Girls Gym Locker	Sink	6:58
216.2-112	Girls Pool Locker	Sink	6:59
216.2-113	Pool Office	Sink	7:00
216.2-114	Boys Pool Locker	Sink	7:01
216.2-115	Pool Boys Restroom Keft	Sink	7:02
216.2-116	Pool Boys Restroom Right	Sink	7:03
216.2-117	Concession Sink	Sink	7:04
216.2-118	Concession Mens Sink Left	Sink	7:04
216.2-119	Concession Mens Sink Right	Sink	7:05
216.2-120	Concession Womens Sink Left	Sink	7:06
216.2-121	Concession Womens Sink Right	Sink	7:07

Notes:
 Please e-mail lab results to labs@stohlenv.com mscinta@stohlenvironmental.com

Sampled By: Matthew McCourt Print Name Matthew McCourt Stohl Env: Matthew McCourt Date: 10/3/2025

Relinquished By: _____ Print Name _____ Stohl Env: Connor Crilly Date: 10/9/2025

Received (Name / Lab): *[Signature]* Date: *10/3* Time: *12:00*

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

R2513169 **5**

Stohl Environmental
 Franklinville CSD Elementary



Cooler Receipt and Preservation

R2513169 **5**
 Stohi Environmental
 Franklinville CSD Elementary

Project/Client STOHL Folder Number _____

Cooler received on 10/9/25 by: Paul COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <input checked="" type="checkbox"/> N
2	Custody papers properly completed (ink, signed)?	<input checked="" type="checkbox"/> Y N
3	Did all bottles arrive in good condition (unbroken)?	<input checked="" type="checkbox"/> Y N
4	Circle: Wet Ice Dry Ice Gel packs present?	<input checked="" type="checkbox"/> Y <input checked="" type="checkbox"/> N

5a	Did VOA vials have sig* bubbles?	Y N <input checked="" type="checkbox"/> NA
5b	Sig* bubbles: Alk? Y N <input checked="" type="checkbox"/> NA Sulfide? Y N <input checked="" type="checkbox"/> NA	
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as: Bulk Encore 5035set	<input checked="" type="checkbox"/> NA

8. Temperature Readings Date: 10/9 Time: 1700 ID: IR#12 IR#11 From: Temp Blank Sample Bottle

Temp (°C)	<u>21.1</u>						
Within 0-6°C?	Y <input checked="" type="checkbox"/> N	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: _____ Ice melted Poorly Packed (described below) Same Day Rule
 & Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SW by Paul on 10/9 at 1755
 5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 10/14 Time: 1716 by: AG

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO NA
- 13. Were dissolved metals filtered in the field? YES NO NA
- 14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated NA

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
<2	<u>002305</u>	HNO ₃		<input checked="" type="checkbox"/>	<u>No Lot info</u>		<u>A11</u>	<u>4mL</u>		<u>5.2</u>
<2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: _____
 Explain all Discrepancies/ Other Comments: _____

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: AG *significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2

Service Request: R2513169

Sample Name: 216.2-105B
Lab Code: R2513169-001
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-106
Lab Code: R2513169-002
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-107
Lab Code: R2513169-003
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-108
Lab Code: R2513169-004
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-109
Lab Code: R2513169-005
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2

Service Request: R2513169

Sample Name: 216.2-110
Lab Code: R2513169-006
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-111
Lab Code: R2513169-007
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 216.2-112
Lab Code: R2513169-008
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-113
Lab Code: R2513169-009
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-114
Lab Code: R2513169-010
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2

Service Request: R2513169

Sample Name: 216.2-115
Lab Code: R2513169-011
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-116
Lab Code: R2513169-012
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-117
Lab Code: R2513169-013
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-118
Lab Code: R2513169-014
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-119
Lab Code: R2513169-015
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2

Service Request: R2513169

Sample Name: 216.2-120
Lab Code: R2513169-016
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 216.2-121
Lab Code: R2513169-017
Sample Matrix: Drinking Water

Date Collected: 10/3/25
Date Received: 10/9/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-105B
Lab Code: R2513169-001

Service Request: R2513169
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 16:41	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-106
Lab Code: R2513169-002

Service Request: R2513169
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 16:43	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-107
Lab Code: R2513169-003

Service Request: R2513169
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 16:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-108
Lab Code: R2513169-004

Service Request: R2513169
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 16:49	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-109
Lab Code: R2513169-005

Service Request: R2513169
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	21.0	ug/L	1.0	1	10/27/25 16:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-110
Lab Code: R2513169-006

Service Request: R2513169
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.2	ug/L	1.0	1	10/27/25 16:52	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-111
Lab Code: R2513169-007

Service Request: R2513169
Date Collected: 10/03/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.7	ug/L	1.0	1	10/27/25 16:53	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-112
Lab Code: R2513169-008

Service Request: R2513169
Date Collected: 10/03/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/28/25 12:11	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-113
Lab Code: R2513169-009

Service Request: R2513169
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.2	ug/L	1.0	1	10/28/25 12:13	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-114
Lab Code: R2513169-010

Service Request: R2513169
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/28/25 12:14	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-115
Lab Code: R2513169-011

Service Request: R2513169
Date Collected: 10/03/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.7	ug/L	1.0	1	10/28/25 12:18	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-116
Lab Code: R2513169-012

Service Request: R2513169
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.9	ug/L	1.0	1	10/28/25 12:19	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-117
Lab Code: R2513169-013

Service Request: R2513169
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/28/25 12:21	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-118
Lab Code: R2513169-014

Service Request: R2513169
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/28/25 12:22	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-119
Lab Code: R2513169-015

Service Request: R2513169
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/28/25 12:23	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-120
Lab Code: R2513169-016

Service Request: R2513169
Date Collected: 10/03/25
Date Received: 10/09/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.9	ug/L	1.0	1	10/28/25 12:24	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: 216.2-121
Lab Code: R2513169-017

Service Request: R2513169
Date Collected: 10/03/25
Date Received: 10/09/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/28/25 12:26	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513169-MB1

Service Request: R2513169
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/27/25 16:12	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513169-MB2

Service Request: R2513169
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	10/28/25 12:02	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water

Service Request: R2513169
Date Collected: 10/03/25
Date Received: 10/09/25
Date Analyzed: 10/27/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 216.2-111
Lab Code: R2513169-007
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2513169-007MS		Duplicate Matrix Spike R2513169-007DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	3.7	23.0	20.0	97	23.2	20.0	98	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water

Service Request: R2513169
Date Analyzed: 10/27/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2513169-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.4	20.0	102	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Franklinville CSD Elementary/2023L-216.2
Sample Matrix: Drinking Water

Service Request: R2513169
Date Analyzed: 10/28/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2513169-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	22.8	20.0	114	85-115

1.5 Laboratory Certifications

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2026
Issued April 01, 2025

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE
Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. CHRISTINE KUTZER
ALS ENVIRONMENTAL - ROCHESTER
1565 JEFFERSON ROAD BUILDING 300, SUITE 360
ROCHESTER, NY 14623

NY Lab Id No: 10145

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2016) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Bacteriology	
Coliform, Total / E. coli (Qualitative)	SM 20, 21-23 9223B (-04) (Colilert)
Dissolved Gases	
Acetylene	RSK-175
Ethane	RSK-175
Ethene (Ethylene)	RSK-175
Methane	RSK-175
Propane	RSK-175
Fuel Additives	
Methyl tert-butyl ether	EPA 524.2
Naphthalene	EPA 524.2
Metals I	
Arsenic, Total	EPA 200.8 Rev. 5.4
Barium, Total	EPA 200.8 Rev. 5.4
Cadmium, Total	EPA 200.8 Rev. 5.4
Chromium, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Copper, Total	EPA 200.8 Rev. 5.4
Iron, Total	EPA 200.7 Rev. 4.4
Lead, Total	EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Mercury, Total	EPA 245.1 Rev. 3.0
Selenium, Total	EPA 200.8 Rev. 5.4
Silver, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Zinc, Total	EPA 200.7 Rev. 4.4

Serial No.: 70111

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elappublicweb/>, by phone (518) 485-6570 or by email to elap@health.ny.gov.



Page 1 of 5