

ENVIRONMENTAL LABWORKS, INC.

December 8, 2025

Highland CSD
320 Pancake Hollow Rd.
Highland, NY 12528

Dear Michael,

The following are results of the analyses performed on water samples from **Highland Elementary School** received at the laboratory on 11/19/25.

Date/Time Collected: 11/19/25 5:39-7:14am First Draw
Collected By: UC BOCES
Project ID: 11192509
Secondary ID: HE254949-5021

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
Kitchen Sink 2 11192509-1	EPA 200.8 Lead	0.00497 mg/L		0.005 mg/L	11/26/25
Kitchen Cleveland Steamer 11192509-2	EPA 200.8 Lead	0.00386 mg/L		0.005 mg/L	11/26/25
Kitchen Sink 4 11192509-3	EPA 200.8 Lead	0.000937 mg/L		0.005 mg/L	11/26/25
Kitchen Sink 5 11192509-4	EPA 200.8 Lead	0.00265 mg/L		0.005 mg/L	11/26/25
Kitchen Sprayer 11192509-5	EPA 200.8 Lead	0.00125 mg/L		0.005 mg/L	11/26/25
Kitchen Sink 7 11192509-6	EPA 200.8 Lead	0.00512 mg/L	X	0.005 mg/L	11/26/25
Kitchen Sink 8 11192509-7	EPA 200.8 Lead	0.00282 mg/L		0.005 mg/L	11/26/25
Faculty Room Sink 11192509-8	EPA 200.8 Lead	0.00633 mg/L	X	0.005 mg/L	11/26/25
Nurse Sink 11192509-9	EPA 200.8 Lead	0.00318 mg/L		0.005 mg/L	11/26/25
Room 101 Bubbler 11192509-10	EPA 200.8 Lead	0.0132 mg/L	X	0.005 mg/L	11/26/25

ENVIRONMENTAL LABWORKS, INC.

Highland Elementary School - 11192509

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
Room 101 Sink 11192509-11	EPA 200.8 Lead	0.0225 mg/L	X	0.005 mg/L	11/26/25
Room 102 Bubbler 11192509-12	EPA 200.8 Lead	0.0176 mg/L	X	0.005 mg/L	11/26/25
Room 102 Sink 11192509-13	EPA 200.8 Lead	0.0188 mg/L	X	0.005 mg/L	11/26/25
Room 103 Bubbler 11192509-14	EPA 200.8 Lead	0.00605 mg/L	X	0.005 mg/L	11/26/25
Room 103 Sink 11192509-15	EPA 200.8 Lead	0.0157 mg/L	X	0.005 mg/L	11/26/25
Room 104 Bubbler 11192509-16	EPA 200.8 Lead	0.0162 mg/L	X	0.005 mg/L	11/26/25
Room 104 Sink 11192509-17	EPA 200.8 Lead	0.0173 mg/L	X	0.005 mg/L	11/26/25
Room 105 Bubbler 11192509-18	EPA 200.8 Lead	0.0169 mg/L	X	0.005 mg/L	11/26/25
Room 105 Sink 11192509-19	EPA 200.8 Lead	0.00768 mg/L	X	0.005 mg/L	11/26/25
Room 106 Bubbler 11192509-20	EPA 200.8 Lead	0.00215 mg/L		0.005 mg/L	11/26/25
Room 106 Sink 11192509-21	EPA 200.8 Lead	0.00454 mg/L		0.005 mg/L	11/26/25
Room 107 Bubbler 11192509-22	EPA 200.8 Lead	0.0139 mg/L	X	0.005 mg/L	11/26/25
Room 107 Sink 11192509-23	EPA 200.8 Lead	0.0273 mg/L	X	0.005 mg/L	11/26/25
Room 108 Bubbler 11192509-24	EPA 200.8 Lead	0.0183 mg/L	X	0.005 mg/L	11/26/25
Room 108 Sink 11192509-25	EPA 200.8 Lead	0.0106 mg/L	X	0.005 mg/L	11/26/25

ENVIRONMENTAL LABWORKS, INC.

Highland Elementary School - 11192509

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
Upper Primary Cooler 11192509-26	EPA 200.8 Lead	<0.00040 mg/L		0.005 mg/L	11/26/25
Lower Primary Cooler 11192509-27	EPA 200.8 Lead	<0.00040 mg/L		0.005 mg/L	11/26/25
Primary Kitchen Sink 1 11192509-28	EPA 200.8 Lead	0.00194 mg/L		0.005 mg/L	11/26/25
Primary Kitchen Sink 2 11192509-29	EPA 200.8 Lead	0.00121 mg/L		0.005 mg/L	11/26/25
Room 202 Bubbler 11192509-30	EPA 200.8 Lead	0.00632 mg/L	X	0.005 mg/L	11/26/25
Room 202 Sink 11192509-31	EPA 200.8 Lead	0.00926 mg/L	X	0.005 mg/L	11/26/25
Room 203 Bubbler 11192509-32	EPA 200.8 Lead	0.0202 mg/L	X	0.005 mg/L	11/26/25
Room 203 Sink 11192509-33	EPA 200.8 Lead	0.0136 mg/L	X	0.005 mg/L	11/26/25
Room 204 Sink 11192509-34	EPA 200.8 Lead	0.0196 mg/L	X	0.005 mg/L	11/26/25
Room 205 Sink 11192509-35	EPA 200.8 Lead	0.0105 mg/L	X	0.005 mg/L	11/26/25
Room 206 Bubbler 11192509-36	EPA 200.8 Lead	0.0194 mg/L	X	0.005 mg/L	11/26/25
Room 206 Sink 11192509-37	EPA 200.8 Lead	0.0168 mg/L	X	0.005 mg/L	11/26/25
200 Wing Girls Bath Cooler 11192509-38	EPA 200.8 Lead	0.00961 mg/L	X	0.005 mg/L	11/26/25
Room 208 Sink 11192509-39	EPA 200.8 Lead	0.0579 mg/L	X	0.005 mg/L	11/26/25
Room 207 Bubbler 11192509-40	EPA 200.8 Lead	0.00814 mg/L	X	0.005 mg/L	11/26/25

ENVIRONMENTAL LABWORKS, INC.

Highland Elementary School - 11192509

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
Room 207 Sink 11192509-41	EPA 200.8 Lead	0.0109 mg/L	X	0.005 mg/L	11/26/25
Room 210 Bubbler 11192509-42	EPA 200.8 Lead	0.00590 mg/L	X	0.005 mg/L	11/26/25
Room 210 Sink 11192509-43	EPA 200.8 Lead	0.0115 mg/L	X	0.005 mg/L	11/26/25
Room 209 Bubbler 11192509-44	EPA 200.8 Lead	0.00778 mg/L	X	0.005 mg/L	11/26/25
Room 209 Sink 11192509-45	EPA 200.8 Lead	0.0172 mg/L	X	0.005 mg/L	11/26/25
Room 212 Sink 11192509-46	EPA 200.8 Lead	0.0138 mg/L	X	0.005 mg/L	11/26/25
Room 211 Bubbler 11192509-47	EPA 200.8 Lead	0.0444 mg/L	X	0.005 mg/L	11/26/25
Room 211 Sink 11192509-48	EPA 200.8 Lead	0.0415 mg/L	X	0.005 mg/L	11/26/25
Room 302 Bubbler 11192509-49	EPA 200.8 Lead	0.00977 mg/L	X	0.005 mg/L	11/26/25
Room 302 Sink 11192509-50	EPA 200.8 Lead	0.0123 mg/L	X	0.005 mg/L	11/26/25
Room 303 Bubbler 11192509-51	EPA 200.8 Lead	0.0121 mg/L	X	0.005 mg/L	11/26/25
Room 303 Sink 11192509-52	EPA 200.8 Lead	0.00772 mg/L	X	0.005 mg/L	11/26/25
Room 304 Bubbler 11192509-53	EPA 200.8 Lead	0.00440 mg/L		0.005 mg/L	11/26/25
Room 304 Sink 11192509-54	EPA 200.8 Lead	0.0868 mg/L	X	0.005 mg/L	11/26/25
Room 305 Bubbler 11192509-55	EPA 200.8 Lead	0.0108 mg/L	X	0.005 mg/L	11/26/25

ENVIRONMENTAL LABWORKS, INC.

Highland Elementary School - 11192509

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
Room 305 Sink 11192509-56	EPA 200.8 Lead	0.0136 mg/L	X	0.005 mg/L	11/26/25
Room 306 Bubblers 11192509-57	EPA 200.8 Lead	0.00356 mg/L		0.005 mg/L	11/26/25
Room 306 Sink 11192509-58	EPA 200.8 Lead	0.0156 mg/L	X	0.005 mg/L	11/26/25
300 Bathroom Cooler 11192509-59	EPA 200.8 Lead	0.00629 mg/L	X	0.005 mg/L	11/26/25
Room 308 Bubblers 11192509-60	EPA 200.8 Lead	0.00737 mg/L	X	0.005 mg/L	11/26/25
Room 308 Sink 11192509-61	EPA 200.8 Lead	0.0149 mg/L	X	0.005 mg/L	11/26/25
Room 307 Bubblers 11192509-62	EPA 200.8 Lead	0.0553 mg/L	X	0.005 mg/L	11/26/25
Room 307 Sink 11192509-63	EPA 200.8 Lead	0.0229 mg/L	X	0.005 mg/L	11/26/25
Room 310 Bubblers 11192509-64	EPA 200.8 Lead	0.00230 mg/L		0.005 mg/L	11/26/25
Room 310 Sink 11192509-65	EPA 200.8 Lead	0.00675 mg/L	X	0.005 mg/L	11/26/25
Room 309 Bubblers 11192509-66	EPA 200.8 Lead	0.00366 mg/L		0.005 mg/L	11/26/25
Room 309 Sink 11192509-67	EPA 200.8 Lead	0.00471 mg/L		0.005 mg/L	11/26/25
Room 312 Bubblers 11192509-68	EPA 200.8 Lead	0.00841 mg/L	X	0.005 mg/L	11/26/25
Room 312 Sink 11192509-69	EPA 200.8 Lead	0.00977 mg/L	X	0.005 mg/L	11/26/25
Ice Machine 11192509-70	EPA 200.8 Lead	<0.00040 mg/L		0.005 mg/L	11/26/25

ENVIRONMENTAL LABWORKS, INC.

Highland Elementary School - 11192509


LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
Room 311 Bubbler 11192509-71	EPA 200.8 Lead	0.00437 mg/L		0.005 mg/L	11/26/25
Room 311 Sink 11192509-72	EPA 200.8 Lead	0.00368 mg/L		0.005 mg/L	11/26/25
Main Lobby Cooler 11192509-73	EPA 200.8 Lead	0.00963 mg/L	X	0.005 mg/L	11/26/25

Qualifier(Q):

X - Value exceeds Maximum Contaminant Level or other Regulatory Level.

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #12150. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
Technical Director