

ENVIRONMENTAL LABWORKS, INC.

December 8, 2025

Highland CSD
320 Pancake Hollow Rd.
Highland, NY 12528

Dear Michael,

The following are results of the analyses performed on water samples from **Highland High School** received at the laboratory on 11/19/25.

Date/Time Collected: 11/19/25 4:47-7:46am First Draw
Collected By: UC BOCES
Project ID: 11192507
Secondary ID: HH254924-39

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
Kitchen Sink 1 11192507-1	EPA 200.8 Lead	0.00507 mg/L	X	0.005 mg/L	11/25/25
Kitchen Sprayer Sink 1 11192507-2	EPA 200.8 Lead	0.00334 mg/L		0.005 mg/L	11/25/25
Kitchen Sink 2 11192507-3	EPA 200.8 Lead	0.00224 mg/L		0.005 mg/L	11/25/25
Kitchen Cleveland Sprayer 11192507-4	EPA 200.8 Lead	0.00496 mg/L		0.005 mg/L	11/25/25
Staff Lounge Sink 4 11192507-5	EPA 200.8 Lead	0.0114 mg/L	X	0.005 mg/L	11/25/25
Nurse Sink 11192507-6	EPA 200.8 Lead	0.00422 mg/L		0.005 mg/L	11/25/25
Boys Locker Cooler 1 11192507-7	EPA 200.8 Lead	0.00115 mg/L		0.005 mg/L	11/25/25
Boys Locker Cooler 2 11192507-8	EPA 200.8 Lead	0.00177 mg/L		0.005 mg/L	11/25/25
Cooler 1 by Gym 11192507-9	EPA 200.8 Lead	0.00229 mg/L		0.005 mg/L	11/25/25
Cooler 2 by Gym 11192507-10	EPA 200.8 Lead	0.00287 mg/L		0.005 mg/L	11/25/25

ENVIRONMENTAL LABWORKS, INC.

Highland High School - 11192507


LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
Girls Cooler 2 11192507-11	EPA 200.8 Lead	0.00377 mg/L		0.005 mg/L	11/25/25
Girls Cooler 1 11192507-12	EPA 200.8 Lead	0.00328 mg/L		0.005 mg/L	11/25/25
Chorus Room Cooler 11192507-13	EPA 200.8 Lead	<0.00040 mg/L		0.005 mg/L	11/25/25
Chorus Cooler 2 11192507-14	EPA 200.8 Lead	<0.00040 mg/L		0.005 mg/L	11/25/25
HS Locker Ice Machine 11192507-15	EPA 200.8 Lead	<0.00040 mg/L		0.005 mg/L	11/25/25
HS Kitchen Ice Machine 11192507-16	EPA 200.8 Lead	<0.00040 mg/L		0.005 mg/L	11/25/25

Qualifier(Q):

X - Value exceeds Maximum Contaminant Level or other Regulatory Level.

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #12150. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
Technical Director