

ENVIRONMENTAL LABWORKS, INC.

December 8, 2025

Highland CSD
320 Pancake Hollow Rd.
Highland, NY 12528

Dear Michael,

The following are results of the analyses performed on water samples from **Highland Middle School** received at the laboratory on 11/19/25.

Date/Time Collected: 11/19/25 5:20-7:15am First Draw
Collected By: UC BOCES
Project ID: 11192508
Secondary ID: HM254940-48

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
Health Office Sink 11192508-1	EPA 200.8 Lead	0.00684 mg/L	X	0.005 mg/L	11/25/25
Conference Room Sink 11192508-2	EPA 200.8 Lead	0.00525 mg/L	X	0.005 mg/L	11/25/25
Prep Hand Sink 11192508-3	EPA 200.8 Lead	0.000837 mg/L		0.005 mg/L	11/26/25
Kitchen Pot Filler 11192508-4	EPA 200.8 Lead	0.00250 mg/L		0.005 mg/L	11/26/25
Kitchen Sink 1 11192508-5	EPA 200.8 Lead	0.00148 mg/L		0.005 mg/L	11/26/25
Kitchen Sink 2 11192508-6	EPA 200.8 Lead	0.000755 mg/L		0.005 mg/L	11/26/25
Kitchen Sprayer 11192508-7	EPA 200.8 Lead	0.00332 mg/L		0.005 mg/L	11/26/25
Gym Cooler 11192508-8	EPA 200.8 Lead	0.000955 mg/L		0.005 mg/L	11/26/25
MS Ice Machine 11192508-9	EPA 200.8 Lead	0.000617 mg/L		0.005 mg/L	11/26/25

Qualifier(Q):

X - Value exceeds Maximum Contaminant Level or other Regulatory Level.


PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911
NYSDOH #10824

ENVIRONMENTAL LABWORKS, INC.

Highland Middle School - 11192508

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #12150. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
Technical Director