



464 Valley Brook Avenue, Lyndhurst NJ 07071  
129 Sea Girt Avenue, Manasquan NJ 08736  
Phone: (800) 423-0766 • Fax: (201) 438-1798  
www.mccabeenv.com

---

## LEAD IN DRINKING WATER TESTING REPORT

***Conducted for:***

Bayonne Board of Education  
669 Avenue A  
Bayonne, New Jersey 07002

***Conducted at:***

Bayonne High School  
669 Avenue A  
Bayonne, New Jersey 07002

***Submitted by:***

McCabe Environmental Services, L.L.C.  
464 Valley Brook Avenue  
Lyndhurst, New Jersey 07071

**REPORT DATE:** August 5, 2025

**MES PROJECT NO.:** 25-05225

***Prepared by:***

A handwritten signature in blue ink, appearing to read 'Arlitzzy Lezama'.

**Arlitzzy Lezama**  
**Environmental Scientist**

***Signed for the Company by:***

A handwritten signature in blue ink, appearing to read 'John H. Chiaviello'.

**John H. Chiaviello**  
**Vice President**

## TABLE OF CONTENTS

	<b>Page</b>
1.0 INTRODUCTION .....	1
2.0 SCOPE OF WORK.....	1
3.0 PROCEDURES.....	1
4.0 TABLE OF SAMPLE RESULTS .....	2
5.0 DISCUSSION AND CONCLUSION .....	5

### **APPENDIX A**

Laboratory Certificates of Analysis  
&  
Sample Chain of Custody Forms

### **APPENDIX B**

School District Sampling Attachments

**1.0 INTRODUCTION**

McCabe Environmental Services, L.L.C. (McCabe) was retained by Bayonne Board of Education (Client) to conduct lead in drinking water testing at the Bayonne High School located at 669 Avenue A, Bayonne, New Jersey.

The project information is as follows:

Client Name: Bayonne Board of Education  
Contact Person: Mr. Daniel Castles

Project Name: Bayonne High School – Lead in Drinking Water  
Project Location: 669 Avenue A  
Bayonne, New Jersey 07002

Date(s) of Service: June 20, 2025

McCabe Personnel: Gary Clare and Arllitzy Lezama

**2.0 SCOPE OF WORK**

Drinking water testing was performed at the Bayonne High School located at 669 Avenue A, Bayonne, New Jersey on June 20, 2025. The purpose of the testing was to determine if the building’s plumbing was having an adverse impact on water quality, specifically with regard to lead concentrations. Samples were collected from various potential drinking water outlets located throughout the building. Testing was followed as per past reports provided by Bayonne Board of Education.

**3.0 PROCEDURES**

After determining which outlets would be sampled, McCabe personnel collected a "first draw" sample at each location. A "first draw" is the initial water that is first to come out of the tap after a period of inactivity. Following the “first draw”, a "30 second flush" sample was also collected where the main service line comes into the building. All samples were collected into 250 mL sterile bottles, labeled with a sample identification, and analyzed in accordance with EPA approved methods to determine the level of lead in drinking water. Samples were analyzed by an accredited laboratory.

The U.S. Environmental Protection Agency (EPA) has established National Primary Drinking Water Regulations (NPDWR) that set mandatory water quality standards for drinking water contaminants. These are enforceable standards called "maximum contaminant levels" or "MCL", which are established to protect the public against consumption of drinking water contaminants that present a risk to human health. An MCL is the maximum allowable amount of a contaminant in drinking water which is delivered to the consumer.

The EPA has established the Lead and Copper Rule that sets standards for state and public water systems. This rule has set an MCL for lead at 15 parts per billion (ppb) for a one liter sample. However, the EPA also established the Lead in Drinking Water at Schools and Child Care Facilities in which the EPA recommends an MCL of 20 ppb for a 250 milliliter first draw sample. In order to be more stringent, for our report purposes we have compared all results to both the 15 ppb and the 20 ppb standards.

**4.0 TABLE OF SAMPLE RESULTS**

The following table presents all sample results in order of sample identification:

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
BH-01	First Draw – Wrestling Room, Right Sink	< 0.5	Pass	Pass
BH-02	30 Second Flush – Wrestling Room, Right Sink	< 0.5	Pass	Pass
BH-03	First Draw – Weight Room Chiller	< 0.5	Pass	Pass
BH-04	First Draw – Beauty Culture Sink (To be Wrestling Room)	< 0.5	Pass	Pass
BH-05	First Draw – First Floor Watercooler by Girl’s Bathroom	< 0.5	Pass	Pass
BH-06	First Draw – Trainer Room Sink	0.5	Pass	Pass
BH-07	First Draw – Water Bottle Filling Station in Wellness Room	< 0.5	Pass	Pass
BH-08	First Draw – Room A8 Sink	1.6	Pass	Pass
BH-09	First Draw – South Gym Bottle Filling Station	< 0.5	Pass	Pass
BH-10	First Draw – In Hallway Outside Language Office Bottle Filling Station	< 0.5	Pass	Pass
BH-11	First Draw – Bottle Filling Station North Gym	< 0.5	Pass	Pass
BH-12	First Draw – Bottle Filling Station Outside Room 101	< 0.5	Pass	Pass
BH-13	First Draw – Principal’s Office Sink	2.4	Pass	Pass
BH-14	First Draw – Nurse’s Office Sink	0.8	Pass	Pass
BH-15	First Draw – Drinking Fountain Outside Room 213	0.6	Pass	Pass
BH-16	First Draw – Library Office	REMOVED		

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
BH-17	First Draw – Drinking Fountain Outside 206	0.6	Pass	Pass
BH-18	First Draw – Drinking Fountain Outside Room 201	0.8	Pass	Pass
BH-19	First Draw – Drinking Fountain Outside 314 – Left Side	0.5	Pass	Pass
BH-20	First Draw – Drinking Fountain Outside 314 – Right Side	< 0.5	Pass	Pass
BH-21	First Draw – Home Ec Sink by Door – Room 314	< 0.5	Pass	Pass
BH-22	First Draw – Home Ec Center Sink Room 314 – Right Side	0.6	Pass	Pass
BH-23	First Draw – School Store Sink	1.1	Pass	Pass
BH-24	First Draw – Cafeteria South Bottle Filling Station	< 0.5	Pass	Pass
BH – 24A	First Draw – Cafeteria North Bottle Filling Station (New Addition)	< 0.5	Pass	Pass
BH-25	First Draw – Cafeteria Kitchen Sink – Food Prep	< 0.5	Pass	Pass
BH-26	First Draw – Cafeteria Kitchen Sink – Food Prep	< 0.5	Pass	Pass
BH-27	First Draw – Drinking Fountain Outside Room 312 – Left Side	< 0.5	Pass	Pass
BH-28	First Draw – Drinking Fountain Outside Room 312 – Right Side	< 0.5	Pass	Pass
BH-29	First Draw – Drinking Fountain Outside Room 304	0.6	Pass	Pass
BH-30	First Draw – Sink in the Back of Room 304	2.2	Pass	Pass
BH-31	First Draw – Room 304 Sink	0.9	Pass	Pass

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
BH-32	First Draw – Drinking Fountain Outside 301 – Left Side	2.4	Pass	Pass
BH-33	First Draw – Drinking Fountain Outside 301 – Right Side	0.6	Pass	Pass
BH-34	First Draw – Watercooler Outside Payroll	< 0.5	Pass	Pass
BH-35	First Draw – Board Meeting Room Watercooler	0.5	Pass	Pass
BH-36	First Draw – Board Meeting Room Sink	4	Pass	Pass
BH-37	First Draw – Superintendent’s Office Kitchen Sink	0.7	Pass	Pass
BH-38	First Draw – Processing Center (Attendance Office) – Sink	1.7	Pass	Pass
BH-39	First Draw – Watercooler Outside Special Services	< 0.5	Pass	Pass
BH-40	First Draw – Special Services Watercooler	< 0.5	Pass	Pass
BH-41	First Draw – Watercooler Outside Auditorium	< 0.5	Pass	Pass
BH-42	First Draw – Drinking Fountain Outside Room 230	1.9	Pass	Pass
BH-43	First Draw – Nurse’s Office Sink at Door	1.5	Pass	Pass
BH-44	First Draw – Guidance Office Bathroom Sink	5.2	Pass	Pass
BH-45	First Draw – Teacher’s Room Sink	< 0.5	Pass	Pass
BH-46	First Draw – Dance Room in Back of Auditorium (Right)	1.8	Pass	Pass
BH-47	First Draw – Custodial Breakroom Sink	< 0.5	Pass	Pass

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
BH-48	First Draw – Bottle Filler Station Outside Student Center	< 0.5	Pass	Pass
BH-49	First Draw – Student Center Sink	< 0.5	Pass	Pass
BH-50	First Draw – Child Study Office Sink	< 0.5	Pass	Pass
BH-51	First Draw – Watercooler Outside Room 136	< 0.5	Pass	Pass
BH-52	First Draw – Watercooler Outside Room 247	< 0.5	Pass	Pass
BH-53	First Draw – Senior Café Sink	< 0.5	Pass	Pass
BH-54	First Draw – Room 5 – 355 Sink	< 0.5	Pass	Pass
BH-55	First Draw – Watercooler Outside Room 353	< 0.5	Pass	Pass
BH-56	First Draw – Bottle Filling Station Outside Room 350	< 0.5	Pass	Pass
BH-57	First Draw – Bottle Filling Station Outside Room G5	< 0.5	Pass	Pass
BH-58	First Draw – Automotive Room Sink	< 0.5	Pass	Pass
BH-59	First Draw – Life Skill’s Sink	0.6	Pass	Pass
BH-60	First Draw – Drinking Fountain Outside Room 129 – Left Side	< 0.5	Pass	Pass
BH-61	First Draw – Drinking Fountain Outside Room 129 – Right Side	< 0.5	Pass	Pass
BH-62	First Draw – Nurses Office Sink	1.7	Pass	Pass

**5.0 DISCUSSION AND CONCLUSION**

A total of sixty-two (62) samples were collected from Bayonne High School. All samples were found to be less than the EPA standards of 15 ppb and 20 ppb.

In addition, McCabe Environmental recommends annual drinking water sampling to ensure that the building’s plumbing is not having an adverse impact on water quality.

**APPENDIX A**

**LABORATORY CERTIFICATES OF ANALYSIS  
&  
SAMPLE CHAIN OF CUSTODY FORMS**



Monday, July 07, 2025

Attn: Jarred Panecki  
McCabe Environmental Services, LLC  
464 Valley Brook Avenue  
Lyndhurst, New Jersey 07071

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
SDG ID: GCT57908  
Sample ID#s: CT57908 - CT57969

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory. This report is incomplete unless all pages indicated in the pagination at the bottom of the page are included.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Sincerely yours,

A handwritten signature in black ink that reads "Phyllis Shiller". The signature is written in a cursive style.

Phyllis Shiller  
Laboratory Director

NELAC - #NY11301  
CT Lab Registration #PH-0618  
MA Lab Registration #M-CT007  
ME Lab Registration #CT-007  
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003  
NY Lab Registration #11301  
PA Lab Registration #68-03530  
RI Lab Registration #63  
VT Lab Registration #VT11301



Environmental Laboratories, Inc.  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823



## Sample Id Cross Reference

July 07, 2025

SDG I.D.: GCT57908

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION

Client Id	Lab Id	Matrix	Col Date
BH-01	CT57908	DRINKING WATER	06/20/25 7:29
BH-02	CT57909	DRINKING WATER	06/20/25 7:31
BH-03	CT57910	DRINKING WATER	06/20/25 7:33
BH-04	CT57911	DRINKING WATER	06/20/25 7:36
BH-05	CT57912	DRINKING WATER	06/20/25 7:38
BH-06	CT57913	DRINKING WATER	06/20/25 7:41
BH-07	CT57914	DRINKING WATER	06/20/25 7:42
BH-08	CT57915	DRINKING WATER	06/20/25 7:45
BH-09	CT57916	DRINKING WATER	06/20/25 7:50
BH-10	CT57917	DRINKING WATER	06/20/25 7:53
BH-11	CT57918	DRINKING WATER	06/20/25 7:55
BH-12	CT57919	DRINKING WATER	06/20/25 7:56
BH-13	CT57920	DRINKING WATER	06/20/25 7:58
BH-14	CT57921	DRINKING WATER	06/20/25 8:02
BH-15	CT57922	DRINKING WATER	06/20/25 8:03
BH-17	CT57923	DRINKING WATER	06/20/25 8:12
BH-18	CT57924	DRINKING WATER	06/20/25 8:15
BH-19	CT57925	DRINKING WATER	06/20/25 8:18
BH-20	CT57926	DRINKING WATER	06/20/25 8:18
BH-21	CT57927	DRINKING WATER	06/20/25 8:19
BH-22	CT57928	DRINKING WATER	06/20/25 8:20
BH-23	CT57929	DRINKING WATER	06/20/25 8:22
BH-24	CT57930	DRINKING WATER	06/20/25 8:23
BH-25	CT57931	DRINKING WATER	06/20/25 8:26
BH-26	CT57932	DRINKING WATER	06/20/25 8:28
BH-27	CT57933	DRINKING WATER	06/20/25 8:32
BH-28	CT57934	DRINKING WATER	06/20/25 8:33
BH-29	CT57935	DRINKING WATER	06/20/25 8:37
BH-30	CT57936	DRINKING WATER	06/20/25 8:38
BH-31	CT57937	DRINKING WATER	06/20/25 8:39



Environmental Laboratories, Inc.  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823



## Sample Id Cross Reference

July 07, 2025

SDG I.D.: GCT57908

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION

Client Id	Lab Id	Matrix	Col Date
BH-32	CT57938	DRINKING WATER	06/20/25 8:44
BH-24A	CT57939	DRINKING WATER	06/20/25 8:42
BH-33	CT57940	DRINKING WATER	06/20/25 8:45
BH-34	CT57941	DRINKING WATER	06/20/25 8:50
BH-35	CT57942	DRINKING WATER	06/20/25 8:53
BH-36	CT57943	DRINKING WATER	06/20/25 8:53
BH-37	CT57944	DRINKING WATER	06/20/25 8:59
BH-38	CT57945	DRINKING WATER	06/20/25 9:00
BH-39	CT57946	DRINKING WATER	06/20/25 9:02
BH-40	CT57947	DRINKING WATER	06/20/25 9:05
BH-41	CT57948	DRINKING WATER	06/20/25 9:07
BH-42	CT57949	DRINKING WATER	06/20/25 9:09
BH-43	CT57950	DRINKING WATER	06/20/25 9:11
BH-44	CT57951	DRINKING WATER	06/20/25 9:12
BH-45	CT57952	DRINKING WATER	06/20/25 9:15
BH-46	CT57953	DRINKING WATER	06/20/25 9:26
BH-47	CT57954	DRINKING WATER	06/20/25 9:30
BH-48	CT57955	DRINKING WATER	06/20/25 9:31
BH-49	CT57956	DRINKING WATER	06/20/25 9:32
BH-50	CT57957	DRINKING WATER	06/20/25 9:35
BH-51	CT57958	DRINKING WATER	06/20/25 9:37
BH-52	CT57959	DRINKING WATER	06/20/25 9:39
BH-53	CT57960	DRINKING WATER	06/20/25 9:42
BH-54	CT57961	DRINKING WATER	06/20/25 9:46
BH-55	CT57962	DRINKING WATER	06/20/25 9:48
BH-56	CT57963	DRINKING WATER	06/20/25 9:50
BH-57	CT57964	DRINKING WATER	06/20/25 9:53
BH-58	CT57965	DRINKING WATER	06/20/25 9:55
BH-59	CT57966	DRINKING WATER	06/20/25 9:58
BH-60	CT57967	DRINKING WATER	06/20/25 0:00



Environmental Laboratories, Inc.  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823



## Sample Id Cross Reference

July 07, 2025

SDG I.D.: GCT57908

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION

---

Client Id	Lab Id	Matrix	Col Date
BH-61	CT57968	DRINKING WATER	06/20/25 0:00
BH-62	CT57969	DRINKING WATER	06/20/25 0:00



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

7:29  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57908

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-01

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/25/25	CPP	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

7:31  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57909

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-02

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/25/25	CPP	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

7:33  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57910

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-03

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/25/25	CPP	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 07, 2025**

**Reviewed and Released by: Phyllis Shiller, Laboratory Director**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

7:36  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57911

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-04

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/25/25	CPP	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 07, 2025**

**Reviewed and Released by: Phyllis Shiller, Laboratory Director**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

7:38  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57912

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-05

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/25/25	CPP	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 07, 2025**

**Reviewed and Released by: Phyllis Shiller, Laboratory Director**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

7:41  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57913

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-06

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.5	0.5	2	ppb	15			06/25/25	CPP	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

7:42  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57914

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-07

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/25/25	CPP	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

7:45  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57915

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-08

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.6	0.5	2	ppb	15			06/25/25	CPP	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

7:50  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57916

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-09

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/25/25	CPP	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 07, 2025**

**Reviewed and Released by: Phyllis Shiller, Laboratory Director**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

7:53  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57917

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-10

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/25/25	CPP	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

7:55  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57918

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-11

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/25/25	CPP	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 07, 2025**

**Reviewed and Released by: Phyllis Shiller, Laboratory Director**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

7:56  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57919

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-12

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/25/25	CPP	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

7:58  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57920

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-13

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	2.4	0.5	2	ppb	15			06/26/25	MGH	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

8:02  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57921

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-14

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.8	0.5	2	ppb	15			06/26/25	MGH	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 07, 2025**

**Reviewed and Released by: Phyllis Shiller, Laboratory Director**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

8:03  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57922

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-15

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.6	0.5	2	ppb	15			06/25/25	CPP	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

8:12  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57923

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-17

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.6	0.5	2	ppb	15			06/25/25	CPP	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

8:15  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57924

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-18

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.8	0.5	2	ppb	15			06/25/25	CPP	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

8:18  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57925

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-19

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.5	0.5	2	ppb	15			06/26/25	MGH	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

8:18  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57926

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-20

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/26/25	MGH	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 07, 2025**

**Reviewed and Released by: Phyllis Shiller, Laboratory Director**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

8:19  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57927

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-21

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/26/25	MGH	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

8:20  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57928

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-22

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.6	0.5	2	ppb	15			06/25/25	MGH	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

8:22  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57929

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-23

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.1	0.5	2	ppb	15			06/25/25	MGH	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

8:23  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57930

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-24

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/25/25	MGH	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 07, 2025**

**Reviewed and Released by: Phyllis Shiller, Laboratory Director**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

8:26  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57931

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-25

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/25/25	MGH	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

8:28  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57932

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-26

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/25/25	MGH	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

8:32  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57933

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-27

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/25/25	MGH	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 07, 2025**

**Reviewed and Released by: Phyllis Shiller, Laboratory Director**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

8:33  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57934

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-28

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/25/25	MGH	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

8:37  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57935

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-29

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.6	0.5	2	ppb	15			06/25/25	MGH	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

8:38  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57936

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-30

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	2.2	0.5	2	ppb	15			06/25/25	MGH	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 07, 2025**

**Reviewed and Released by: Phyllis Shiller, Laboratory Director**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

8:39  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57937

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-31

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.9	0.5	2	ppb	15			06/25/25	MGH	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 07, 2025**

**Reviewed and Released by: Phyllis Shiller, Laboratory Director**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

8:44  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57938

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-32

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	2.4	0.5	2	ppb	15			06/25/25	MGH	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

8:42  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57939

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-24A

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/25/25	MGH	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

8:45  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57940

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-33

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.6	0.5	2	ppb	15			06/25/25	MGH	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

8:50  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57941

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-34

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/25/25	MGH	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

8:53  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57942

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-35

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.5	0.5	2	ppb	15			06/25/25	MGH	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

8:53  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57943

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-36

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	4	0.5	2	ppb	15			06/25/25	MGH	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

8:59  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57944

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-37

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.7	0.5	2	ppb	15			06/25/25	MGH	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

9:00  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57945

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-38

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.7	0.5	2	ppb	15			06/25/25	MGH	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

9:02  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57946

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-39

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/25/25	MGH	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 07, 2025**

**Reviewed and Released by: Phyllis Shiller, Laboratory Director**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

9:05  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57947

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-40

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/26/25	MGH	E200.8
Total Metal Digestion	Completed							06/24/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 07, 2025**

**Reviewed and Released by: Phyllis Shiller, Laboratory Director**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

9:07  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57948

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-41

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/26/25	CPP	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

9:09  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57949

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-42

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.9	0.5	2	ppb	15			06/26/25	CPP	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

9:11  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57950

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-43

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.5	0.5	2	ppb	15			06/26/25	CPP	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

9:12  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57951

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-44

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	5.2	0.5	2	ppb	15			06/26/25	CPP	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

9:15  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57952

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-45

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/26/25	CPP	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

9:26  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57953

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-46

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.8	0.5	2	ppb	15			06/26/25	CPP	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

9:30  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57954

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-47

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/26/25	CPP	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 07, 2025**

**Reviewed and Released by: Phyllis Shiller, Laboratory Director**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

9:31  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57955

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-48

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/26/25	CPP	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 07, 2025**

**Reviewed and Released by: Phyllis Shiller, Laboratory Director**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

9:32  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57956

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-49

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/26/25	CPP	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

9:35  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57957

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-50

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/26/25	CPP	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

9:37  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57958

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-51

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/26/25	CPP	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

9:39  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57959

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-52

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/27/25	MGH	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 07, 2025**

**Reviewed and Released by: Phyllis Shiller, Laboratory Director**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

9:42  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57960

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-53

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/27/25	MGH	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

9:46  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57961

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-54

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/27/25	MGH	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

9:48  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57962

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-55

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/27/25	MGH	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 07, 2025**

**Reviewed and Released by: Phyllis Shiller, Laboratory Director**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

9:50  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57963

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-56

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/27/25	MGH	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 07, 2025**

**Reviewed and Released by: Phyllis Shiller, Laboratory Director**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

9:53  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57964

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-57

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/27/25	MGH	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 07, 2025**

**Reviewed and Released by: Phyllis Shiller, Laboratory Director**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

9:55  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57965

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-58

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/27/25	MGH	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

9:58  
 16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57966

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-59

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.6	0.5	2	ppb	15			06/30/25	CPP	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57967

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-60

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/27/25	MGH	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57968

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-61

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/26/25	CPP	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 07, 2025**

**Reviewed and Released by: Phyllis Shiller, Laboratory Director**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 07, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

16:20

## Laboratory Data

SDG ID: GCT57908  
 Phoenix ID: CT57969

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: BH-62

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.7	0.5	2	ppb	15			06/26/25	CPP	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 07, 2025

Reviewed and Released by: Phyllis Shiller, Laboratory Director

# Analysis Report - Summary

July 07, 2025

Attn: Jarred Panecki  
McCabe Environmental Services, LLC  
464 Valley Brook Avenue  
Lyndhurst, New Jersey 07071



Environmental Laboratories, Inc.  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823

SDG I.D.: GCT57908



Sample	Client Id	Col Date	Parameter	Result	RL	Units	Date Analyzed	Reference
Project: 25-05225 Bayonne Board Of Education								
CT57908	BH-01	06/20/25	Lead	< 0.5	0.5	ppb	06/25/25	E200.8
CT57909	BH-02	06/20/25	Lead	< 0.5	0.5	ppb	06/25/25	E200.8
CT57910	BH-03	06/20/25	Lead	< 0.5	0.5	ppb	06/25/25	E200.8
CT57911	BH-04	06/20/25	Lead	< 0.5	0.5	ppb	06/25/25	E200.8
CT57912	BH-05	06/20/25	Lead	< 0.5	0.5	ppb	06/25/25	E200.8
CT57913	BH-06	06/20/25	Lead	0.5	0.5	ppb	06/25/25	E200.8
CT57914	BH-07	06/20/25	Lead	< 0.5	0.5	ppb	06/25/25	E200.8
CT57915	BH-08	06/20/25	Lead	1.6	0.5	ppb	06/25/25	E200.8
CT57916	BH-09	06/20/25	Lead	< 0.5	0.5	ppb	06/25/25	E200.8
CT57917	BH-10	06/20/25	Lead	< 0.5	0.5	ppb	06/25/25	E200.8
CT57918	BH-11	06/20/25	Lead	< 0.5	0.5	ppb	06/25/25	E200.8
CT57919	BH-12	06/20/25	Lead	< 0.5	0.5	ppb	06/25/25	E200.8
CT57920	BH-13	06/20/25	Lead	2.4	0.5	ppb	06/26/25	E200.8
CT57921	BH-14	06/20/25	Lead	0.8	0.5	ppb	06/26/25	E200.8
CT57922	BH-15	06/20/25	Lead	0.6	0.5	ppb	06/25/25	E200.8
CT57923	BH-17	06/20/25	Lead	0.6	0.5	ppb	06/25/25	E200.8
CT57924	BH-18	06/20/25	Lead	0.8	0.5	ppb	06/25/25	E200.8
CT57925	BH-19	06/20/25	Lead	0.5	0.5	ppb	06/26/25	E200.8
CT57926	BH-20	06/20/25	Lead	< 0.5	0.5	ppb	06/26/25	E200.8
CT57927	BH-21	06/20/25	Lead	< 0.5	0.5	ppb	06/26/25	E200.8
CT57928	BH-22	06/20/25	Lead	0.6	0.5	ppb	06/25/25	E200.8
CT57929	BH-23	06/20/25	Lead	1.1	0.5	ppb	06/25/25	E200.8
CT57930	BH-24	06/20/25	Lead	< 0.5	0.5	ppb	06/25/25	E200.8
CT57931	BH-25	06/20/25	Lead	< 0.5	0.5	ppb	06/25/25	E200.8
CT57932	BH-26	06/20/25	Lead	< 0.5	0.5	ppb	06/25/25	E200.8

Sample	Client Id	Col Date	Parameter	Result	RL	Units	Date Analyzed	Reference
CT57933	BH-27	06/20/25	Lead	< 0.5	0.5	ppb	06/25/25	E200.8
CT57934	BH-28	06/20/25	Lead	< 0.5	0.5	ppb	06/25/25	E200.8
CT57935	BH-29	06/20/25	Lead	0.6	0.5	ppb	06/25/25	E200.8
CT57936	BH-30	06/20/25	Lead	2.2	0.5	ppb	06/25/25	E200.8
CT57937	BH-31	06/20/25	Lead	0.9	0.5	ppb	06/25/25	E200.8
CT57938	BH-32	06/20/25	Lead	2.4	0.5	ppb	06/25/25	E200.8
CT57939	BH-24A	06/20/25	Lead	< 0.5	0.5	ppb	06/25/25	E200.8
CT57940	BH-33	06/20/25	Lead	0.6	0.5	ppb	06/25/25	E200.8
CT57941	BH-34	06/20/25	Lead	< 0.5	0.5	ppb	06/25/25	E200.8
CT57942	BH-35	06/20/25	Lead	0.5	0.5	ppb	06/25/25	E200.8
CT57943	BH-36	06/20/25	Lead	4	0.5	ppb	06/25/25	E200.8
CT57944	BH-37	06/20/25	Lead	0.7	0.5	ppb	06/25/25	E200.8
CT57945	BH-38	06/20/25	Lead	1.7	0.5	ppb	06/25/25	E200.8
CT57946	BH-39	06/20/25	Lead	< 0.5	0.5	ppb	06/25/25	E200.8
CT57947	BH-40	06/20/25	Lead	< 0.5	0.5	ppb	06/26/25	E200.8
CT57948	BH-41	06/20/25	Lead	< 0.5	0.5	ppb	06/26/25	E200.8
CT57949	BH-42	06/20/25	Lead	1.9	0.5	ppb	06/26/25	E200.8
CT57950	BH-43	06/20/25	Lead	1.5	0.5	ppb	06/26/25	E200.8
CT57951	BH-44	06/20/25	Lead	5.2	0.5	ppb	06/26/25	E200.8
CT57952	BH-45	06/20/25	Lead	< 0.5	0.5	ppb	06/26/25	E200.8
CT57953	BH-46	06/20/25	Lead	1.8	0.5	ppb	06/26/25	E200.8
CT57954	BH-47	06/20/25	Lead	< 0.5	0.5	ppb	06/26/25	E200.8
CT57955	BH-48	06/20/25	Lead	< 0.5	0.5	ppb	06/26/25	E200.8
CT57956	BH-49	06/20/25	Lead	< 0.5	0.5	ppb	06/26/25	E200.8
CT57957	BH-50	06/20/25	Lead	< 0.5	0.5	ppb	06/26/25	E200.8
CT57958	BH-51	06/20/25	Lead	< 0.5	0.5	ppb	06/26/25	E200.8
CT57959	BH-52	06/20/25	Lead	< 0.5	0.5	ppb	06/27/25	E200.8
CT57960	BH-53	06/20/25	Lead	< 0.5	0.5	ppb	06/27/25	E200.8
CT57961	BH-54	06/20/25	Lead	< 0.5	0.5	ppb	06/27/25	E200.8
CT57962	BH-55	06/20/25	Lead	< 0.5	0.5	ppb	06/27/25	E200.8
CT57963	BH-56	06/20/25	Lead	< 0.5	0.5	ppb	06/27/25	E200.8
CT57964	BH-57	06/20/25	Lead	< 0.5	0.5	ppb	06/27/25	E200.8
CT57965	BH-58	06/20/25	Lead	< 0.5	0.5	ppb	06/27/25	E200.8
CT57966	BH-59	06/20/25	Lead	0.6	0.5	ppb	06/30/25	E200.8

Sample	Client Id	Col Date	Parameter	Result	RL	Units	Date Analyzed	Reference
CT57967	BH-60	06/20/25	Lead	< 0.5	0.5	ppb	06/27/25	E200.8
CT57968	BH-61	06/20/25	Lead	< 0.5	0.5	ppb	06/26/25	E200.8
CT57969	BH-62	06/20/25	Lead	1.7	0.5	ppb	06/26/25	E200.8

Comments:

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 ND=Not detected BDL=Below Detection Level RL=Reporting Level CL=Client Limit

  
 Phyllis Shiller  
 Laboratory Director  
 July 07, 2025



Environmental Laboratories, Inc.  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102



# QA/QC Report

July 07, 2025

## QA/QC Data

SDG I.D.: GCT57908

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
QA/QC Batch 790473 (mg/L), QC Sample No: CT57908 (CT57908, CT57909, CT57910, CT57911, CT57912, CT57913, CT57914, CT57915, CT57916, CT57917)													
<u>ICP MS Metals - Aqueous</u>													
Lead	BRL	0.0001	<0.0005	<0.0001	NC	103						92.0	
QA/QC Batch 790473A (mg/L), QC Sample No: CT57918 (CT57918, CT57919, CT57920, CT57921, CT57922, CT57923, CT57924, CT57925, CT57926, CT57927)													
<u>ICP MS Metals - Aqueous</u>													
Lead	BRL	0.0001				103						92.8	
Comment: This batch does not include a duplicate.													
QA/QC Batch 790474 (mg/L), QC Sample No: CT57928 (CT57928, CT57929, CT57930, CT57931, CT57932, CT57933, CT57934, CT57935, CT57936, CT57937)													
<u>ICP MS Metals - Aqueous</u>													
Lead	BRL	0.0010	0.0006	0.0006	NC	106						92.0	
QA/QC Batch 790474A (mg/L), QC Sample No: CT57938 (CT57938, CT57939, CT57940, CT57941, CT57942, CT57943, CT57944, CT57945, CT57946, CT57947)													
<u>ICP MS Metals - Aqueous</u>													
Lead	BRL	0.0010				106						88.4	
Comment: This batch does not include a duplicate.													
QA/QC Batch 790692 (mg/L), QC Sample No: CT57948 (CT57948, CT57949, CT57950, CT57951, CT57952, CT57953, CT57954, CT57955, CT57956, CT57957)													
<u>ICP MS Metals - Aqueous</u>													
Lead	BRL	0.0001	<0.0005	<0.0001	NC	98.4						92.8	
QA/QC Batch 790692A (mg/L), QC Sample No: CT57958 (CT57958, CT57959, CT57960, CT57961, CT57962, CT57963, CT57964, CT57965, CT57966, CT57967)													
<u>ICP MS Metals - Aqueous</u>													
Lead	BRL	0.0001				98.4						96.6	
Comment: This batch does not include a duplicate.													
QA/QC Batch 790693 (mg/L), QC Sample No: CT57968 (CT57968, CT57969)													
<u>ICP MS Metals - Aqueous</u>													
Lead	BRL	0.0001	<0.0005	0.0001	NC	107						96.4	

# QA/QC Data

SDG I.D.: GCT57908

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	-------	-----------	------------------	---------------	------------	----------	-----------	------------	---------	----------	-----------	--------------------	--------------------

---

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Intf - Interference
- (ISO) - Isotope Dilution

  
Phyllis Shiller, Laboratory Director  
July 07, 2025

Monday, July 07, 2025

Criteria: NJ: DW

State: NJ

# Sample Criteria Exceedances Report

GCT57908 - MCCABE-PB

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
--------	-------	-----------------	----------	--------	----	----------	----------------	-------------------

\*\*\* No Data to Display \*\*\*

Phoenix Laboratories does not assume responsibility for the data contained in this exceedance report. It is provided as an additional tool to identify requested criteria exceedences. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedence information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



**Environmental Laboratories, Inc.**  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823



## Analysis Comments

July 07, 2025

SDG I.D.: GCT57908

---

The following analysis comments are made regarding exceptions to criteria not already noted in the Analysis Report or QA/QC Report: None.

MCCABE ENVIRONMENTAL SERVICES, L.L.C.  
 464 VALLEY BROOK AVENUE LYNDBURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD in DRINKING WATER  
 CHAIN-OF-CUSTODY FORM

CLIENT NAME: Bayonne Board of Education  
 SITE ADDRESS: Bayonne High School  
 669 Avenue A, Bayonne, NJ 07002

FIELD INSPECTOR'S NAME: A. Lezama & G. Clark  
 TURNAROUND TIME REQUESTED: 2-Week  
 MES PROJECT #: 25-05225  
 SAMPLE DATE: 6/20/25

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW	BH-01	First draw - Wrestling Room Right sink	7:29 AM	LEAD - 200.8
DW	BH-02	30 second flush - Wrestling Room Right Sink	7:31 AM	LEAD - 200.8
DW	BH-03	First draw - weight room chiller	7:33 AM	LEAD - 200.8
DW	BH-04	First draw - beauty & culture sink (TO BE WRESTLING ROOM)	7:36 AM	LEAD - 200.8
DW	BH-05	First draw - 1st floor water cooler by girls bathroom	7:38 AM	LEAD - 200.8
DW	BH-06	First draw - Trainer Room Sink	7:41 AM	LEAD - 200.8
DW	BH-07	First draw - First draw - Water Bottle filling station - Wellness Room	7:42 AM	LEAD - 200.8
DW	BH-08	First draw - Room 48 Sink	7:45 AM	LEAD - 200.8
DW	BH-09	First draw - South gym Bottle Filling Station	7:50 AM	LEAD - 200.8
DW	BH-10	First draw - In Hallway outside Language office filling station	7:53 AM	LEAD - 200.8

Relinquished by (Print) Gary Clare  
 Date: 6/23/25 Time: 10:15  
 Signature: [Signature]  
 Received by: (Print) J. Demers  
 Signature: [Signature]  
 Date: 8-23-2025 Time: 10:15

Relinquished by (Print) [Signature]  
 Date: [ ] Time: [ ]  
 Signature: [Signature]  
 Received by: (Print) Abby Lee  
 Signature: [Signature]  
 Date: 6/23/25 Time: 16:20

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

2.2°C WCI P

MCCABE ENVIRONMENTAL SERVICES, L.L.C.  
 464 VALLEY BROOK AVENUE LYNDBURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD in DRINKING WATER  
 CHAIN-OF-CUSTODY FORM

CLIENT NAME: Bayonne Board of Education		SITE ADDRESS: Bayonne High School 669 Avenue A, Bayonne, NJ 07002		
FIELD INSPECTOR'S NAME: A. Legama & G. Clare		TURNAROUND TIME REQUESTED: 2-Week		
MES PROJECT #: 25-05225		SAMPLE DATE: 6/20/25		
Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW	BH-11	First draw - Bottle filling station North Gym	7:55 AM	LEAD - 200.8
DW	BH-12	First draw - Bottle filling station outside Room 101	7:56 AM	LEAD - 200.8
DW	BH-13	First draw - Principal's office sink	7:58 AM	LEAD - 200.8
DW	BH-14	First draw - Nurses office sink	8:02 AM	LEAD - 200.8
DW	BH-15	First draw - drinking fountain outside 213	8:05 AM	LEAD - 200.8
DW	<del>BH-16</del>	<del>First draw - library office sink</del>		<del>LEAD - 200.8</del>
DW	BH-17	First draw - Drinking fountain outside 206	8:12 AM	LEAD - 200.8
DW	BH-18	First draw - Drinking fountain outside 201	8:15 AM	LEAD - 200.8
DW	BH-19	First draw - Drinking fountain outside 314-left	8:18 AM	LEAD - 200.8
DW	BH-20	First draw - Drinking fountain outside 314-Right	8:18 AM	LEAD - 200.8
Relinquished by (Print) Gary Clare		Received by: (Print) J. Demers	Date: 8/23	Time: 1015
Signature: <i>[Signature]</i>		Signature: <i>[Signature]</i>	Date: 8/25	Time: 1015
Relinquished by (Print)		Received by: (Print) Abby Lee	Date: 10/23/25	Time: 1020
Signature: <i>[Signature]</i>		Signature: <i>[Signature]</i>		
Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories				

57918  
57919  
57920  
57921  
57922

57923  
57924  
57925  
57926

MCCABE ENVIRONMENTAL SERVICES, L.L.C.  
 464 VALLEY BROOK AVENUE LYNDBURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD in DRINKING WATER  
 CHAIN-OF-CUSTODY FORM

CLIENT NAME: Bayonne Board of Education

SITE ADDRESS: Bayonne High School  
 669 Avenue A, Bayonne, NJ 07002

TURNAROUND TIME REQUESTED: 2-Week

FIELD INSPECTOR'S NAME: A. Velazquez & G. Clark

MES PROJECT #: 25-05225 SAMPLE DATE: 6/20/25

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED	
DW	BH-21	First draw - Home ec sink by door - Rm. 314 center	8:19 AM	LEAD - 200.8	57927
DW	BH-22	First draw - Home ec sink - Right - Rm 314	8:20 AM	LEAD - 200.8	57928
DW	BH-23	First draw - School store sink	8:22 AM	LEAD - 200.8	57929
DW	BH-24	First draw - Cafeteria South Bottle Filling station	8:23 AM	LEAD - 200.8	57930
DW	BH-25	First draw - Cafeteria Kitchen Sink - <del>Hand Wash</del> Food prep	8:26 AM	LEAD - 200.8	57931
DW	BH-26	First draw - Cafeteria Kitchen Sink - <del>Hand Wash</del> Food prep	8:28 AM	LEAD - 200.8	57932
DW	BH-27	First draw - Drinking fountain outside Room 312 - Left	8:32 AM	LEAD - 200.8	57933
DW	BH-28	First draw - Drinking fountain outside Room 312 - Right	8:33 AM	LEAD - 200.8	57934
DW	BH-29	First draw - Drinking fountain outside Room 304	8:37 AM	LEAD - 200.8	57935
DW	BH-30	First draw - Drinking fountain in back of 304	8:38 AM	LEAD - 200.8	57936

Relinquished by (Print) Gary Clark

Signature: *GA* Date: 6/23/25 Time: 10:15

Relinquished by (Print)

Signature: *AL* Date: 6/23/25 Time: 10:20

Received by: (Print) J Demers

Signature: *JD*

Received by: (Print) Abby Lee

Signature: *AL*

Received by: (Print) Abby Lee

Signature: *AL*

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

MCCABE ENVIRONMENTAL SERVICES, L.L.C.

464 VALLEY BROOK AVENUE LYNDBURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD in DRINKING WATER  
CHAIN-OF-CUSTODY FORM

CLIENT NAME: Bayonne Board of Education		SITE ADDRESS: Bayonne High School 669 Avenue A, Bayonne, NJ 07002	
FIELD INSPECTOR'S NAME: A. Letourneau & G. Clare		TURNAROUND TIME REQUESTED: 2-Week	
MES PROJECT #: 25-05225	SAMPLE DATE: 6/20/25		
Matrix	SAMPLE ID	SAMPLE LOCATION	ANALYSIS REQUESTED
DW	BH-31	First draw - Room 304 sink	LEAD - 200.8
DW	BH-32	First draw - Drinking fountain outside 200-Left (New location)	LEAD - 200.8
DW	BH-24A	First draw - Cafeteria North Bottle filling station	LEAD - 200.8
DW	BH-33	First draw - Drinking fountain Water cooler outside 300-Right	LEAD - 200.8
DW	BH-34	First draw - Water cooler outside payroll	LEAD - 200.8
DW	BH-35	First draw - Board meeting room water cooler	LEAD - 200.8
DW	BH-36	First draw - Board meeting room sink	LEAD - 200.8
DW	BH-37	First draw - Superintendents Office - Kitchen sink	LEAD - 200.8
DW	BH-38	First draw - Processing Center (Attendance office) - Sink	LEAD - 200.8
DW	BH-39	First draw - Water cooler outside special services	LEAD - 200.8
Relinquished by (Print) Gary Clare		Received by: (Print) J. Deppers	Date: 8-23-2025
Signature: <i>GC</i>		Signature: <i>JD</i>	Time: 1015
Relinquished by (Print)		Received by: (Print) Abby Lee	Date: 6/23/25
Signature: <i>AL</i>		Signature: <i>Abby Lee</i>	Time: 1620
Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories			

MCCABE ENVIRONMENTAL SERVICES, L.L.C.  
 464 VALLEY BROOK AVENUE LYNDBURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD in DRINKING WATER  
 CHAIN-OF-CUSTODY FORM

CLIENT NAME: Bayonne Board of Education  
 SITE ADDRESS: Bayonne High School  
 669 Avenue A, Bayonne, NJ 07002

FIELD INSPECTOR'S NAME:  
 MES PROJECT #: 25-05225  
 SAMPLE DATE: 6/20/25  
 TURNAROUND TIME REQUESTED: 2-Week

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED	
DW	BH-40	First draw - Special services water cooler	9:05 am	LEAD - 200.8	57947
DW	BH-41	First draw - Water cooler outside auditorium	9:07 am	LEAD - 200.8	57948
DW	BH-42	FD - Drinking fountain outside 230	9:09 am	LEAD - 200.8	57949
DW	BH-43	FD - Nurses office sink at door	9:11 am	LEAD - 200.8	57950
DW	BH-44	FD - <del>Guidance Office</del> <sup>Guidance Office</sup> Bathroom Sink	9:12 am	LEAD - 200.8	57951
DW	BH-45	FD - Teachers Rm - <del>outside</del> Sink	9:15 am	LEAD - 200.8	57952
DW	BH-46	FD - Dance Room in back of Auditorium (Right)	9:26 am	LEAD - 200.8	57953
DW	BH-47	FD - Custodial Breakroom Sink	9:30 am	LEAD - 200.8	57954
DW	BH-48	FD - Bottle Filler outside Student Center	9:31 am	LEAD - 200.8	57955
DW	BH-49	FD - Student Center Sink	9:32 am	LEAD - 200.8	57956

Relinquished by (Print) Gary Clare  
 Date: 6/23/25 Time: 10:15  
 Signature: *GA*  
 Received by (Print) D. Demers  
 Signature: *DD*  
 Date: 8-23-2025 Time: 10:15

Relinquished by (Print)  
 Date:  
 Signature:  
 Received by (Print) Abby Lee  
 Signature: *Abby Lee*  
 Date: 6/23/25 Time: 10:20

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

a.g.c w.c.i.p

MCCABE ENVIRONMENTAL SERVICES, L.L.C.  
 464 VALLEY BROOK AVENUE LYNDBURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD in DRINKING WATER  
 CHAIN-OF-CUSTODY FORM

CLIENT NAME: Bayonne Board of Education  
 SITE ADDRESS: Bayonne High School  
 669 Avenue A, Bayonne, NJ 07002

FIELD INSPECTOR'S NAME: Gary Clare + Arlitzky Lezama  
 TURNAROUND TIME REQUESTED: 2-Week  
 MES PROJECT #: 25-05225  
 SAMPLE DATE: 6/20/25

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW	BH-50	FD - Child Study Office Sink	9:35 am	LEAD - 200.8
DW	BH-51	FD - Water Cooler outside Room 136	9:37 am	LEAD - 200.8
DW	BH-52	FD - Water Cooler Outside Room 247	9:39 am	LEAD - 200.8
DW	BH-53	FD - Senior Cafe Sink	9:42 am	LEAD - 200.8
DW	BH-54	FD - Room 5-355 Sink	9:46 am	LEAD - 200.8
DW	BH-55	FD - Water Cooler outside Room 353	9:48 am	LEAD - 200.8
DW	BH-56	FD - Water Cooler outside Room 350	9:50 am	LEAD - 200.8
DW	BH-57	FD - Bottle Filling Station Outside 65	9:53 am	LEAD - 200.8
DW	BH-58	FD - <del>Sink</del> Automotive Room Sink	9:55 am	LEAD - 200.8
DW	BH-59	FD - Life Skills Sink	9:58 am	LEAD - 200.8

Relinquished by (Print) Gary Clare	Received by: (Print) S Demers	Date: 8-23 1015
Signature:	Signature:	Date: 8/23/25
Relinquished by (Print)	Received by: (Print) Abby Lee	Date: 6/23/25 1620
Signature:	Signature:	Date: 6/23/25 1620

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

NJ Certified WBE

2.2 WCIP

**MCCABE ENVIRONMENTAL SERVICES, L.L.C.**

464 VALLEY BROOK AVENUE LYNDBURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

**LEAD in DRINKING WATER  
CHAIN-OF-CUSTODY FORM**

CLIENT NAME: Bayonne Board of Education  
 SITE ADDRESS: Bayonne High School  
 669 Avenue A, Bayonne, NJ 07002  
 FIELD INSPECTOR'S NAME:  
 TURNAROUND TIME REQUESTED: 2-Week  
 MES PROJECT #: 25-05225 SAMPLE DATE:

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW	BH-60	FD - Drinking fountain Outside Rm 129-Left		LEAD - 200.8
DW	BH-61	FD - Drinking fountain Outside Rm 129-Right		LEAD - 200.8
DW	BH-62	FD - Nurses Office Sink		LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8

57967  
57968  
57969

Relinquished by (Print) Gay Clare  
 Signature: *GC* Date: 6/23/25 Time: 10/15  
 Received by (Print) J. Deppers  
 Signature: *JD* Date: 8-23-2025 Time: 7:15  
 Relinquished by (Print) *MS*  
 Signature: *MS* Date: 6/23/25 Time: 16:20  
 Received by (Print) Abby Lee  
 Signature: *Abby Lee* Date: 6/23/25 Time: 16:20

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

NJ Certified WBE

**APPENDIX B**

**SCHOOL DISTRICT SAMPLING  
ATTACHMENTS**

## Attachment A - List of Priority for Sampling

SCHOOL NAME	DATE OF SAMPLING	CERTIFIED LABORATORY	NOTES
Bayonne High School	06/20/2025	Phoenix Environmental Laboratories Inc.	

## Attachment B – Plumbing Profile

**Note:** Complete for each school. For additional information see the USEPA publication, "The 3Ts for Reducing Lead in Drinking Water in Schools"

Name of School: Bayonne High School Grade Levels: 9-12

Address: 669 Ave. A, Bayonne, NJ 07002

Individual school project officer Signature: *Scott Nelson* Date: 8/5/2025

Questions	Answers
<b>Background Information</b>	
1. What year was the original building constructed? Were any buildings or additions added to the original facility?	Annex built in 1923 / Main Building in 1935 / Vocational wing built in 1986
2. If the building was constructed or repaired after 1986, was lead-free plumbing and solder utilized? What type of solder was used? Document all locations where lead solder was used.	Any repairs made after 1986 were done using lead free solder
3. Where are the most recent plumbing repairs and replacements?	Location: six girls lavatories, five science labs, main gym, cafe, corridors, Supt. kitchen, 2 trainer rooms Description: upgrade girls lavatories upgrade science labs, replace water fountains with bottle filling stations, sink replace sink faucet
4. With what materials is the service connection (the pipe that carries water to the school from the public water system's main in the street) made? Where is the Service Line located? (This is the POE location.)	Material: 1- Annex - duct iron 2 - Main duct iron 3 - vocational wing duct iron Location: 1- boiler room 2 - telephone equipment room 3 - mechanical room
5. Is there point of entry (POE) or point of use (POU) treatment in use?	Y / N No treatment of water at Type: POE. City water comes treated Location: 1-Annex - 1923 building 2 - main - 1935 3 - Vocational wing - 1983

Questions	Answers
6. Are there tanks in your plumbing system (pressure tanks, gravity storage tanks)?	Y / N Y - Mainbuilding has a 3,000 gallon hot water storage tank (pump rm) Y - Main building basement (girls locker rm) has a 40 gallon hot water storage tank Y-Voc. building has a 100 gallon hot water storage tank (boiler rm)
7. Does the school have a filter maintenance and operation program? If so, who is responsible for this program? What is the process for adding filters?	Yes, Scott Nolan, Andy McCabe, Vinny Caiola, change filters on an as needed basis assign plumbers
8. Have accessible screens or aerators on outlets that provide drinking water been cleaned? Does the school have a screen or aerator maintenance program?	Y / N No - After testing is complete district will set up a routine maintenance program to clean screens
9. Have there been any complaints about bad (metallic) taste? Note location(s).	Y / N No Location:
10. Review records and consult with the public water supplier to determine whether any water samples have been taken in the building for any contaminants. If so, identify: <ul style="list-style-type: none"> <li>• Name of contaminant(s)</li> <li>• Concentrations found</li> <li>• pH level</li> </ul> Is testing done regularly at the building?	No indoor testing by public water supplier
11. Other plumbing background questions include: <ul style="list-style-type: none"> <li>• Are blueprints of the building available?</li> <li>• Are there known plumbing "dead-ends", low use areas, existing leaks or other "problem areas"?</li> </ul> Are renovations planned for any of the plumbing system?	Not all prints are available No dead-end low use areas All leaks were identified during walk through and have been repaired No plumbing system renovations planned

Questions	Answers				
<p><b>Walk-Through</b>  <i>These questions should be addressed during the walk-through of the facility, while Attachment C- Drinking Water Outlet Inventory is being completed.</i></p>					
1. Confirm the material of Service Line visually.	Duct iron				
2. Confirm the presence of POE or POU treatment.	No POE or POU treatment				
<p>3. What are the potable water pipes made of in your facility?</p> <ul style="list-style-type: none"> <li>• Lead</li> <li>• Plastic</li> <li>• Galvanized Metal</li> <li>• Cast Iron</li> <li>• Copper</li> <li>• Other</li> </ul> <p>Note the water flow through the building and the areas that receive water first, and which areas receive water last.</p>	<p>Copper Galvanized metal Brass</p> <p>Water flow through the building shown on the prints</p>				
4. Are electrical wires grounded to Water Pipes? Note location(s).	<table border="1" style="width: 100%;"> <tr> <td style="width: 50%; text-align: center;">Y / N</td> <td style="width: 50%; text-align: center;">NO</td> </tr> <tr> <td colspan="2">Location:</td> </tr> </table>	Y / N	NO	Location:	
Y / N	NO				
Location:					
5. Are brass fittings, faucets, or valves used in your drinking water system? Note that most faucets are brass on the inside. Document the locations of any brass water outlet to be sampled.	Complete in "Brass" Column in Attachment C- Water Outlet Inventory. Yes See Attachment C				
6. Locate all drinking water outlets (i.e. water coolers, bubblers, ice machines, kitchen/ food prep sinks, etc.) in the facility.	Complete in Attachment C-Water Outlet Inventory. See Attachment C				

<b>Questions</b>	<b>Answers</b>	
<p>7. Have the brands and models of the water coolers in the school been compared to the list of recalled water coolers in the Toolkit?  Recalled Drinking Water Fountains  Make and Model</p>	<p>Y / N  YES, All water coolers have checked and compared to the list of recalled water coolers  None on the list of recalled water coolers</p>	
<p>8. Have signs of corrosion, such as frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry been detected?  Note the locations of water outlets.</p>	<p>Type  Complete in "Signs of Corrosion" column in Attachment C- Drinking Water Outlet Inventory. See in Attachment C</p>	
<p>9. Are there any outlets that are not operational and therefore out of service? Permanently? Temporarily?</p> <p style="text-align: center;">Permanently</p> <p style="text-align: center;">Temporarily</p>	<p>Y / N  Complete "Operational Column" in Attachment C- Drinking Water Outlet Inventory.  Type/ Location</p>	<p>No  Description</p>

## Attachment C – Drinking Water Outlet Inventory

Name of School: Bayonne High School

Address: 669 Avenue A, Bayonne, New Jersey 07002

Grade Levels: High School Year School Constructed: Unknown Renovated/Additions: NA

Individual School Project Officer: Scott Nolan

Date Completed: 07/24/2025

# <sup>1</sup>	Type	Location	Code	Operational <sup>2</sup> (Y/N)	Signs of Corrosion <sup>3</sup> (Y/N)	Filter <sup>4</sup> (Y/N)	Brass Fittings, Faucets or valves? (Y/N)	Aerator/ Screen (Y/N)	Motion Activated (Y/N)	Chiller (Y/N)	Water Cooler		Comments
											Make	Model	
01	Sink	Wrestling Room Right Sink	BH-01	Y	N	Y	N	N	N	N	NA	NA	
02	Sink	Wrestling Room Right Sink	BH-02	Y	N	Y	N	N	N	N	NA	NA	Flush
03	Chiller	Weight Room	BH-03	Y	N	Y	N	N	Y	Y	NA	NA	
04	Sink	Beauty Culture (to be Wrestling Room)	BH-04	Y	N	N	N	Y	N	N	NA	NA	
05	Watercooler	First Floor by Girl's Bathroom	BH-05	Y	N	Y	N	N	Y	Y	NA	NA	
06	Sink	Trainer Room Sink	BH-06	Y	N	Y	N	N	N	N	NA	NA	

<sup>1</sup> Number outlets starting at the closest outlet to the Point of Entry (POE).

<sup>2</sup> Document if permanently or temporarily out of service on the Attachment B- Plumbing Profile.

<sup>3</sup> Signs of corrosion detected, such as but not limited to frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry.

<sup>4</sup> Document on Attachment D- Filter Inventory.

07	Water Bottle Filling Station	Wellness Room	BH-07	Y	N	Y	N	N	Y	Y	NA	NA	
08	Sink	Room A8	BH-08	Y	N	N	N	N	N	N	NA	NA	
09	Bottle Filling Station	South Gym	BH-09	Y	N	Y	N	N	Y	Y	NA	NA	
10	Bottle Filling Station	Outside Language Office	BH-10	Y	N	Y	N	N	Y	Y	NA	NA	
11	Bottle Filling Station	North Gym	BH-11	Y	N	Y	N	N	Y	Y	NA	NA	
12	Bottle Filling Station	Outside Room 101	BH-12	Y	N	Y	N	N	Y	Y	NA	NA	
13	Sink	Principal's Office	BH-13	Y	N	Y	N	Y	N	N	NA	NA	
14	Sink	Nurse's Office	BH-14	Y	N	Y	N	Y	N	N	NA	NA	
15	Drinking Fountain	Outside Room 213	BH-15	Y	N	Y	N	N	N	Y	NA	NA	
16	Sink	Library Office	BH-16	N	N	N	N	N	N	N	NA	NA	REMOVED
17	Drinking Fountain	Outside Room 206	BH-17	Y	N	N	N	N	N	N	NA	NA	
18	Drinking Fountain	Outside Room 201	BH-18	Y	N	N	N	N	N	N	NA	NA	
19	Drinking Fountain	Outside 314 Left Side	BH-19	Y	N	Y	N	N	N	N	NA	NA	
20	Drinking Fountain	Outside 314, Right Side	BH-20	Y	N	Y	N	N	N	N	NA	NA	
21	Sink	Room 314 Sink by Door	BH-21	Y	N	N	N	Y	N	N	NA	NA	
22	Sink	Room 314 Middle Sink, Right Side	BH-22	Y	N	N	N	N	N	N	NA	NA	
23	Sink	School Store	BH-23	Y	N	N	N	N	N	N	NA	NA	
24	Bottle Filling	Cafeteria South	BH-24	Y	N	Y	N	N	Y	Y	NA	NA	

	Station												
24 -A	Bottle Filling Station	Cafeteria North	BH-24-A	Y	N	Y	N	N	Y	Y	NA	NA	
25	Sink	Cafeteria Kitchen Sink, Food Prep	BH-25	Y	N	Y	N	N	N	N	NA	NA	
26	Sink	Cafeteria Kitchen Sink, Food Prep	BH-26	Y	N	Y	N	N	N	N	NA	NA	
27	Drinking Fountain	Outside Room 312, Left Side	BH-27	Y	N	N	N	N	N	N	NA	NA	
28	Drinking Fountain	Outside Room 312, Right Side	BH-28	Y	N	N	N	N	N	N	NA	NA	
29	Drinking Fountain	Outside Room 304	BH-29	Y	N	N	N	N	N	N	NA	NA	
30	Drinking Fountain	The Back of Room 304	BH-30	Y	N	N	N	Y	N	N	NA	NA	
31	Sink	Room 304	BH-31	Y	N	N	N	Y	N	N	NA	NA	
32	Drinking Fountain	Outside 301, Left Side	BH-32	Y	N	N	N	N	N	N	NA	NA	
33	Drinking Fountain	Outside 301, Right Side	BH-33	Y	N	N	N	N	N	N	NA	NA	
34	Watercooler	Outside Payroll	BH-34	Y	N	Y	N	N	N	Y	NA	NA	
35	Watercooler	Board Meeting Room	BH-35	Y	N	Y	N	N	N	Y	NA	NA	
36	Sink	Board Meeting Room	BH-36	Y	N	N	N	N	N	N	NA	NA	
37	Sink	Superintendent's Office Kitchen	BH-37	Y	N	H	N	Y	N	N	NA	NA	
38	Sink	Processing Center (Attendance	BH-38	Y	N	Y	N	Y	N	N	NA	NA	

		Office)											
39	Watercooler	Outside Special Services	BH-39	Y	N	Y	N	N	N	Y	NA	NA	
40	Watercooler	Special Services	BH-40	Y	N	Y	N	N	N	Y	NA	NA	
41	Watercooler	Outside Auditorium	BH-41	Y	N	Y	N	N	N	Y	NA	NA	
42	Drinking Fountain	Outside Room 230	BH-42	Y	N	N	N	N	N	N	NA	NA	
43	Sink	Nurse's Office	BH-43	Y	N	N	N	Y	N	N	NA	NA	
44	Sink	Guidance Office Bathroom	BH-44	Y	N	N	N	Y	N	N	NA	NA	
45	Sink	Teacher's Room	BH-45	Y	N	Y	N	Y	N	N	NA	NA	
46	Sink	Dance Room in Back of Auditorium	BH-46	Y	N	N	N	Y	N	N	NA	NA	
47	Sink	Custodial Breakroom	BH-47	Y	N	Y	N	Y	N	N	NA	NA	
48	Bottle Filler Station	Outside Student Center	BH-48	Y	N	Y	N	N	Y	Y	NA	NA	
49	Sink	Student Center	BH-49	Y	N	Y	N	N	N	N	NA	NA	
50	Sink	Child Study Office	BH-50	Y	N	N	N	N	N	N	NA	NA	
51	Watercooler	Outside Room 136	BH-51	Y	N	Y	N	N	N	Y	NA	NA	
52	Watercooler	Outside Room 247	BH-52	Y	N	Y	N	N	N	Y	NA	NA	
53	Sink	Senior Café	BH-53	Y	N	Y	N	N	N	N	NA	NA	
54	Sink	Room 5 - 355	BH-54	Y	N	N	N	Y	N	N	NA	NA	
55	Watercooler	Outside Room 353	BH-55	Y	N	Y	N	N	N	Y	NA	NA	
56	Watercooler	Outside Room	BH-56	Y	N	Y	N	N	N	Y	NA	NA	

		350											
57	Bottle Filling Station	Outside Room G5	BH-57	Y	N	Y	N	N	Y	Y	NA	NA	
58	Sink	Automotive Room	BH-58	Y	N	Y	N	Y	N	N	NA	NA	
59	Sink	Life Skills	BH-59	Y	N	Y	N	Y	N	N	NA	NA	
60	Drinking Fountain	Outside Room 129, Left Side	BH-60	Y	N	N	N	N	N	N	NA	NA	
61	Drinking Fountain	Outside Room 129, Right Side	BH-61	Y	N	N	N	N	N	N	NA	NA	
62	Sink	Nurse's Office	BH-62	Y	N	N	N	N	N	N	NA	NA	

<sup>1</sup> Number outlets starting at the closest outlet to the Point of Entry (POE).

<sup>1</sup> Document if permanently or temporarily out of service on the Attachment B- Plumbing Profile.

<sup>1</sup> Signs of corrosion detected, such as but not limited to frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry.

<sup>1</sup> Document on Attachment D- Filter Inventory.

## Attachment D - Filter Inventory

Name of School: Bayonne High School Grade Levels: High School

Address: 669 Avenue A, Bayonne, New Jersey 07002

Individual School Project Officer: Scott Nolan

Date: 07/24/25

Sample Location / Code	Brand	Type (Make & Model)	Date Installed or Replaced	Replacement Frequency	NSF Certified for Lead Reduction Y/N
BH-01	3M Aqua Pure	N/A	N/A	N/A	N/A
BH-02	3M Aqua Pure	N/A	N/A	N/A	N/A
BH-03	Elkay	LZWSR_1C	N/A	N/A	N/A
BH-04	N/A	N/A	N/A	N/A	N/A
BH-05	3M Aqua Pure	AP 200	N/A	N/A	N/A
BH-06	3M Aqua Pure	AP 200	N/A	N/A	N/A
BH-07	Elkay	LZWSR_1C	N/A	N/A	N/A
BH-08	Aqua Pure	3MFF101	N/A	N/A	N/A
BH-09	Elkay	LZWSR_1C	N/A	N/A	N/A
BH-10	Elkay	LZWSR_1C	N/A	N/A	N/A
BH-11	Elkay	LZWSR_1C	N/A	N/A	N/A
BH-12	Elkay	LZWSR_1C	N/A	N/A	N/A
BH-13	3M Aqua Pure	3MFF101	N/A	N/A	N/A
BH-14	3M Aqua Pure	3MFF101	N/A	N/A	N/A
BH-15	Elkay	N/A	N/A	N/A	N/A
BH-16	REMOVED				
BH-17	3M Aqua Pure	AP 200	N/A	N/A	N/A
BH-18	N/A	N/A	N/A	N/A	N/A
BH-19	Elkay	N/A	N/A	N/A	N/A
BH-20	Elkay	N/A	N/A	N/A	N/A
BH-21	N/A	N/A	N/A	N/A	N/A

BH-22	N/A	N/A	N/A	N/A	N/A
BH-23	N/A	N/A	N/A	N/A	N/A
BH-24	Elkay	LZWSR_1C	N/A	N/A	N/A
BH-24-A	Elkay	LZWSR_1C	N/A	N/A	N/A
BH-25	3M Aqua Pure	3MFF101	N/A	N/A	N/A
BH-26	3M Aqua Pure	3MFF101	N/A	N/A	N/A
BH-27	Elkay	EDFP2100	N/A	N/A	N/A
BH-28	Elkay	EDFP2100	N/A	N/A	N/A
BH-29	Elkay	EDFP2100	N/A	N/A	N/A
BH-30	3M Aqua Pure	AP 200	N/A	N/A	N/A
BH-31	3M Aqua Pure	AP 200	N/A	N/A	N/A
BH-32	Elkay	EDFP2100	N/A	N/A	N/A
BH-33	Elkay	EDFP2100	N/A	N/A	N/A
BH-34	Elkay	EFA8_1L	N/A	N/A	N/A
BH-24-A	Elkay	LZWSR_1C	N/A	N/A	N/A
BH-35	Elkay	EFA8_1L	N/A	N/A	N/A
BH-36	N/A	N/A	N/A	N/A	N/A
BH-37	N/A	N/A	N/A	N/A	N/A
BH-38	N/A	N/A	N/A	N/A	N/A
BH-39	Elkay	EDFP2100	N/A	N/A	N/A
BH-40	Elkay	EFA8_1L	N/A	N/A	N/A
BH-41	Elkay	EFA8_1L	N/A	N/A	N/A
BH-42	N/A	N/A	N/A	N/A	N/A
BH-43	3M Aqua Pure	3MFF101	N/A	N/A	N/A
BH-44	N/A	N/A	N/A	N/A	N/A
BH-45	3M Aqua Pure	3MFF101	N/A	N/A	N/A
BH-46	N/A	N/A	N/A	N/A	N/A
BH-47	3M Aqua Pure	AP 200	N/A	N/A	N/A
BH-48	Elkay	LZWSR_1C	N/A	N/A	N/A
BH-49	3M Aqua Pure	N/A	N/A	N/A	N/A
BH-50	Elkay	EFA8_1L	N/A	N/A	N/A
BH-51	Elkay	N/A	N/A	N/A	N/A
BH-52	Elkay	N/A	N/A	N/A	N/A
BH-53	3M Aqua Pure	3MFF101	N/A	N/A	N/A
BH-54	N/A	N/A	N/A	N/A	N/A
BH-55	Elkay	EFA8_1L	N/A	N/A	N/A

BH-56	Elkay	EFA8_1L	N/A	N/A	N/A
BH-57	Elkay	N/A	N/A	N/A	N/A
BH-58	3M Aqua Pure	N/A	N/A	N/A	N/A
BH-59	N/A	N/A	N/A	N/A	N/A
BH-60	Elkay	EDFP2100	N/A	N/A	N/A
BH-61	Elkay	EDFP2100	N/A	N/A	N/A
BH-62	N/A	N/A	N/A	N/A	N/A

### Attachment E – Flushing Log

Name of School: Bayonne High School

Address: 669 Avenue A, Bayonne, New Jersey 07002

Grade Levels: High School

Individual School Project Officer: Scott Nolan

Date: 07/25/2025

Sample Location Description	Sample Location Code	Date	Time	Duration of Flushing	Reason for Flushing
Wrestling Room Right Sink	BH-01	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Wrestling Room Right Sink	BH-02	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Weight Room	BH-03	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Beauty Culture (To be Wrestling Room)	BH-04	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
First Floor by Girl's Bathroom	BH-05	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Trainer Room Sink	BH-06	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Wellness Room	BH-07	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room A8	BH-08	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
South Gym	BH-09	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Outside Language Office	BH-10	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
North Gym	BH-11	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Outside Room 101	BH-12	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Principal's Office	BH-13	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Nurse's Office	BH-14	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Outside Room 213	BH-15	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Library Office	BH-16	REMOVED			
Outside Room 206	BH-17	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Outside Room 201	BH-18	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Outside 314 Left Side	BH-19	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Outside 314, Right Side	BH-20	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling

Room 314 Sink by Door	BH-21	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 314 Middle Sink, Right Side	BH-22	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
School Store	BH-23	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Cafeteria South	BH-24	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Cafeteria North	BH-24A	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Cafeteria Kitchen Sink, Food Prep	BH-25	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Cafeteria Kitchen Sink	BH-26	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Outside Room 312, Left Side	BH-27	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Outside Room 312, Right Side	BH-28	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Outside Room 304	BH-29	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
The Back of Room 304	BH-30	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 304	BH-31	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Outside 301, Left Side	BH-32	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Outside 301, Right Side	BH-33	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Outside Payroll	BH-34	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Board Meeting Room	BH-35	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Board Meeting Room	BH-36	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Superintendent's Office Kitchen	BH-37	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Processing Center Sink	BH-38	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Outside Special Services	BH-39	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Special Services	BH-40	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Outside Auditorium	BH-41	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Outside Room 230	BH-42	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Nurse's Office	BH-43	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Guidance Office Bathroom	BH-44	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Teacher's Room	BH-45	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Dance Room in Back of	BH-46	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling

Auditorium					
Custodial Breakroom	BH-47	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Outside Student Center	BH-48	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Student Center	BH-49	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Child Study Office	BH-50	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Outside Room 136	BH-51	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Outside Room 247	BH-52	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Senior Café	BH-53	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 5 - 355	BH-54	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Outside Room 353	BH-55	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Outside Room 350	BH-56	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Outside Room G5	BH-57	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Automotive Room	BH-58	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Life Skill's Sink	BH-59	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Outside Room 129, Left Side	BH-60	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Outside Room 129, Right Side	BH-61	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Nurses Office Sink	BH-62	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling

## Attachment F - Pre - Sampling Water Use Certification

TO BE COMPLETED BY THE BAYONNE BOE DISTRICT REPRESENTATIVE:		
School Name:	<u>Bayonne High School</u>	
Sample collection address:	<u>669 Avenue A, Bayonne, New Jersey 07002</u>	
Water was last used:	<u>Time: 5:30 pm</u>	<u>Date: June 19, 2025</u>
Sample commencement:	<u>Time: 7:29 am</u>	<u>Date: June 20, 2025</u>
I have read the Lead Drinking Water Testing Sampling Plan and Quality Assurance Project Plan and I am certifying that samples were collected in accordance with these plans.		
Scott Nolan	<u>07/22/2025</u>	
Signature	Date	