



464 Valley Brook Avenue, Lyndhurst NJ 07071  
129 Sea Girt Avenue, Manasquan NJ 08736  
Phone: (800) 423-0766 • Fax: (201) 438-1798  
www.mccabeenv.com

---

## LEAD IN DRINKING WATER TESTING REPORT

*Conducted for:*

Bayonne Board of Education  
669 Avenue A  
Bayonne, New Jersey 07002

*Conducted at:*

Woodrow Wilson Community School  
101 West 56th Street  
Bayonne, New Jersey 07002

*Submitted by:*

McCabe Environmental Services, L.L.C.  
464 Valley Brook Avenue  
Lyndhurst, New Jersey 07071

**REPORT DATE:** August 5, 2025

**MES PROJECT NO.:** 25-05225

*Prepared by:*

A handwritten signature in blue ink, appearing to read 'Arllitzy Lezama'.

**Arllitzy Lezama**  
**Environmental Scientist**

*Signed for the Company by:*

A handwritten signature in blue ink, appearing to read 'John H. Chiaviello'.

**John H. Chiaviello**  
**Vice President**

## TABLE OF CONTENTS

---

	<b>Page</b>
1.0 INTRODUCTION .....	1
2.0 SCOPE OF WORK.....	1
3.0 PROCEDURES.....	1
4.0 TABLE OF SAMPLE RESULTS .....	2
5.0 DISCUSSION AND CONCLUSION .....	4

### **APPENDIX A**

Laboratory Certificates of Analysis  
&  
Sample Chain of Custody Forms

### **APPENDIX B**

School District Sampling Attachments

**1.0 INTRODUCTION**

McCabe Environmental Services, L.L.C. (McCabe) was retained by Bayonne Board of Education (Client) to conduct lead in drinking water testing at the Woodrow Wilson Community School located at 101 West 56th Street, Bayonne, New Jersey.

The project information is as follows:

Client Name: Bayonne Board of Education  
Contact Person: Mr. Daniel Castles

Project Name: Woodrow Wilson Community School – Lead in Drinking Water  
Project Location: 101 West 56th Street  
Bayonne, New Jersey 07002

Date(s) of Service: June 21, 2025

McCabe Personnel: Gary Clare, Kevin Brossok & Arllitzzy Lezama

**2.0 SCOPE OF WORK**

Drinking water testing was performed at the Woodrow Wilson Community School located at 101 West 56th Street, Bayonne, New Jersey on June 21, 2025. The purpose of the testing was to determine if the building’s plumbing was having an adverse impact on water quality, specifically with regard to lead concentrations. Samples were collected from various potential drinking water outlets located throughout the building. Testing was followed as per past reports provided by Bayonne Board of Education.

**3.0 PROCEDURES**

After determining which outlets would be sampled, McCabe personnel collected a "first draw" sample at each location. A "first draw" is the initial water that is first to come out of the tap after a period of inactivity. Following the “first draw”, a "30 second flush" sample was also collected where the main service line comes into the building. All samples were collected into 250 mL sterile bottles, labeled with a sample identification, and analyzed in accordance with EPA approved methods to determine the level of lead in drinking water. Samples were analyzed by an accredited laboratory.

The U.S. Environmental Protection Agency (EPA) has established National Primary Drinking Water Regulations (NPDWR) that set mandatory water quality standards for drinking water contaminants. These are enforceable standards called "maximum contaminant levels" or "MCL", which are established to protect the public against consumption of drinking water contaminants that present a risk to human health. An MCL is the maximum allowable amount of a contaminant in drinking water which is delivered to the consumer.

The EPA has established the Lead and Copper Rule that sets standards for state and public water systems. This rule has set an MCL for lead at 15 parts per billion (ppb) for a one liter sample. However, the EPA also established the Lead in Drinking Water at Schools and Child Care Facilities in which the EPA recommends an MCL of 20 ppb for a 250 milliliter first draw sample. In order to be more stringent, for our report purposes we have compared all results to both the 15 ppb and the 20 ppb standards.

**4.0 TABLE OF SAMPLE RESULTS**

The following table presents all sample results in order of sample identification:

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
WW-01	First Draw – Chiller Outside Mezzanine Boy’s Bathroom	< 1	Pass	Pass
WW-02	30 Second Draw – Chiller Outside Mezzanine Boy’s Bathroom	1.2	Pass	Pass
WW-03	First Draw – Chiller Next to Elevator Subbasement	< 1	Pass	Pass
WW-04	First Draw – Lunchroom Kitchen Subbasement	2.1	Pass	Pass
WW-05	First Draw – Bubbler Outside Girl’s Bathroom	Out of Service		
WW-06	First Draw – Room 100 Bathroom Sink	1.2	Pass	Pass
WW-07	First Draw – Room 101 Bathroom Sink	< 1	Pass	Pass
WW-08	First Draw – Room 102 Faucet	< 1	Pass	Pass
WW-09	First Draw – Room 103 Faucet	< 1	Pass	Pass
WW-10	First Draw – Bubbler Across from Room 103	1.1	Pass	Pass
WW-11	First Draw – Bottle Filler Across from Main Office	< 1	Pass	Pass
WW-12	First Draw – Room 105 Faucet	< 1	Pass	Pass
WW-13	First Draw – Room 106 Faucet	6.4	Pass	Pass
WW-14	First Draw – Room 107 Bathroom Sink	< 1	Pass	Pass
WW-15	First Draw – Engineer Breakroom Sink	2	Pass	Pass
WW-16	First Draw – Bubbler Across Boy’s Bathroom	< 1	Pass	Pass
WW-17	First Draw – Chiller by Elevator – First Floor	< 1	Pass	Pass

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
WW-18	First Draw – Bubbler Across from Girl’s Room, Second Floor	< 1	Pass	Pass
WW-19	First Draw – Chiller by Elevator – First Floor	Out of Service		
WW-20	First Draw – Bottle Filler Across from Room 208	< 1	Pass	Pass
WW-21	First Draw – Room 209 Faucet – Life Skills	< 1	Pass	Pass
WW-22	First Draw – Room 211 Faucet	< 1	Pass	Pass
WW-23	First Draw – Nurse’s Office Faucet	< 1	Pass	Pass
WW-24	First Draw – Bubbler Across Boy’s Bathroom – Second Floor	< 1	Pass	Pass
WW-25	First Draw – Chiller by Elevator – Second Floor	< 1	Pass	Pass
WW-26	First Draw – Art Room – Right Faucet	< 1	Pass	Pass
WW-27	First Draw – Bubbler Across from Art Room	< 1	Pass	Pass
WW-28	First Draw – Bubbler Across from Room 306	< 1	Pass	Pass
WW-29	First Draw – Bottle Filler Across from Room 311	< 1	Pass	Pass
WW-30	First Draw – Bubbler Across from Room 315	< 1	Pass	Pass
WW-31	First Draw – Chiller by Elevator – Third Floor	< 1	Pass	Pass

**5.0 DISCUSSION AND CONCLUSION**

A total of twenty-nine (29) samples were collected from the Woodrow Wilson Community School. All samples were found to be less than the EPA Lead in Drinking Water at Schools and Child Care Facilities standard of 20 ppb, as well as the EPA Lead and Copper Rule standard of 15 ppb.

In addition, McCabe Environmental recommends annual drinking water sampling to ensure that the building's plumbing is not having an adverse impact on water quality.

**APPENDIX A**

**LABORATORY CERTIFICATES OF ANALYSIS  
&  
SAMPLE CHAIN OF CUSTODY FORMS**



Thursday, July 03, 2025

Attn: Jarred Panecki  
McCabe Environmental Services, LLC  
464 Valley Brook Avenue  
Lyndhurst, New Jersey 07071

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
SDG ID: GCT58198  
Sample ID#s: CT58198 - CT58226

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory. This report is incomplete unless all pages indicated in the pagination at the bottom of the page are included.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Sincerely yours,

A handwritten signature in black ink that reads "Phyllis Shiller". The signature is written in a cursive style.

Phyllis Shiller  
Laboratory Director

NELAC - #NY11301  
CT Lab Registration #PH-0618  
MA Lab Registration #M-CT007  
ME Lab Registration #CT-007  
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003  
NY Lab Registration #11301  
PA Lab Registration #68-03530  
RI Lab Registration #63  
VT Lab Registration #VT11301



Environmental Laboratories, Inc.  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823



## Sample Id Cross Reference

July 03, 2025

SDG I.D.: GCT58198

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION

Client Id	Lab Id	Matrix	Col Date
WW-01	CT58198	DRINKING WATER	06/21/25 10:56
WW-02	CT58199	DRINKING WATER	06/21/25 10:56
WW-03	CT58200	DRINKING WATER	06/21/25 10:59
WW-04	CT58201	DRINKING WATER	06/21/25 11:01
WW-06	CT58202	DRINKING WATER	06/21/25 11:05
WW-07	CT58203	DRINKING WATER	06/21/25 11:07
WW-08	CT58204	DRINKING WATER	06/21/25 11:08
WW-09	CT58205	DRINKING WATER	06/21/25 11:09
WW-10	CT58206	DRINKING WATER	06/21/25 11:12
WW-11	CT58207	DRINKING WATER	06/21/25 11:14
WW-12	CT58208	DRINKING WATER	06/21/25 11:15
WW-13	CT58209	DRINKING WATER	06/21/25 11:15
WW-14	CT58210	DRINKING WATER	06/21/25 11:17
WW-15	CT58211	DRINKING WATER	06/21/25 11:19
WW-16	CT58212	DRINKING WATER	06/21/25 11:20
WW-17	CT58213	DRINKING WATER	06/21/25 11:22
WW-18	CT58214	DRINKING WATER	06/21/25 11:25
WW-20	CT58215	DRINKING WATER	06/21/25 11:27
WW-21	CT58216	DRINKING WATER	06/21/25 11:29
WW-22	CT58217	DRINKING WATER	06/21/25 11:32
WW-23	CT58218	DRINKING WATER	06/21/25 11:33
WW-24	CT58219	DRINKING WATER	06/21/25 11:33
WW-25	CT58220	DRINKING WATER	06/21/25 11:35
WW-26	CT58221	DRINKING WATER	06/21/25 11:38
WW-27	CT58222	DRINKING WATER	06/21/25 11:38
WW-28	CT58223	DRINKING WATER	06/21/25 11:39
WW-29	CT58224	DRINKING WATER	06/21/25 11:41
WW-30	CT58225	DRINKING WATER	06/21/25 11:42
WW-31	CT58226	DRINKING WATER	06/21/25 11:43



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

10:56  
 16:20

## Laboratory Data

SDG ID: GCT58198  
 Phoenix ID: CT58198

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WW-01

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 03, 2025**

**Reviewed and Released by: Alejandro Paredes, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

10:56  
 16:20

## Laboratory Data

SDG ID: GCT58198  
 Phoenix ID: CT58199

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WW-02

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.2	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

10:59  
 16:20

## Laboratory Data

SDG ID: GCT58198  
 Phoenix ID: CT58200

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WW-03

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 03, 2025**

**Reviewed and Released by: Alejandro Paredes, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

11:01  
 16:20

## Laboratory Data

SDG ID: GCT58198  
 Phoenix ID: CT58201

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WW-04

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	2.1	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

11:05  
 16:20

## Laboratory Data

SDG ID: GCT58198  
 Phoenix ID: CT58202

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WW-06

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.2	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

11:07  
 16:20

## Laboratory Data

SDG ID: GCT58198  
 Phoenix ID: CT58203

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WW-07

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

11:08  
 16:20

## Laboratory Data

SDG ID: GCT58198  
 Phoenix ID: CT58204

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WW-08

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

11:09  
 16:20

## Laboratory Data

SDG ID: GCT58198  
 Phoenix ID: CT58205

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WW-09

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

11:12  
 16:20

## Laboratory Data

SDG ID: GCT58198  
 Phoenix ID: CT58206

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WW-10

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.1	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

11:14  
 16:20

## Laboratory Data

SDG ID: GCT58198  
 Phoenix ID: CT58207

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WW-11

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

11:15  
 16:20

## Laboratory Data

SDG ID: GCT58198  
 Phoenix ID: CT58208

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WW-12

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

11:15  
 16:20

## Laboratory Data

SDG ID: GCT58198  
 Phoenix ID: CT58209

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WW-13

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	6.4	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

11:17  
 16:20

## Laboratory Data

SDG ID: GCT58198  
 Phoenix ID: CT58210

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WW-14

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

11:19  
 16:20

## Laboratory Data

SDG ID: GCT58198  
 Phoenix ID: CT58211

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WW-15

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	2	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

11:20  
 16:20

## Laboratory Data

SDG ID: GCT58198  
 Phoenix ID: CT58212

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WW-16

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

11:22  
 16:20

## Laboratory Data

SDG ID: GCT58198  
 Phoenix ID: CT58213

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WW-17

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

11:25  
 16:20

## Laboratory Data

SDG ID: GCT58198  
 Phoenix ID: CT58214

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WW-18

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

11:27  
 16:20

## Laboratory Data

SDG ID: GCT58198  
 Phoenix ID: CT58215

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WW-20

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

11:29  
 16:20

## Laboratory Data

SDG ID: GCT58198  
 Phoenix ID: CT58216

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WW-21

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

11:32  
 16:20

## Laboratory Data

SDG ID: GCT58198  
 Phoenix ID: CT58217

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WW-22

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

11:33  
 16:20

## Laboratory Data

SDG ID: GCT58198  
 Phoenix ID: CT58218

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WW-23

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

11:33  
 16:20

## Laboratory Data

SDG ID: GCT58198  
 Phoenix ID: CT58219

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WW-24

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 03, 2025**

**Reviewed and Released by: Alejandro Paredes, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

11:35  
 16:20

## Laboratory Data

SDG ID: GCT58198  
 Phoenix ID: CT58220

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WW-25

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/30/25	TH	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

11:38  
 16:20

## Laboratory Data

SDG ID: GCT58198  
 Phoenix ID: CT58221

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WW-26

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/30/25	TH	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

11:38  
 16:20

## Laboratory Data

SDG ID: GCT58198  
 Phoenix ID: CT58222

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WW-27

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/30/25	TH	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

11:39  
 16:20

## Laboratory Data

SDG ID: GCT58198  
 Phoenix ID: CT58223

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WW-28

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/30/25	TH	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

11:41  
 16:20

## Laboratory Data

SDG ID: GCT58198  
 Phoenix ID: CT58224

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WW-29

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			07/01/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

11:42  
 16:20

## Laboratory Data

SDG ID: GCT58198  
 Phoenix ID: CT58225

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WW-30

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			07/01/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

11:43  
 16:20

## Laboratory Data

SDG ID: GCT58198  
 Phoenix ID: CT58226

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WW-31

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			07/01/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager

# Analysis Report - Summary

July 03, 2025

Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

SDG I.D.: GCT58198



Sample	Client Id	Col Date	Parameter	Result	RL	Units	Date Analyzed	Reference
Project: 25-05225 Bayonne Board Of Education								
CT58198	WW-01	06/21/25	Lead	< 1	1	ppb	06/30/25	E200.5
CT58199	WW-02	06/21/25	Lead	1.2	1	ppb	06/30/25	E200.5
CT58200	WW-03	06/21/25	Lead	< 1	1	ppb	06/30/25	E200.5
CT58201	WW-04	06/21/25	Lead	2.1	1	ppb	06/30/25	E200.5
CT58202	WW-06	06/21/25	Lead	1.2	1	ppb	06/30/25	E200.5
CT58203	WW-07	06/21/25	Lead	< 1	1	ppb	06/30/25	E200.5
CT58204	WW-08	06/21/25	Lead	< 1	1	ppb	06/30/25	E200.5
CT58205	WW-09	06/21/25	Lead	< 1	1	ppb	06/30/25	E200.5
CT58206	WW-10	06/21/25	Lead	1.1	1	ppb	06/30/25	E200.5
CT58207	WW-11	06/21/25	Lead	< 1	1	ppb	06/30/25	E200.5
CT58208	WW-12	06/21/25	Lead	< 1	1	ppb	06/30/25	E200.5
CT58209	WW-13	06/21/25	Lead	6.4	1	ppb	06/30/25	E200.5
CT58210	WW-14	06/21/25	Lead	< 1	1	ppb	06/30/25	E200.5
CT58211	WW-15	06/21/25	Lead	2	1	ppb	06/30/25	E200.5
CT58212	WW-16	06/21/25	Lead	< 1	1	ppb	06/30/25	E200.5
CT58213	WW-17	06/21/25	Lead	< 1	1	ppb	06/30/25	E200.5
CT58214	WW-18	06/21/25	Lead	< 1	1	ppb	06/30/25	E200.5
CT58215	WW-20	06/21/25	Lead	< 1	1	ppb	06/30/25	E200.5
CT58216	WW-21	06/21/25	Lead	< 1	1	ppb	06/30/25	E200.5
CT58217	WW-22	06/21/25	Lead	< 1	1	ppb	06/30/25	E200.5
CT58218	WW-23	06/21/25	Lead	< 1	1	ppb	06/30/25	E200.5
CT58219	WW-24	06/21/25	Lead	< 1	1	ppb	06/30/25	E200.5
CT58220	WW-25	06/21/25	Lead	< 1	1	ppb	06/30/25	E200.5
CT58221	WW-26	06/21/25	Lead	< 1	1	ppb	06/30/25	E200.5
CT58222	WW-27	06/21/25	Lead	< 1	1	ppb	06/30/25	E200.5

Sample	Client Id	Col Date	Parameter	Result	RL	Units	Date Analyzed	Reference
CT58223	WW-28	06/21/25	Lead	< 1	1	ppb	06/30/25	E200.5
CT58224	WW-29	06/21/25	Lead	< 1	1	ppb	07/01/25	E200.5
CT58225	WW-30	06/21/25	Lead	< 1	1	ppb	07/01/25	E200.5
CT58226	WW-31	06/21/25	Lead	< 1	1	ppb	07/01/25	E200.5

Comments:

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

ND=Not detected BDL=Below Detection Level RL=Reporting Level CL=Client Limit



Phyllis Shiller  
Laboratory Director

July 03, 2025



Environmental Laboratories, Inc.  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102



# QA/QC Report

July 03, 2025

## QA/QC Data

SDG I.D.: GCT58198

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	-------	--------	---------------	------------	---------	-------	--------	---------	------	-------	--------	--------------	--------------

QA/QC Batch 791296A (mg/L), QC Sample No: CT58194 (CT58198, CT58199, CT58200, CT58201, CT58202, CT58203)

### ICP Metals - Aqueous

Lead	BRL	0.0010				104			107			85 - 115	20
------	-----	--------	--	--	--	-----	--	--	-----	--	--	----------	----

Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 791297 (mg/L), QC Sample No: CT58204 (CT58204, CT58205, CT58206, CT58207, CT58208, CT58209, CT58210, CT58211, CT58212, CT58213)

### ICP Metals - Aqueous

Lead	BRL	0.0010	<0.0010	<0.0010	NC	99.0			99.7			85 - 115	20
------	-----	--------	---------	---------	----	------	--	--	------	--	--	----------	----

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 791297A (mg/L), QC Sample No: CT58214 (CT58214, CT58215, CT58216, CT58217, CT58218, CT58219, CT58220, CT58221, CT58222, CT58223)

### ICP Metals - Aqueous

Lead	BRL	0.0010				99.0			106			85 - 115	20
------	-----	--------	--	--	--	------	--	--	-----	--	--	----------	----

Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 791298 (mg/L), QC Sample No: CT58224 (CT58224, CT58225, CT58226)

### ICP Metals - Aqueous

Lead	BRL	0.0010	<0.0010	<0.0010	NC	102			105			85 - 115	20
------	-----	--------	---------	---------	----	-----	--	--	-----	--	--	----------	----

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Inf - Interference
- (ISO) - Isotope Dilution

  
Phyllis Shiller, Laboratory Director  
July 03, 2025

Thursday, July 03, 2025

Criteria: NJ: DW

State: NJ

## Sample Criteria Exceedances Report

GCT58198 - MCCABE-PB

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
--------	-------	-----------------	----------	--------	----	----------	----------------	-------------------

\*\*\* No Data to Display \*\*\*

Phoenix Laboratories does not assume responsibility for the data contained in this exceedance report. It is provided as an additional tool to identify requested criteria exceedences. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedence information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



**Environmental Laboratories, Inc.**  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823



## Analysis Comments

July 03, 2025

SDG I.D.: GCT58198

---

The following analysis comments are made regarding exceptions to criteria not already noted in the Analysis Report or QA/QC Report: None.

2.2°C WCIIP

MCCABE ENVIRONMENTAL SERVICES, L.L.C.  
 464 VALLEY BROOK AVENUE LYNTHURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD in DRINKING WATER  
 CHAIN-OF-CUSTODY FORM

CLIENT NAME: Bayonne Board of Education  
 SITE ADDRESS: Woodrow Wilson Community School  
 101 W 56th St, Bayonne, NJ 07002

FIELD INSPECTOR'S NAME: A. Legume, G. Clark, R. Braszk  
 MES PROJECT #: 25-05225  
 SAMPLE DATE: 6/21/25  
 TURNAROUND TIME REQUESTED: 2-Week

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED	
DW	WW-01	FD - Chiller outside mezzanine Boys Bathroom	10:56 AM	LEAD - 200.8	58198
DW	WW-02	30 second flush - Chiller outside mezzanine Boys Bathroom	10:56 AM	LEAD - 200.8	58199
DW	WW-03	FD - Chiller next to <del>sewer</del> elevator subbasement	10:59 AM	LEAD - 200.8	58200
DW	WW-04	FD - lunch room kitchen subbasement	11:01 AM	LEAD - 200.8	58201
DW	<del>WW-05</del>	<del>FD - bubbler outside girl's Bathroom</del>	<del>LEAD - 200.8</del>		
DW	WW-06	FD - Room 100 Bathroom sink	11:05 AM	LEAD - 200.8	58202
DW	WW-07	FD - Room 101 Bathroom sink	11:07 AM	LEAD - 200.8	58203
DW	WW-08	FD - Room 102 faucet	11:08 AM	LEAD - 200.8	58204
DW	WW-09	FD - Room 103 faucet	11:09 AM	LEAD - 200.8	58205
DW	WW-10	FD - Bubbler across Room 103	11:12 AM	LEAD - 200.8	58206

Relinquished by (Print) Gary Clark  
 Signature: *[Signature]* Date: 6/23/25 Time: 1015  
 Received by: (Print) S. Demers  
 Signature: *[Signature]* Date: 6/23/25 Time: 1015

Relinquished by (Print)  
 Signature: *[Signature]* Date: 6/23/25 Time: 1620  
 Received by: (Print) Abby Lee  
 Signature: *[Signature]* Date: 6/23/25 Time: 1620

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

NJ Certified WBE

MCCABE ENVIRONMENTAL SERVICES, L.L.C.  
 464 VALLEY BROOK AVENUE LYNDBURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD in DRINKING WATER  
 CHAIN-OF-CUSTODY FORM

CLIENT NAME: Bayonne Board of Education  
 SITE ADDRESS: Woodrow Wilson Community School  
 101 W 56th St, Bayonne, NJ 07002

FIELD INSPECTOR'S NAME: A. Lyzanna G. Clark, K. Brossok  
 TURNAROUND TIME REQUESTED: 2-Week

MES PROJECT #: 25-05225  
 SAMPLE DATE: 6/2/25

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED	
DW	WW-11	FD - Bottle filler across from Main office	11:14AM	LEAD - 200.8	58207
DW	WW-12	FD - Room 105 faucet	11:15AM	LEAD - 200.8	58208
DW	WW-13	FD - Room 106 faucet	11:15AM	LEAD - 200.8	58209
DW	WW-14	FD - Room 167 Bathroom Sink	11:17AM	LEAD - 200.8	58210
DW	WW-15	FD - Engineer Breakroom sink	11:19AM	LEAD - 200.8	58211
DW	WW-16	FD - Bottle filler Across Boy's Bathroom	11:20AM	LEAD - 200.8	58212
DW	WW-17	FD - Chiller by elevator - first floor	11:22AM	LEAD - 200.8	58213
DW	WW-18	FD - Bubler Across from girls bathroom - 2nd floor	11:25AM	LEAD - 200.8	58214
DW	WW-20	FD - Bottle filler across from Room 205	11:27AM	LEAD - 200.8	58215
DW	WW-21	FD - Room 209 faucet - Life skills.	11:29AM	LEAD - 200.8	58216

Relinquished by (Print) Gary Clark  
 Date: 4/23/25 1015  
 Signature: *[Signature]*  
 Received by: (Print) J. Doreys  
 Date: 8-23 2025  
 Signature: *[Signature]*  
 Relinquished by (Print)  
 Date:  
 Signature: *[Signature]*  
 Received by: (Print) Abby Lee  
 Date: 6/23/25 1620  
 Signature: *[Signature]*

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

**MCCABE ENVIRONMENTAL SERVICES, L.L.C.**

464 VALLEY BROOK AVENUE LYNDBURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

**LEAD in DRINKING WATER  
CHAIN-OF-CUSTODY FORM**

CLIENT NAME: Bayonne Board of Education

SITE ADDRESS: Woodrow Wilson Community School  
101 W 56th St, Bayonne, NJ 07002

FIELD INSPECTOR'S NAME: *A. Uzama, G. Clare, K. Braszak*

TURNAROUND TIME REQUESTED: 2-Week

MES PROJECT #: 25-05225

SAMPLE DATE: *6/21/25*

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED	
DW	WW-22	FD - Room 211 faucet	11:32 AM	LEAD - 200.8	58217
DW	WW-23	FD - Nurse's office faucet	11:33 AM	LEAD - 200.8	58218
DW	WW-24	FD - Bubblers across from boys Bathroom - 2nd fl.	11:33 AM	LEAD - 200.8	58219
DW	WW-25	FD - Chiller by elevator - 2nd floor	11:35 AM	LEAD - 200.8	58220
DW	WW-26	FD - Art Room - Right faucet	11:38 AM	LEAD - 200.8	58221
DW	WW-27	FD - Bubblers across from Art Room	11:58 AM	LEAD - 200.8	58222
DW	WW-28	FD - Bubblers across from Room 306	11:39 AM	LEAD - 200.8	58223
DW	WW-29	FD - Bottle filler across from Room 311	11:41 AM	LEAD - 200.8	58224
DW	WW-30	FD - Bubblers across from Room 315	11:42 AM	LEAD - 200.8	58225
DW	WW-31	FD - Chiller by elevator - 3rd fl.	11:43 AM	LEAD - 200.8	58226

Relinquished by (Print) *Gary Clare*

Date: ~~6/21/25~~ 6/21/25

Received by: (Print) *J. Demers*

Date: 8-23-2025

Signature: *[Signature]*

Time: 1015

Signature: *[Signature]*

Time: 1015

Relinquished by (Print) *[Signature]*

Date: 6/23/25

Received by: (Print) *Abby Lee*

Date: 6/23/25

Signature: *[Signature]*

Time: 1020

Signature: *[Signature]*

Time: 1020

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

**APPENDIX B**

**SCHOOL DISTRICT SAMPLING  
ATTACHMENTS**

## Attachment A - List of Priority for Sampling

SCHOOL NAME	DATE OF SAMPLING	CERTIFIED LABORATORY	NOTES
Woodrow Wilson Community School	June 21, 2025	Phoenix Environmental Laboratories Inc.	

## Attachment B – Plumbing Profile

*Note: Complete for each school. For additional information see the USEPA publication, "The 3Ts for Reducing Lead in Drinking Water in Schools"*

Name of School: Woodrow Wilson Community School Levels: K-8

Address: 101 West 56th St., Bayonne, NJ 07002

Individual school project officer Signature: *Scott Wilson* Date: 8/5/2025

Questions	Answers		
<b>Background Information</b>			
1. What year was the original building constructed? Were any buildings or additions added to the original facility?	K-8 Grade School Built in 1930 K-8 Grade School Addition in 2006		
2. If the building was constructed or repaired after 1986, was lead-free plumbing and solder utilized? What type of solder was used? Document all locations where lead solder was used.	Any repairs made after 1986 were done using lead free solder		
3. Where are the most recent plumbing repairs and replacements?	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%; padding: 5px;"> <b>Location:</b> 3rd floor hallway 2nd floor life skills 1st floor Pre-K room                 </td> <td style="width: 50%; padding: 5px;"> <b>Description:</b> Replace water fountain Replace faucet Install new bathroom                 </td> </tr> </table>	<b>Location:</b> 3rd floor hallway 2nd floor life skills 1st floor Pre-K room	<b>Description:</b> Replace water fountain Replace faucet Install new bathroom
<b>Location:</b> 3rd floor hallway 2nd floor life skills 1st floor Pre-K room	<b>Description:</b> Replace water fountain Replace faucet Install new bathroom		
4. With what materials is the service connection (the pipe that carries water to the school from the public water system's main in the street) made? Where is the Service Line located? (This is the POE location.)	<p><b>Material:</b> Main Building - Duct Iron</p> <p><b>Location:</b> The water main (57th st) enters the basement boiler room where the water meter is located and continues to the remainder of the building</p>		
5. Is there point of entry (POE) or point of use (POU) treatment in use?	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%; padding: 5px;"> <b>Y / N</b> No treatment of water Type: at POE City water comes treated                 </td> <td style="width: 50%; padding: 5px;"> <b>Location:</b> Main Building 1930                 </td> </tr> </table>	<b>Y / N</b> No treatment of water Type: at POE City water comes treated	<b>Location:</b> Main Building 1930
<b>Y / N</b> No treatment of water Type: at POE City water comes treated	<b>Location:</b> Main Building 1930		

Questions	Answers
6. Are there tanks in your plumbing system (pressure tanks, gravity storage tanks)?	Y / N Yes Building has two 75 gallon hot water storage tanks located in the boiler room and new wing slop sink
7. Does the school have a filter maintenance and operation program? If so, who is responsible for this program? What is the process for adding filters?	Y / N Yes Yes, Scott Nolan, Andy McCabe, Vinny Caiola, change filters on an as needed basis assign plumbers
8. Have accessible screens or aerators on outlets that provide drinking water been cleaned? Does the school have a screen or aerator maintenance program?	Y / N Yes The district has set-up a routine maintenance program to clean screens
9. Have there been any complaints about bad (metallic) taste? Note location(s).	Y / N NO Location:
10. Review records and consult with the public water supplier to determine whether any water samples have been taken in the building for any contaminants. If so, identify: <ul style="list-style-type: none"> <li>• Name of contaminant(s)</li> <li>• Concentrations found</li> <li>• pH level</li> </ul> Is testing done regularly at the building?	No indoor testing by public water supplier
11. Other plumbing background questions include: <ul style="list-style-type: none"> <li>• Are blueprints of the building available?</li> <li>• Are there known plumbing “dead-ends”, low use areas, existing leaks or other “problem areas”?</li> </ul> Are renovations planned for any of the plumbing system?	Not all prints are available No dead-end low use areas All leaks were identified during walk through and have been repaired No plumbing system renovations planned

Questions	Answers
<b>Walk-Through</b> <i>These questions should be addressed during the walk-through of the facility, while Attachment C- Drinking Water Outlet Inventory is being completed.</i>	
1. Confirm the material of Service Line visually.	Duct iron
2. Confirm the presence of POE or POU treatment.	No POE or POU treatment
3. What are the potable water pipes made of in your facility? <ul style="list-style-type: none"> <li>• Lead</li> <li>• Plastic</li> <li>• Galvanized Metal</li> <li>• Cast Iron</li> <li>• Copper</li> <li>• Other</li> </ul> Note the water flow through the building and the areas that receive water first, and which areas receive water last.	Cooper Galvanized Metal Brass  Water flow through the building shown on the prints
4. Are electrical wires grounded to Water Pipes? Note location(s).	Y / N  No  No electrical wires grounded to water pipes
5. Are brass fittings, faucets, or valves used in your drinking water system? Note that most faucets are brass on the inside. Document the locations of any brass water outlet to be sampled.	Location: Complete in "Brass" Column in Attachment C- Water Outlet Inventory. Yes Completed in Attachment C - Water Outlet Inventory
6. Locate all drinking water outlets (i.e. water coolers, bubblers, ice machines, kitchen/ food prep sinks, etc.) in the facility.	Complete in Attachment C-Water Outlet Inventory.

Questions	Answers
<p>7. Have the brands and models of the water coolers in the school been compared to the list of recalled water coolers in the Toolkit?</p> <p>Recalled Drinking Water Fountains</p>	<p>Y / N Yes all water coolers have been checked and compared to the list of recalled water coolers</p>
<p>Make and Model</p> <p>8. Have signs of corrosion, such as frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry been detected? Note the locations of water outlets.</p>	<p>Type None on the list of recalled water coolers</p> <p>Complete in "Signs of Corrosion" column in Attachment C- Drinking Water Outlet Inventory.</p>
<p>9. Are there any outlets that are not operational and therefore out of service? Permanently? Temporarily?</p> <p>Permanently</p> <p>Temporarily</p>	<p>Y / N</p> <p>Complete "Operational Column" in Attachment C- Drinking Water Outlet Inventory.</p> <p>Type/ Location</p> <p>Description</p>

## Attachment C – Drinking Water Outlet Inventory

Name of School: Woodrow Wilson Community School

Address: 101 West 56th Street, Bayonne, New Jersey 07002

Grade Levels: Elementary School Year School Constructed: Unknown Renovated/Additions: NA

Individual School Project Officer: Scott Nolan

Date Completed: 07/14/2025

# <sup>1</sup>	Type	Location	Code	Operational <sup>2</sup> (Y/N)	Signs of Corrosion <sup>3</sup> (Y/N)	Filter <sup>4</sup> (Y/N)	Brass Fittings, Faucets or valves? (Y/N)	Aerator/ Screen (Y/N)	Motion Activated (Y/N)	Chiller (Y/N)	Water Cooler		Comments
											Make	Model	
01	Chiller	Outside Mezzanine Boy's Bathroom	WW-01	Y	N	Y	N	N	N	Y	NA	NA	
02	Chiller	Outside Mezzanine Boy's Bathroom	WW-02	Y	N	Y	N	N	N	Y	NA	NA	Flush
03	Chiller	Next to Elevator Subbasement	WW-03	Y	N	N	N	N	N	Y	NA	NA	

<sup>1</sup> Number outlets starting at the closest outlet to the Point of Entry (POE).

<sup>2</sup> Document if permanently or temporarily out of service on the Attachment B- Plumbing Profile.

<sup>3</sup> Signs of corrosion detected, such as but not limited to frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry.

<sup>4</sup> Document on Attachment D- Filter Inventory.

04	Sink	Lunchroom Kitchen Subbasement	WW-04	Y	N	N	N	N	N	N	NA	NA	
05	Water Fountain	Outside Girl's Bathroom	WW-05	N	N	N	N	N	N	N	NA	NA	Out of Service
06	Sink	Room 100 Bathroom	WW-06	Y	N	N	N	Y	N	N	NA	NA	
07	Sink	Room 101 Bathroom	WW-07	Y	N	N	N	Y	N	N	NA	NA	
08	Sink	Room 102	WW-08	Y	N	N	N	Y	N	N	NA	NA	
9	Sink	Room 103	WW-9	Y	N	N	N	Y	N	N	NA	NA	
10	Water Fountain	Across from Room 103	WW-10	Y	N	Y	N	N	N	N	NA	NA	
11	Water Fountain	Across from Main Office	WW-11	Y	N	Y	N	N	N	N	NA	NA	
12	Sink	Room 105	WW-12	Y	N	N	N	Y	N	N	NA	NA	
13	Sink	Room 106	WW-13	Y	N	N	N	Y	N	N	NA	NA	
14	Sink	107 Bathroom	WW-14	Y	N	N	N	Y	N	N	NA	NA	
15	Sink	Engineer Breakroom	WW-15	Y	N	N	N	N	N	N	NA	NA	
16	Water Fountain	Across Boy's Bathroom	WW-16	Y	N	Y	N	N	N	N	NA	NA	
17	Chiller	By Elevator, First Floor	WW-17	Y	N	Y	N	N	N	Y	NA	NA	
18	Water Fountain	Across from Girl's Room, Second Floor	WW-18	Y	N	Y	N	N	N	N	NA	NA	
19	Water Fountain	Across from Room 205	WW-19	N	N	Y	N	N	N	N	NA	NA	Out of Order
20	Water Fountain	Across from Room 208	WW-20	Y	Y	Y	N	N	N	N	NA	NA	
21	Sink	Room 209	WW-21	Y	N	N	N	N	N	N	NA	NA	
22	Sink	Room 211	WW-22	Y	N	N	N	Y	N	N	NA	NA	
23	Sink	Nurse's Office	WW-23	Y	N	N	N	Y	N	N	NA	NA	
24	Water Fountain	Across Boy's Bathroom	WW-24	Y	N	Y	N	N	N	N	NA	NA	

25	Chiller	By Elevator, Second Floor	WW-25	Y	N	Y	N	N	N	Y	NA	NA	
26	Sink	Art Room, Right Faucet	WW-26	Y	N	N	N	Y	N	N	NA	NA	
27	Water Fountain	Across from Art Room	WW-27	Y	N	Y	N	N	N	N	NA	NA	
28	Water Fountain	Across from Room 306	WW-28	Y	N	Y	N	N	N	N	NA	NA	
29	Water Fountain	Across from Room 311	WW-29	Y	N	Y	N	N	N	N	NA	NA	
30	Water Fountain	Across from Room 315	WW-30	Y	N	Y	N	N	N	N	NA	NA	
31	Chiller	By Elevator, Third Floor	WW-31	Y	N	Y	N	N	N	Y	NA	NA	

<sup>1</sup> Number outlets starting at the closest outlet to the Point of Entry (POE).

<sup>1</sup> Document if permanently or temporarily out of service on the Attachment B- Plumbing Profile.

<sup>1</sup> Signs of corrosion detected, such as but not limited to frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry.

<sup>1</sup> Document on Attachment D- Filter Inventory.

## Attachment D - Filter Inventory

Name of School: Woodrow Wilson Community School

Grade Levels: Elementary School

Address: 101 West 56th Street, Bayonne, New Jersey 07002

Individual School Project Officer: Scott Nolan

Date: 07/14/2025

Sample Location / Code	Brand	Type (Make & Model)	Date Installed or Replaced	Replacement Frequency	NSF Certified for Lead Reduction Y/N
WW-01	Elkay	EZFS8_1B	N/A	N/A	N/A
WW-02	Elkay	EZFS8_1B	N/A	N/A	N/A
WW-03	Elkay	EZFS8_1B	N/A	N/A	N/A
WW-04	N/A	N/A	N/A	N/A	N/A
WW-05	Halsey Taylor	N/A	N/A	N/A	N/A
WW-06	Franke USA	N/A	N/A	N/A	N/A
WW-07	N/A	N/A	N/A	N/A	N/A
WW-08	N/A	N/A	N/A	N/A	N/A
WW-09	Halsey Taylor	N/A	N/A	N/A	N/A
WW-10	Elkay	LZWSR_1D	N/A	N/A	N/A
WW-11	N/A	N/A	N/A	N/A	N/A
WW-12	N/A	N/A	N/A	N/A	N/A
WW-13	N/A	N/A	N/A	N/A	N/A
WW-14	N/A	N/A	N/A	N/A	N/A
WW-15	N/A	N/A	N/A	N/A	N/A
WW-16	Elkay	LZWSR_1D	N/A	N/A	N/A
WW-17	N/A	N/A	N/A	N/A	N/A
WW-18	Elkay	LZWSR_1D	N/A	N/A	N/A
WW-19	N/A	N/A	N/A	N/A	N/A
WW-20	N/A	N/A	N/A	N/A	N/A
WW-21	N/A	N/A	N/A	N/A	N/A
WW-22	Elkay	LZWSR_1D	N/A	N/A	N/A
WW-23	N/A	N/A	N/A	N/A	N/A

WW-24	N/A	N/A	N/A	N/A	N/A
WW-25	Halsey Taylor	N/A	N/A	N/A	N/A
WW-26	Halsey Taylor	N/A	N/A	N/A	N/A
WW-27	Elkay	LZWSR_1D	N/A	N/A	N/A
WW-28	Halsey Taylor	N/A	N/A	N/A	N/A
WW-29	Elkay	LZWSR_1D	N/A	N/A	N/A
WW-30	Halsey Taylor	N/A	N/A	N/A	N/A
WW-31	Elkay	EZFS8_1B	N/A	N/A	N/A

## Attachment E – Flushing Log

Name of School: Woodrow Wilson Community School

Address: 101 West 56th Street, Bayonne, New Jersey 07002

Grade Levels: Elementary School

Individual School Project Officer: Scott Nolan

Date: 07/14/2025

Sample Location Description	Sample Location Code	Date	Time	Duration of Flushing	Reason for Flushing
Chiller Outside Mezzanine Boy's Bathroom	WW-01	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Chiller Outside Mezzanine Boy's Bathroom	WW-02	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
First Draw – Chiller Next to Elevator Subbasement	WW-03	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Lunchroom Kitchen Subbasement	WW-04	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler Outside Girl's Bathroom	WW-05	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 100 Bathroom Sink	WW-06	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 101 Bathroom Sink	WW-07	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 102 Faucet	WW-08	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 103 Faucet	WW-09	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler Across from Room 103	WW-10	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler Across from Main Office	WW-11	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 105 Faucet	WW-12	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 106 Faucet	WW-13	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
107 Bathroom Sink	WW-14	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Engineer Breakroom Sink	WW-15	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler Across Boy's Bathroom	WW-16	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Chiller by Elevator, First Floor	WW-17	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler Across from Girl's Room, Second Floor	WW-18	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler Across from Room 205	WW-19	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler Across from	WW-20	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling

Room 208					
Room 209 Faucet	WW-21	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 211 Faucet	WW-22	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Nurse's Office Faucet	WW-23	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler Across Boy's Bathroom	WW-24	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Chiller by Elevator, Second Floor	WW-25	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Art Room, Right Faucet	WW-26	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler Across from Art Room	WW-27	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler Across from Room 306	WW-28	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler Across from Room 311	WW-29	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler Across from Room 315	WW-30	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Chiller by Elevator, Third Floor	WW-31	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling

## Attachment F - Pre - Sampling Water Use Certification

TO BE COMPLETED BY THE BAYONNE BOE DISTRICT REPRESENTATIVE:		
School Name:	<u>Woodrow Wilson Community School</u>	
Sample collection address:	<u>101 West 56th Street, Bayonne, New Jersey 07002</u>	
Water was last used:	<u>Time: 5:30 pm</u>	<u>Date: June 20, 2025</u>
Sample commencement:	<u>Time: 10:56 am</u>	<u>Date: June 21, 2025</u>
I have read the Lead Drinking Water Testing Sampling Plan and Quality Assurance Project Plan and I am certifying that samples were collected in accordance with these plans.		
Scott Nolan	<u>07/22/2025</u>	
Signature	Date	