



464 Valley Brook Avenue, Lyndhurst NJ 07071  
129 Sea Girt Avenue, Manasquan NJ 08736  
Phone: (800) 423-0766 • Fax: (201) 438-1798  
www.mccabeenv.com

---

## LEAD IN DRINKING WATER TESTING REPORT

*Conducted for:*

Bayonne Board of Education  
669 Avenue A  
Bayonne, New Jersey 07002

*Conducted at:*

Mary J. Donohoe Elementary School  
25 E 5<sup>th</sup> Street  
Bayonne, New Jersey 07002

*Submitted by:*

McCabe Environmental Services, L.L.C.  
464 Valley Brook Avenue  
Lyndhurst, New Jersey 07071

**REPORT DATE:** August 5, 2025

**MES PROJECT NO.:** 25-05225

*Prepared by:*

A handwritten signature in blue ink, appearing to read 'Arllitzy Lezama'.

**Arllitzy Lezama**  
**Environmental Scientist**

*Signed for the Company by:*

A handwritten signature in blue ink, appearing to read 'John H. Chiaviello'.

**John H. Chiaviello**  
**Vice President**

## TABLE OF CONTENTS

	<b>Page</b>
1.0 INTRODUCTION .....	1
2.0 SCOPE OF WORK.....	1
3.0 PROCEDURES.....	1
4.0 TABLE OF SAMPLE RESULTS .....	2
5.0 DISCUSSION AND CONCLUSION .....	3

### **APPENDIX A**

Laboratory Certificates of Analysis  
&  
Sample Chain of Custody Forms

### **APPENDIX B**

School District Sampling Attachments

## **1.0 INTRODUCTION**

McCabe Environmental Services, L.L.C. (McCabe) was retained by Bayonne Board of Education (Client) to conduct lead in drinking water testing at Mary J. Donohoe Elementary School located at 25 E 5<sup>th</sup> Street, Bayonne, New Jersey 07002.

The project information is as follows:

<u>Client Name:</u>	Bayonne Board of Education
<u>Contact Person:</u>	Mr. Daniel Castles
<u>Project Name:</u>	Mary J. Donohoe – Lead in Drinking Water Testing
<u>Project Location:</u>	25 E 5 <sup>th</sup> Street Bayonne, New Jersey 07002
<u>Date(s) of Service:</u>	June 21, 2025
<u>McCabe Personnel:</u>	Gary Clare, Kevin Brossok & Arlitzzy Lezama

## **2.0 SCOPE OF WORK**

Drinking water testing was performed at Mary J. Donohoe Elementary School on June 21, 2025. The purpose of the testing was to determine if the building’s plumbing was having an adverse impact on water quality, specifically with regard to lead concentrations. Samples were collected from various potential drinking water outlets located throughout the building. Testing was followed as per past reports provided by Bayonne Board of Education.

## **3.0 PROCEDURES**

After determining which outlets would be sampled, McCabe personnel collected a "first draw" sample at each location. A "first draw" is the initial water that is first to come out of the tap after a period of inactivity. Following the “first draw”, a "30 second flush" sample was also collected closest to where the main service line comes into the building. All samples were collected into 250 mL sterile bottles, labeled with a sample identification, and analyzed in accordance with EPA approved methods to determine the level of lead in drinking water. Samples were analyzed by an accredited laboratory.

The U.S. Environmental Protection Agency (EPA) has established National Primary Drinking Water Regulations (NPDWR) that set mandatory water quality standards for drinking water contaminants. These are enforceable standards called "maximum contaminant levels" or "MCL", which are established to protect the public against consumption of drinking water contaminants that present a risk to human health. An MCL is the maximum allowable amount of a contaminant in drinking water which is delivered to the consumer.

The EPA has established the Lead and Copper Rule that sets standards for state and public water systems. This rule has set an MCL for lead at 15 parts per billion (ppb) for a one liter sample. However, the EPA also established the Lead in Drinking Water at Schools and Child Care Facilities in which the EPA recommends an MCL of 20 ppb for a 250 milliliter first draw sample. In order to be more stringent, for our report purposes we have compared all results to both the 15 ppb and the 20 ppb standards.

**4.0 TABLE OF SAMPLE RESULTS**

The following table presents all sample results in order of sample identification:

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
MJ-01	First Draw – 1 <sup>st</sup> Floor Pre-K Bathroom Sink	< 1	Pass	Pass
MJ-02	30 Second Flush – 1 <sup>st</sup> Floor Pre-K Bathroom Sink	< 1	Pass	Pass
MJ-03	First Draw – Bubbler by Room 5A	< 1	Pass	Pass
MJ-04	First Draw – Pre-K HR3 Bathroom Sink – Left	< 1	Pass	Pass
MJ-05	First Draw – Pre-K HR3 Bathroom Sink – Right	1.7	Pass	Pass
MJ-06	First Draw – Bottle Filler by Principal Office	< 1	Pass	Pass
MJ-07	First Draw – Food Storage Sink	1.3	Pass	Pass
MJ-08	First Draw – Chiller by Pre-K Room 1	< 1	Pass	Pass
MJ-09	First Draw – Pre-K Room 1 – Sink	< 1	Pass	Pass
MJ-10	First Draw – Pre-K Room 1 Bathroom Sink	< 1	Pass	Pass
MJ-11	First Draw – Pre-K Room 2 – Sink	< 1	Pass	Pass
MJ-12	First Draw – Pre-K Room 2 Bathroom Sink	< 1	Pass	Pass
MJ-13	First Draw – Bubbler by Room 11B	< 1	Pass	Pass
MJ-14	First Draw – Bottle Filler by Room 6B	< 1	Pass	Pass
MJ-15	First Draw – Nurse’s Office Sink	2.5	Pass	Pass
MJ-16	First Draw – Teacher’s Room Faucet	< 1	Pass	Pass
MJ-17	First Draw – Bubbler by Room 19C	1.8	Pass	Pass
MJ-18	First Draw – Bottle Filler by Room 13C	< 1	Pass	Pass

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
MJ-19	First Draw – Chiller by Music Room	< 1	Pass	Pass
MJ-20	First Draw – Professional Development Room Bubbler	< 1	Pass	Pass
MJ-21	First Draw – Professional Development Room Faucet	1.3	Pass	Pass
MJ-22	First Draw – Music Room Bubbler	1.3	Pass	Pass
MJ-23	First Draw – Music Room Faucet	< 1	Pass	Pass
MJ-24	First Draw – Art Room Bubbler	< 1	Pass	Pass
MJ-25	First Draw – Art Room Faucet	< 1	Pass	Pass

**5.0 DISCUSSION AND CONCLUSION**

A total of twenty five (25) samples were collected from Mary J. Donohoe Community School. All samples were found to be less than the EPA Lead in Drinking Water at Schools and Child Care Facilities standard of 20 ppb, as well as the EPA Lead and Copper Rule standard of 15 ppb.

In addition, McCabe Environmental recommends annual drinking water sampling to ensure that the building’s plumbing is not having an adverse impact on water quality.

**APPENDIX A**

**LABORATORY CERTIFICATES OF ANALYSIS  
&  
SAMPLE CHAIN OF CUSTODY FORMS**



Monday, June 30, 2025

Attn: Jarred Panecki  
McCabe Environmental Services, LLC  
464 Valley Brook Avenue  
Lyndhurst, New Jersey 07071

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
SDG ID: GCT58128  
Sample ID#s: CT58128 - CT58152

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory. This report is incomplete unless all pages indicated in the pagination at the bottom of the page are included.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Sincerely yours,

A handwritten signature in black ink that reads "Phyllis Shiller". The signature is written in a cursive style.

Phyllis Shiller  
Laboratory Director

NELAC - #NY11301  
CT Lab Registration #PH-0618  
MA Lab Registration #M-CT007  
ME Lab Registration #CT-007  
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003  
NY Lab Registration #11301  
PA Lab Registration #68-03530  
RI Lab Registration #63  
VT Lab Registration #VT11301



Environmental Laboratories, Inc.  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823



## Sample Id Cross Reference

June 30, 2025

SDG I.D.: GCT58128

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION

Client Id	Lab Id	Matrix	Col Date
MJ-01	CT58128	DRINKING WATER	06/21/25 8:19
MJ-02	CT58129	DRINKING WATER	06/21/25 8:20
MJ-03	CT58130	DRINKING WATER	06/21/25 8:21
MJ-04	CT58131	DRINKING WATER	06/21/25 8:23
MJ-05	CT58132	DRINKING WATER	06/21/25 8:24
MJ-06	CT58133	DRINKING WATER	06/21/25 8:26
MJ-07	CT58134	DRINKING WATER	06/21/25 8:28
MJ-08	CT58135	DRINKING WATER	06/21/25 8:29
MJ-09	CT58136	DRINKING WATER	06/21/25 8:30
MJ-10	CT58137	DRINKING WATER	06/21/25 8:31
MJ-11	CT58138	DRINKING WATER	06/21/25 8:31
MJ-12	CT58139	DRINKING WATER	06/21/25 8:32
MJ-13	CT58140	DRINKING WATER	06/21/25 8:34
MJ-14	CT58141	DRINKING WATER	06/21/25 8:36
MJ-15	CT58142	DRINKING WATER	06/21/25 8:37
MJ-16	CT58143	DRINKING WATER	06/21/25 8:39
MJ-17	CT58144	DRINKING WATER	06/21/25 8:44
MJ-18	CT58145	DRINKING WATER	06/21/25 8:46
MJ-19	CT58146	DRINKING WATER	06/21/25 8:47
MJ-20	CT58147	DRINKING WATER	06/21/25 8:49
MJ-21	CT58148	DRINKING WATER	06/21/25 8:50
MJ-22	CT58149	DRINKING WATER	06/21/25 8:51
MJ-23	CT58150	DRINKING WATER	06/21/25 8:52
MJ-24	CT58151	DRINKING WATER	06/21/25 8:52
MJ-25	CT58152	DRINKING WATER	06/21/25 8:53



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

8:19  
 16:20

## Laboratory Data

SDG ID: GCT58128  
 Phoenix ID: CT58128

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: MJ-01

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/26/25	CPP	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 30, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

8:20  
 16:20

## Laboratory Data

SDG ID: GCT58128  
 Phoenix ID: CT58129

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: MJ-02

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/26/25	CPP	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 30, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

8:21  
 16:20

## Laboratory Data

SDG ID: GCT58128  
 Phoenix ID: CT58130

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: MJ-03

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/26/25	CPP	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 30, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

8:23  
 16:20

## Laboratory Data

SDG ID: GCT58128  
 Phoenix ID: CT58131

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: MJ-04

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/26/25	CPP	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 30, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

8:24  
 16:20

## Laboratory Data

SDG ID: GCT58128  
 Phoenix ID: CT58132

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: MJ-05

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.7	1	1	ppb	15			06/26/25	CPP	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 30, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

8:26  
 16:20

## Laboratory Data

SDG ID: GCT58128  
 Phoenix ID: CT58133

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: MJ-06

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/26/25	CPP	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 30, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

8:28  
 16:20

## Laboratory Data

SDG ID: GCT58128  
 Phoenix ID: CT58134

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: MJ-07

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.3	1	1	ppb	15			06/26/25	CPP	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**June 30, 2025**

**Reviewed and Released by: Alejandro Paredes, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

8:29  
 16:20

## Laboratory Data

SDG ID: GCT58128  
 Phoenix ID: CT58135

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: MJ-08

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/26/25	CPP	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 30, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

8:30  
 16:20

## Laboratory Data

SDG ID: GCT58128  
 Phoenix ID: CT58136

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: MJ-09

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/26/25	CPP	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 30, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

8:31  
 16:20

## Laboratory Data

SDG ID: GCT58128  
 Phoenix ID: CT58137

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: MJ-10

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/26/25	CPP	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 30, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

8:31  
 16:20

## Laboratory Data

SDG ID: GCT58128  
 Phoenix ID: CT58138

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: MJ-11

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/26/25	CPP	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**June 30, 2025**

**Reviewed and Released by: Alejandro Paredes, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

8:32  
 16:20

## Laboratory Data

SDG ID: GCT58128  
 Phoenix ID: CT58139

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: MJ-12

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/26/25	CPP	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 30, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

8:34  
 16:20

## Laboratory Data

SDG ID: GCT58128  
 Phoenix ID: CT58140

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: MJ-13

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/26/25	CPP	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 30, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

8:36  
 16:20

## Laboratory Data

SDG ID: GCT58128  
 Phoenix ID: CT58141

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: MJ-14

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/26/25	CPP	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 30, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

8:37  
 16:20

## Laboratory Data

SDG ID: GCT58128  
 Phoenix ID: CT58142

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: MJ-15

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	2.5	1	1	ppb	15			06/26/25	CPP	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 30, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

8:39  
 16:20

## Laboratory Data

SDG ID: GCT58128  
 Phoenix ID: CT58143

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: MJ-16

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/26/25	CPP	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 30, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

8:44  
 16:20

## Laboratory Data

SDG ID: GCT58128  
 Phoenix ID: CT58144

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: MJ-17

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.8	1	1	ppb	15			06/26/25	CPP	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 30, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

8:46  
 16:20

## Laboratory Data

SDG ID: GCT58128  
 Phoenix ID: CT58145

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: MJ-18

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/26/25	CPP	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 30, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

8:47  
 16:20

## Laboratory Data

SDG ID: GCT58128  
 Phoenix ID: CT58146

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: MJ-19

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/26/25	CPP	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 30, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

8:49  
 16:20

## Laboratory Data

SDG ID: GCT58128  
 Phoenix ID: CT58147

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: MJ-20

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/26/25	CPP	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 30, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

8:50  
 16:20

## Laboratory Data

SDG ID: GCT58128  
 Phoenix ID: CT58148

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: MJ-21

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.3	1	1	ppb	15			06/26/25	CPP	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 30, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

8:51  
 16:20

## Laboratory Data

SDG ID: GCT58128  
 Phoenix ID: CT58149

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: MJ-22

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.3	1	1	ppb	15			06/26/25	CPP	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**June 30, 2025**

**Reviewed and Released by: Alejandro Paredes, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

8:52  
 16:20

## Laboratory Data

SDG ID: GCT58128  
 Phoenix ID: CT58150

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: MJ-23

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/26/25	CPP	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 30, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

8:52  
 16:20

## Laboratory Data

SDG ID: GCT58128  
 Phoenix ID: CT58151

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: MJ-24

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/26/25	CPP	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 30, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC, KB  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

8:53  
 16:20

## Laboratory Data

SDG ID: GCT58128  
 Phoenix ID: CT58152

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: MJ-25

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/26/25	CPP	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 30, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager

# Analysis Report - Summary

June 30, 2025

Attn: Jarred Panecki  
McCabe Environmental Services, LLC  
464 Valley Brook Avenue  
Lyndhurst, New Jersey 07071



Environmental Laboratories, Inc.  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823

SDG I.D.: GCT58128



Sample	Client Id	Col Date	Parameter	Result	RL	Units	Date Analyzed	Reference
Project: 25-05225 Bayonne Board Of Education								
CT58128	MJ-01	06/21/25	Lead	< 1	1	ppb	06/26/25	E200.5
CT58129	MJ-02	06/21/25	Lead	< 1	1	ppb	06/26/25	E200.5
CT58130	MJ-03	06/21/25	Lead	< 1	1	ppb	06/26/25	E200.5
CT58131	MJ-04	06/21/25	Lead	< 1	1	ppb	06/26/25	E200.5
CT58132	MJ-05	06/21/25	Lead	1.7	1	ppb	06/26/25	E200.5
CT58133	MJ-06	06/21/25	Lead	< 1	1	ppb	06/26/25	E200.5
CT58134	MJ-07	06/21/25	Lead	1.3	1	ppb	06/26/25	E200.5
CT58135	MJ-08	06/21/25	Lead	< 1	1	ppb	06/26/25	E200.5
CT58136	MJ-09	06/21/25	Lead	< 1	1	ppb	06/26/25	E200.5
CT58137	MJ-10	06/21/25	Lead	< 1	1	ppb	06/26/25	E200.5
CT58138	MJ-11	06/21/25	Lead	< 1	1	ppb	06/26/25	E200.5
CT58139	MJ-12	06/21/25	Lead	< 1	1	ppb	06/26/25	E200.5
CT58140	MJ-13	06/21/25	Lead	< 1	1	ppb	06/26/25	E200.5
CT58141	MJ-14	06/21/25	Lead	< 1	1	ppb	06/26/25	E200.5
CT58142	MJ-15	06/21/25	Lead	2.5	1	ppb	06/26/25	E200.5
CT58143	MJ-16	06/21/25	Lead	< 1	1	ppb	06/26/25	E200.5
CT58144	MJ-17	06/21/25	Lead	1.8	1	ppb	06/26/25	E200.5
CT58145	MJ-18	06/21/25	Lead	< 1	1	ppb	06/26/25	E200.5
CT58146	MJ-19	06/21/25	Lead	< 1	1	ppb	06/26/25	E200.5
CT58147	MJ-20	06/21/25	Lead	< 1	1	ppb	06/26/25	E200.5
CT58148	MJ-21	06/21/25	Lead	1.3	1	ppb	06/26/25	E200.5
CT58149	MJ-22	06/21/25	Lead	1.3	1	ppb	06/26/25	E200.5
CT58150	MJ-23	06/21/25	Lead	< 1	1	ppb	06/26/25	E200.5
CT58151	MJ-24	06/21/25	Lead	< 1	1	ppb	06/26/25	E200.5
CT58152	MJ-25	06/21/25	Lead	< 1	1	ppb	06/26/25	E200.5

Sample	Client Id	Col Date	Parameter	Result	RL	Units	Date Analyzed	Reference
--------	-----------	-------------	-----------	--------	----	-------	------------------	-----------

Comments:

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

ND=Not detected BDL=Below Detection Level RL=Reporting Level CL=Client Limit



Phyllis Shiller  
 Laboratory Director  
 June 30, 2025



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# QA/QC Report

June 30, 2025

## QA/QC Data

SDG I.D.: GCT58128

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	-------	--------	---------------	------------	---------	-------	--------	---------	------	-------	--------	--------------	--------------

QA/QC Batch 790690A (mg/L), QC Sample No: CT58124 (CT58128, CT58129, CT58130, CT58131, CT58132, CT58133)

### ICP Metals - Aqueous

Lead	BRL	0.0010				105			106			85 - 115	20
------	-----	--------	--	--	--	-----	--	--	-----	--	--	----------	----

Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 790691 (mg/L), QC Sample No: CT58134 (CT58134, CT58135, CT58136, CT58137, CT58138, CT58139, CT58140, CT58141, CT58142, CT58143)

### ICP Metals - Aqueous

Lead	BRL	0.0010	0.0013	0.0011	NC	105			106			85 - 115	20
------	-----	--------	--------	--------	----	-----	--	--	-----	--	--	----------	----

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 790691A (mg/L), QC Sample No: CT58144 (CT58144, CT58145, CT58146, CT58147, CT58148, CT58149, CT58150, CT58151, CT58152)

### ICP Metals - Aqueous

Lead	BRL	0.0010				105			104			85 - 115	20
------	-----	--------	--	--	--	-----	--	--	-----	--	--	----------	----

Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Intf - Interference
- (ISO) - Isotope Dilution

  
 Phyllis Shiller, Laboratory Director  
 June 30, 2025

Monday, June 30, 2025

Criteria: NJ: DW

State: NJ

## Sample Criteria Exceedances Report

GCT58128 - MCCABE-PB

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
--------	-------	-----------------	----------	--------	----	----------	----------------	-------------------

\*\*\* No Data to Display \*\*\*

Phoenix Laboratories does not assume responsibility for the data contained in this exceedance report. It is provided as an additional tool to identify requested criteria exceedences. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedence information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



**Environmental Laboratories, Inc.**  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823



## Analysis Comments

June 30, 2025

SDG I.D.: GCT58128

---

The following analysis comments are made regarding exceptions to criteria not already noted in the Analysis Report or QA/QC Report: None.

MCCABE ENVIRONMENTAL SERVICES, L.L.C.  
 464 VALLEY BROOK AVENUE LYNDBURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD in DRINKING WATER  
 CHAIN-OF-CUSTODY FORM

CLIENT NAME: Bayonne Board of Education		SITE ADDRESS: Mary J. Donohoe Community School 25 E 5th St, Bayonne, NJ 07002	
FIELD INSPECTOR'S NAME: C. Clare, A. Lezama K. Bossak		TURNAROUND TIME REQUESTED: 2-Week	
MES PROJECT #: 25-05225		SAMPLE DATE: 6/21/25	

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW	MJ-01	FD - 1st Fl. Pre K Bathroom Sink	8:19 am	LEAD - 200.8
DW	MJ-02	30 second Flush - 1st Fl. Pre K Bathroom Sink	8:20 am	LEAD - 200.8
DW	MJ-03	FD - Bubble by SA	8:21 am	LEAD - 200.8
DW	MJ-04	FD - Pre K HR3 Bathroom Sink - Left	8:23 am	LEAD - 200.8
DW	MJ-05	FD - Pre K HR3 Bathroom Sink - Right	8:24 am	LEAD - 200.8
DW	MJ-06	FD - Bottle Filler by Principal Office	8:26 am	LEAD - 200.8
DW	MJ-07	FD - Food Storage Sink	8:28 am	LEAD - 200.8
DW	MJ-08	FD - Chiller by Pre K Room	8:29 am	LEAD - 200.8
DW	MJ-09	FD - Pre K Room 1 - Sink	8:30 am	LEAD - 200.8
DW	MJ-10	FD - Pre K Room Bathroom Sink	8:31	LEAD - 200.8

Relinquished by (Print) <i>Gary Clare</i>	Date: 6/23/25	Time: 1015	Received by: (Print) <i>J. Demers</i>	Date: 8/23	Time: 1015
Signature: <i>GC</i>			Signature: <i>JD</i>		
Relinquished by (Print)	Date:	Time:	Received by: (Print) <i>Aby Lee</i>	Date: 6/23/25	Time: 1620
Signature: <i>GA</i>			Signature: <i>Aby Lee</i>		

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

2.2" WCIIP

**MCCABE ENVIRONMENTAL SERVICES, L.L.C.**

464 VALLEY BROOK AVENUE LYNHURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

**LEAD in DRINKING WATER  
CHAIN-OF-CUSTODY FORM**

CLIENT NAME: Bayonne Board of Education  
SITE ADDRESS: Mary J. Donohoe Community School  
25 E 5th St, Bayonne, NJ 07002

FIELD INSPECTOR'S NAME: G. Clare, A. Lezama, K. Broszek  
TURNAROUND TIME REQUESTED: 2-Week  
MES PROJECT #: 25-05225  
SAMPLE DATE: 6/21/25

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED	
DW	MJ-11	FD - Pre K Room 2 - Sink	8:31	LEAD - 200.8	58138
DW	MJ-12	FD - Pre K Room 2 - Bathroom Sink	8:32	LEAD - 200.8	58139
DW	MJ-13	FD - Bubble by Room 11B	8:34	LEAD - 200.8	58140
DW	MJ-14	FD - Bottle Filler by Room 6B	8:36	LEAD - 200.8	58141
DW	MJ-15	FD - Nurses Office Sink	8:37	LEAD - 200.8	58142
DW	MJ-16	FD - Teachers Room Faucet	8:39	LEAD - 200.8	58143
DW	MJ-17	FD - Bubble by Room 19C	8:44	LEAD - 200.8	58144
DW	MJ-18	FD - Bottle Filler by Room 13C	8:46	LEAD - 200.8	58145
DW	MJ-19	FD - Chiller by Music Room	8:47	LEAD - 200.8	58146
DW	MJ-20	FD - Professional Development Rm Bubble	8:49	LEAD - 200.8	58147

Relinquished by (Print) Gary Clare  
Signature: [Signature] Date: 6/23/25 Time: 1015  
Received by: (Print) J. Demers  
Signature: [Signature] Date: 6/20/25 Time: 1015

Relinquished by (Print) [Signature]  
Signature: [Signature] Date: 6/20/25 Time: 1620  
Received by: (Print) Abby Lee  
Signature: [Signature]

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

NJ Certified WBE

2.2° WCIP

**MCCABE ENVIRONMENTAL SERVICES, L.L.C.**

464 VALLEY BROOK AVENUE LYNDBURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

**LEAD in DRINKING WATER  
CHAIN-OF-CUSTODY FORM**

CLIENT NAME: Bayonne Board of Education  
 SITE ADDRESS: Mary J. Donohoe Community School  
 25 E 5th St, Bayonne, NJ 07002

FIELD INSPECTOR'S NAME: G. Clare, A. Lezama, K. Roscoe  
 TURNAROUND TIME REQUESTED: 2-Week  
 MES PROJECT #: 25-05225  
 SAMPLE DATE: 6/21/25

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED	
DW	MJ-21	FD- Professional Development Room Faucet	8:50	LEAD - 200.8	58148
DW	MJ-22	FD- <del>Art</del> Music Room Bubblers	8:51	LEAD - 200.8	58149
DW	MJ-23	FD- Music Room Faucet	8:52	LEAD - 200.8	58150
DW	MJ-24	FD- Art Room Bubblers	8:52	LEAD - 200.8	58151
DW	MJ-25	FD- Art Room Faucet	8:53	LEAD - 200.8	58152
DW				LEAD - 200.8	
DW				LEAD - 200.8	
DW				LEAD - 200.8	
DW				LEAD - 200.8	
DW				LEAD - 200.8	

Relinquished by (Print) Gary Clare  
 Signature: *[Signature]*  
 Date: 6/23/25 Time: 1015  
 Received by: (Print) J. Demers  
 Signature: *[Signature]*  
 Date: 8-23-2025 Time: 1015

Relinquished by (Print)  
 Signature: *[Signature]*  
 Date: 6/23/25 Time: 1620  
 Received by: (Print) Abby Lee  
 Signature: *[Signature]*

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phipenix Environmental Laboratories

NJ Certified WBE

**APPENDIX B**

**SCHOOL DISTRICT SAMPLING  
ATTACHMENTS**

## Attachment A - List of Priority for Sampling

SCHOOL NAME	DATE OF SAMPLING	CERTIFIED LABORATORY	NOTES
Mary J. Donohoe Community School	06/21/2025	Phoenix Environmental Laboratories Inc.	

## Attachment B – Plumbing Profile

**Note:** Complete for each school. For additional information see the USEPA publication, "The 3Ts for Reducing Lead in Drinking Water in Schools"

Name of School: Mary J. Donohoe Community School Grade Levels: K-8

Address: 25 East 5th St., Bayonne, NJ 07002

Individual school project officer Signature: *Scott Nolan*

Date: 8/5/2025

Questions	Answers
<b>Background Information</b>	
1. What year was the original building constructed? Were any buildings or additions added to the original facility?	K-8 Grade School Built in 1900 K-8 Addition was added in 2000
2. If the building was constructed or repaired after 1986, was lead-free plumbing and solder utilized? What type of solder was used? Document all locations where lead solder was used.	Any repairs made after 1986 were done using lead free solder
3. Where are the most recent plumbing repairs and replacements?	Location: 1st floor hallway Description: New bottle filler fountain
4. With what materials is the service connection (the pipe that carries water to the school from the public water system's main in the street) made? Where is the Service Line located? (This is the POE location.)	Material: Main Building - Duct Iron Location: The water main (East 5th St) enters the basement/first floor flows through the building to the boiler room where the water meter is located and continues to the remainder of the building
5. Is there point of entry (POE) or point of use (POU) treatment in use?	Y / N No treatment of water Type: at POE Location: Main Building 1920 City water comes treated

Questions	Answers
6. Are there tanks in your plumbing system (pressure tanks, gravity storage tanks)?	Y / N Yes Building has two 75 gallon hot water storage tank located in the old boiler room Building has a 50 gallon hot water storage tank located in boiler room Building has a 38 gallon hot water heater located 2nd floor storage
7. Does the school have a filter maintenance and operation program? If so, who is responsible for this program? What is the process for adding filters?	Yes, Scott Nolan, Andy McCabe, Vinny Caiola, change filters on an as needed basis assign plumbers
8. Have accessible screens or aerators on outlets that provide drinking water been cleaned? Does the school have a screen or aerator maintenance program?	Y / N Yes  The district has set-up a routine maintenance program to clean screens
9. Have there been any complaints about bad (metallic) taste? Note location(s).	Y / N NO  Location:
10. Review records and consult with the public water supplier to determine whether any water samples have been taken in the building for any contaminants. If so, identify: <ul style="list-style-type: none"> <li>• Name of contaminant(s)</li> <li>• Concentrations found</li> <li>• pH level</li> </ul> Is testing done regularly at the building?	No indoor testing by public water supplier
11. Other plumbing background questions include: <ul style="list-style-type: none"> <li>• Are blueprints of the building available?</li> <li>• Are there known plumbing “dead-ends”, low use areas, existing leaks or other “problem areas”?</li> </ul> Are renovations planned for any of the plumbing system?	Not all prints are available No dead-end low use areas All leaks were identified during walk through and have been repaired No plumbing system renovations

Questions	Answers
<b>Walk-Through</b> <i>These questions should be addressed during the walk-through of the facility, while Attachment C- Drinking Water Outlet Inventory is being completed.</i>	
1. Confirm the material of Service Line visually.	Duct iron
2. Confirm the presence of POE or POU treatment.	No POE or POU treatment
3. What are the potable water pipes made of in your facility? <ul style="list-style-type: none"> <li>• Lead</li> <li>• Plastic</li> <li>• Galvanized Metal</li> <li>• Cast Iron</li> <li>• Copper</li> <li>• Other</li> </ul> Note the water flow through the building and the areas that receive water first, and which areas receive water last.	Cooper Galvanized Metal Brass  Water flow through the building shown on the prints
4. Are electrical wires grounded to Water Pipes? Note location(s).	Y / N  No  No electrical wires grounded to water pipes
5. Are brass fittings, faucets, or valves used in your drinking water system? Note that most faucets are brass on the inside. Document the locations of any brass water outlet to be sampled.	Location: Complete in "Brass" Column in Attachment C- Water Outlet Inventory. Yes Completed in Attachment C - Water Outlet Inventory
6. Locate all drinking water outlets (i.e. water coolers, bubblers, ice machines, kitchen/ food prep sinks, etc.) in the facility.	Complete in Attachment C-Water Outlet Inventory.

Questions	Answers
<p>7. Have the brands and models of the water coolers in the school been compared to the list of recalled water coolers in the Toolkit?</p> <p>Recalled Drinking Water Fountains</p> <p>Make and Model</p>	<p>Y / N Yes all water coolers have been checked and compared to the list of recalled water coolers</p>
<p>8. Have signs of corrosion, such as frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry been detected? Note the locations of water outlets.</p>	<p>Type None on the list of recalled water coolers</p> <p>Complete in "Signs of Corrosion" column in Attachment C- Drinking Water Outlet Inventory.</p>
<p>9. Are there any outlets that are not operational and therefore out of service? Permanently? Temporarily?</p> <p>Permanently</p> <p>Temporarily</p>	<p>Y / N</p> <p>Complete "Operational Column" in Attachment C- Drinking Water Outlet Inventory.</p> <p>Type/ Location</p> <p>Description</p>

## Attachment C – Drinking Water Outlet Inventory

Name of School: Mary J. Donohoe Community School

Address: 25 E 5th Street, Bayonne, New Jersey 07002

Grade Levels: Elementary School

Year School Constructed: Unknown

Renovated/Additions: NA

Individual School Project Officer: Scott Nolan

Date Completed: 07/11/2025

# <sup>1</sup>	Type	Location	Code	Operational <sup>2</sup> (Y/N)	Signs of Corrosion <sup>3</sup> (Y/N)	Filter <sup>4</sup> (Y/N)	Brass Fittings, Faucets or valves? (Y/N)	Aerator/ Screen (Y/N)	Motion Activated (Y/N)	Chiller (Y/N)	Water Cooler		Comments
											Make	Model	
01	Sink	1st Floor Pre-K Bathroom	MJ-01	Y	N	N	N	Y	N	N	NA	NA	
02	Sink	1st Floor Pre-K Bathroom	MJ-02	Y	N	N	N	Y	N	N	NA	NA	Flush
03	Water Fountain	Bubbler by Room 5A	MJ-03	Y	N	Y	N	N	N	N	NA	NA	
04	Sink	Pre-K HR3 Bathroom Sink – Left	MJ-04	Y	N	N	N	Y	N	N	NA	NA	
05	Sink	Pre-K HR3 Bathroom Sink – Right	MJ-05	Y	N	N	N	Y	N	N	NA	NA	

<sup>1</sup> Number outlets starting at the closest outlet to the Point of Entry (POE).

<sup>2</sup> Document if permanently or temporarily out of service on the Attachment B- Plumbing Profile.

<sup>3</sup> Signs of corrosion detected, such as but not limited to frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry.

<sup>4</sup> Document on Attachment D- Filter Inventory.

06	Bottle Filling Station	By Principal Office	MJ-06	Y	N	Y	N	N	Y	Y	NA	NA	
07	Sink	Food Storage	MJ-07	Y	N	Y	N	N	N	N	NA	NA	
08	Chiller	Chiller by Pre-K Room 1	MJ-08	Y	N	Y	N	N	N	Y	NA	NA	
09	Sink	Pre-K Room 1 – Sink	MJ-09	Y	N	N	N	Y	N	N	NA	NA	
10	Sink	Pre-K Room 1 Bathroom Sink	MJ-10	Y	N	N	N	Y	N	N	NA	NA	
11	Sink	Pre-K Room 2 – Sink	MJ-11	Y	N	N	N	Y	N	N	NA	NA	
12	Sink	Pre-K Room 2 Bathroom Sink	MJ-12	Y	N	N	N	Y	N	N	NA	NA	
13	Water Fountain	Bubbler by Room 11B	MJ-13	Y	N	N	N	N	N	N	NA	NA	
14	Bottle Filling Station	Bottle Filler by Room 6B	MJ-14	Y	N	Y	N	N	Y	Y	NA	NA	
15	Sink	Nurse's Office	MJ-15	Y	N	N	N	Y	N	N	NA	NA	
16	Sink	Teacher's Room	MJ-16	Y	N	N	N	Y	N	N	NA	NA	
17	Water Fountain	Bubbler by Room 19C	MJ-17	Y	N	Y	N	N	N	N	NA	NA	
18	Bottle Filling Station	By Room 13C	MJ-18	Y	N	Y	N	N	Y	Y	NA	NA	
19	Chiller	Chiller by Music Room	MJ-19	Y	N	Y	N	N	N	Y	NA	NA	
20	Water Fountain	Professional Development Room Bubbler	MJ-20	Y	N	N	N	N	N	N	NA	NA	
21	Sink	Professional Development Room Faucet	MJ-21	Y	N	N	N	Y	N	N	NA	NA	
22	Water Fountain	Music Room Bubbler	MJ-22	Y	N	N	N	N	N	N	NA	NA	
23	Sink	Music Room Faucet	MJ-23	Y	N	N	N	Y	N	N	NA	NA	
24	Water Fountain	Art Room Bubbler	MJ-24	Y	N	N	N	N	N	N	NA	NA	

25	Sink	Art Room Faucet	MJ-25	Y	N	N	N	Y	N	N	NA	NA	
----	------	--------------------	-------	---	---	---	---	---	---	---	----	----	--

<sup>1</sup> Number outlets starting at the closest outlet to the Point of Entry (POE).

<sup>1</sup> Document if permanently or temporarily out of service on the Attachment B- Plumbing Profile.

<sup>1</sup> Signs of corrosion detected, such as but not limited to frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry.

<sup>1</sup> Document on Attachment D- Filter Inventory.

### Attachment D - Filter Inventory

Name of School: Mary J. Donohoe Community School

Grade Levels: Elementary School

Address: 25 E 5th Street, Bayonne, New Jersey 07002

Individual School Project Officer: Scott Nolan

Date: 07/11/2025

Sample Location / Code	Brand	Type (Make & Model)	Date Installed or Replaced	Replacement Frequency	NSF Certified for Lead Reduction Y/N
MJ-01	N/A	N/A	N/A	N/A	N/A
MJ-02	N/A	N/A	N/A	N/A	N/A
MJ-03	Aqua Pure	AP217	5/6/2025	N/A	N/A
MJ-04	N/A	N/A	N/A	N/A	N/A
MJ-05	N/A	N/A	N/A	N/A	N/A
MJ-06	Elkay	LZWSRSM	N/A	N/A	N/A
MJ-07	American Plumber	W385-PR	N/A	N/A	N/A
MJ-08	Elkay	EBFSA8-1B	N/A	N/A	N/A
MJ-09	N/A	N/A	N/A	N/A	N/A
MJ-10	N/A	N/A	N/A	N/A	N/A
MJ-11	N/A	N/A	N/A	N/A	N/A
MJ-12	N/A	N/A	N/A	N/A	N/A
MJ-13	Aqua Pure	AP 217	N/A	N/A	N/A
MJ-14	Elkay	LZWRSM	N/A	N/A	N/A
MJ-15	Aqua Pure	AP 217	N/A	N/A	N/A
MJ-16	N/A	N/A	N/A	N/A	N/A
MJ-17	Elkay	N/A	N/A	N/A	N/A
MJ-18	Elkay	LZWRSM	N/A	N/A	N/A
MJ-19	Elkay	EBFSA8-1D	N/A	N/A	N/A
MJ-20	N/A	N/A	N/A	N/A	N/A
MJ-21	N/A	N/A	N/A	N/A	N/A
MJ-22	N/A	N/A	N/A	N/A	N/A
MJ-23	N/A	N/A	N/A	N/A	N/A
MJ-24	N/A	N/A	N/A	N/A	N/A
MJ-25	N/A	N/A	N/A	N/A	N/A

### Attachment E – Flushing Log

Name of School: Mary J. Donohoe Community School

Address: 25 E 5th Street, Bayonne, New Jersey 07002

Grade Levels: Elementary School

Individual School Project Officer: Scott Nolan

Date: 07/15/2025

Sample Location Description	Sample Location Code	Date	Time	Duration of Flushing	Reason for Flushing
1st Floor Pre-K Bathroom Sink	MJ-01	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
1st Floor Pre-K Bathroom Sink	MJ-02	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Room 5A	MJ-03	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Pre-K HR3 Bathroom Sink – Left	MJ-04	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Pre-K HR3 Bathroom Sink – Right	MJ-05	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bottle Filler by Principal Office	MJ-06	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Food Storage Sink	MJ-07	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Chiller by Pre-K Room 1	MJ-08	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Pre-K Room 1 – Sink	MJ-09	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Pre-K Room 1 Bathroom Sink	MJ-10	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Pre-K Room 2 – Sink	MJ-11	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Pre-K Room 2 Bathroom Sink	MJ-12	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Room 11B	MJ-13	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bottle Filler by Room 6B	MJ-14	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Nurse’s Office Sink	MJ-15	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Teacher’s Room Faucet	MJ-16	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Room 19C	MJ-17	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bottle Filler by Room 13C	MJ-18	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Chiller by Music Room	MJ-19	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Professional Development Room Bubbler	MJ-20	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling

Bayonne BOE: Sampling Plan

Professional Development Room Faucet	MJ-21	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Music Room Bubbler	MJ-22	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Music Room Faucet	MJ-23	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Art Room Bubbler	MJ-24	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Art Room Faucet	MJ-25	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling

## Attachment F - Pre - Sampling Water Use Certification

TO BE COMPLETED BY THE BAYONNE BOE DISTRICT REPRESENTATIVE:		
School Name:	<u>Mary J. Donohoe Community School</u>	
Sample collection address:	<u>25 E 5th Street, Bayonne, New Jersey 07002</u>	
Water was last used:	<u>Time: 5:30 pm</u>	<u>Date: June 20, 2025</u>
Sample commencement:	<u>Time: 8:19 am</u>	<u>Date: June 21, 2025</u>
I have read the Lead Drinking Water Testing Sampling Plan and Quality Assurance Project Plan and I am certifying that samples were collected in accordance with these plans.		
Scott Nolan	<u>07/29/25</u>	
Signature	Date	