



464 Valley Brook Avenue, Lyndhurst NJ 07071
129 Sea Girt Avenue, Manasquan NJ 08736
Phone: (800) 423-0766 • Fax: (201) 438-1798
www.mccabeenv.com

LEAD IN DRINKING WATER TESTING REPORT

Conducted for:

Bayonne Board of Education
669 Avenue A
Bayonne, New Jersey 07002

Conducted at:

William Shemin Midtown Community
550 Avenue A
Bayonne, New Jersey 07002

Submitted by:

McCabe Environmental Services, L.L.C.
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

REPORT DATE: August 5, 2025

MES PROJECT NO.: 25-05225

Prepared by:

A handwritten signature in blue ink, appearing to read 'Arllitzy Lezama'.

Arllitzy Lezama
Environmental Scientist

Signed for the Company by:

A handwritten signature in blue ink, appearing to read 'John H. Chiaviello'.

John H. Chiaviello
Vice President

TABLE OF CONTENTS

	Page
1.0 INTRODUCTION	1
2.0 SCOPE OF WORK.....	1
3.0 PROCEDURES.....	1
4.0 TABLE OF SAMPLE RESULTS	2
5.0 DISCUSSION AND CONCLUSION	5

APPENDIX A

Laboratory Certificates of Analysis
&
Sample Chain of Custody Forms

APPENDIX B

School District Sampling Attachments

1.0 INTRODUCTION

McCabe Environmental Services, L.L.C. (McCabe) was retained by Bayonne Board of Education (Client) to conduct lead in drinking water testing at William Shemin Community School.

The project information is as follows:

Client Name: Bayonne Board of Education

Contact Person: Mr. Daniel Castles

Project Name: William Shemin Community School – Lead in Drinking Water

Project Location: 550 Avenue A
Bayonne, New Jersey 07002

Date(s) of Service: June 20, 2025

McCabe Personnel: Gary Clare and Arllitzy Lezama

2.0 SCOPE OF WORK

Drinking water testing was performed at William Shemin Community School located at 550 Avenue A, Bayonne, New Jersey on June 20, 2025. The purpose of the testing was to determine if the building’s plumbing was having an adverse impact on water quality, specifically with regard to lead concentrations. Samples were collected from various potential drinking water outlets located throughout the building. Testing was followed as per past reports provided by Bayonne Board of Education.

3.0 PROCEDURES

After determining which outlets would be sampled, McCabe personnel collected a "first draw" sample at each location. A "first draw" is the initial water that is first to come out of the tap after a period of inactivity. Following the “first draw”, a "30 second flush" sample was also collected where the main service line comes into the building. All samples were collected into 250 mL sterile bottles, labeled with a sample identification, and analyzed in accordance with EPA approved methods to determine the level of lead in drinking water. Samples were analyzed by an accredited laboratory.

The U.S. Environmental Protection Agency (EPA) has established National Primary Drinking Water Regulations (NPDWR) that set mandatory water quality standards for drinking water contaminants. These are enforceable standards called "maximum contaminant levels" or "MCL", which are established to protect the public against consumption of drinking water contaminants that present a risk to human health. An MCL is the maximum allowable amount of a contaminant in drinking water which is delivered to the consumer.

The EPA has established the Lead and Copper Rule that sets standards for state and public water systems. This rule has set an MCL for lead at 15 parts per billion (ppb) for a one liter sample. However, the EPA also established the Lead in Drinking Water at Schools and Child Care Facilities in which the EPA recommends an MCL of 20 ppb for a 250 milliliter first draw sample. In order to be more stringent, for our report purposes we have compared all results to both the 15 ppb and the 20 ppb standards.

4.0 TABLE OF SAMPLE RESULTS

The following table presents all sample results in order of sample identification:

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
MC-01	First Draw – Chiller by Laundry Room - Left	< 0.5	Pass	Pass
MC-02	30 Second Flush – Chiller by Laundry Room - Left	< 0.5	Pass	Pass
MC-03	First Draw – Bubbler by Laundry Room - Right	< 0.5	Pass	Pass
MC-04	First Draw – Room 001 Pre-K Bathroom Sink	0.6	Pass	Pass
MC-05	First Draw – Room 003 Pre-K Bathroom Sink	< 0.5	Pass	Pass
MC-06	First Draw – Room 005 Pre-K Bathroom Sink	< 0.5	Pass	Pass
MC-07	First Draw – Room 107 Bubbler	< 0.5	Pass	Pass
MC-08	First Draw – Room 107 Faucet	< 0.5	Pass	Pass
MC-09	First Draw – Room 109 Bubbler	< 0.5	Pass	Pass
MC-10	First Draw – Room 109 Faucet	< 0.5	Pass	Pass
MC-11	First Draw – Room 111 Bubbler	1.6	Pass	Pass
MC-12	First Draw – Room 111 Faucet	0.9	Pass	Pass
MC-13	First Draw – Bubbler by Room 112 - Left	< 0.5	Pass	Pass
MC-14	First Draw – Chiller by Room 112 - Right	< 0.5	Pass	Pass
MC-15	First Draw – Room 113 Bubbler	1.5	Pass	Pass
MC-16	First Draw – Room 113 Faucet	< 0.5	Pass	Pass
MC-17	First Draw – Room 114 Faucet	< 0.5	Pass	Pass
MC-18	First Draw – Room 115 Bubbler	< 0.5	Pass	Pass

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
MC-19	First Draw – Room 115 Faucet	< 0.5	Pass	Pass
MC-20	First Draw – Room 116 Bubblers	0.5	Pass	Pass
MC-21	First Draw - Room 116 Faucet	< 0.5	Pass	Pass
MC-22	First Draw – Room 117 Bubblers	< 0.5	Pass	Pass
MC-23	First Draw – Room 117 Faucet	< 0.5	Pass	Pass
MC-24	First Draw – Room 118 Faucet	< 0.5	Pass	Pass
MC-25	First Draw – Chiller by Gym	0.8	Pass	Pass
MC-26	First Draw – Bubblers by Gym – Bank 1 (Right)	< 0.5	Pass	Pass
MC-27	First Draw – Bubblers Gym – Bank 2	OUT OF ORDER		
MC-28	First Draw - Bubblers by Gym – Bank 3	< 0.5	Pass	Pass
MC-29	First Draw - Bubblers by Gym – Bank 4 (Left)	< 0.5	Pass	Pass
MC-30	First Draw – Nurse’s Office Faucet	1.7	Pass	Pass
MC-31	First Draw – Bubblers by Elevator – Left First Floor	< 0.5	Pass	Pass
MC-32	First Draw - Bubblers by Elevator – Right First Floor	< 0.5	Pass	Pass
MC-33	First Draw – Kitchen Sink – Right Faucet	< 0.5	Pass	Pass
MC-34	First Draw – Kitchen Sink – Left Faucet	< 0.5	Pass	Pass
MC-35	First Draw - Bubblers by Room 219 – Bank 1 (Left)	< 0.5	Pass	Pass
MC-36	First Draw - Bubblers by Room 219 – Bank 2	< 0.5	Pass	Pass
MC-37	First Draw - Bubblers by Room 219 – Bank 3	< 0.5	Pass	Pass
MC-38	First Draw - Bubblers by Room 219 – Bank 4 (Right)	< 0.5	Pass	Pass

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
MC-39	First Draw - Chiller by Room 219	< 0.5	Pass	Pass
MC-40	First Draw – Bubbler by Elevator – Left – Second Floor	< 0.5	Pass	Pass
MC-41	First Draw – Bubbler by Elevator – Middle Second Floor	< 0.5	Pass	Pass
MC-42	First Draw - Bubbler by Elevator – Right Second Floor	< 0.5	Pass	Pass
MC-43	First Draw – Faucet in Storage Room Next to Room 201	< 0.5	Pass	Pass
MC-44	First Draw – Faculty Room Faucet	< 0.5	Pass	Pass
MC-45	First Draw – Bubbler Outside Faculty Room – Left	< 0.5	Pass	Pass
MC-46	First Draw - Bubbler by Bathrooms – Bank 1 (Left) – Third Floor	< 0.5	Pass	Pass
MC-47	First Draw - Bubbler by Room 305 – Bank 2 – Third Floor	< 0.5	Pass	Pass
MC-48	First Draw - Bubbler by Room 305 – Bank 3 – Third Floor	< 0.5	Pass	Pass
MC-49	First Draw - Bubbler by Room 305 – Bank 4 (Right) – Third Floor	< 0.5	Pass	Pass
MC-50	First Draw – Chiller by Bathrooms – Third Floor (Right)	< 0.5	Pass	Pass
MC-51	First Draw - Bubbler by Elevator - Left – Third Floor	1	Pass	Pass
MC-52	First Draw - Bubbler by Elevator – Middle – Third Floor	< 0.5	Pass	Pass
MC-53	First Draw - Bubbler by Elevator – Right – Third Floor	< 0.5	Pass	Pass
MC-54	First Draw – Faculty Room Faucet – Third Floor	< 0.5	Pass	Pass

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
MC-55	First Draw – Bubblers Outside Faculty Room - Left	OUT OF ORDER		
MC-56	First Draw - Bubblers Outside Faculty Room – Right	< 0.5	Pass	Pass

5.0 DISCUSSION AND CONCLUSION

A total of fifty-four (54) samples were collected from William Shemin Community School. All samples were found to be less than the EPA Lead in Drinking Water at Schools and Child Care Facilities standard of 20 ppb, as well as the EPA Lead and Copper Rule standard of 15 ppb.

In addition, McCabe Environmental recommends annual drinking water sampling to ensure that the building’s plumbing is not having an adverse impact on water quality.

APPENDIX A

**LABORATORY CERTIFICATES OF ANALYSIS
&
SAMPLE CHAIN OF CUSTODY FORMS**



Thursday, July 03, 2025

Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
SDG ID: GCT58040
Sample ID#s: CT58040 - CT58093

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory. This report is incomplete unless all pages indicated in the pagination at the bottom of the page are included.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Sincerely yours,

A handwritten signature in black ink that reads "Phyllis Shiller". The signature is written in a cursive style.

Phyllis Shiller
Laboratory Director

NELAC - #NY11301
CT Lab Registration #PH-0618
MA Lab Registration #M-CT007
ME Lab Registration #CT-007
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003
NY Lab Registration #11301
PA Lab Registration #68-03530
RI Lab Registration #63
VT Lab Registration #VT11301



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Sample Id Cross Reference

July 03, 2025

SDG I.D.: GCT58040

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION

Client Id	Lab Id	Matrix	Col Date
MC-01	CT58040	DRINKING WATER	06/20/25 14:07
MC-02	CT58041	DRINKING WATER	06/20/25 14:08
MC-03	CT58042	DRINKING WATER	06/20/25 14:08
MC-04	CT58043	DRINKING WATER	06/20/25 14:09
MC-05	CT58044	DRINKING WATER	06/20/25 14:11
MC-06	CT58045	DRINKING WATER	06/20/25 14:14
MC-07	CT58046	DRINKING WATER	06/20/25 14:16
MC-08	CT58047	DRINKING WATER	06/20/25 14:18
MC-09	CT58048	DRINKING WATER	06/20/25 14:20
MC-10	CT58049	DRINKING WATER	06/20/25 14:21
MC-11	CT58050	DRINKING WATER	06/20/25 14:22
MC-12	CT58051	DRINKING WATER	06/20/25 14:23
MC-13	CT58052	DRINKING WATER	06/20/25 14:25
MC-14	CT58053	DRINKING WATER	06/20/25 14:26
MC-15	CT58054	DRINKING WATER	06/20/25 14:28
MC-16	CT58055	DRINKING WATER	06/20/25 14:29
MC-17	CT58056	DRINKING WATER	06/20/25 14:29
MC-18	CT58057	DRINKING WATER	06/20/25 14:30
MC-19	CT58058	DRINKING WATER	06/20/25 14:31
MC-20	CT58059	DRINKING WATER	06/20/25 14:31
MC-21	CT58060	DRINKING WATER	06/20/25 14:32
MC-22	CT58061	DRINKING WATER	06/20/25 14:32
MC-23	CT58062	DRINKING WATER	06/20/25 14:32
MC-24	CT58063	DRINKING WATER	06/20/25 14:33
MC-25	CT58064	DRINKING WATER	06/20/25 14:33
MC-26	CT58065	DRINKING WATER	06/20/25 14:34
MC-28	CT58066	DRINKING WATER	06/20/25 14:35
MC-29	CT58067	DRINKING WATER	06/20/25 14:37
MC-30	CT58068	DRINKING WATER	06/20/25 14:38
MC-31	CT58069	DRINKING WATER	06/20/25 14:40



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Sample Id Cross Reference

July 03, 2025

SDG I.D.: GCT58040

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION

Client Id	Lab Id	Matrix	Col Date
MC-32	CT58070	DRINKING WATER	06/20/25 14:41
MC-33	CT58071	DRINKING WATER	06/20/25 14:43
MC-34	CT58072	DRINKING WATER	06/20/25 14:44
MC-35	CT58073	DRINKING WATER	06/20/25 14:51
MC-36	CT58074	DRINKING WATER	06/20/25 14:52
MC-37	CT58075	DRINKING WATER	06/20/25 14:52
MC-38	CT58076	DRINKING WATER	06/20/25 14:53
MC-39	CT58077	DRINKING WATER	06/20/25 14:53
MC-40	CT58078	DRINKING WATER	06/20/25 14:54
MC-41	CT58079	DRINKING WATER	06/20/25 14:55
MC-42	CT58080	DRINKING WATER	06/20/25 14:55
MC-43	CT58081	DRINKING WATER	06/20/25 14:57
MC-44	CT58082	DRINKING WATER	06/20/25 14:58
MC-45	CT58083	DRINKING WATER	06/20/25 15:00
MC-46	CT58084	DRINKING WATER	06/20/25 15:01
MC-47	CT58085	DRINKING WATER	06/20/25 15:02
MC-48	CT58086	DRINKING WATER	06/20/25 15:03
MC-49	CT58087	DRINKING WATER	06/20/25 15:04
MC-50	CT58088	DRINKING WATER	06/20/25 15:04
MC-51	CT58089	DRINKING WATER	06/20/25 15:07
MC-52	CT58090	DRINKING WATER	06/20/25 15:08
MC-53	CT58091	DRINKING WATER	06/20/25 15:10
MC-54	CT58092	DRINKING WATER	06/20/25 15:11
MC-56	CT58093	DRINKING WATER	06/20/25 15:12



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:07
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58040

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-01

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	JM	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:08
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58041

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-02

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	JM	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:08
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58042

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-03

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	JM	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:09
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58043

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-04

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.6	0.5	2	ppb	15			07/01/25	JM	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:11
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58044

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-05

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	JM	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:14
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58045

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-06

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	JM	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:16
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58046

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-07

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	JM	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:18
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58047

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-08

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	JM	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:20
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58048

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-09

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	JM	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:21
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58049

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-10

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	JM	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:22
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58050

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-11

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.6	0.5	2	ppb	15			07/01/25	JM	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:23
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58051

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-12

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.9	0.5	2	ppb	15			07/01/25	JM	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:25
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58052

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-13

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	JM	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:26
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58053

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-14

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	JM	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:28
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58054

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-15

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.5	0.5	2	ppb	15			07/01/25	JM	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:29
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58055

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-16

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	JM	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:29
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58056

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-17

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	JM	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:30
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58057

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-18

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	JM	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:31
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58058

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-19

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	JM	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:31
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58059

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-20

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.5	0.5	2	ppb	15			07/01/25	MGH	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:32
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58060

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-21

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	MGH	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:32
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58061

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-22

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	MGH	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:32
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58062

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-23

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	MGH	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:33
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58063

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-24

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	MGH	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:33
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58064

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-25

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	MGH	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:34
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58065

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-26

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	MGH	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:35
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58066

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-28

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	MGH	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:37
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58067

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-29

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	MGH	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:38
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58068

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-30

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.7	0.5	2	ppb	15			07/01/25	MGH	E200.8
Total Metal Digestion	Completed							06/28/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:40
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58069

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-31

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	MGH	E200.8
Total Metal Digestion	Completed							06/28/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:41
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58070

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-32

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	MGH	E200.8
Total Metal Digestion	Completed							06/28/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:43
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58071

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-33

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.1	0.5	2	ppb	15			07/01/25	MGH	E200.8
Total Metal Digestion	Completed							06/28/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:44
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58072

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-34

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.3	0.5	2	ppb	15			07/01/25	MGH	E200.8
Total Metal Digestion	Completed							06/28/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:51
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58073

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-35

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	MGH	E200.8
Total Metal Digestion	Completed							06/28/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:52
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58074

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-36

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	MGH	E200.8
Total Metal Digestion	Completed							06/28/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:52
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58075

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-37

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	MGH	E200.8
Total Metal Digestion	Completed							06/28/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:53
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58076

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-38

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	MGH	E200.8
Total Metal Digestion	Completed							06/28/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:53
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58077

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-39

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	MGH	E200.8
Total Metal Digestion	Completed							06/28/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:54
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58078

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-40

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	MGH	E200.8
Total Metal Digestion	Completed							06/28/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:55
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58079

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-41

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	MGH	E200.8
Total Metal Digestion	Completed							06/28/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:55
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58080

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-42

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/02/25	MGH	E200.8
Total Metal Digestion	Completed							06/28/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:57
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58081

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-43

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/02/25	MGH	E200.8
Total Metal Digestion	Completed							06/28/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

14:58
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58082

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-44

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/02/25	MGH	E200.8
Total Metal Digestion	Completed							06/28/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

15:00
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58083

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-45

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/02/25	MGH	E200.8
Total Metal Digestion	Completed							06/28/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

15:01
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58084

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-46

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/02/25	MGH	E200.8
Total Metal Digestion	Completed							06/28/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

15:02
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58085

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-47

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/02/25	MGH	E200.8
Total Metal Digestion	Completed							06/28/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

15:03
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58086

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-48

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/02/25	MGH	E200.8
Total Metal Digestion	Completed							06/28/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

15:04
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58087

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-49

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/02/25	MGH	E200.8
Total Metal Digestion	Completed							06/28/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

15:04
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58088

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-50

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/02/25	MGH	E200.8
Total Metal Digestion	Completed							06/28/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

15:07
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58089

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-51

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1	0.5	2	ppb	15			07/02/25	MGH	E200.8
Total Metal Digestion	Completed							06/28/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

15:08
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58090

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-52

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/02/25	MGH	E200.8
Total Metal Digestion	Completed							06/28/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

15:10
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58091

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-53

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/02/25	MGH	E200.8
Total Metal Digestion	Completed							06/28/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

15:11
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58092

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-54

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/02/25	MGH	E200.8
Total Metal Digestion	Completed							06/28/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

15:12
 16:20

Laboratory Data

SDG ID: GCT58040
 Phoenix ID: CT58093

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: MC-56

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/02/25	MGH	E200.8
Total Metal Digestion	Completed							06/28/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager

Analysis Report - Summary

July 03, 2025

Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

SDG I.D.: GCT58040



Sample	Client Id	Col Date	Parameter	Result	RL	Units	Date Analyzed	Reference
Project: 25-05225 Bayonne Board Of Education								
CT58040	MC-01	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58041	MC-02	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58042	MC-03	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58043	MC-04	06/20/25	Lead	0.6	0.5	ppb	07/01/25	E200.8
CT58044	MC-05	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58045	MC-06	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58046	MC-07	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58047	MC-08	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58048	MC-09	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58049	MC-10	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58050	MC-11	06/20/25	Lead	1.6	0.5	ppb	07/01/25	E200.8
CT58051	MC-12	06/20/25	Lead	0.9	0.5	ppb	07/01/25	E200.8
CT58052	MC-13	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58053	MC-14	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58054	MC-15	06/20/25	Lead	1.5	0.5	ppb	07/01/25	E200.8
CT58055	MC-16	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58056	MC-17	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58057	MC-18	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58058	MC-19	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58059	MC-20	06/20/25	Lead	0.5	0.5	ppb	07/01/25	E200.8
CT58060	MC-21	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58061	MC-22	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58062	MC-23	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58063	MC-24	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58064	MC-25	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8

Sample	Client Id	Col Date	Parameter	Result	RL	Units	Date Analyzed	Reference
CT58065	MC-26	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58066	MC-28	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58067	MC-29	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58068	MC-30	06/20/25	Lead	1.7	0.5	ppb	07/01/25	E200.8
CT58069	MC-31	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58070	MC-32	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58071	MC-33	06/20/25	Lead	1.1	0.5	ppb	07/01/25	E200.8
CT58072	MC-34	06/20/25	Lead	1.3	0.5	ppb	07/01/25	E200.8
CT58073	MC-35	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58074	MC-36	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58075	MC-37	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58076	MC-38	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58077	MC-39	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58078	MC-40	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58079	MC-41	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58080	MC-42	06/20/25	Lead	< 0.5	0.5	ppb	07/02/25	E200.8
CT58081	MC-43	06/20/25	Lead	< 0.5	0.5	ppb	07/02/25	E200.8
CT58082	MC-44	06/20/25	Lead	< 0.5	0.5	ppb	07/02/25	E200.8
CT58083	MC-45	06/20/25	Lead	< 0.5	0.5	ppb	07/02/25	E200.8
CT58084	MC-46	06/20/25	Lead	< 0.5	0.5	ppb	07/02/25	E200.8
CT58085	MC-47	06/20/25	Lead	< 0.5	0.5	ppb	07/02/25	E200.8
CT58086	MC-48	06/20/25	Lead	< 0.5	0.5	ppb	07/02/25	E200.8
CT58087	MC-49	06/20/25	Lead	< 0.5	0.5	ppb	07/02/25	E200.8
CT58088	MC-50	06/20/25	Lead	< 0.5	0.5	ppb	07/02/25	E200.8
CT58089	MC-51	06/20/25	Lead	1	0.5	ppb	07/02/25	E200.8
CT58090	MC-52	06/20/25	Lead	< 0.5	0.5	ppb	07/02/25	E200.8
CT58091	MC-53	06/20/25	Lead	< 0.5	0.5	ppb	07/02/25	E200.8
CT58092	MC-54	06/20/25	Lead	< 0.5	0.5	ppb	07/02/25	E200.8
CT58093	MC-56	06/20/25	Lead	< 0.5	0.5	ppb	07/02/25	E200.8

Sample	Client Id	Col Date	Parameter	Result	RL	Units	Date Analyzed	Reference
--------	-----------	-------------	-----------	--------	----	-------	------------------	-----------

Comments:

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

ND=Not detected BDL=Below Detection Level RL=Reporting Level CL=Client Limit



Phyllis Shiller
Laboratory Director

July 03, 2025



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



QA/QC Report

July 03, 2025

QA/QC Data

SDG I.D.: GCT58040

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
QA/QC Batch 791169A (mg/L), QC Sample No: CT58038 (CT58040, CT58041, CT58042, CT58043, CT58044, CT58045, CT58046, CT58047)													
<u>ICP MS Metals - Aqueous</u>													
Lead	BRL	0.0001				100			89.8				
Comment: This batch does not include a duplicate.													
QA/QC Batch 791170 (mg/L), QC Sample No: CT58048 (CT58048, CT58049, CT58050, CT58051, CT58052, CT58053, CT58054, CT58055, CT58056, CT58057)													
<u>ICP MS Metals - Aqueous</u>													
Lead	BRL	0.0001	<0.0005	0.0006	NC	92.4			87.2				
QA/QC Batch 791170A (mg/L), QC Sample No: CT58058 (CT58058, CT58059, CT58060, CT58061, CT58062, CT58063, CT58064, CT58065, CT58066, CT58067)													
<u>ICP MS Metals - Aqueous</u>													
Lead	BRL	0.0001				92.4			88.2				
Comment: This batch does not include a duplicate.													
QA/QC Batch 791294 (mg/L), QC Sample No: CT58068 (CT58068, CT58069, CT58070, CT58071, CT58072, CT58073, CT58074, CT58075, CT58076, CT58077)													
<u>ICP MS Metals - Aqueous</u>													
Lead	BRL	0.0001	0.0017	0.0016	6.10	90.8			84.4				
QA/QC Batch 791294A (mg/L), QC Sample No: CT58078 (CT58078, CT58079, CT58080, CT58081, CT58082, CT58083, CT58084, CT58085, CT58086, CT58087)													
<u>ICP MS Metals - Aqueous</u>													
Lead	BRL	0.0001				90.8			87.0				
Comment: This batch does not include a duplicate.													
QA/QC Batch 791295 (mg/L), QC Sample No: CT58088 (CT58088, CT58089, CT58090, CT58091, CT58092, CT58093)													
<u>ICP MS Metals - Aqueous</u>													
Lead	BRL	0.0001	<0.0005	0.0003	NC	93.8			87.6				

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Intf - Interference
- (ISO) - Isotope Dilution


Phyllis Shiller, Laboratory Director
July 03, 2025

Thursday, July 03, 2025

Criteria: NJ: DW

State: NJ

Sample Criteria Exceedances Report

GCT58040 - MCCABE-PB

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
--------	-------	-----------------	----------	--------	----	----------	----------------	-------------------

*** No Data to Display ***

Phoenix Laboratories does not assume responsibility for the data contained in this exceedance report. It is provided as an additional tool to identify requested criteria exceedences. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedence information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Comments

July 03, 2025

SDG I.D.: GCT58040

The following analysis comments are made regarding exceptions to criteria not already noted in the Analysis Report or QA/QC Report: None.

2.2" WCIPL

MCCABE ENVIRONMENTAL SERVICES, L.L.C.
 464 VALLEY BROOK AVENUE LYNTHURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD in DRINKING WATER

CHAIN-OF-CUSTODY FORM

CLIENT NAME: Bayonne Board of Education

SITE ADDRESS: William Shemin Midtown Community School
 550 Avenue A, Bayonne, NJ 07002

FIELD INSPECTOR'S NAME: A. Kazuma & G. Clare

TURNAROUND TIME REQUESTED: 2-Week

MES PROJECT #: 25-05225

SAMPLE DATE: 6/20/25

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED	
DW	MC-01	FD - Chiller by laundry Rm Right Left	2:07 PM	LEAD - 200.8	58040
DW	MC-02	30 sec. Flush - Chiller by laundry Rm Right Left	2:08 PM	LEAD - 200.8	58041
DW	MC-03	FD - bubbler by laundry Rm - Right	2:08 PM	LEAD - 200.8	58042
DW	MC-04	FD - Room 001 PreK BR Sink	2:09 PM	LEAD - 200.8	58043
DW	MC-05	FD - Room 003 PreK Bathroom Sink	2:11 PM	LEAD - 200.8	58044
DW	MC-06	FD - Room 005 PreK Bathroom Sink	2:14 PM	LEAD - 200.8	58045
DW	MC-07	FD - Room 107 Bubbler	2:16 PM	LEAD - 200.8	58046
DW	MC-08	FD - Room 107 Faucet	2:18 PM	LEAD - 200.8	58047
DW	MC-09	FD - Room 109 Bubbler	2:20 PM	LEAD - 200.8	58048
DW	MC-10	FD - Room 109 - Faucet	2:21 PM	LEAD - 200.8	58049

Relinquished by (Print) Gary Clare
 Signature: [Signature]

Date: 6/20/25
 Time: 10:15

Received by: (Print) D. Dennis
 Signature: [Signature]

Date: 8-23-2025
 Time: 10:15

Relinquished by (Print)
 Signature: [Signature]

Date:
 Time:

Received by: (Print) Abby Lee
 Signature: [Signature]

Date: 6/23/25
 Time: 1620

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

NJ Certified WBE

2.2" WCIP

MCCABE ENVIRONMENTAL SERVICES, L.L.C.
 464 VALLEY BROOK AVENUE LYNTHURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD in DRINKING WATER

CHAIN-OF-CUSTODY FORM

CLIENT NAME: Bayonne Board of Education
 SITE ADDRESS: William Shemin Midtown Community School
 550 Avenue A, Bayonne, NJ 07002

FIELD INSPECTOR'S NAME: A. Letzama & G. Clare
 TURNAROUND TIME REQUESTED: 2-Week
 MES PROJECT #: 25-05225
 SAMPLE DATE: 6/20/25

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW	MC-11	FD - Room 111 Bubbler	2:22 PM	LEAD - 200.8
DW	MC-12	FD - Room 111 Faucet	2:23 PM	LEAD - 200.8
DW	MC-13	FD - Bubbler by Room 112 - Left	2:25 PM	LEAD - 200.8
DW	MC-14	FD - Chiller by Room 112 - Right	2:26 PM	LEAD - 200.8
DW	MC-15	FD - Room 113 Bubbler	2:28 PM	LEAD - 200.8
DW	MC-16	FD - Room 113 Faucet	2:29 PM	LEAD - 200.8
DW	MC-17	FD - Room 114 Faucet	2:29 PM	LEAD - 200.8
DW	MC-18	FD - Room 115 Bubbler	2:30 PM	LEAD - 200.8
DW	MC-19	FD - Room 115 Faucet	2:31	LEAD - 200.8
DW	MC-20	FD - Room 116 Bubbler	2:31	LEAD - 200.8

Relinquished by (Print) Gary Clare
 Date: 6/29/25 10:15
 Signature: [Signature]

Received by: (Print) J. Demers
 Date: 8-23 10:15
 Signature: [Signature]

Relinquished by (Print) [Signature]
 Date: [Blank]
 Signature: [Signature]

Received by: (Print) Abby Lee
 Date: 6/23/25 16:20
 Signature: [Signature]

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

NJ Certified WBE

2.2.22 WCIIP

MCCABE ENVIRONMENTAL SERVICES, L.L.C.
464 VALLEY BROOK AVENUE LYNDHURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD in DRINKING WATER

CHAIN-OF-CUSTODY FORM

CLIENT NAME: Bayonne Board of Education
SITE ADDRESS: William Shemin Midtown Community School
550 Avenue A, Bayonne, NJ 07002

FIELD INSPECTOR'S NAME: A. Letoma & G. Clare
TURNAROUND TIME REQUESTED: 2-Week
MES PROJECT #: 25-05225
SAMPLE DATE: 6/20/25

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED	
DW	MC-21	FD - Room 116 - Faucet	2:32	LEAD - 200.8	58060
DW	MC-22	FD - Room 117 - Bubblers	2:32	LEAD - 200.8	58061
DW	MC-23	FD - Room 117 - Faucet	2:32	LEAD - 200.8	58062
DW	MC-24	FD - Room 118 - Faucet	2:33	LEAD - 200.8	58063
DW	MC-25	FD - Chiller by Gym	2:33	LEAD - 200.8	58064
DW	MC-26	FD - Bubblers by Gym - 1	2:34	LEAD - 200.8	58065
DW	MC-28	FD - Bubblers by Gym - 3	2:35	LEAD - 200.8	58066
DW	MC-29	FD - Bubblers by Gym - 4	2:37	LEAD - 200.8	58067
DW	MC-30	FD - Nurses Office Faucet	2:38	LEAD - 200.8	58068
DW	MC-31	FD - Bubblers by Elevator 1st Fl - Left	2:40	LEAD - 200.8	58069

Relinquished by (Print) Gary Clare
 Date: 6/20/25 Time: 10:15
 Signature: [Signature]

Received by: (Print) 3. Deyrus
 Date: 6/23/25 Time: 10:15
 Signature: [Signature]

Relinquished by (Print) [Signature]
 Date: 6/23/25 Time: 10:20
 Signature: Abby Lee

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

NJ Certified WBE

2.2°C WCLP

MCCABE ENVIRONMENTAL SERVICES, L.L.C.
464 VALLEY BROOK AVENUE LYNTHURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD in DRINKING WATER

CHAIN-OF-CUSTODY FORM

CLIENT NAME: Bayonne Board of Education

SITE ADDRESS: William Shemin Midtown Community School
550 Avenue A, Bayonne, NJ 07002

FIELD INSPECTOR'S NAME: A. Lezama & G. Clure

TURNAROUND TIME REQUESTED: 2-Week

MES PROJECT #: 25-05225

SAMPLE DATE: 6/20/25

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED	
DW	MC-32	FD - Bubblers by Elevator 1st Fl - Right	2:41	LEAD - 200.8	58070
DW	MC-33	FD - Kitchen Sink - Right Faucet	2:43	LEAD - 200.8	58071
DW	MC-34	FD - Kitchen Sink - Left Faucet	2:44	LEAD - 200.8	58072
DW	MC-35	FD - Bubblers by Room 219 - 1 (Left)	2:51	LEAD - 200.8	58073
DW	MC-36	FD - Bubblers by Room 219 - 2	2:52	LEAD - 200.8	58074
DW	MC-37	FD - Bubblers by Room 219 - 3	2:52	LEAD - 200.8	58075
DW	MC-38	FD - Bubblers by Room 219 - 4 (Right)	2:53	LEAD - 200.8	58076
DW	MC-39	FD - Chiller by Room 219	2:53	LEAD - 200.8	58077
DW	MC-40	FD - Bubblers by Elevator - Left 2nd Fl.	2:54	LEAD - 200.8	58078
DW	MC-41	FD - Bubblers by Elevator - Middle 2nd Fl.	2:55	LEAD - 200.8	58079

Relinquished by (Print) Gary Clure

Date: 6/20/25

Received by: (Print) J. Daners

Date: 8-23

Time: 10:15

Signature: [Signature]

Signature: [Signature]

Signature: [Signature]

Date: 6/23/20

Time: 10:20

Relinquished by (Print)

Date:

Received by: (Print) Abby Lee

Date:

Time:

Signature: [Signature]

Signature: [Signature]

Signature: [Signature]

Date:

Time:

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

2.2^c WCIP

MCCABE ENVIRONMENTAL SERVICES, L.L.C.
 464 VALLEY BROOK AVENUE LYNTHURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD in DRINKING WATER

CHAIN-OF-CUSTODY FORM

CLIENT NAME: Bayonne Board of Education		SITE ADDRESS: William Shemin Midtown Community School 550 Avenue A, Bayonne, NJ 07002		
FIELD INSPECTOR'S NAME: G. Clare, A. Lezama		TURNAROUND TIME REQUESTED: 2-Week		
MES PROJECT #: 25-05225	SAMPLE DATE: 6/20/25			
Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW	MC-42	FD - Bubler by Elevator - Right 2nd Fl.	2:55	LEAD - 200.8
DW	MC-43	FD - Faucet Storage Room Next to Rm. 201	2:57	LEAD - 200.8
DW	MC-44	FD - Faculty Rm Faucet	2:58	LEAD - 200.8
DW	MC-45	FD - Bubler Outside Faculty Rm - Left	3:00	LEAD - 200.8
DW	MC-46	FD - Bubler by Bathrooms - 1 (Left) 3rd Fl.	3:01	LEAD - 200.8
DW	MC-47	FD - Bubler by Bathrooms - 2 (3rd Fl.)	3:02	LEAD - 200.8
DW	MC-48	FD - Bubler by Bathrooms - 3 (3rd Fl.)	3:03	LEAD - 200.8
DW	MC-49	FD - Bubler by Bathrooms - 4 (3rd Fl.)	3:04	LEAD - 200.8
DW	MC-50	FD - Chiller by Bathrooms - 3rd Fl. (Right)	3:04	LEAD - 200.8
DW	MC-51	FD - Bubler by Elevator - Left 3rd Fl.	3:07	LEAD - 200.8
Relinquished by (Print) Gary Clare		Received by: (Print) S. Demers	Date: 8/23/25	Time: 10:15
Signature: <i>GA</i>		Signature: <i>SD</i>		
Relinquished by (Print)		Received by: (Print) Abby Lee	Date: 6/23/25	Time: 16:20
Signature: <i>GA</i>		Signature: <i>Abby Lee</i>		
Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories				

NJ Certified WBE

2.2% WCIP

MCCABE ENVIRONMENTAL SERVICES, L.L.C.
 464 VALLEY BROOK AVENUE LYNHURST, NJ 07071 • PHONE: (201) 438-4839 FAX: (201) 438-1798

LEAD in DRINKING WATER

CHAIN-OF-CUSTODY FORM

CLIENT NAME: Bayonne Board of Education
 SITE ADDRESS: William Shemin Midtown Community School
 550 Avenue A, Bayonne, NJ 07002

TURNAROUND TIME REQUESTED: 2-Week

FIELD INSPECTOR'S NAME:

MES PROJECT #: 22-04448 SAMPLE DATE:

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW	MC-52	FD - Bubblers by Elevator - Middle 3rd Fl.	3:08	LEAD - 200.8
DW	MC-53	FD - Bubblers by Elevator - Right 3rd Fl.	3:10	LEAD - 200.8
DW	MC-54	FD - Faculty Rm Faucet - 3rd Fl.	3:11	LEAD - 200.8
DW	MC-56	FD - Bubblers outside Faculty Rm - Right	3:12	LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8

Relinquished by (Print) Gary Clare	Received by: (Print) J. Devers	Date: 8/23/25	Time: 10:15
Signature: [Signature]	Signature: [Signature]	Date: 8/23/25	Time: 10:15
Relinquished by (Print)	Received by: (Print) Abby Lee	Date: 8/23/25	Time: 10:20
Signature: [Signature]	Signature: [Signature]	Date: 8/23/25	Time: 10:20

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

APPENDIX B

**SCHOOL DISTRICT SAMPLING
ATTACHMENTS**

Attachment A - List of Priority for Sampling

SCHOOL NAME	DATE OF SAMPLING	CERTIFIED LABORATORY	NOTES
William Shemin Midtown Community	06/20/2025	Phoenix Environmental Laboratories Inc.	

Attachment B – Plumbing Profile

Note: Complete for each school. For additional information see the USEPA publication, "The 3Ts for Reducing Lead in Drinking Water in Schools"

Name of School: William Shemin Midtown Community Grade Levels: K-8

Address: 550 Avenue A, Bayonne, NJ 07002

Individual school project officer Signature: *Scott Valan* Date: 8/5/2025

Questions	Answers
Background Information	
1. What year was the original building constructed? Were any buildings or additions added to the original facility?	K-8 Grade School built in 1992
2. If the building was constructed or repaired after 1986, was lead-free plumbing and solder utilized? What type of solder was used? Document all locations where lead solder was used.	Any repairs made after 1986 were done using lead free solder
3. Where are the most recent plumbing repairs and replacements?	Location: Basement Four New-Pre-K Rooms Description: New Lavatories
4. With what materials is the service connection (the pipe that carries water to the school from the public water system's main in the street) made? Where is the Service Line located? (This is the POE location.)	Material: Main Building - Duct Iron Location: The water main (23rd st) enters the basement (by generator room) flows through the water meter and continues to the remainder of the building
5. Is there point of entry (POE) or point of use (POU) treatment in use?	Y / N No treatment of water Type: at POE City water comes treated Location: Main Building 1992

Questions	Answers
6. Are there tanks in your plumbing system (pressure tanks, gravity storage tanks)?	Y / N Yes Building has two 75 gallon hot water storage tank
7. Does the school have a filter maintenance and operation program? If so, who is responsible for this program? What is the process for adding filters?	Yes, Scott Nolan, Andy McCabe, Vinny Caiola, change filters on an as needed basis assign plumbers
8. Have accessible screens or aerators on outlets that provide drinking water been cleaned? Does the school have a screen or aerator maintenance program?	Y / N Yes The district has set up a routine maintenance program to clean screens
9. Have there been any complaints about bad (metallic) taste? Note location(s).	Y / N NO Location:
10. Review records and consult with the public water supplier to determine whether any water samples have been taken in the building for any contaminants. If so, identify: <ul style="list-style-type: none"> • Name of contaminant(s) • Concentrations found • pH level Is testing done regularly at the building?	No indoor testing by public water supplier
11. Other plumbing background questions include: <ul style="list-style-type: none"> • Are blueprints of the building available? • Are there known plumbing "dead-ends", low use areas, existing leaks or other "problem areas"? Are renovations planned for any of the plumbing system?	Not all prints are available No dead-end low areas All leaks were identified during walk through and have been repaired No plumbing system renovations

Questions	Answers	
<p>Walk-Through <i>These questions should be addressed during the walk-through of the facility, while Attachment C- Drinking Water Outlet Inventory is being completed.</i></p>		
1. Confirm the material of Service Line visually.	Duct iron	
2. Confirm the presence of POE or POU treatment.	No POE or POU treatment	
3. What are the potable water pipes made of in your facility? <ul style="list-style-type: none"> • Lead • Plastic • Galvanized Metal • Cast Iron • Copper • Other <p>Note the water flow through the building and the areas that receive water first, and which areas receive water last.</p>	Cooper	
4. Are electrical wires grounded to Water Pipes? Note location(s).	Y / N	No No electrical wires grounded to water pipes
5. Are brass fittings, faucets, or valves used in your drinking water system? Note that most faucets are brass on the inside. Document the locations of any brass water outlet to be sampled.	Complete in "Brass" Column in Attachment C- Water Outlet Inventory.	
6. Locate all drinking water outlets (i.e. water coolers, bubblers, ice machines, kitchen/ food prep sinks, etc.) in the facility.	Complete in Attachment C-Water Outlet Inventory.	

Questions	Answers	
<p>7. Have the brands and models of the water coolers in the school been compared to the list of recalled water coolers in the Toolkit? Recalled Drinking Water Fountains Make and Model</p>	<p>Y / N Yes all water coolers have been checked and compared to the list of recalled water coolers</p>	
<p>8. Have signs of corrosion, such as frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry been detected? Note the locations of water outlets.</p>	<p>Type None on the list of recalled water coolers</p> <p>Complete in "Signs of Corrosion" column in Attachment C- Drinking Water Outlet Inventory.</p>	
<p>9. Are there any outlets that are not operational and therefore out of service? Permanently? Temporarily?</p> <p style="text-align: center;">Permanently</p> <p style="text-align: center;">Temporarily</p>	<p>Y / N</p> <p>Complete "Operational Column" in Attachment C- Drinking Water Outlet Inventory.</p> <p>Type/ Location</p>	<p>Description</p>

Attachment C – Drinking Water Outlet Inventory

Name of School: William Shemin Midtown Community

Address: 550 Avenue A, Bayonne, NJ 07002

Grade Levels: Elementary School Year School Constructed: Unknown Renovated/Additions: NA

Individual School Project Officer: Scott Nolan

Date Completed: 07/14/2025

# ¹	Type	Location	Code	Operational ² (Y/N)	Signs of Corrosion ³ (Y/N)	Filter ⁴ (Y/N)	Brass Fittings, Faucets or valves? (Y/N)	Aerator/ Screen (Y/N)	Motion Activated (Y/N)	Chiller (Y/N)	Water Cooler		Comments
											Make	Model	
01	Water Fountain	Bubbler by Laundry Room - Left	MC-01	Y	N	Y	N	N	N	N	NA	NA	
02	Water Fountain	Bubbler by Laundry Room - Left	MC-02	Y	N	Y	N	N	N	N	NA	NA	Flush
03	Chiller	Chiller by Laundry Room - Right	MC-03	Y	N	Y	N	N	N	Y	NA	NA	
04	Sink	Room 001 Pre-K Bathroom	MC-04	Y	N	N	N	N	N	N	NA	NA	
05	Sink	Room 003 Pre-K Bathroom	MC-05	Y	N	N	N	N	N	N	NA	NA	
06	Sink	Room 005 Pre-K Bathroom	MC-06	Y	N	N	N	N	N	N	NA	NA	

¹ Number outlets starting at the closest outlet to the Point of Entry (POE).

² Document if permanently or temporarily out of service on the Attachment B- Plumbing Profile.

³ Signs of corrosion detected, such as but not limited to frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry.

⁴ Document on Attachment D- Filter Inventory.

07	Water Fountain	Room 107	MC-07	Y	N	N	N	N	N	N	NA	NA	
08	Sink	Room 107	MC-08	Y	N	N	N	N	N	N	NA	NA	
09	Water Fountain	Room 109	MC-09	Y	N	N	N	N	N	N	NA	NA	
10	Sink	Room 109	MC-10	Y	N	N	N	N	N	N	NA	NA	
11	Water Fountain	Room 111	MC-11	Y	N	N	N	N	N	N	NA	NA	
12	Sink	Room 111	MC-12	Y	N	N	N	N	N	N	NA	NA	
13	Water Fountain	By Room 112 - Left	MC-13	Y	N	Y	N	N	N	N	NA	NA	
14	Water Fountain	By Room 112 - Right	MC-14	Y	N	Y	N	N	N	N	NA	NA	
15	Water Fountain	Room 113	MC-15	Y	N	N	N	N	N	N	NA	NA	
16	Sink	Room 113	MC-16	Y	N	N	N	N	N	N	NA	NA	
17	Sink	Room 114	MC-17	Y	N	N	N	N	N	N	NA	NA	
18	Water Fountain	Room 115 Bubbler	MC-18	Y	N	N	N	N	N	N	NA	NA	
19	Sink	Room 115	MC-19	Y	N	N	N	N	N	N	NA	NA	
20	Water Fountain	Room 116	MC-20	Y	N	N	N	N	N	N	NA	NA	
21	Sink	Room 116	MC-21	Y	N	N	N	N	N	N	NA	NA	
22	Water Fountain	Room 117	MC-22	Y	N	N	N	N	N	N	NA	NA	
23	Sink	Room 117	MC-23	Y	N	N	N	N	N	N	NA	NA	
24	Sink	Room 118	MC-24	Y	N	N	N	N	N	N	NA	NA	
25	Chiller	Chiller by Gym	MC-25	Y	N	Y	N	N	N	Y	NA	NA	
26	Water Fountain	Bubbler by Gym – Bank 1	MC-26	Y	N	Y	N	N	N	N	NA	NA	
27	Water Fountain	Bubbler by Gym - Bank 2	MC-27	N	N	Y	N	N	N	N	NA	NA	Out of Order
28	Water Fountain	Bubbler by Gym – Bank 3	MC-28	Y	N	Y	N	N	N	N	NA	NA	
29	Water Fountain	Bubbler by Gym – Bank 4	MC-29	Y	N	Y	N	N	N	N	NA	NA	

30	Sink	Nurse's Office	MC-30	Y	N	Y	N	N	N	N	NA	NA	
31	Water Fountain	By Elevator – Left First Floor	MC-31	Y	N	Y	N	N	N	N	NA	NA	
32	Water Fountain	By Elevator – Right First Floor	MC-32	Y	N	Y	N	N	N	N	NA	NA	
33	Sink	Kitchen Hand Washing Sink	MC-33	Y	N	N	N	N	N	N	NA	NA	
34	Sink	Kitchen Sink Left Faucet	MC-34	Y	N	N	N	N	N	N	NA	NA	
35	Water Fountain	Bubbler by Room 219– Bank 1	MC-35	Y	N	Y	N	N	N	N	NA	NA	
36	Water Fountain	Bubbler by Room 219 – Bank 2	MC-36	Y	N	Y	N	N	N	N	NA	NA	
37	Water Fountain	Bubbler by Room 219 – Bank 3	MC-37	Y	N	Y	N	N	N	N	NA	NA	
38	Water Fountain	Bubbler by Room 219 – Bank 4	MC-38	Y	N	Y	N	N	N	N	NA	NA	
39	Chiller	Chiller by Room 219	MC-39	Y	N	Y	N	N	N	Y	NA	NA	
40	Water Fountain	By Elevator – Left – Second Floor	MC-40	Y	N	Y	N	N	N	N	NA	NA	
41	Water Fountain	By Elevator – Middle Second Floor	MC-41	Y	N	Y	N	N	N	N	NA	NA	
42	Water Fountain	Bubbler by Elevator – Right Second Floor	MC-42	Y	N	Y	N	N	N	N	NA	NA	
43	Sink	Storage Room Next to Room 201	MC-43	Y	N	N	N	N	N	N	NA	NA	
44	Sink	Faculty Room	MC-44	Y	N	N	N	N	N	N	NA	NA	
45	Sink	Outside Faculty Room – Left	MC-45	Y	N	Y	N	N	N	N	NA	NA	
46	Water Fountain	Bubbler by Room 305 – Bank 1	MC-46	Y	N	Y	N	N	N	N	NA	NA	
47	Water Fountain	Bubbler by Room 305 – Bank 2	MC-47	Y	N	Y	N	N	N	N	NA	NA	
48	Water Fountain	Bubbler by Room 305 – Bank 3	MC-48	Y	N	Y	N	N	N	N	NA	NA	
49	Water Fountain	Bubbler by Room 305 – Bank 4	MC-49	Y	N	Y	N	N	N	N	NA	NA	

50	Chiller	Chiller by Room 305	MC-50	Y	N	Y	N	N	N	Y	NA	NA	
51	Water Fountain	By Elevator - Left	MC-51	Y	N	Y	N	N	N	N	NA	NA	
52	Water Fountain	By Elevator – Middle	MC-52	Y	N	Y	N	N	N	N	NA	NA	
53	Water Fountain	By Elevator - Right	MC-53	Y	N	Y	N	N	N	N	NA	NA	
54	Sink	Faculty Room– Third Floor	MC-54	Y	N	N	N	N	N	N	NA	NA	
55	Water Fountain	Outside Faculty Room – Left	MC-55	N	N	Y	N	N	N	N	NA	NA	Out of Order
56	Water Fountain	Outside Faculty Room – Right	MC-56	Y	N	Y	N	N	N	N	NA	NA	

¹ Number outlets starting at the closest outlet to the Point of Entry (POE).

¹ Document if permanently or temporarily out of service on the Attachment B- Plumbing Profile.

¹ Signs of corrosion detected, such as but not limited to frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry.

¹ Document on Attachment D- Filter Inventory.

Attachment D - Filter Inventory

Name of School: William Shemin Midtown Community

Grade Levels: Elementary School

Address: 550 Avenue A, Bayonne, NJ 07002

Individual School Project Officer: Scott Nolan

Date: 6/20/2025

Sample Location / Code	Brand	Type (Make & Model)	Date Installed or Replaced	Replacement Frequency	NSF Certified for Lead Reduction Y/N
MC-01	Elkay	LZWSR_1D	N/A	N/A	N/A
MC-02	Elkay	LZWSR_1D	N/A	N/A	N/A
MC-03	Elkay	LZWSR_1D	N/A	N/A	N/A
MC-04	N/A	N/A	N/A	N/A	N/A
MC-05	N/A	N/A	N/A	N/A	N/A
MC-06	N/A	N/A	N/A	N/A	N/A
MC-07	N/A	N/A	N/A	N/A	N/A
MC-08	N/A	N/A	N/A	N/A	N/A
MC-09	N/A	N/A	N/A	N/A	N/A
MC-10	N/A	N/A	N/A	N/A	N/A
MC-11	N/A	N/A	N/A	N/A	N/A
MC-12	N/A	N/A	N/A	N/A	N/A
MC-13	Elkay	LZWSR_1D	N/A	N/A	N/A
MC-14	Elkay	LZWSR_1D	N/A	N/A	N/A
MC-15	N/A	N/A	N/A	N/A	N/A
MC-16	N/A	N/A	N/A	N/A	N/A
MC-17	N/A	N/A	N/A	N/A	N/A
MC-18	N/A	N/A	N/A	N/A	N/A
MC-19	N/A	N/A	N/A	N/A	N/A
MC-20	N/A	N/A	N/A	N/A	N/A
MC-21	N/A	N/A	N/A	N/A	N/A
MC-22	N/A	N/A	N/A	N/A	N/A
MC-23	N/A	N/A	N/A	N/A	N/A
MC-24	N/A	N/A	N/A	N/A	N/A
MC-25	Elkay	LZWSR_1D	N/A	N/A	N/A

MC-26	Elkay	LZWSR_1D	N/A	N/A	N/A
MC-27	Elkay	LZWSR_1D	N/A	N/A	N/A
MC-28	Elkay	LZWSR_1D	N/A	N/A	N/A
MC-29	Elkay	LZWSR_1D	N/A	N/A	N/A
MC-30	Elkay	LZWSR_1D	N/A	N/A	N/A
MC-31	Elkay	LZWSR_1D	N/A	N/A	N/A
MC-32	Elkay	LZWSR_1D	N/A	N/A	N/A
MC-33	N/A	N/A	N/A	N/A	N/A
MC-34	N/A	N/A	N/A	N/A	N/A
MC-35	Elkay	LZWSR_1D	N/A	N/A	N/A
MC-36	Elkay	LZWSR_1D	N/A	N/A	N/A
MC-37	Elkay	LZWSR_1D	N/A	N/A	N/A
MC-38	Elkay	LZWSR_1D	N/A	N/A	N/A
MC-39	Elkay	LZWSR_1D	N/A	N/A	N/A
MC-40	Elkay	LZWSR_1D	N/A	N/A	N/A
MC-41	Elkay	LZWSR_1D	N/A	N/A	N/A
MC-42	Elkay	LZWSR_1D	N/A	N/A	N/A
MC-43	N/A	N/A	N/A	N/A	N/A
MC-44	N/A	N/A	N/A	N/A	N/A
MC-45	Elkay	LZWSR_1D	N/A	N/A	N/A
MC-46	Elkay	LZWSR_1D	N/A	N/A	N/A
MC-47	Elkay	LZWSR_1D	N/A	N/A	N/A
MC-48	Elkay	LZWSR_1D	N/A	N/A	N/A
MC-49	Elkay	LZWSR_1D	N/A	N/A	N/A
MC-50	Elkay	LZWSR_1D	N/A	N/A	N/A
MC-51	Elkay	LZWSR_1D	N/A	N/A	N/A
MC-52	Elkay	LZWSR_1D	N/A	N/A	N/A
MC-53	Elkay	LZWSR_1D	N/A	N/A	N/A
MC-54	N/A	N/A	N/A	N/A	N/A
MC-55	Elkay	N/A	N/A	N/A	N/A
MC-56	Elkay	LZWSR_1D	N/A	N/A	N/A

Attachment E – Flushing Log

Name of School: William Shemin Midtown Community School

Address: 550 Avenue A, Bayonne, NJ 07002

Grade Levels: Elementary School

Individual School Project Officer: Scott Nolan

Date: 07/14/2025

Sample Location Description	Sample Location Code	Date	Time	Duration of Flushing	Reason for Flushing
Bubbler by Laundry Room - Left	MC-01	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Laundry Room - Left	MC-02	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Chiller by Laundry Room - Right	MC-03	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 001 Pre-K Bathroom Sink	MC-04	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 003 Pre-K Bathroom Sink	MC-05	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 005 Pre-K Bathroom Sink	MC-06	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 107 Bubbler	MC-07	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 107 Faucet	MC-08	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 109 Bubbler	MC-09	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 109 Faucet	MC-10	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 111 Bubbler	MC-11	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 111 Faucet	MC-12	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Room 112 - Left	MC-13	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Chiller by Room 112 - Right	MC-14	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 113 Bubbler	MC-15	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 113 Faucet	MC-16	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 114 Faucet	MC-17	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 115 Bubbler	MC-18	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 115 Faucet	MC-19	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 116 Bubbler	MC-20	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling

Bayonne BOE: Sampling Plan

Room 116 Faucet	MC-21	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 117 Bubbler	MC-22	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 117 Faucet	MC-23	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 118 Faucet	MC-24	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Chiller by Gym	MC-25	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Gym – Bank 1	MC-26	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Gym - Bank 2	MC-27	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Gym – Bank 3	MC-28	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Gym – Bank 4	MC-29	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Nurse’s Office Faucet	MC-30	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Elevator – Left First Floor	MC-31	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Elevator – Right First Floor	MC-32	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Kitchen Hand Washing Sink	MC-33	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Kitchen Sink Left Faucet	MC-34	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Room 219 – Bank 1	MC-35	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Room 219 – Bank 2	MC-36	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Room 219 – Bank 3	MC-37	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Room 219 – Bank 4	MC-38	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Chiller by Room 219	MC-39	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Elevator – Left – Second Floor	MC-40	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Elevator – Middle Second Floor	MC-41	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Elevator – Right Second Floor	MC-42	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Faucet in Storage Room Next to Room 201	MC-43	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Faculty Room Faucet	MC-44	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler Outside Faculty Room – Left	MC-45	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Room 305 – Bank 1	MC-46	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Room 305 – Bank 2	MC-47	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Room 305 – Bank 3	MC-48	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling

Bayonne BOE: Sampling Plan

Bubbler by Room 305 – Bank 4	MC-49	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Chiller by Room 305	MC-50	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Elevator - Left	MC-51	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Elevator – Middle	MC-52	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Elevator - Right	MC-53	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Faculty Room Faucet – Third Floor	MC-54	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler Outside Faculty Room – Left	MC-55	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler Outside Faculty Room – Right	MC-56	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling

Attachment F - Pre - Sampling Water Use Certification

TO BE COMPLETED BY THE BAYONNE BOE DISTRICT REPRESENTATIVE:		
School Name:	<u>William Shemin Midtown Community</u>	
Sample collection address:	<u>550 Avenue A, Bayonne, NJ 07002</u>	
Water was last used:	<u>Time: 5:30 pm</u>	<u>Date: June 19, 2025</u>
Sample commencement:	<u>Time: 2:32 pm</u>	<u>Date: June 20, 2025</u>
I have read the Lead Drinking Water Testing Sampling Plan and Quality Assurance Project Plan and I am certifying that samples were collected in accordance with these plans.		
Scott Nolan	<u>07/22/2025</u>	
Signature	Date	