



December 18, 2025

Mikayla Higgins
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

RE: Project: Warwick High School
Pace Project No.: 70394895

Dear Mikayla Higgins:

Enclosed are the analytical results for sample(s) received by the laboratory on December 04, 2025. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink that reads 'Felicia Morgan-Nichols'.

Felicia Morgan-Nichols
felicia.morgan-nichols@pacelabs.com
(845)562-0890
Project Manager

Enclosures

cc: Ashley Kimiecik, Orange-Ulster BOCES
Juliana Lennon, Orange-Ulster BOCES
Halina Redner, Orange-Ulster BOCES



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



PROJECT NARRATIVE

Project:

Pace Project No.:

Method:

Description:

Client:

Date:


This data package has been reviewed for quality and completeness and is approved for release.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pa

W0#: 70394895



703948995

[illegible]

Lab Use Only	
Actium / Client ID:	
Table #:	
Profile / Template:	* 11266 non-conformance identification for sample

[illegible]

# Coolers:	Thermometer ID:	Correction Factor (C _d):	Cooler Temp (C _d):	Corrected Temp (C _d):	() On Ice
				20.8	
	Date/Time:	7/2/14	11:03	Trailing Number:	
	Date/Time:			Delivered by: () In-Person () Courier	
	Date/Time:			() FedEx () UPS () Other	
				Page: 1 of 6	

Pace® Location Requested (City/State): **CHAIN-OF-CUSTODY Analytical Request Document**

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Company Name: Orange-Ulster BOCES

Street Address:

53 Gibson Road
Goshen, NY 10924

Customer Project #:

Project Name:
Lead Drinking Water- Warwick Valley CSD

Site Collection Info/Facility ID (as applicable):

Warwick High School

Contact/Report To: Mikayla Higgins
Phone #: 845-781-4887
E-Mail: Mikayla.Higgins@ouboces.org
CC E-Mail: Halina.Redner@ouboces.org

Invoice to: Halina Redner
Invoice E-mail: halina.redner@ouboces.org
Purchase Order # (if applicable): A26-00316
Quote #:

County / State origin of sample(s): Orange County / New York

Time Zone Collected: ☐ AK ☐ PT ☐ MT ☒ CT ☐ ET

Data Deliverables:

DOH

Regulatory Program (DW, RCRA, etc.) as applicable: ☒ Yes ☐ No

Rush (Pre-approval required): ☐ Same Day ☐ 1 Day ☐ 2 Day ☐ 3 Day Other: _____

Date Results Requested: _____

Field Filtered (if applicable): ☐ Yes ☒ No

Analysis: _____

*Matrix codes (insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Wastewater (WW), Product (P), Soil/Solid (SS), Oil/Gel, Wipe (WP), Tissue (TS), Biossary (B), Vapor (V), Surface Water (SW), Sediment (SED), Sludge (SL), Cask (CK), Leachate (LL), Biosolid (BS), Other (OT)

Customer Sample ID	Matrix *	Comp / Grab	Composite Start Date	Time	Collected or Composite End Date	Time	# Cont.	Residual Volume	Units
Nurse Ice machine	DW	G			12/14/25	5:11	1		
Nurse KS	DW	G				5:11	1		
Stage CU/BF	DW	G				5:17	1		
Stage CU/DF right	DW	G				5:17	1		
Stage DF Left	DW	G				5:18	1		
Band Room CS	DW	G				5:19	1		
South Cafeteria CU/BF	DW	G				5:22	1		
South Cafeteria CU/DF right	DW	G				5:22	1		
Kitchen Prep Sink (Sink 2)	DW	G				5:23	1		
Kitchen Pot Filler	DW	G				5:23	1		

Additional Instructions from Pace®:

Collected By: ASHLEY KIMMICK
Printed Name
Signature

Relinquished by (Company): (Signature) _____ Date/Time: 12/14/25 11:03

Relinquished by (Company): (Signature) _____ Date/Time: _____

Relinquished by (Company): (Signature) _____ Date/Time: _____

Relinquished by (Company): (Signature) _____ Date/Time: _____

Received by (Company): (Signature) _____

Received by (Company): (Signature) _____

Received by (Company): (Signature) _____

Received by (Company): (Signature) _____

WIO#: 70394895
PM: FMN
CLIENT: NB-0U BOCES
Due Date: 12/18/25

Specify Container Size **	Identify Container Preservative Type ***	Analysis Requested
3		
2		

Lab Use Only	Sample Comment
Act/Num / Client ID:	
Table #:	
Profile / Template:	
Prodlog / Bottle Ord. ID:	

Customer Remarks / Special Conditions / Possible Hazards:	# Coders	Thermometer ID:	Correction Factor (°C):	Obs Temp (°C):	Comp Temp (°C):	Tracking Number:	Delivered by: ☐ In-Person ☐ Courier ☐ FedEx ☐ UPS ☐ Other
					20.8		

Pace® Location Requested (City/State): **CHAIN-OF-CUSTODY Analytical Request Document**

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Company Name: Orange-Ulster BOCES

Street Address:
53 Gibson Road
Goshen, NY 10924

Customer Project #:

Project Name:
Lead Drinking Water- Warwick Valley CSD

Site Collection Info/Facility ID (as applicable):

Warwick High School

Contact/Report To: Mikayla Higgins
Phone #: 845-781-4887
E-Mail: Mikayla.Higgins@ouboces.org
Cc E-Mail: Halina.Redner@ouboces.org
Invoice to: Halina Redner
Invoice E-mail: halina.redner@ouboces.org
Purchase Order # (if applicable): AZB-00316
Quote #:

Time Zone Collected: [] AK [] PT [] MT [] CT ☒ ET

Data Deliverables: Regulatory Program (DW, RCRA, etc.) as applicable: Reportable ☒ Yes [] No

[] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

[] Level I [] Level II [] Level III [] Level IV

MO#: 70394895

PM: FMN
CLIENT: NB-OU BOCES

Due Date: 12/18/25

Specify Container Size **

Identify Container Preservative Type***

Analysis Requested

*Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL via, (7) Encore, (8) Terracore, (9) 50mL, (10) Other
***Preservative Type: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) 2% Acetic Acid, (7) 10% H2SO4, (8) 5% Thiosulfate, (9) Ascorbic Acid, (10) H2O2, (11) Other
Proj. Mgr:
ActNum / Client ID:
Table #:
Profile / Template:
Prelab / Bottle Ord. ID:
Sample Comment:
Preservation non-conformance identified for sample.

Lead

Customer Sample ID	Matrix *	Comp / Grab	Composite Start Date	Time	Collected or Composite End Date	Time	# Cont.	Result	Residual Chlorine Units
o/s 164 CU/DF left	DW	G			12/14/25	5:43	1		
o/s 164 CU/DF	DW	G				5:43	1		
BY 165 BF	DW	G							
Faculty Room KS	DW	G				5:48	1		
Library KS	DW	G				5:54	1		
CU/BF by 142	DW	G				5:55	1		
CU/DF by 142	DW	G				5:55	1		
Trainers Room Ice Machine	DW	G				5:39	1		
Kitchen Ice Machine	DW	G				5:25	1		
145 KS Left	DW	G				5:57	1		

Additional Instructions from Pace®:

Collected By: ASHLEY KIMBLE

Printed Name

Signature

Customer Remarks / Special Conditions / Possible Hazards:

Codes: Thermometer ID: Correction Factor (°C): Obs. Temp. (°C): Corrected Temp. (°C): [] On Ice

Relinquished by (Company) (Signature)

Date/Time: 12/14/25, 11:03

Received by (Company) (Signature)

Relinquished by (Company) (Signature)

Date/Time: 12/14/25, 11:03

Received by (Company) (Signature)

Relinquished by (Company) (Signature)

Date/Time: 12/14/25, 11:03

Received by (Company) (Signature)

Relinquished by (Company) (Signature)

Date/Time: 12/14/25, 11:03

Received by (Company) (Signature)

Relinquished by (Company) (Signature)

Date/Time: 12/14/25, 11:03

Received by (Company) (Signature)

Relinquished by (Company) (Signature)

Date/Time: 12/14/25, 11:03

Received by (Company) (Signature)

Relinquished by (Company) (Signature)

Date/Time: 12/14/25, 11:03

Received by (Company) (Signature)

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace® Terms and Conditions found at <https://www.pacelabs.com/resource-library/resource-pace-terms-and-conditions/>

Page: 4 of 6

ENV-FRM-CORR-0019_V02_110123 ©

Pace® Location Requested (City/State):
Newburgh, NY

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Company Name: Orange-Ulster BOCES

Street Address:

53 Gibson Road
Goshen, NY 10924

Customer Project #:

Project Name:

Lead Drinking Water: Warwick Valley CSD

Site Collection Info/Facility ID (as applicable):

Warwick High School

Contact/Report To: Mikayla Higgins
Phone #: 845-781-4987

E-Mail: Mikayla.Higgins@oubores.org
Cc E-Mail: Halina.Redner@oubores.org

Invoice to: Halina Redner

Invoice E-Mail: halina.redner@oubores.org

Purchase Order # (if applicable): A26-00316

Quote #:

Time Zone Collected: () AK () PT () MT () CT (X) ET

County / State origin of sample(s): Orange County / New York

Reportable (X) Yes () No

Data Deliverables:

() Level II () Level III () Level IV

() ECUS

() Other

Regulatory Program (DW, RCRA, etc.) as applicable:

DOH

Rush (Pre-approval required):

() Same Day () 1 Day () 2 Day () 3 Day Other

Date Results

Requested:

Analysis:

DW PWSID # or WW Permit # as applicable:

Field Filtered (if applicable): () Yes (X) No

Matrix Code (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Wastewater (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Biosolid (BS), Other (O)

Sludge (SL), Cask (CK), Leachate (LL), Biosolid (BS), Other (O)

Customer Sample ID

Matrix *

Comp / Grab

Composite Start

Date

Time

Collected or Composite End

Date

Time

Cont.

Result

Units

Residual Chlorine

12/14/25

5:57

1

1

1

1

1

1

1

1

1

1

1

1

1

1

1

1

1

1

1

1

1

1

Collected By:

Printed Name

Signature

ASHLEY KIMIEK

12/14/25

11:03

1

1

1

1

1

1

1

1

1

1

1

Customer Remarks / Special Conditions / Possible Hazards:

Collectors:

Thermometer ID:

Correction Factor (°C):

Obs. Temp. (°C):

Corrected Temp. (°C):

() On Ice

12/14/25

11:03

1

1

1

1

1

1

1

1

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Tracking Number:

Delivered by: () In-Person () Courier

() FedEx () UPS () Other

Page: 5 of 6

ENV-FRM-CORQ-0019_V02_110123 ©

LAB USE ONLY
MIO#: 70394895
PM: FMN Due Date: 12/18/25
CLIENT: NB-OU BOCES

Specify Container Size **

(4) 125mL, (5) 100mL, (6) 50mL, (7) 250mL, (8) 100mL, (9) 50mL, (10) Other

Identify Container Preservative Type **

(1) HCl, (2) NaOH, (3) HNO3, (4) H2SO4, (5) H3PO4, (6) Ascorbic Acid, (7) Methanol, (8) Other

Analysis Requested

Profil. Mgr:

Act/turn / Client ID:

Table #:

Profile / Template:

Printed / Bottle Ord. ID:

Sample Comment

Preservation non-conformance identified for sample.

Sample Condition Upon Receipt Form (SCUR)

Project # 70394895
Client: OU-BOCES

Date and Initials of person:
Examining contents: _____
Label: _____
Deliver to location: _____
pH: _____

Thermometer Used: IRG4 Date: 12.4.2025 Time: 1103 Initials: _____

State of Origin: NY

Cooler #1 Temp. °C 20.8 (Visual) 0.1@0°C, -0.1@20°C (Correction Factor) _____ (Actual) ☐ Samples on ice, cooling process has begun

Courier: ☐ Fed Ex ☐ UPS ☐ USPS ☒ Client ☐ Commercial ☐ Pace ☐ Other _____

Shipping Method: ☐ First Overnight ☐ Priority Overnight ☐ Standard Overnight ☐ Ground
☐ Other _____

Tracking # _____

Custody Seal on Cooler/Box Present: ☐ Yes ☐ No Seals intact: ☐ Yes ☐ No Ice: Wet Blue Melted None ☒

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ None ☐ Other _____

Samples were collected by Pace employee ☐ Yes ☐ No ☐ N/A

Comments:

Chain of Custody Present	☒ Yes ☐ No ☐ N/A	
Chain of Custody Filled Out	☒ Yes ☐ No ☐ N/A	
Relinquished Signature on COC	☒ Yes ☐ No ☐ N/A	
Sampler Name and Signature on COC	☒ Yes ☐ No ☐ N/A	
Samples Arrived within Hold Time	☒ Yes ☐ No ☐ N/A	
Rush TAT requested on COC	☐ Yes ☐ No ☐ N/A	
Sufficient Volume	☒ Yes ☐ No ☐ N/A	
Correct Containers Used	☒ Yes ☐ No ☐ N/A	
Containers Intact	☒ Yes ☐ No ☐ N/A	
Sample Labels match COC (sample IDs & date/time of collection)	☒ Yes ☐ No ☐ N/A	
All containers needing acid/base preservation have been checked.	☐ Yes ☐ No ☒ N/A	Preservation Information:
All Containers needing preservation are found to be in compliance with EPA recommendation:	☐ Yes ☐ No ☒ N/A	Preservative: _____
Exceptions: Vials, Microbiology, O&G, Metals		Lot #/Trace #: _____
		Date: _____ Time: _____
		Initials: _____
Headspace in VOA Vials? (>6mm):	☐ Yes ☐ No ☐ N/A	
Trip Blank Present:	☐ Yes ☐ No ☐ N/A	

Additional Login Comments:

Client notification/ Resolution

Person Contacted: _____ Date/Time: _____
Comments/Resolution: _____

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

CERTIFICATE OF ANALYSIS

Felicia Morgan-Nichols

**Pace Analytical Services, LLC
Newburgh, NY
315 Fullerton Ave
Newburgh, NY 12550**

Project Name and Number:

Warwick Highschool

Workorder:

25L1456

Purchase Order:

December 18, 2025

This report relates only to the sample(s) as received by the laboratory on December 16, 2025. Laboratory reports may not be reproduced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Caution is advised for the utilization of preliminary data included in reports labeled as "Preliminary Report" and should not be used for regulatory purposes. A laboratory signature is provided on final reports only.

If you have any questions in reference to this laboratory report, please contact your Pace Analytical Services, LLC-Fairfield project coordinator.

Note: This cover page is included as part of the Analytical Report and must be retained as a permanent record thereof.



Timothy Swavely, Project Manager

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-01 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:06
Sample ID: BF by 218 (70394895001) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 17:48	12/17/2025 17:48	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-02 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:06
Sample ID: BF by 218 Right (70394895002) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 17:58	12/17/2025 17:58	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-03 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:06
Sample ID: BF by 218 Left (70394895003) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 18:00	12/17/2025 18:00	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-04 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:51
Sample ID: Outside Old Gym CU/BF (70394895004) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 18:07	12/17/2025 18:07	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-05 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:51
Sample ID: Outside Old Gym CU/DF (70394895005) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 18:10	12/17/2025 18:10	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-06 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:59
Sample ID: Main Office Breakroom ice mac (70394895006) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 18:12	12/17/2025 18:12	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-07 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:08
Sample ID: BF by 118 (70394895007) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 18:15	12/17/2025 18:15	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-08 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:08
Sample ID: BF by 118 left (70394895008) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 18:17	12/17/2025 18:17	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-09 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:08
Sample ID: BF by 118 right (70394895009) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 18:19	12/17/2025 18:19	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-10 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:11
Sample ID: Nurse NS (70394895010) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	0.00837		mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 18:22	12/17/2025 18:22	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-11 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:11
Sample ID: Nurse ice Machine (70394895011) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 18:24	12/17/2025 18:24	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-12 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:11
Sample ID: Nurse KS (70394895012) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 18:27	12/17/2025 18:27	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-13 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:17
Sample ID: Stage CU/BF (70394895013) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 18:29	12/17/2025 18:29	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-14 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:17
Sample ID: Stage CU/DF right (70394895014) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 18:36	12/17/2025 18:36	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-15 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:18
Sample ID: Stage DF left (70394895015) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 18:39	12/17/2025 18:39	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-16 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:19
Sample ID: Band Room CS (70394895016) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	0.00741		mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 18:41	12/17/2025 18:41	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-17 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:22
Sample ID: South Cafeteria CU/BF (70394895017) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 18:43	12/17/2025 18:43	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-18 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:22
Sample ID: South Cafeteria CU/BF right (70394895018) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 18:46	12/17/2025 18:46	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-19 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:23
Sample ID: Kitchen Prep Sink (Sink 2) (70394895019) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	0.00212		mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 18:48	12/17/2025 18:48	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-20 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:23
Sample ID: Kitchen Pot Filler (70394895020) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 18:51	12/17/2025 18:51	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-21 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:24
Sample ID: Kitchen Sink R (Sink 1) (70394895021) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 18:58	12/17/2025 18:58	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-22 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:26
Sample ID: North Cafe CU/BF (70394895022) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 19:12	12/17/2025 19:12	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-23 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:26
Sample ID: North Cafe CU/DF left (70394895023) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 19:15	12/17/2025 19:15	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-24 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:37
Sample ID: Training Room CS (70394895024) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 19:17	12/17/2025 19:17	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-25 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:37
Sample ID: Training Room Hose (70394895025) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 19:20	12/17/2025 19:20	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-26 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:35
Sample ID: New Gym CU/BF (70394895026) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 19:22	12/17/2025 19:22	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-27 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:35
Sample ID: New Gym CU/DF right (70394895027) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 19:24	12/17/2025 19:24	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-28 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:35
Sample ID: New Gym CU/DF left (70394895028) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 19:27	12/17/2025 19:27	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-29 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:46
Sample ID: Athletic Director KS (70394895029) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 19:34	12/17/2025 19:34	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-30 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:43
Sample ID: o/s 164 DF Right (70394895030) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 19:36	12/17/2025 19:36	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-31 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:43
Sample ID: o/s 164 CU/DF left (70394895031) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 19:39	12/17/2025 19:39	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-32 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:43
Sample ID: o/s 164 CU/BF (70394895032) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 19:41	12/17/2025 19:41	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-33 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:48
Sample ID: Faculty Room KS (70394895033) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 19:44	12/17/2025 19:44	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-34 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:54
Sample ID: Library KS (70394895034) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	0.00281		mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 19:46	12/17/2025 19:46	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-35 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:55
Sample ID: CU/BF by 142 (70394895035) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 19:48	12/17/2025 19:48	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-36 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:55
Sample ID: CU/BF by 142 right (70394895036) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 19:51	12/17/2025 19:51	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-37 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:39
Sample ID: Trainers Room ice machine (70394895037) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 19:53	12/17/2025 19:53	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-38 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:25
Sample ID: Kitchen ice machine (70394895038) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 19:56	12/17/2025 19:56	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-39 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:57
Sample ID: 145 KS Left (70394895039) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	0.00242		mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 20:03	12/17/2025 20:03	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-40 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:57
Sample ID: 145 KS Right (70394895040) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 20:05	12/17/2025 20:05	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-41 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:33
Sample ID: Fitness Center DF Right (70394895041) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 20:13	12/17/2025 20:13	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-42 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:33
Sample ID: Fitness Center DF left (70394895042) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 20:22	12/17/2025 20:22	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-43 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:31
Sample ID: Hall of Fame DF Right (70394895043) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 20:25	12/17/2025 20:25	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-44 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:31
Sample ID: Hall of Fame DF Left (70394895044) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 20:32	12/17/2025 20:32	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-45 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:42
Sample ID: CU/BF across from 65 (70394895045) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 20:34	12/17/2025 20:34	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-46 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:42
Sample ID: CU/DF across from 65 (70394895046) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 20:37	12/17/2025 20:37	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-47 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:42
Sample ID: DF across from 65 Right (70394895047) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 20:39	12/17/2025 20:39	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-48 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:22
Sample ID: South Cafeteria DF Left (70394895048) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 20:41	12/17/2025 20:41	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-49 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:27
Sample ID: North cafe DF right (70394895049) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 20:44	12/17/2025 20:44	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25L1456-50 **Matrix:** Drinking Water **Date Collected:** 12/04/2025 05:55
Sample ID: DF by 142 left (70394895050) **Date Received:** 12/16/2025 08:00

Total Metals - PAS - Fairfield, NJ

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	12/17/2025 20:46	12/17/2025 20:46	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Qualifiers

U Compound not detected

Abbreviations

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the Reporting Detection Limit (RDL)
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
<	Less than reporting limit
≤	Less than or equal to reporting limit
>	Greater than reporting limit
≥	Greater than or equal to reporting limit
MDL	Method Detection Limit
RDL	Reporting Detection Limit
MCL/AL	Maximum Contaminant Level/Action Level
mg/kg wet	Results reported as wet weight
TTLC	Total Threshold Limit Concentration
STLC	Soluble Threshold Limit Concentration
TCLP	Toxicity Characteristic Leachate Procedure

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Laboratory Certification List for this report.

Laboratory	Certification			
	NJ	NY	PA	CT
Pace Analytical Services, LLC Ewing 812 Silvia Street Ewing, NJ 08628	11005	12046	68-05417	
Pace Analytical Services, LLC-Fairfield 1275 Bloomfield Ave, Ste 37D Fairfield, NJ 07004	07010	11634	68-02903	

Internal Transfer Chain of Custody



☐ Rush Multiplier ☒ X
☐ Samples Pre-Logged into eCOC
Workorder Name: Warwick High School
Subcontract To

State Of Origin: NY
Cert. Needed: ☐ Yes ☐ No
Owner Received Date: 12/4/2025
Results Requested By: 12/18/2025

Report To: Felicia Morgan-Nichols
Pace Analytical Newburgh
315 Fullerton Avenue
Newburgh, NY 12550
Phone (845)562-0890

Report To				Requested Analysis									
Subcontract To				Requested Analysis									
Pace Analytical Fairfield 1275 Bloomfield Avenue Suite 6 Fairfield, NJ 07004 Phone 973-227-0422				Requested Analysis									
Item	Sample ID	Sample Type	Collect Date/Time	Lab ID	Matrix	HN03	Preserved Containers						
1	BF by 218	PS	12/4/2025 05:06	70394895001	Drinking	1							
2	BF by 218 Right	PS	12/4/2025 05:06	70394895002	Drinking	1							
3	BF by 218 Left	PS	12/4/2025 05:06	70394895003	Drinking	1							
4	Outside Old Gym CU/DF	PS	12/4/2025 05:51	70394895004	Drinking	1							
5	Outside Old Gym CU/DF	PS	12/4/2025 05:51	70394895005	Drinking	1							
6	Main Office breakroom ice mac	PS	12/4/2025 05:59	70394895006	Drinking	1							
7	BF by 118	PS	12/4/2025 05:08	70394895007	Drinking	1							
8	DF by 118 Left	PS	12/4/2025 05:08	70394895008	Drinking	1							
9	DF by 118 Right	PS	12/4/2025 05:08	70394895009	Drinking	1							
10	Nurse NS	PS	12/4/2025 05:11	70394895010	Drinking	1							
11	Nurse ice machine	PS	12/4/2025 05:11	70394895011	Drinking	1							
12	Nurse KS	PS	12/4/2025 05:11	70394895012	Drinking	1							
13	Stage CU/DF	PS	12/4/2025 05:17	70394895013	Drinking	1							
14	Stage CU/DF right	PS	12/4/2025 05:17	70394895014	Drinking	1							
15	Stage DF Left	PS	12/4/2025 05:18	70394895015	Drinking	1							
16	Band Room CS	PS	12/4/2025 05:19	70394895016	Drinking	1							
17	South Cafeteria CU/DF	PS	12/4/2025 05:22	70394895017	Drinking	1							
18	South Cafeteria CU/DF right	PS	12/4/2025 05:22	70394895018	Drinking	1							
19	Kitchen Prep Sink (Sink 2)	PS	12/4/2025 05:23	70394895019	Drinking	1							



25L1456

Pace Analytical Services, LLC Newburgh, N
Warwick Highschool



State Of Origin: NY ☐ Yes ☐ No

12/4/2025 **Results Requested By:** **12/18/2025**

Subcontract To

**Pace Analytical Fairfield
1275 Bloomfield Avenue
Suite 6
Fairfield, NJ 07004
Phone 973-227-0422**

[illegible]

Internal Transfer Chain of Custody



☐ Rush Multiplier ☒ X
☐ Samples Pre-Logged into eCOC
Workorder: 70394895 Workorder Name: Warwick High School

State Of Origin: NY
Cert. Needed: ☐ Yes ☐ No
Owner Received Date: 12/4/2025 Results Requested By: 12/18/2025

Report To: Subcontract To: Requested Analysis

Felicia Morgan-Nichols
Pace Analytical Newburgh
315 Fullerton Avenue
Newburgh, NY 12550
Phone (845)562-0890

Pace Analytical Fairfield
1275 Bloomfield Avenue
Suite 6
Fairfield, NJ 07004
Phone 973-227-0422

Item	Sample ID	Sample Type	Collect Date/Time	Lab ID	Matrix	Preserved Containers			LAB USE ONLY
						3	8	LEAD	
40	145 KS Right	PS	12/4/2025 05:57	70394895040	Drinking	1		X	
41	Fitness Center DF Right	PS	12/4/2025 05:33	70394895041	Drinking	1		X	
42	Fitness Center DF Left	PS	12/4/2025 05:33	70394895042	Drinking	1		X	
43	Hall of Fame DF Right	PS	12/4/2025 05:31	70394895043	Drinking	1		X	
44	Hall of Fame DF Left	PS	12/4/2025 05:31	70394895044	Drinking	1		X	
45	CJ/BF across from 65	PS	12/4/2025 05:42	70394895045	Drinking	1		X	
46	CJ/DF across from 65	PS	12/4/2025 05:42	70394895046	Drinking	1		X	
47	DF across from 65 Right	PS	12/4/2025 05:42	70394895047	Drinking	1		X	
48	South Cafeteria DF Left	PS	12/4/2025 05:22	70394895048	Drinking	1		X	
49	North Cafe DF right	PS	12/4/2025 05:27	70394895049	Drinking	1		X	
50	DF by 142 left	PS	12/4/2025 05:55	70394895050	Drinking	1		X	

Transfers		Released By		Received By		Date/Time		Comments	
1		Pace	Tran NB	12/15 1325	Pace	12/15 1500			
2		Pace	Tran NB	12/15 1745	Pace	12/15 1745			
3		Pace	Tran NB	12/16 0600	Pace	12/16 0600			
Cooler Temperature on Receipt				22.0°C	Custody Seal	Y or N	Received on Ice	Y or N	Samples Intact Y or N

***In order to maintain client confidentiality, location/name of the sampling site, sampler's name and signature may not be provided on this COC document.

This chain of custody is considered complete as is since this information is available in the owner laboratory.

Red Don't Willard the 12/16/25 08:00
LB Pace 12/16/25 08:00



Ship To:
Pace Analytical Fairfield
1275 Bloomfield Avenue
Suite 6
Fairfield, NJ 07004
Phone 973-227-0422

INTER_LABORATORY WORK ORDER # 70394895

(To be completed by sending lab)

Sending Project No:	70394895
Receiving Project No:	
Check Box for Consolidated Invoice:	☐
Date Prepared:	12/15/25
REQUESTED COMPLETION DATE:	12/18/2025

Sending Region	IR70-Melville	Sending Project Mgr.	Felicia Morgan-Nichols
Receiving Region	S883-Fairfield	External Client	Orange-Ulster BOCES
State of Sample Origin	NY	QC Deliverable	STD REPORT

All questions should be addressed to sending project manager.

Requested Reportable Units _____ Report Wet or Dry Weight? Dry Weight ☐ IRWO Lab Need to run? Cert. Needed _____

WORK REQUESTED						
Method Description	Container Type	Quantity of containers	Preservative	Quantity of Samples	Acode	Acode Desc
200.8 LEAD	BP3N		HNO3	50	SI-21WET	SUB PASI WET

Special Requirements: Report B, Standard Report (B), Newburgh Excel Summary (1868)

FOR ANALYTICAL WORK COMPLETED THIS SECTION ALSO
--

Return Samples to Sending Region: ☐ Yes ☐ No

DISPOSITION of FORM

Original sent to the receiving lab - Copy kept at the sending lab.

When work completed: Original sent to the ABM at the receiving laboratory. Copies are made to corporate as needed.

25L1456

Sample Condition Upon Receipt Form (SCUR)



Affix Sample Label Here

Date and Initials of person:

Examining contents: _____

Label: _____

Deliver to location: _____

pH: _____

Thermometer Used: 717R08

Date: 12/16/25

Time: 8:00

Initials: LB

State of Origin: NJ

Cooler #1 Temp.°C 23.3 (Visual) -1.3 (Correction Factor) 22.0 (Actual)

☒ Samples on ice, cooling process has begun

Courier: ☐ Fed Ex ☐ UPS ☐ USPS ☒ Client ☐ Commercial ☐ Pace

☐ Other _____

Shipping Method: ☐ First Overnight ☐ Priority Overnight ☐ Standard Overnight ☐ Ground

☐ Other _____

Tracking # _____

Custody Seal on Cooler/Box Present: ☐ Yes ☒ No

Seals intact: ☐ Yes ☐ No

Ice: Wet Blue Melted None

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☒ None

☐ Other _____

Samples were collected by Pace employee

☐ Yes

☒ No

☐ N/A

Comments:

Chain of Custody Present	☒ Yes ☐ No ☐ N/A	
Chain of Custody Filled Out	☒ Yes ☐ No ☐ N/A	
Relinquished Signature on COC	☒ Yes ☐ No ☐ N/A	
Sampler Name and Signature on COC	☒ Yes ☐ No ☐ N/A	
Samples Arrived within Hold Time	☒ Yes ☐ No ☐ N/A	
Rush TAT requested on COC	☒ Yes ☐ No ☐ N/A	
Sufficient Volume	☒ Yes ☐ No ☐ N/A	
Correct Containers Used	☒ Yes ☐ No ☐ N/A	
Containers Intact	☒ Yes ☐ No ☐ N/A	
Sample Labels match COC (sample IDs & date/time of collection)	☒ Yes ☐ No ☐ N/A	
All containers needing acid/base preservation have been checked.	☒ Yes ☐ No ☐ N/A	Preservation Information: Preservative: _____ Lot #/Trace #: _____ Date: _____ Time: _____ Initials: _____
All Containers needing preservation are found to be in compliance with EPA recommendation: Exceptions: Vials, Microbiology, O&G, Metals	☒ Yes ☐ No ☐ N/A	
Headspace in VOA Vials? (>6mm):	☐ Yes ☐ No ☒ N/A	
Trip Blank Present:	☐ Yes ☐ No ☒ N/A	

Additional Login Comments:

Client notification/ Resolution

Person Contacted: _____

Date/Time: _____

Comments/Resolution: _____