

Lead in Drinking Water Report

Northern Heights Elementary School



Date of Sample		5/19/2023	6/18/2024	
Sampled by		Washington State Department of Health	Washington State Department of Health	Final Remediation
Fixture Location	Fixture Type	Lead Test Results (ppb)	Lead Test Results (ppb)	
Entrance fountain	Fountain - Multi-level	<1		
Entrance fountains	Fountain - Multi-level	<1		
Kitchen	Sink - Multi-compartment	9	<1	None
Kitchen	Sink - Multi-compartment	1		
Kitchen	Sink	1		
Room 239	Sink	4		
Room 238	Sink	2		
Room 237	Sink	3		
Room 237	Sink	3		
Room 228	Sink	<1		
Room 228	Sink	1		
Room 222	Sink	1		
Room 222	Sink	<1		
Room 221	Sink	1		

Room 221	Sink	4		
Room 217	Sink	2		
Room 217	Sink	1		
Room 216	Sink	2		
Room 216	Sink	2		
Room 215	Sink	3		
Room 215	Sink	<1		
Room 202	Sink	2		
Room 134	Sink	2		
Room 134	Sink	<1		
Room 133	Sink	<1		
Room 133	Sink	3		
Room 132	Sink	2		
Room 132	Sink	4		
Room 131	Sink	3		
Room 131	Sink	1		
Room 112	Sink	5		
Room 112	Sink	6		Handwashing Only
Room 130	Sink	3		
Room 130	Sink	<1		
Room 129	Sink	2		
Room 129	Sink	1		
Room 126	Sink	2		
Room 126	Sink	1		
Room 125	Sink	<1		
Room 125	Sink	1		
Room 119	Sink	2		
Room 120	Sink	2		
Room 120	Sink	2		
Room 118	Sink	2		
Room 105	Sink	13	<1	None
Room 105	Sink	2		
Room 114	Sink	3		

Room 114	Sink	2		
Room 114	Sink	2		
Music room	Sink	1		
Kitchen	Sink - Multi-compartment	<1		
Room 105	Sink	<1		