

Lead in Drinking Water Report Lowell Elementary School



Date of Sample		11/3/2023	10/18/2024	
Sampled by		Washington State Department of Health	Terracon	Final Remediation
Fixture Location	Fixture Type	Lead Test Results (ppb)	Lead Test Results (ppb)	
Kitchen	Sink	<1		
Kitchen	Sink	<1		
Kitchen	Sink	6	3.1	N/A
Kitchen	Sink - Multi-compartment	<1		
Kitchen	Sink - Multi-compartment	<1		
Kitchen	Sink	<1		
Cafeteria	Fountain - Multi-level with Bottle Filler	<1		
Cafeteria	Fountain - Multi-level with Bottle Filler	<1		
Cafeteria	Fountain - Multi-level with Bottle Filler	<1		
Gym - commons left	Fountain - Multi-level with Bottle Filler	<1		
Gym - commons left	Fountain - Multi-level with Bottle Filler	<1		
Gym - commons left	Fountain - Multi-level with Bottle Filler	<1		
Basement	Fountain	13	4.6	N/A
Basement A1	Sink	2		
Basement A5	Sink	<1		

Basement A6	Sink	<1		
Basement	Fountain	2		
Basement A10	Sink - Multi-compartment	<1		
Floor1 B7	Sink	2		
Floor1 Hallway North	Fountain	2		
Floor1 B5	Sink	13	29	Handwashing Only
Floor1 staff room	Sink	2		
Floor1 hallway south	Fountain	2		
Floor1 B1	Sink	1		
Floor1 hallway trough sink	Sink	4		
Floor1 hallway trough sinks	Sink	2		
Floor1 B6	Sink	12	26	Handwashing Only
Floor2 hallway north	Fountain	<1		
Floor2 hallway south	Fountain	3		