

**Project No.:**  
082826-1762

**Prepared For:**  
Brian Berner  
Milwaukee Public Schools

**Address of Structure Inspected:**  
Lloyd Barbee School, 4456 N Teutonia Ave, Milwaukee, WI

**Owner:**  
Milwaukee Public Schools, 1125 N. 11th Street, Milwaukee, WI 53233  
at (414) 531-2558

**Inspection Date & Time**  
8/28/2025 at 8am

## Partial Lead-Based Paint Inspection Report

**Investigation Conducted and Report Prepared By:**



Testudo LLC • P.O. Box 259964, Madison, WI 53725-9964 • (608) 205-8025

**DHS Lead Company Certification No.:**  
1374120

**Lead Risk Assessor:**  
Douglas Dalsing, DHS certification No.: 158778

A handwritten signature in black ink that reads "Doug Dalsing". The signature is written in a cursive, flowing style.

**Report Prepared & Signed**  
9/3/2025

## **Methods of Investigation**

Work comprised a Partial Lead-Based Paint Inspection of the floors & sills at Lloyd Barbee School, 4456 N Teutonia Ave, Milwaukee, WI.

**Dust wipe sampling**, if requested, was used to determine lead dust loading on horizontal surfaces, like floors, window sills and window wells; through observation and/or interviewing the occupant, these wipe samples were collected from areas where small children would be most likely to eat, sleep or play, & a blank sample was conducted for quality control purposes.

## **Findings**

### **Dust Sampling**

These are included in the attached lab reports. Samples indicating lead loading that exceeds general hazard levels set by WI's Department of Health Services (DHS) are marked, & any sample description that includes "2112" is a quality control blank sample.

## **Limitations**

The professional opinions found in this report were based upon site observations, interpretations of analysis, and interpretations of current regulations for the regulated materials. These opinions apply to the site conditions existing at the time of the inspection. Current regulations should always be verified prior to any work involving regulated materials such as lead-based paint. Future activities at this dwelling may alter the results of this inspection. This inspection did not include sources of lead exposure other than surface coatings on building components and soil. All untested items must be assumed to contain lead if they are coated in paint, stain, shellac or varnish and if they were installed prior to 1978. It may be assumed that any component installed after 1977 is free of lead-based paint; however, it's installation after 1977 must be documented.

## **Disclosure**

A copy of this summary must be provided to new tenants and purchasers of this property under Federal Law (24 CFR part 35 and 40 CFR part 745) before they become obligated under a lease or sales contract. The complete report must also be provided to new purchasers and made available to new tenants. Landlords and sellers are also required to distribute an educational pamphlet and include standard warning language in their leases or sales contracts to ensure that parents have the information they need to protect their children from lead-based paint hazards. State law requires Testudo LLC to disclose to a state agency, the WI Department of Health Services, the address and results from structures in which it conducts work.

## **List of Appendices**

Lab reports

CITY OF MILWAUKEE  
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM  
841 N Broadway Ave  
1st Floor  
Milwaukee, WI 53202

Order ID : Z6280003

LRN : 0000325517

Auxiliary ID : 08282025-188

Date Collected: 08/28/25

Date Received : 08/28/25

Requested by: UNKNOWN, DOCTOR

FINAL

Patient Name: CP/N/TEUTONIAAVE, 4456

DOB:

Age:

Sex:

Ord. Comm: 5 Clearance Dust Wipes  
Job # 082825-188

## Lead in Dust Wipes

| TEST-NAME                                        | RESULT | AB | NRML-RANGE | UNITS | DATE-TIME |
|--------------------------------------------------|--------|----|------------|-------|-----------|
| COLLECTED 08/28/25 00:00 RECEIVED 08/28/25 10:05 |        |    |            |       |           |

Sample 1

|             |        |  |           |                |
|-------------|--------|--|-----------|----------------|
| Dust Wipe 1 | *47    |  | ug/sq.ft. | 08/28/25 17:05 |
| Width       | *12.00 |  | in.       | 08/28/25 17:05 |
| Length      | *12.00 |  | in.       | 08/28/25 17:05 |

Sample 2

|             |        |           |                |
|-------------|--------|-----------|----------------|
| Dust Wipe 2 | *<5.0  | ug/sq.ft. | 08/28/25 17:05 |
| Width       | *12.00 | in.       | 08/28/25 17:05 |
| Length      | *12.00 | in.       | 08/28/25 17:05 |

Sample 3

|             |        |           |                |
|-------------|--------|-----------|----------------|
| Dust Wipe 3 | *<5.0  | ug/sq.ft. | 08/28/25 17:05 |
| Width       | *12.00 | in.       | 08/28/25 17:05 |
| Length      | *12.00 | in.       | 08/28/25 17:05 |

Sample 4

|             |        |           |                |
|-------------|--------|-----------|----------------|
| Dust Wipe 4 | *<5.0  | ug/sq.ft. | 08/28/25 17:05 |
| Width       | *12.00 | in.       | 08/28/25 17:05 |
| Length      | *12.00 | in.       | 08/28/25 17:05 |

Sample 5

|             |        |           |                |
|-------------|--------|-----------|----------------|
| Dust Wipe 5 | *<5.0  | ug/sq.ft. | 08/28/25 17:05 |
| Width       | *12.00 | in.       | 08/28/25 17:05 |

continued on next page

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

David Payne, PhD.  
Laboratory Director

Printed: 08/28/2025 17:05

PAGE: 1 of 2

CITY OF MILWAUKEE  
HEALTH DEPARTMENT

**City of Milwaukee-Public Health Laboratories**  
**841 North Broadway, Room 205 Milwaukee, WI 53202-3653**  
**Phone Number: (414)286-3526 Fax Number: (414)286-5098**  
**Autoreporting Lab**

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM  
 841 N Broadway Ave  
 1st Floor  
 Milwaukee, WI 53202

Order ID : Z6280003

LRN : 0000325517

Auxiliary ID : 08282025-188

Date Collected: 08/28/25

Date Received : 08/28/25

Requested by: UNKNOWN, DOCTOR

**FINAL**

Patient Name: CP/N/TEUTONIAAVE, 4456

DOB:

Age:

Sex:

Ord. Comm: 5 Clearance Dust Wipes  
 Job # 082825-188

continued

**Lead in Dust Wipes**

| TEST-NAME | RESULT | AB | NRML-RANGE | UNITS | DATE-TIME      |
|-----------|--------|----|------------|-------|----------------|
| Length    | *12.00 |    |            | in.   | 08/28/25 17:05 |

**Test Method**

Test Method

\*see below

08/28/25 10:34

Sample Preparation: Modified ASTM E1644 per PbSOP

Analytical Method: Modified EPA Method 7000B per PbSOP

Minimum Reporting Limit: 5.0 ug/sqft

Minimum Detection Limit: 2.5 ug/sqft

Sample results have not been corrected for field blank or analytical blank. Results related only to those samples tested. All sample area information is provided to the lab by the client unless otherwise stated.

QC results associated with these samples were acceptable unless otherwise noted.

Data reviewed and approved by the QA Coordinator/Technical Manager.

Accrediting body: AIHA-LAP, LLC; Lab ID #102186.

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

David Payne, PhD.

Laboratory Director

Printed: 08/28/2025 17:05

PAGE: 2 of 2