



# Mystic Air Quality Consultants, Inc.

1204 North Road, Groton, Connecticut 06340

www.mysticair.com

maq2@aol.com

800 247-7746

December 29, 2025

Christine MacDonald  
Region 18 Lyme-Old Lyme Schools  
49 Lyme Street  
Old Lyme, CT 06371

Re: **Radon Testing (12/15 – 18/25)**  
Lyme Consolidated School  
478 Hamburg Road  
Lyme-Old Lyme, CT

Dear Christine:

As requested, Mystic Air Quality Consultants, Inc. conducted radon testing at the location above on December 15<sup>th</sup> – 18<sup>th</sup>, 2025. The kits were placed in their respective locations at your facilities, then picked up and mailed to Airchek lab, where Mystic Air Quality arranged for analytical services. The testing was conducted by a Certified Radon Specialist, Christopher Muller (NRSB License #6SS0019).

**The results for radon in air are summarized below:**

<u>Location</u>	<u>Radon Test Kit #</u>	<u>Result (pCi/L)</u>
B1 –Blank	12279910	<0.3
5	12279911	0.7
21	12279912	0.9
16	12279917	1.2
9	12279918	0.8
2	12279920	1.0
2 (dup.)	12279925	0.8

A concentration of 4.0 picocuries of radon per liter of air (pCi/L) is the threshold at which the US EPA recommends further testing and consideration of remediation. **All locations are safe for occupancy under current EPA standards for radon.**

Thank you for selecting Mystic Air Quality to perform these services.

Sincerely,

Christopher J. Eident CIH, CSP, MPH  
CEO



**STATE OF CONNECTICUT**  
 DEPARTMENT OF PUBLIC HEALTH  
 RADON PROGRAM  
 SCHOOL RADON RE-EVALUATION REPORT FORM



July 2023

The following form must be submitted to the Connecticut Department of Public Health Radon Program within ten (10) business days of providing a final written report of radon measurement activities to school personnel.

**Do not send test results or other documents.**

Submit this signed form by **email** to the Radon Program at:

[DPH.RadonReports@ct.gov](mailto:DPH.RadonReports@ct.gov)

**Name of School:** LYME CONSOLIDATED SCHOOL

**Address:** 478 HAMBURG ROAD  
 (Street, town, zip code) LYME - OLD LYME, CT 06371

**Measurement Company:** Metric Air Quality Consultants

*Please provide the following summary information:*

**Dates of Testing:**  
 (Deployment/retrieval dates. Include confirmatory testing dates, if applicable.) 12/15/2025 To 12/18/2025

**Total # of Rooms Tested:** 5

**Total # of Rooms Requiring Re-Testing:** 0

**Total # of Rooms Where Average Results Were at or above 4.0 pCi/L:** 0

Radon measurement activities were carried out in accordance with United States Environmental Protection Agency protocols and the Connecticut Department of Public Health Radon Program's *School Radon Testing Guidance* at the location described above.

Christina Munnell / 6550019      Christina Munnell      12/29/25  
 Measurement Professional / NRPP/NRSB #      Signature      Date

\_\_\_\_\_  
 School Designee / Title      Signature      Date



Phone: (860) 509-7300  
 Telephone Device for the Deaf (860) 509-7191  
 410 Capitol Avenue - MS # 12-RAD  
 P.O. Box 340308, Hartford, CT 06134  
 An Equal Opportunity Employer

---

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
12279910	2025-12-15	7:00 am	2025-12-18	7:00 am	70	LYME - OLD LYME, CT	LYME CONSOLIDATED SCHOOL	B1		3	< 0.3
12279911	2025-12-15	7:00 am	2025-12-18	7:00 am	70	LYME - OLD LYME, CT	LYME CONSOLIDATED SCHOOL	5		0	0.7
12279912	2025-12-15	7:00 am	2025-12-18	7:00 am	70	LYME - OLD LYME, CT	LYME CONSOLIDATED SCHOOL	21		0	0.9
12279917	2025-12-15	7:00 am	2025-12-18	7:00 am	70	LYME - OLD LYME, CT	LYME CONSOLIDATED SCHOOL	16		0	1.2
12279918	2025-12-15	7:00 am	2025-12-18	7:00 am	70	LYME - OLD LYME, CT	LYME CONSOLIDATED SCHOOL	9		0	0.8
12279920	2025-12-15	7:00 am	2025-12-18	7:00 am	70	LYME - OLD LYME, CT	LYME CONSOLIDATED SCHOOL	2		0	1.0
12279925	2025-12-15	7:00 am	2025-12-18	7:00 am	70	LYME - OLD LYME, CT	LYME CONSOLIDATED SCHOOL	2		0	0.8

---



# Mystic Air Quality Consultants, Inc.

1204 North Road, Groton, Connecticut 06340

www.mysticair.com

maq2@aol.com

800 247-7746

December 29, 2025

Christine MacDonald  
Region 18 Lyme-Old Lyme Schools  
49 Lyme Street  
Old Lyme, CT 06371

Re: **Radon Testing (12/15 – 18/25)**  
Center School  
49 Lyme Street  
Lyme-Old Lyme, CT

Dear Christine:

As requested, Mystic Air Quality Consultants, Inc. conducted radon testing at the location above on December 15<sup>th</sup> – 18<sup>th</sup>, 2025. The kits were placed in their respective locations at your facilities, then picked up and mailed to Airchek lab, where Mystic Air Quality arranged for analytical services. The testing was conducted by a Certified Radon Specialist, Christopher Muller (NRSB License #6SS0019).

**The results for radon in air are summarized below:**

<u>Location</u>	<u>Radon Test Kit #</u>	<u>Result (pCi/L)</u>
Media Center (dup.)	12279901	0.8
Media Center	12279927	1.0
127	12279929	<0.3
B1 –Blank	12279931	<0.3
111	12279932	<0.3
117	12279933	<0.3

A concentration of 4.0 picocuries of radon per liter of air (pCi/L) is the threshold at which the US EPA recommends further testing and consideration of remediation. **All locations are safe for occupancy under current EPA standards for radon.**

Thank you for selecting Mystic Air Quality to perform these services.

Sincerely,

Christopher J. Eident CIH, CSP, MPH  
CEO





**STATE OF CONNECTICUT**  
 DEPARTMENT OF PUBLIC HEALTH  
 RADON PROGRAM  
 SCHOOL RADON RE-EVALUATION REPORT FORM



July 2023

The following form must be submitted to the Connecticut Department of Public Health Radon Program within ten (10) business days of providing a final written report of radon measurement activities to school personnel.

**Do not send test results or other documents.**

Submit this signed form by email to the Radon Program at:

[DPH.RadonReports@ct.gov](mailto:DPH.RadonReports@ct.gov)

Name of School: CENTER SCHOOL

Address: 49 LYME STREET  
 (Street, town, zip code) LYME - OLD LYME, CT 06371

Measurement Company: MASSIVE AIR QUALITY CONSULTANTS

Please provide the following summary information:

**Dates of Testing:**  
 (Deployment/retrieval dates. Include confirmatory testing dates, if applicable.)  
12/15/2025 TO 12/18/2025

**Total # of Rooms Tested:**  
4

**Total # of Rooms Requiring Re-Testing:**  
0

**Total # of Rooms Where Average Results Were at or above 4.0 pCi/L:**  
0

Radon measurement activities were carried out in accordance with United States Environmental Protection Agency protocols and the Connecticut Department of Public Health Radon Program's *School Radon Testing Guidance* at the location described above.

Christina M... / 6550019      Christina M...      12/29/25  
 Measurement Professional / NRPP/NRSB #      Signature      Date

\_\_\_\_\_  
 School Designee / Title      Signature      Date



Phone: (860) 509-7300  
 Telephone Device for the Deaf (860) 509-7191  
 410 Capitol Avenue - MS # 12-RAD  
 P.O. Box 340308, Hartford, CT 06134  
 An Equal Opportunity Employer

---

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
12279901	2025-12-15	8:00 am	2025-12-18	8:00 am	70	LYME - OLD LYME. CT	CENTER SCHOOL	MEDIA CENTER		0	0.8
12279927	2025-12-15	8:00 am	2025-12-18	8:00 am	70	LYME - OLD LYME. CT	CENTER SCHOOL	MEDIA CENTER		0	1.0
12279929	2025-12-15	8:00 am	2025-12-18	8:00 am	70	LYME - OLD LYME. CT	CENTER SCHOOL	127		0	< 0.3
12279931	2025-12-15	8:00 am	2025-12-18	8:00 am	70	LYME - OLD LYME. CT	CENTER SCHOOL	B1		3	< 0.3
12279932	2025-12-15	8:00 am	2025-12-18	8:00 am	70	LYME - OLD LYME. CT	CENTER SCHOOL	111		0	< 0.3
12279933	2025-12-15	8:00 am	2025-12-18	8:00 am	70	LYME - OLD LYME. CT	CENTER SCHOOL	117		0	< 0.3

---



# Mystic Air Quality Consultants, Inc.

1204 North Road, Groton, Connecticut 06340

www.mysticair.com

maq2@aol.com

800 247-7746

December 29, 2025

Christine MacDonald  
Region 18 Lyme-Old Lyme Schools  
49 Lyme Street  
Old Lyme, CT 06371

Re: **Radon Testing (12/15 – 18/25)**  
Lyme-Old Lyme High School  
69-2 Lyme Street  
Lyme-Old Lyme, CT

Dear Christine:

As requested, Mystic Air Quality Consultants, Inc. conducted radon testing at the location above on December 15<sup>th</sup> – 18<sup>th</sup>, 2025. The kits were placed in their respective locations at your facilities, then picked up and mailed to Airchek lab, where Mystic Air Quality arranged for analytical services. The testing was conducted by a Certified Radon Specialist, Christopher Muller (NRSB License #6SS0019).

**The results for radon in air are summarized below:**

<u>Location</u>	<u>Radon Test Kit #</u>	<u>Result (pCi/L)</u>
151	12279902	1.1
B1 –Blank	12279906	<0.3
116F	12279908	0.8
124	12279915	0.7
115C	12279916	0.7
108	12279923	0.8
151 (dup.)	12279926	1.1

A concentration of 4.0 picocuries of radon per liter of air (pCi/L) is the threshold at which the US EPA recommends further testing and consideration of remediation. **All locations are safe for occupancy under current EPA standards for radon.**

Thank you for selecting Mystic Air Quality to perform these services.

Sincerely,

Christopher J. Eident CIH, CSP, MPH  
CEO



**STATE OF CONNECTICUT**  
 DEPARTMENT OF PUBLIC HEALTH  
 RADON PROGRAM  
 SCHOOL RADON RE-EVALUATION REPORT FORM



July 2023

The following form must be submitted to the Connecticut Department of Public Health Radon Program within ten (10) business days of providing a final written report of radon measurement activities to school personnel.

**Do not send test results or other documents.**

Submit this signed form by **email** to the Radon Program at:

[DPH.RadonReports@ct.gov](mailto:DPH.RadonReports@ct.gov)

**Name of School:**

LYME - OLD LYME HIGH SCHOOL

**Address:**

(Street, town, zip code)

69 - 2 LYME STREET

LYME - OLD LYME, CT 06371

**Measurement Company:**

MUSTEL AIR QUALITY CONSULTANTS

*Please provide the following summary information:*

**Dates of Testing:**

(Deployment/retrieval dates. Include confirmatory testing dates, if applicable.)

12/15/2025 To 12/18/2025

**Total # of Rooms Tested:**

5

**Total # of Rooms Requiring Re-Testing:**

0

**Total # of Rooms Where Average Results Were at or above 4.0 pCi/L:**

0

Radon measurement activities were carried out in accordance with United States Environmental Protection Agency protocols and the Connecticut Department of Public Health Radon Program's *School Radon Testing Guidance* at the location described above.

Christina M... / 6550019  
 Measurement Professional / NRPP/NRSB #

Christina M...  
 Signature

12/29/25  
 Date

\_\_\_\_\_  
 School Designee / Title

\_\_\_\_\_  
 Signature

\_\_\_\_\_  
 Date



Phone: (860) 509-7300  
 Telephone Device for the Deaf (860) 509-7191  
 410 Capitol Avenue - MS # 12-RAD  
 P.O. Box 340308, Hartford, CT 06134  
 An Equal Opportunity Employer

---

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
12279902	2025-12-15	7:00 am	2025-12-18	7:00 am	70	LYME - OLD LYME, CT	LYME - OLD LYME HIGH SCHOOL	151		0	1.1
12279906	2025-12-15	7:00 am	2025-12-18	7:00 am	70	LYME - OLD LYME, CT	LYME - OLD LYME HIGH SCHOOL	B1		3	< 0.3
12279908	2025-12-15	7:00 am	2025-12-18	7:00 am	70	LYME - OLD LYME, CT	LYME - OLD LYME HIGH SCHOOL	116F		0	0.8
12279915	2025-12-15	7:00 am	2025-12-18	7:00 am	70	LYME - OLD LYME, CT	LYME - OLD LYME HIGH SCHOOL	124		0	0.7
12279916	2025-12-15	7:00 am	2025-12-18	7:00 am	70	LYME - OLD LYME, CT	LYME - OLD LYME HIGH SCHOOL	115C		0	0.7
12279923	2025-12-15	7:00 am	2025-12-18	7:00 am	70	LYME - OLD LYME, CT	LYME - OLD LYME HIGH SCHOOL	108		0	0.8
12279926	2025-12-15	7:00 am	2025-12-18	7:00 am	70	LYME - OLD LYME, CT	LYME - OLD LYME HIGH SCHOOL	151		0	1.1

---



# Mystic Air Quality Consultants, Inc.

1204 North Road, Groton, Connecticut 06340

www.mysticair.com

maq2@aol.com

800 247-7746

December 29, 2025

Christine MacDonald  
Region 18 Lyme-Old Lyme Schools  
49 Lyme Street  
Old Lyme, CT 06371

Re: **Radon Testing (12/15 – 18/25)**  
Lyme-Old Lyme Middle School  
53 Lyme Street  
Lyme-Old Lyme, CT

Dear Christine:

As requested, Mystic Air Quality Consultants, Inc. conducted radon testing at the location above on December 15<sup>th</sup> – 18<sup>th</sup>, 2025. The kits were placed in their respective locations at your facilities, then picked up and mailed to Airchek lab, where Mystic Air Quality arranged for analytical services. The testing was conducted by a Certified Radon Specialist, Christopher Muller (NRSB License #6SS0019).

The results for radon in air are summarized below:

Location	Radon Test Kit #	Result (pCi/L)
304	12279903	<0.3
410	12279905	<0.3
Art Technology	12279907	<0.3
B1 –Blank	12279909	<0.3
417	12279913	<0.3
501 Office	12279914	0.6
206	12279919	0.7
Main Office	12279921	0.7
Main Office (dup.)	12279922	0.6

A concentration of 4.0 picocuries of radon per liter of air (pCi/L) is the threshold at which the US EPA recommends further testing and consideration of remediation. **All locations are safe for occupancy under current EPA standards for radon.**

Thank you for selecting Mystic Air Quality to perform these services.

Sincerely,

Christopher J. Eident CIH, CSP, MPH  
CEO



**STATE OF CONNECTICUT**  
 DEPARTMENT OF PUBLIC HEALTH  
 RADON PROGRAM  
 SCHOOL RADON RE-EVALUATION REPORT FORM



July 2023

The following form must be submitted to the Connecticut Department of Public Health Radon Program within ten (10) business days of providing a final written report of radon measurement activities to school personnel.

**Do not send test results or other documents.**

Submit this signed form by email to the Radon Program at:

[DPH.RadonReports@ct.gov](mailto:DPH.RadonReports@ct.gov)

Name of School: LYME - OLD LYME MIDDLE SCHOOL

Address:  
(Street, town, zip code)  
53 LYME STREET  
LYME - OLD LYME, CT 06371

Measurement Company: MUSTEL AIR QUALITY CONSULTANTS

Please provide the following summary information:

**Dates of Testing:**  
(Deployment/retrieval dates. Include confirmatory testing dates, if applicable.)  
12/15/2025 To 12/18/2025

**Total # of Rooms Tested:**  
7

**Total # of Rooms Requiring Re-Testing:**  
0

**Total # of Rooms Where Average Results Were at or above 4.0 pCi/L:**  
0

Radon measurement activities were carried out in accordance with United States Environmental Protection Agency protocols and the Connecticut Department of Public Health Radon Program's *School Radon Testing Guidance* at the location described above.

Christina M... / 6550019  
Measurement Professional / NRPP/NRSB #

Christina M...  
Signature

12/29/25  
Date

\_\_\_\_\_  
School Designee / Title

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date



Phone: (860) 509-7300  
 Telephone Device for the Deaf (860) 509-7191  
 410 Capitol Avenue - MS # 12-RAD  
 P.O. Box 340308, Hartford, CT 06134  
 An Equal Opportunity Employer

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
12279903	2025-12-15	7:00 am	2025-12-18	7:00 am	70	LYME - OLD LYME, CT	LYME - OLD LYME MIDDLE SCHOOL	304		0	< 0.3
12279905	2025-12-15	7:00 am	2025-12-18	7:00 am	70	LYME - OLD LYME, CT	LYME - OLD LYME MIDDLE SCHOOL	410		0	< 0.3
12279907	2025-12-15	7:00 am	2025-12-18	7:00 am	70	LYME - OLD LYME, CT	LYME - OLD LYME MIDDLE SCHOOL	ART TECHNOLOGY		0	< 0.3
12279909	2025-12-15	7:00 am	2025-12-18	7:00 am	70	LYME - OLD LYME, CT	LYME - OLD LYME MIDDLE SCHOOL	B1		3	< 0.3
12279913	2025-12-15	7:00 am	2025-12-18	7:00 am	70	LYME - OLD LYME, CT	LYME - OLD LYME MIDDLE SCHOOL	417		0	< 0.3
12279914	2025-12-15	7:00 am	2025-12-18	7:00 am	70	LYME - OLD LYME, CT	LYME - OLD LYME MIDDLE SCHOOL	501 OFFICE		0	0.6
12279919	2025-12-15	7:00 am	2025-12-18	7:00 am	70	LYME - OLD LYME, CT	LYME - OLD LYME MIDDLE SCHOOL	206		0	0.7
12279921	2025-12-15	7:00 am	2025-12-18	7:00 am	70	LYME - OLD LYME, CT	LYME - OLD LYME MIDDLE SCHOOL	MAIN OFFICE		0	0.7
12279922	2025-12-15	7:00 am	2025-12-18	7:00 am	70	LYME - OLD LYME, CT	LYME - OLD LYME MIDDLE SCHOOL	MAIN OFFICE		0	0.6



# Mystic Air Quality Consultants, Inc.

1204 North Road, Groton, Connecticut 06340

www.mysticair.com

maq2@aol.com

800 247-7746

December 29, 2025

Christine MacDonald  
Region 18 Lyme-Old Lyme Schools  
49 Lyme Street  
Old Lyme, CT 06371

Re: **Radon Testing (12/15 – 18/25)**  
Mile Creek School  
205 Mile Creek Road  
Lyme –Old Lyme, CT

Dear Christine:

As requested, Mystic Air Quality Consultants, Inc. conducted radon testing at the location above on December 15<sup>th</sup> – 18<sup>th</sup>, 2025. The kits were placed in their respective locations at your facilities, then picked up and mailed to Airchek lab, where Mystic Air Quality arranged for analytical services. The testing was conducted by a Certified Radon Specialist, Christopher Muller (NRSB License #6SS0019).

**The results for radon in air are summarized below:**

<u>Location</u>	<u>Radon Test Kit #</u>	<u>Result (pCi/L)</u>
40	12279930	1.1
40 (dup.)	12279934	1.0
B1 –Blank	12279935	<0.3
29	12279936	0.7
13A	12279955	0.8
Mr. Kennedy	12279957	1.0
G5	12279960	1.3

A concentration of 4.0 picocuries of radon per liter of air (pCi/L) is the threshold at which the US EPA recommends further testing and consideration of remediation. **All locations are safe for occupancy under current EPA standards for radon.**

Thank you for selecting Mystic Air Quality to perform these services.

Sincerely,

Christopher J. Eident CIH, CSP, MPH  
CEO



**STATE OF CONNECTICUT**  
 DEPARTMENT OF PUBLIC HEALTH  
 RADON PROGRAM  
 SCHOOL RADON RE-EVALUATION REPORT FORM



July 2023

The following form must be submitted to the Connecticut Department of Public Health Radon Program within ten (10) business days of providing a final written report of radon measurement activities to school personnel.

**Do not send test results or other documents.**

Submit this signed form by email to the Radon Program at:

[DPH.RadonReports@ct.gov](mailto:DPH.RadonReports@ct.gov)

**Name of School:** MILE CREEK SCHOOL

**Address:** 205 MILE CREEK ROAD  
 (Street, town, zip code) LYME - OLD LYME, CT 06371

**Measurement Company:** MUSKIE AIR QUALITY CONSULTANTS

Please provide the following summary information:

**Dates of Testing:**  
 (Deployment/retrieval dates. Include confirmatory testing dates, if applicable.) 12/15/2025 To 12/18/2025

**Total # of Rooms Tested:** 5

**Total # of Rooms Requiring Re-Testing:** 0

**Total # of Rooms Where Average Results Were at or above 4.0 pCi/L:** 0

Radon measurement activities were carried out in accordance with United States Environmental Protection Agency protocols and the Connecticut Department of Public Health Radon Program's *School Radon Testing Guidance* at the location described above.

Christina Moore / 6550019  
 Measurement Professional / NRPP/NRSB #

Christina Moore  
 Signature

12/29/25  
 Date

\_\_\_\_\_  
 School Designee / Title

\_\_\_\_\_  
 Signature

\_\_\_\_\_  
 Date



Phone: (860) 509-7300  
 Telephone Device for the Deaf (860) 509-7191  
 410 Capitol Avenue - MS # 12-RAD  
 P.O. Box 340308, Hartford, CT 06134  
 An Equal Opportunity Employer

---

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
12279930	2025-12-15	8:00 am	2025-12-18	8:00 am	70	LYME - OLD LYME, CT	MILE CREEK SCHOOL	40		0	1.1
12279934	2025-12-15	8:00 am	2025-12-18	8:00 am	70	LYME - OLD LYME, CT	MILE CREEK SCHOOL	40		0	1.0
12279935	2025-12-15	8:00 am	2025-12-18	8:00 am	70	LYME - OLD LYME, CT	MILE CREEK SCHOOL	B1		3	< 0.3
12279936	2025-12-15	8:00 am	2025-12-18	8:00 am	70	LYME - OLD LYME, CT	MILE CREEK SCHOOL	29		0	0.7
12279955	2025-12-15	8:00 am	2025-12-18	8:00 am	70	LYME - OLD LYME, CT	MILE CREEK SCHOOL	13A		0	0.8
12279957	2025-12-15	8:00 am	2025-12-18	8:00 am	70	LYME - OLD LYME, CT	MILE CREEK SCHOOL	MR. KENNEDY		0	1.0
12279960	2025-12-15	8:00 am	2025-12-18	8:00 am	70	LYME - OLD LYME, CT	MILE CREEK SCHOOL	G5		0	1.3

---